

**Table B.3.12-1. Downs Substation Ambient Noise Levels**

Recorded Time of Noise Level (a.m.)	Measured 1-hour Noise Level (dBA Leq)	Recorded Time of Noise Level (p.m.)	Measured 1-hour Noise Level (dBA Leq)
12:00 a.m.	56.3	12:00 p.m.	64.4
1:00 a.m.	54.8	1:00 p.m.	66.0
2:00 a.m.	55.2	2:00 p.m.	64.3
3:00 a.m.	54.6	3:00 p.m.	64.5
4:00 a.m.	55.6	4:00 p.m.	64.8
5:00 a.m.	58.9	5:00 p.m.	65.0
6:00 a.m.	61.1	6:00 p.m.	65.0
7:00 a.m.	60.9	7:00 p.m.	64.4
8:00 a.m.	68.1	8:00 p.m.	65.3
9:00 a.m.	62.6	9:00 p.m.	64.6
10:00 a.m.	60.1	10:00 p.m.	64.4
11:00 a.m.	64.5	11:00 p.m.	64.3

Notes: The 24-hour noise monitor was programmed to record continuously throughout a typical weekday on Wednesday, July 14, 2010

Source: SCE, 2010a.