

APPENDIX D
APPLICANT'S PREPARED DIRECT TESTIMONY
FOR
TALEGA-ESCONDIDO/VALLEY-SERRANO 500 KV INTERCONNECT
PROJECT

Table of Contents

Section 1 Prepared Testimony of Peter Lewandowski

Section 2 Prepared Testimony of Rexford Wait

Section 3 Prepared Testimony of Mingxia Zhang, Ph.D.

Section 4 Prepared Testimony of Philippe Auclair

1 **APPENDIX D – Section 1**
2 **Prepared Direct Testimony of**
3 **Peter Lewandowski**
4 **on behalf of the**
5 **The Nevada Hydro Company**
6 **TE/VS Interconnect**
7

8 Q. Please state your name and business address for the record.

9 A. My Name is Peter Lewandowski and my business address is 2416 Cades Way, Vista
10 California 92081.

11 Q. By who are you employed?

12 A. I am the President of The Hydro Company, Inc., which is doing business in California as
13 The Nevada Hydro Company, Inc. (“TNHC”).

14 Q. Briefly describe your present responsibilities at TNHC.

15 A. As President of TNHC, I have overall responsibility for the advancement of the
16 company’s electrical generation and transmission projects, including the responsibility
17 for the preparation and processing of the Proponent’s Environmental Assessment
18 (“PEA”), such other environmental documentation as may required under the provisions
19 of the California Environmental Quality Act (“CEQA”). I also am responsible for the
20 preparation, processing, and receipt of those discretionary permits as may be required
21 from federal, State, and local resource agencies for the projects’ construction and
22 operation.

23 Q. Briefly describe your educational and professional background.

24 A. I have over 25 years of experience in the environmental field, preparing literally hundreds
25 of CEQA and NEPA documents for both energy-related and non-energy projects. I was

1 responsible for the preparation and acceptance by the Federal Energy Regulatory
2 Commission (“FERC”) of Exhibit E (Environmental Report), comprising a major part of
3 the federal hydropower license application for the Lake Elsinore Advanced Pumped
4 Storage Project (“LEAPS”), including the management of all technical consultants
5 participating in that work product. For the LEAPS and Talega-Escondido/Valley-Serrano
6 500-kV Interconnect Project (“TE/VS Interconnect”), I am response for the preparation
7 and processing of environmental permits and associated entitlements from a wide array of
8 state and federal agencies, including the State Water Resources Control Board and the
9 United States Army Corps of Engineers. I formerly served as Director of Planning and
10 Environmental Services for Ultrasystems Engineers & Constructors, Inc., a Hadson
11 Company, a Fortune 500 energy company, subsequently acquired by LG&E Energy and
12 operated as LG&E Power Systems. In 1998, I established a separate consulting firm,
13 Environmental Impact Sciences, specializing in the provision of planning and
14 environmental permitting services to both the public and private sectors, including
15 individual development projects ranging in size up to 10,000 dwelling units. I have an
16 undergraduate degree in Social Ecology from the University of California at Irvine and a
17 Master's Degree in Urban Planning and have post-graduate work in Architecture at
18 California State University at Pomona. In addition, I have completed the certificate
19 program in Construction Management at the University of California at Irvine. Among
20 other awards, based on my professional work, I have received a United States
21 Congressional Recognition for Environmental Excellence.

22 Q. What is the purpose of your testimony in this proceeding?

1 A. I am sponsoring the PEA. I had the principal responsibility for the preparation and
2 technical review of the PEA. The document draws upon and presents, in a cohesive
3 fashion, a wide array of technical studies, including the “Final Environmental Impact
4 Statement for the Lake Elsinore Advanced Pumped Storage Project, FERC Project No.
5 11858” (“FEIS”) issued in our pending hydropower license proceeding before FERC.

6 Q. Does this conclude your prepared testimony?

7 A. Yes it does.

1 **APPENDIX D - SECTION 2**
2 **Prepared Direct Testimony of**
3 **Rexford Wait**
4 **on behalf of the**
5 **The Nevada Hydro Company**
6 **TE/VS Interconnect**
7

8 Q. Please state your name and business address for the record.

9 A. My Name is Rexford Wait and my business address is 2416 Cades Way, Vista California
10 92081.

11 Q. By who are you employed?

12 A. I am employed by The Nevada Hydro Company (“TNHC”).

13 Q. Briefly describe your present responsibilities at TNHC.

14 A. I am Vice President of the Company with overall responsibility for the development of
15 the TE/VS Interconnect project, particularly focusing on the engineering and cost aspects
16 of the project.

17 Q. Briefly describe your educational and professional background.

18 A. I have been in the business of developing and constructing energy facilities my entire
19 career. I have an undergraduate degree in electrical and process engineering, and have
20 developed and constructed energy facilities in a variety of countries around the world.

21 Q. What is the purpose of your testimony in this proceeding?

22 A. I am sponsoring the engineering cost elements of the project.

23 Q. Please elaborate on the cost of the project.

1 A. In the final Environmental Impact Statement (“FEIS”) prepared by the Federal Energy
 2 Regulatory Commission (“FERC”), the FERC prepared an estimate of the cost for the
 3 project. This estimate appears in the following table, extracted in total from the FEIS:

Table 53. Summary of construction costs and characteristics for the co-applicants’ proposed and staff alternative transmission alignments. (Source: Staff)

Alignment	Overall Length (miles)	Buried Length (miles)	Helicopter Installed Length (miles) ^a	Conventional Transmission Line (miles)	Access Road Length (miles) ^b	Total Construction Cost (\$2005) ^c
Revised co-applicants’ proposed transmission alignment	32.1	3.2	24.9	4.0	10.8	\$393,316,800
Staff alternative transmission alignment	31.7	2.1	25.5	4.1	9.3	\$381,082,875

^a This length results in additional cost for construction of transmission lines by helicopter in areas where slopes are greater the 15 percent.

^b We assume that access road lengths are equal to 1.5 times the transmission line length and are required in areas with slopes less than or equal to 15 percent.

^c Total construction costs include the applicants estimated transmission lines costs and contingency, additional staff contingency and other major construction items such as additional access roads, buried lines or helicopter aided construction. Certain environmental measures associated with erosion control, easements, and terrestrial lands mitigation, etc. are not included in this cost.

^d We assume the co-applicants may have accounted for up to 50 percent of the helicopter aided construction costs in their cost estimate and have added an additional \$1,984,100 for possibly unaccounted helicopter installation costs. We assume a transmission line tower every 1000 feet and that incremental helicopter costs would amount to one-half of \$30,761 per tower.

^e We assume that shorter line lengths in the area where slopes are greater than 15 percent result in saving of \$30,761 per tower eliminated or in this case 3 towers or \$92,300. We also account for longer access roads at \$125,000 per mile or in this case \$337,500. Because the overall transmission line is 1.2 miles longer, we also estimate an additional construction cost of \$2,496,000.

^f An additional 2-mile segment connects the main transmission line to the Santa Rosa powerhouse.

^g The number of towers per mile were determine by GIS analysis for each alignment.

4
 5
 6 As FERC has selected the “staff alternative” alignment, FERC has concluded that
 7 the project will cost roughly \$381 million. We are currently working to refine this
 8 estimate, but until this revised estimate is completed, we are comfortable relying on
 9 FERC’s estimated cost for purposes of this filing.

10 Q. Was the material prepared by you or under your supervision?

11 A. While the FERC material was not, I am prepared to sponsor it before the Commission.

1 Q. Insofar as the material is factual in nature, do you believe it to be correct?

2 A. Yes I do.

3 Q. Insofar as the material is in the nature of opinion or judgment, does it represent your best
4 judgment?

5 A. Yes it does.

6 Q. Does this conclude your qualifications and prepared testimony?

7 A. Yes it does.

8

1 **APPENDIX D - Section 3**
2 **Prepared Direct Testimony of**
3 **Mingxia Zhang, Ph.D.**
4 **on behalf of the**
5 **The Nevada Hydro Company**
6 **TE/VS Interconnect**

7 **1.0**

8 **1.0 INTRODUCTION AND TESTIMONY OVERVIEW**

9 Q: Please state your name, title, and business address.

10 A: My name is Mingxia Zhang. I am a consultant with Z Global, Inc., Engineering and
11 Energy Solutions. My business address is Suite 120, 193 Blue Ravine Road, Folsom, CA
12 95630.

13 Q: Please describe your employment and other relevant experience prior to becoming a
14 consultant for Z Global.

15 A: Prior to joining Z Global, I had more than five years experience working at the California
16 Independent System Operator (“CAISO”). While at the CAISO, my responsibilities
17 included: Project Lead for Market Redesign and Technology Upgrade (“MRTU”)
18 Competitive Path Assessment; Lead Market Monitoring Specialist for Congestion
19 Management Market, FTR Market, Ancillary Services Market, and Real-Time Market;
20 and Principal Economist for developing the CAISO’s Transmission Evaluation
21 Assessment Methodology (“TEAM”). I also testified before the California Public
22 Utilities Commission (“CPUC”) on TEAM Methodology and the Palo Verde – Devers #2
23 Line Study (“PVD2”). In addition, I had over ten years of research and teaching
24 experience at the University of California - Davis prior to joining the CAISO. I have
25 published more than ten peer-reviewed journal articles in nationally and internationally

1 leading economics and power system journals. I have provided my qualifications as an
2 attachment to this testimony.

3 Q: On whose behalf are you submitting this testimony?

4 A: I am submitting this testimony on behalf of The Nevada Hydro Company (TNHC).

5 Q: What is the purpose of your testimony?

6 A: The purpose of my testimony is to support TNHC's filing at the Commission. In doing
7 so, I have used the PLEXOS for Power System, a production cost and market simulation
8 tool, to create and run a base case model of the CAISO transmission system and markets,
9 and a model consisting of the base case plus the proposed LEAPS and TE/VS facilities.
10 The purpose of these simulations is to quantify the energy and ancillary services benefit
11 to CAISO ratepayers of the TE/VS Interconnect project, and the TE/VS Interconnect
12 project when linked to the LEAPS pumped storage facility as proposed by TNHC in this
13 proceeding.

14 Q: How is your base model for the CAISO transmission system and markets the same or
15 different from the base case model that the CAISO uses for evaluating its transmission
16 system and markets?

17 A: Is the essentially the same, as further described below.

18 Q: How is your testimony organized?

19 A: My testimony is presented in three parts. First, I will explain the features of the PLEXOS
20 modeling program. Second, I will explain the base case model that I created using
21 PLEXOS, including the sources of inputs, assumptions used and types of outputs.
22 Finally, I will describe the results of adding both the LEAPS and the TE/VS projects to
23 the PLEXOS base case model.

1 Q: Are the results of your PLEXOS modeling of the LEAPS and TE/VS projects utilized by
2 any other witness to this proceeding?

3 A: Yes. The results of my analysis of the LEAPS and TE/VS projects using PLEXOS will be
4 used by Mr. Philippe Auclair in performing a cost-benefit analysis of the combined
5 projects. Mr. Auclair's testimony is being submitted contemporaneously with this
6 testimony.

7 **2.0 DESCRIPTION OF PLEXOS MODELING**

8 Q: Please briefly describe the PLEXOS modeling system that you relied on for your analysis
9 in this case.

10 A: PLEXOS for Power System was developed by Energy Exemplar. It is a proven,
11 Windows-based, market simulation tool. PLEXOS integrates generation dispatch,
12 transmission power flow, and pricing simulation with hydro electric generation
13 (including pumped storage) and ancillary services dispatch. The CAISO, for example,
14 used PLEXOS in implementing TEAM to analyze the benefits and costs of new
15 transmission projects. PLEXOS satisfies the five key principles of TEAM's economic
16 approach because PLEXOS: (i) quantifies benefits to market participants and sets up
17 appropriate economic criterion for cost/benefit analysis; (ii) provides full network
18 modeling; (iii) models market prices (including market power); (iv) models risk and
19 uncertainty; and (v) considers transmission and resource (demand/generation)
20 substitution.

21 Accordingly, PLEXOS has been used in a number of the CAISO's economic
22 transmission evaluation studies. For example, the CAISO used PLEXOS modeling for its
23 TEAM/Path 26 Study and the PDV2 Study. In addition, PLEXOS modeling is currently

1 used by the CAISO to conduct the MRTU Competitive Path Assessment, as well as in its
2 locational marginal pricing (“LMP”) studies.

3 Q: Why did you choose to use PLEXOS for the modeling you performed in this case?

4 A: PLEXOS for Power System, unlike other similar tools, has the capability to co-optimize
5 ancillary services (“AS”) and energy production and is better capable than other
6 simulation software of modeling hydro electric resources, particularly pumped storage. .
7 The TE/VS project will provide much needed transmission congestion relief in the
8 Southern California area such that there is both an energy benefit and an AS optimization
9 benefit that results from more efficient use of generation resources to meet grid energy
10 and AS requirements with or without LEAPS. This is additionally relevant in the TEVS
11 with LEAPS case because the LEAPS project will enhance CAISO’s AS capability As a
12 result; the capability of PLEXOS to optimize both AS and pumped storage in its
13 modeling produces more reliable and accurate results for evaluating the TEVS and
14 TE/VS with LEAPS cases.

15 **3.0 THE PLEXOS BASE CASE MODEL**

16 Q: Please explain how you developed your base case using PLEXOS, including the inputs
17 for the modeling and the source of those inputs.

18 A: I began with the base case utilized by, and obtained from, the CAISO in its analysis for
19 the pending licensing proceeding for San Diego Gas & Electric Company’s
20 (“SDG&E’s”) proposed Sunrise Powerlink project before the California Public Utilities
21 Commission (“CPUC”) in Application No. 06-08-010. Consistent with the CAISO’s
22 approach, I set up my base case in PLEXOS using the Western Electricity Coordinating
23 Council’s (“WECC”) most current production cost simulation database for 2015. The

1 WECC database included a full WECC system model for the year 2015 (Generation plus
2 Transmission plus Load assumptions) and was converted into PLEXOS format for me by
3 PLEXOS Solutions. I then updated many input assumptions in the WECC 2015
4 production cost simulation database to make it more consistent with the CAISO's base
5 case used in SDG&E's Sunrise proceeding. In addition, I added some necessary
6 information for ancillary services modeling and pumped storage modeling into this
7 database.

8 Q: Please describe the assumptions you used in developing the PLEXOS base case model
9 and the outputs of the modeling.

10 A: The PLEXOS model consists of three major components: Generation, Load, and
11 Transmission Network. Therefore, I will provide additional detail on the development of
12 the base case model and the assumptions for each of these components.

13 **3.1 Generation**

14 For the generation heat rate component of the PLEXOS base case model, I used
15 heat rate data from the WECC database for thermal generation modeling. This heat rate
16 data reflected typical fuel type, size of generation, vintage, and technology of plants as
17 provided by WECC. I also relied on fuel (gas, coal, and others) prices in the WECC
18 database for the thermal generation modeling.

19 In addition, the generation component of the PLEXOS simulation model produces
20 LMPs for all buses in the network under two alternative assumptions: generators bid in
21 their marginal costs, or generators bid in prices that reflect their strategic positions in the
22 market. I assumed that generators bid in their marginal cost in establishing this
23 component. By doing so, I recognize that the benefit estimated under this assumption is

1 conservative, and that the TE/VS and LEAPS projects will provide higher benefits. (This
2 is because, as a general economic premise, producers either earn more over time than
3 variable operating cost or they become money losing operations and go out of business.
4 If they go out of business then supply goes down and prices tend to rise.)

5 Next, I assumed the presence of 600 MW of new renewable resources located in
6 the Salton Sea and Imperial Valley areas in the base case and the base case plus TE/VS
7 case and the base case plus TE/VS plus LEAPS case. This is consistent with the
8 CAISO's position in the Sunrise proceeding. Also, I assumed certain generation
9 retirements. For example, I assumed that the South Bay power plant and Mohave power
10 plant will be off-line in year 2015, just as the CAISO assumed in the Sunrise proceeding.
11 See "Initial Testimony of the California Independent System Operator Corporation Part
12 1," A. 06-08-010, at 21 (January 26, 2007).

13 Furthermore, I included in the generator component of the PLEXOS base case
14 model all the generators, specified by their capacity, costs, and availability, that are listed
15 in the WECC 2015 database. Generators are identified as dispatchable, such as most
16 thermal units, or as non-dispatchable, such as most hydro, wind, and solar units. I
17 modeled the generation for these non-dispatchable units as hourly curves.

18 In my study, pumped storage units (such as the existing Helms and Hyatt
19 facilities, as well as LEAPS) are internally optimized using PLEXOS' potential energy
20 modeling approach to optimize the value of water to achieve daily, weekly, or monthly
21 energy targets. More specifically, a pumped storage unit is modeled as if the storage
22 naturally cycles between its upper and lower reservoir a number of times inside its daily
23 or weekly or monthly simulation horizon, and the water value is optimized and equal to

1 the opportunity cost of thermal resources displaced by the pumped storage generation in
2 future periods. In other words, PLEXOS automatically determines the optimal
3 generation and pump pattern for a pumped storage unit to maximize the water value.
4 This functionality of PLEXOS is essential for modeling pumped storage units and
5 calculating the benefit of LEAPS Project.

6 I included 2500 MW new wind resources in the Tehachapi area. I relied on the
7 hourly dispatch shapes/curves included in WECC database for renewable resources
8 dispatch. These hourly dispatch shapes/curves are developed by WECC based on
9 historical data. Wind resources are assumed to have zero variable cost.

10 In addition, I input the CAISO utility-retained generation (“URG”) ownership in
11 the database. By so doing, the PLEXOS model was able to directly calculate the CAISO
12 URG margin based on dispatch results.

13 Finally, I included non-QF, participating generation units in the CAISO Control
14 Area as an approximate of generation units that are capable of providing ancillary
15 services in the PLEXOS database. The non-QF, participating generation 1 2 3 4 units are
16 based on the most recent Master CAISO Control Area Generating Capability List¹ since
17 the CAISO certified AS unit list is not publicly available. I assume each non-QF,
18 participating generation unit can provide up to 25% of its maximum capacity as ancillary
19 services.

¹/ See Master CAISO Control Area Generating Capability List, publicly available at
<http://www.caiso.com/14d4/14d4c6c961cc0.xls>.

1 **3.2 Load**

2 The load component of the PLEXOS base case model included load distribution
 3 by WECC region, which incorporated annual energy, annual peak demand, and base year
 4 hourly demand profiles. In setting up this component in the PLEXOS base case model, I
 5 used the same assumptions about system loading conditions in 2015 as the CAISO South
 6 Regional Transmission Plan (“CSRTP”) report.² When I was unable to assemble the load
 7 forecasts directly from the CSRTP report, I relied on CAISO’s TEAM Report³ to forecast
 8 2015 demand for some of the WECC sub-regions. The following table represents the
 9 demand assumptions used in my PLEXOS model, both in the base case and sensitivity
 10 cases.

Region Name	Z Global Peak Demand Forecast for 2015 (MW)	Z Global Energy Forecast for 2015 (GWh)	Z Global Data Source
ALBERTA	9,540	65,697	CAISO CSRTP-2006 Study 2015 forecast
AQUILA	976	6,588	CAISO CSRTP-2006 Study 2015 forecast
ARIZONA	22,626	104,761	CAISO CSRTP-2006 Study 2015 forecast
B.C.HYDRO	10,588	63,034	CAISO CSRTP-2006 Study 2015 forecast
IDAHO	3,694	18,621	CAISO CSRTP-2006 Study 2015 forecast
IID	1,644	6,215	CAISO CSRTP-2006 Study 2015 forecast
LADWP	6,597	29,956	CAISO Testimony, CPUC Dkt. A.06-08-010, January, 2007
MEXICO-CFE	3,209	15,278	CAISO CSRTP-2006 Study 2015 forecast
MONTANA	1,698	10,807	CAISO CSRTP-2006 Study 2015 forecast
NEVADA	7,276	29,345	CAISO CSRTP-2006 Study 2015 forecast
NEW MEXICO	4,730	27,246	CAISO CSRTP-2006 Study 2015 forecast
NORTHWEST	30,268	181,939	CAISO CSRTP-2006 Study 2015 forecast
PACE	8,444	48,801	CAISO TEAM Report 2013 forecast*
PG AND E	27,848	139,488	CAISO Testimony, CPUC Dkt. A.06-08-010, January, 2007
PSCOLORADO	8,199	38,983	CAISO TEAM Report 2013 forecast*
SANDIEGO	5,289	24,998	CAISO Testimony, CPUC Dkt. A.06-08-010, January, 2007
SIERRA	1,995	11,728	CAISO CSRTP-2006 Study 2015 forecast
SOCALIF	27,173	121,275	CAISO Testimony, CPUC Dkt. A.06-08-010, January, 2007
WAPA L.C.	252	1,591	CAISO CSRTP-2006 Study 2015 forecast
WAPA R.M.	5,388	27,100	CAISO TEAM Report 2013 forecast*
WAPA U.M.	271	1,545	CAISO TEAM Report 2013 forecast*
TOTAL		974,996	

^{2/} See “CAISO South Regional Transmission Plan for 2006,” (July 28, 2006), publicly available at <http://www.caiso.com/1841/1841b1925a320.pdf>.

^{3/} See CAISO’s TEAM Report, publicly available at <http://www.caiso.com/docs/2004/06/03/2004060313241622985.pdf>.

1 * Assumed annual growth rate of 2 percent for peak demand and 1.5 percent for energy from TEAM's 2013 forecast. .In
2 addition, I used the WECC database's hourly load profiles for 2008 as my base profiles and used the 2015 load forecast from the
3 above table to grow the 2008 hourly profiles to 2015. I assumed normal conditions for future supply/demand in 2015 for the base
4 case and the base case plus the LEAPS and TE/VS projects.

5 **3.3 Transmission**

6 The base case transmission network used in the PLEXOS model production cost
7 simulation study was developed based on a full-loop WECC 2015 Heavy Summer ("HS")
8 power flow base case. I also included in the PLEXOS base case model certain
9 assumptions about new transmission and transmission upgrades. For example, I assumed
10 Path 42 being upgraded to 1,500 MW transfer capability prior to year 2015, as the
11 CAISO assumed in the CPUC's Sunrise proceeding. See "Initial Testimony of the
12 California Independent System Operator Corporation Part 1," A. 06-08-010, at 27
13 (January 26, 2007).

14 Furthermore, the PLEXOS base case model included transmission constraints,
15 including interfaces, transmission lines or group of lines, nomograms, and limitations
16 associated with transmission outages (also modeled as nomograms). While calculating
17 the power flow for each hour of the year, PLEXOS enforced all constraints to ensure that
18 the line flow, interface value, or nomograms flow did not exceed the specified rating by
19 re-dispatching the system generation to satisfy the constraints.

20 Q: Please briefly describe the co-optimization of energy and ancillary services in PLEXOS
21 modeling.

22 A: PLEXOS is capable of co-optimizing energy and ancillary services. When co-optimizing
23 energy and ancillary services, the objective function in PLEXOS is minimizing total
24 generation production cost and total ancillary service procurement cost. A generation
25 unit, depending on its capability, can bid to provide energy or ancillary services to the
26 market, or both. AS awards and AS market prices are determined by solving an

1 integrated mathematical problem which considers physical operating limits of the
2 generation units and transmission network, as well as the reserve requirement constraints.

3 PLEXOS can model several classes of ancillary services, including regulation,
4 spinning reserve, and non-spinning reserve. Due to time constraint, for the evaluation of
5 LEAPS, I chose to focus on regulation up and operating reserve.

6 To set up the PLEXOS AS model, I first need to define AS regions.⁴ I defined
7 two AS regions for this study: CAISO system AS region, and SP 26 AS region. Next I
8 need to define the reserve requirements in each AS region. For the CAISO system AS
9 region, I assume the operating reserve requirement is 5% of the CAISO internal load and
10 regulation up requirement is 600 MW. For the SP 26 region, I assume the operating
11 reserve requirement is 40% of the CAISO system operating reserve requirement.

12 Note that due to time constraint I did not model regulation down. Therefore the
13 AS benefit of TEVS and TEVS w/LEAPS reported in this filing is a conservative
14 estimate. I expect that the AS benefit of TEVS and TEVS w/LEAPS will be higher if all
15 ancillary services and all AS regions are modeled.

16 Q: Please briefly describe the outputs from the PLEXOS base case model.

17 A: The outputs from the PLEXOS base case model include LMPs, Ancillary Service Market
18 Prices (ASMPs), flows on transmission lines, dispatch levels, AS awards, and economic
19 measurements (such as Cost-to-Load, Production Cost, Producer Revenue, Transmission
20 Congestion Revenue, URG profit, etc.). Having economic measurements calculated

⁴/ In the future MRTU market, 10 or more AS regions will be modeled in day ahead and real time market, including CAISO system AS region, expanded system AS region, SP 26 AS region, expanded SP 26 AS region, etc.

1 directly and internally within the simulation tool and reported directly avoids potential
 2 errors that may occur during a spreadsheet-type of benefit calculation model.

3 **4.0 PLEXOS MODELING RESULTS OF THE LEAPS AND TE/VVS PROJECTS**

4 Q: Can you explain the modeling you performed using the PLEXOS TE/VVS case and TV/VVS
 5 plus LEAPS case and the results of that modeling?

6 A: Yes. I ran a production cost simulation for the TE/VVS case and the TE/VVS plus LEAPS
 7 case, using PLEXOS. In so doing, I kept all assumptions of the base case model constant
 8 and included the generation and transmission facilities that are proposed for the TE/VVS
 9 and LEAPS projects, as provided to me by TNHC. Table 1 represents the estimation of
 10 the total energy/ancillary service cost and benefit of the TE/VVS and TE/VVS plus LEAPS
 11 projects based on the comparison of the base case results (the No TEVS or LEAPS case)
 12 with the results of the base case plus TE/VVS and the base case with TE/VVS and LEAPS.
 13 The net results of the model runs of the three cases is that there is a total energy/ancillary
 14 service benefit from the LEAPS and TE/VVS projects is \$151 Million (nominal) in year
 15 2015. The results of the three model runs are summarized in the table below.

16 **Table 1**
 17 **Estimated energy benefits of the LEAPS and TE/VVS projects**
 18 **using PLEXOS modeling**
 19 **(in \$millions)**

	Cost			Benefit		
	Base Case	TE/VVS	LEAPS +TE/VVS	TE/VVS	LEAPS	LEAPS + TV/ES
Customer Energy Payments from PLEXOS (M\$)	15,546	15,507	15,487	39	20	59
Customer AS Payment from PLEXOS (M\$)	189	188	160	1	28	29
less CAISO PTO Transmission Rent (M\$)	364	350	347	(15)	(2)	(17)
less CAISO URG Margin (M\$)	3,238	3,239	2,232	1	(7)	(6)
less IOU excess loss payments	1,017	1,013	1,008	(4)	(5)	(9)
LEAPS Energy Storage Value (M\$)	-	-	66	-	66	66
LEAPS AS Margin to Consumers (M\$)	-	-	29	-	29	29
Total Energy/AS Cost and Benefit (M\$)	11,116	11,093	10,965	23	128	151

20

1 I would note that the energy/ancillary service benefits of the LEAPS and TE/VS
2 projects represented in Table 1 is not an estimate of the total benefits that the LEAPS and
3 TE/VS projects may bring to the CAISO ratepayers. My analysis does not project other
4 benefits of the combined projects, including reliability benefits, renewable portfolio
5 standards (“RPS”) compliance benefits, and reliability must run (“RMR”) capacity
6 benefits, all of which Mr. Auclair discusses in his testimony. Also note that the AS
7 benefit is a conservative estimate due to not including Regulation Down in the modeling.
8 Furthermore, the energy benefit is also a conservative estimate by assuming generators
9 bid competitively in the market.

10 Q: What assumptions have you made in term of new Transmission Lines?

11 A. The base case analysis contains PVD2 and GPN in service and no Sunrise. The
12 sensitivity cases are: Sensitivity Case 1: PVD2, GPN, and TE/VS, but no Sunrise.
13 Sensitivity Case 2: PVD2, GPN, TE/VS plus LEAPS pump storage, but no Sunrise.

14 Q: What is the amount of renewable capacity in Imperial and Tehachapi modeled in the base
15 case, the TE/VS case, and the TE/VS + LEAPS case?

16 A: Same input assumptions are used in all three cases in terms of Imperial and Tehachapi
17 renewable resources. I included 900 MW renewable resources in Imperial region,
18 including the 600 MW new geothermal resources in the Salton Sea/IID area. For the
19 Tehachapi area, I included 2500 MW new wind resources in Kern County.

20 Q. Was Otay Mesa plant available to be dispatch in your cases?

21 A. Yes.

22 Q. Was South Bay plant unavailable to be dispatch in all your cases?

23 A. Yes.

1 Q. What was the import limits into SDGE in your cases?
2 A: The import capability into SDG&E is modeled at 2500 MW in the base case and 3500
3 MW in both the TE/VS case and the TE/VS plus LEAPS case.
4 Q. What was the limit of the TE/VS line?
5 A. The limit on the 500kV portion of the TE/VS project (i.e., from Lee Lake to Camp
6 Pendleton) is set to 2598 MW both directions.
7 Q. What is the total available generation in the San Diego area?
8 A. Around 3900 MW.
9 A: Does this conclude your testimony?
10 A. Yes it does.
11

- 1 • Second, it discusses the benefits of TE/VS and the combined TE/VS+LEAPS
- 2 projects and;
- 3 • Third, it provides a net benefit calculation for the TE/VS and the combined
- 4 TE/VS+LEAPS projects.

5 Q. Please describe your conclusions.

6 A. I conclude that the TE/VS transmission line will have a positive net economic benefit,
 7 and that the TE/VS transmission line and LEAPS pumped storage project together
 8 (TE/VS+LEAPS) will have a positive net economic benefit. Estimates of the value of the
 9 principal elements of the benefits of TE/VS and the combined TE/VS+LEAPS projects
 10 are summarized in Table 1 below. I will explain the nature of each type of benefit and
 11 how the estimates for each were derived later in my testimony.

12 **Table 1**
 13 **Estimated Net Benefit of the TE/VS and TE/VS+LEAPS Combined Projects**
 14 **(\$M 2015 Nominal)**

	BENEFIT		
	TE/VS	LEAPS	TE/VS + LEAPS
Energy Benefit	\$22*	\$71*	\$93*
Ancillary Services Benefit	1*	\$57*	\$58*
Wind Integration and Over-Gen Mitigation Benefit		\$33	\$33
Local Reliability Compliance Benefit	\$126	-	\$126
Resource Adequacy Compliance Benefit	-	\$14	\$14
Total Benefit	\$149	\$174	\$324
Total Levelized Annual Cost	\$51	\$94	\$145
NET ANNUAL BENEFIT	\$98	\$81	\$179

15 * These numbers are approximate because the model used does not apportion deductions for PTO Transmission Rent, URG
 16 Margin, and IOU Excess Loss Payments between the Energy Benefit and the Ancillary Services Benefit. This issue does not
 17 affect the total Energy and Ancillary Service Benefit figures (*see table 2, infra*). The impact on the Energy Benefit and Ancillary
 18 Services Benefit numbers in Table 1 would be relatively minimal.

1 **2.0 ECONOMIC EVALUATION METHODOLOGY**

2 Q. What methodology do you rely on to evaluate the economic net benefit of the TE/VS and
3 TE/VS+LEAPS projects?

4 A. I rely on the California Independent System Operator Corporation's (CAISO's)
5 Transmission Economic Assessment Methodology (TEAM),¹ as supplemented by the
6 CAISO South Regional Transmission Plan for 2006 (CSRTP)² and by the CAISO's
7 written testimony in the California Public Utilities Commission's (CPUC's) pending
8 proceeding regarding SDG&E's application for a certificate of public convenience and
9 necessity for its proposed Sunrise Powerlink transmission project (Sunrise Proceeding).³

10 Q. What is TEAM?

11 A. TEAM is a constrained optimization problem in which the economic modeler (resource
12 planner)⁴ picks the least-cost⁵ transmission and generation resource capacity plan (and
13 energy delivery plan) that satisfies three sets of constraints.⁶ The three sets of constraints
14 are:

- 15 • A model of the existing and projected infrastructure and network topology;

^{1/} Transmission Economic Assessment Methodology, July 2004, CAISO, Folsom, CA.

^{2/} CAISO South Regional Transmission Plan for 2006 (CSRTP): Findings and Recommendation on the Sun Path Project, July 28, 2006, California ISO, Folsom, CA.

^{3/} Initial Testimony of the California Independent System Operator Corporation – Part I, San Diego Gas & Elect. Co., Application 06-08-010, January 26, 2007.

^{4/} The term 'resource planner' is not used here to imply that the CAISO is the state's resource planner. Instead, the term is used to illustrate that the TEAM exercise is an integrated resource planning exercise. As such, one who engages in this modeling exercise is a resource planner within the context of the exercise.

^{5/} This study's working assumption is that the price elasticity of demand for electricity is inelastic.

^{6/} Compliance with the State of California's loading order is assumed throughout this discussion. It is assumed that energy efficiency and demand response programs are either resources or means to reduce load forecasts.

- 1 • Economic and financial input assumptions (e.g., projected demand based on an
2 adopted load forecast); and
- 3 • Policy and regulatory standards.

4 Another way of explaining the TEAM approach is that the objective of the TEAM
5 modeler (resource planner) is to find the resource plan (generation and transmission
6 capacity) that minimizes total expected consumer expenditures on generation and
7 transmission, while satisfying forecasted energy demand and all network, financial and
8 regulatory constraints.

9 Q. What do you mean by least-cost resource plan?

10 A. The least-cost resource plan is the plan that has the lowest total cost. The total cost of
11 generation is equal to the total variable cost plus the total fixed cost of generation
12 infrastructure that consumers must pay. The total cost of transmission is equal to the total
13 variable cost plus the total fixed cost of transmission infrastructure that consumers must
14 pay. The resource planner focuses on avoidable costs, not sunk costs, in choosing the
15 least-cost plan.

16 Q. How does the TEAM modeler (resource planner) account for and value the expected
17 stream of future costs (expenditures) associated with a resource plan?

18 A. The resource planner calculates the present value of the stream of expected expenditures
19 across the entire planning horizon. As an alternative, the resource planner may calculate
20 and use the annual levelized equivalent. Lastly, the resource planner may also rely on a
21 snapshot in time, such as 2015 or 2020, or both.

22 Q. How should the resource planner satisfy, or obey, the existing and projected network
23 topology and regulatory requirements?

1 A. The TEAM modeler (resource planner) should obey the projected network topology and
2 regulatory requirements by imposing reliability and regulatory constraints (standards) on
3 the transmission and generation infrastructure capacity plan, and by solving a constrained
4 least cost dispatch problem for the present and future financial delivery of energy.

5 Lastly, the TEAM modeler (resource planner) should obey the State of
6 California's imposed energy procurement constraint - the Renewable Portfolio Standard
7 (RPS), as well as the State's loading order, which includes Demand Response (DR) and
8 Energy Efficiency (EE) programs.

9 Q. Has the CAISO modified the original TEAM approach to evaluating transmission and
10 generation projects?

11 A. Yes. The 2006 CAISO CSRTP for the Sun Path Project⁷ added a CAISO and WECC
12 reliability constraint to the TEAM approach. In addition, CAISO's written testimony in
13 the Sunrise Proceeding also includes a system RA constraint to comply with the
14 Commission's resource adequacy policy. The reliability and RA constraints now include:

- 15 1. CPUC system Resource Adequacy Requirement.
- 16 2. CPUC/CAISO Local Capacity Resource Adequacy (LCRA) requirements.
- 17 3. CAISO RMR requirements, until the CPUC LCRA is fully implemented.

18 Q. What is a feasible resource plan?

19 A. When the TEAM modeler (resource planner) imposes present and projected future
20 network constraints on transmission and generation infrastructure capacity plans, he
21 obtains a feasible resource plan.

1 Q. What is a feasible dispatch?

2 A. When the TEAM modeler (resource planner) imposes present and projected future
3 network constraints on present and projected energy delivery, he obtains a set of feasible
4 dispatches across time. (i.e., a feasible set of energy injections and withdrawals from the
5 present to 2015 or 2020.)

6 Q. What is the objective of the resource planner after he obeys all the network and
7 regulatory constraints?

8 A. The objective of the TEAM modeler is to find the least-cost resource plan among the set
9 of feasible resource plans. At the same time, the TEAM modeler must also ensure that
10 each feasible resource plan solves the constrained least cost dispatch problem. Solving
11 the constrained least cost dispatch problem yields Locational Marginal Cost Prices
12 (LMP).

13 Q. What approach does the TEAM modeler use to find the least-cost resource plan?

14 A. The TEAM modeler first defines a feasible “base-case” resource plan and calculates the
15 total cost of that plan. The base-case resource plan serves as a benchmark or reference
16 against which the modeler compares all other alternative resource plans. The base-case
17 resource plan defines and includes certain financial and electricity infrastructure
18 assumptions (referred to as “input data assumptions”) that generally remain constant
19 during the evaluation of the feasible alternative resource plans. These input data
20 assumptions include variables such as load forecasts, forecasted price of natural gas,

⁷/ CAISO South Regional Transmission Plan for 2006 (CS RTP): Findings and Recommendation on the Sun Path Project, July 28, 2006, California ISO, Folsom, CA.

1 projected generation infrastructure by location, vintage, and technology (operational
2 profile, such as heat-rates), and projected transmission infrastructure.

3 The TEAM modeler then specifies alternative feasible resource plans. Each
4 alternative resource plan differs from the base-case resource plan by substituting one or
5 more generation projects and/or one or more transmission projects. In some cases, each
6 alternative resource plan may include input data assumptions that differ from those used
7 in the base-case. The TEAM modeler must be very careful not to allow the changes in
8 input assumptions to bias the results of her study. The TEAM modeler then compares the
9 total costs (total expenditures) of each alternative feasible resource plan to the total cost
10 (total expenditures) of the base-case resource plan.

11 Q. How is the benefit of an alternative resource plan calculated?

12 A. The benefit of the alternative resource plan is equal to the total expenditure on the
13 alternative resource plan minus the total expenditures on the base-case resource plan.

14 Q. How is the net benefit of a proposed alternative resource plan or project calculated?

15 A. The net benefit of a proposed alternative resource plan or project is obtained by
16 subtracting its total cost from its total benefit. The least-cost (lowest expenditure)
17 resource plan has the highest net benefit.

18 **3.0 APPLICATION OF ECONOMIC EVALUATION METHODOLOGY TO TE/VIS** 19 **AND TEV+LEAPS**

20 Q. How do you apply the TEAM-based approach you describe above to evaluate the cost
21 effectiveness of TE/VIS line and TE/VIS+LEAPS?

22 A. I use the three resource plans developed in the testimony of Dr. Mingxia Zhang submitted
23 contemporaneously with mine. The first plan is the base case plan. The second is the
24 TE/VIS resource plan, and the third is the combined TE/VIS+LEAPS resource plan. Each

1 plan includes one study year, 2015, in which the benefits and costs are expressed in
2 nominal dollars.

3 I calculate the benefit of the TE/VS line as the difference between the consumer
4 expenditures necessary for the base case resource plan and consumer expenditures
5 necessary for the plan with the TE/VS line in service.

6 I also calculate the benefit of the combined TE/VS+LEAPS resource as the
7 difference between the consumer expenditures necessary with the combined
8 TE/VS+LEAPS projects in service and the consumer expenditure necessary for the base
9 case plan.

10 Q. Please describe the types of benefits you considered in evaluating the TE/VS line and the
11 combined TE/VS+LEAPS project relative to the base case plan.

12 A. I considered and summed the following benefits expressed as the respective differences
13 in expenditures between the project plans and the base case plan:

14 1. The Energy Benefit of the project is the difference in the load-weighted locational
15 marginal prices (“LMP”) in the applicable study area between the project case and
16 the base case, net of:

- 17 • The difference in Utility Retained Generation (URG) margins between the
18 project plan and the base case plan;
- 19 • The difference in congestion rent between the project plan and the base
20 case plan;⁸

⁸/ Adding a well-planned transmission line or a resource may reduce congestion rents. However, this reduction in congestion rents is not included as a benefit because congestion rents are rebated to the CAISO area consumers who already pay the CAISO’s Transmission Access Charge (TAC). Congestion rent and congestion cost are two distinct concepts. Congestion cost is the aggregate re-dispatch cost + the consumer deadweight loss due to binding transmission constraints. Congestion rent is an assignable financial property right, and as such, is a transfer payment; congestion cost is a loss to society as a whole

1 generation for SDG&E customers. As such, it provides an energy price benefit by
2 reducing the energy market clearing prices (i.e., location marginal prices, or LMPs) to
3 CAISO consumers.

4 The TE/VS line also provides SDG&E with access to renewable energy resources,
5 and may increase the depth of the pool of renewable suppliers to SDG&E. For example,
6 the TE/VS line facilitates access for SDG&E consumers to renewable resources located
7 north of San Diego, including Tehachapi wind resources, as well as Pacific Northwest,
8 other western U.S., and Canadian renewable resources. In addition, should the Los
9 Angeles Department of Water and Power decide to construct its proposed Green Path
10 North transmission project from the Imperial Valley/Salton Sea area to the Los Angeles
11 basin, the TE/VS line could also provide SDG&E customers with access to renewable
12 energy resources to the east of San Diego. As such, the TE/VS line is well-positioned to
13 assist SDG&E in meeting its RPS compliance objectives.

14 In addition, by increasing the transmission import capacity to the San Diego Local
15 Capacity Requirement (LCR) area by 1000 MW, the TE/VS transmission line will reduce
16 SDG&E's local reliability compliance costs relative to the base case. Finally, by
17 interconnecting LEAPS to the CAISO high voltage transmission system, TE/VS will
18 permit CAISO customers to realize the economic benefits provided by the LEAPS
19 project.

20 Q. Please describe the benefits of the LEAPS project that would be made possible by the
21 addition of TE/VS.

1 A. LEAPS will provide the following benefits: Ancillary Services (AS); energy and energy
2 storage; resource adequacy capacity; integration of intermittent resource including wind;
3 and the capability of mitigating over-generation situations.

4 It is my understanding that the LEAPS resource provides the following Ancillary
5 Services (AS):

- 6 • Black Start (15 seconds)
- 7 • Regulation up and down (up to 500 MW per minute)
- 8 • Spinning Reserve (up to 500 MW per minute)
- 9 • Non-spinning reserve (up to 500 MW per minute)

10 A reasonable benefit evaluation methodology should account for the very rapid
11 response time of the LEAPS resource to dispatch instructions – 15 seconds – and should
12 value it accordingly. The methodology should also account for the fact that LEAPS can
13 provide up to 500 MW to the grid in 15 seconds. These capabilities make LEAPS an
14 extremely valuable asset in assisting the grid operator to maintain system balance and
15 stability. Other than perhaps some conventional hydro,⁹ I am unaware of any other grid
16 facility that can match LEAPS’ ability to provide 500 MW to the grid within 15 seconds
17 in response to a CAISO dispatch notice. These operational characteristics should make
18 LEAPS one of the best sources of regulation and spinning reserve capacity for the grid
19 operator. In addition, LEAPS’ rapid dispatch response and ramping capability should
20 enable it also to efficiently provide load-following service, should the CAISO decide to
21 adopt a load following product as an Ancillary Service. The emergency value of LEAPS

^{9/} It is my understanding that no new, sizeable conventional hydro has been added to the California grid in over 15 years.

1 should not be overlooked. The ability to provide 500 MW in one minute will be a very
2 valuable service in times of system emergency.

3 To put LEAPS' response capabilities in perspective, it is my understanding that
4 combustion turbines (CTs) require anywhere from 10 to 60 minutes to respond to a
5 dispatch signal and do not provide regulation or spinning reserve capability. Combined
6 cycle CTs take anywhere from one to four hours to respond to a dispatch signal, have no
7 black start capability, and, compared with a plant like LEAPS, have a much more limited
8 capability to provide regulation and spinning reserve services. It is also my understanding
9 that combined cycle units may take hours to ramp up to full capability, e.g., to provide
10 500 MW to the grid in one minute may require 10 to 12 combined cycle units, each of
11 500 MW generating capacity. Accordingly, LEAPS represents an efficient, cost-effective
12 source of regulation, spinning reserve and load-following services.

13 Another important benefit of LEAPS is that it can effectively function as a large
14 energy storage battery. For example, wind and other generation with low marginal
15 operating costs may be used to power LEAPS' pumps at night to fill the project's upper
16 reservoir. The water stored there thus represents low-cost, stored energy. In a well-
17 designed, competitive spot energy market, this storage value should equal the difference
18 between the on-peak energy price and the off-peak energy price. During conditions of
19 high demand, the value of storage and associated increase in grid efficiency can be quite
20 significant.

21 Q. Why would the energy storage capability of LEAPS be important in such an evaluation?

22 A. California is implementing aggressive RPS goals. Achievement of these goals will mean
23 relying on a significant amount of wind generation resources. Wind energy is

1 intermittent and unpredictable. LEAPS' storage capability provides a mechanism to
2 consume and store wind energy (e.g., Tehachapi wind) when it is available, but not
3 needed, during off-peak periods, and to release the stored energy during peak demand
4 periods. Because LEAPS can respond to a CAISO dispatch signal in 15 seconds and also
5 can provide up to 500 MW in one minute, it would be an efficient and valuable
6 complement to wind energy, whose capacity factors typically range from 25 to 35
7 percent. In this role, LEAPS is said to "firm up" wind energy.

8 In addition, adding significant quantities of wind capacity to the grid will create
9 integration challenges for the CAISO that, if not properly planned for, may lead to
10 unnecessarily high integration costs. For example, the unpredictable and intermittent
11 nature of wind will increasingly place CAISO operators in the position of having to
12 adjust either up or down the output of slow-responding, fossil fuel thermal generation.
13 This may lead, in turn, to greater reliance on spinning reserve and regulation services.
14 This reliance likely will become increasingly inefficient and costly to CAISO
15 ratepayers.¹⁰ California load is growing by nearly two percent per year. However, it is
16 my understanding that the supply of regulation units (e.g., conventional hydro) in
17 California has not changed appreciably in more than 15 years, and is not expected to
18 change in the foreseeable future. As a percentage of the growing load, the fleet of
19 existing, conventional generation is becoming less and less flexible with respect to the
20 CAISO's operational needs, even as such flexibility is becoming an increasingly
21 valuable and necessary commodity.

¹⁰ This greater reliance on fossil fuel thermal generation for purposes of integrating wind resources would be contrary to California's Greenhouse Gas Policy and RPS objectives.

- 1 Q. Please explain your assessment of the Energy and AS Benefits of the TE/Vs and
 2 TE/Vs+LEAPS projects.
- 3 A. I use the TE/Vs and LEAPS energy benefit results from TNHC’s witness Dr. Mingxia
 4 Zhang, reproduced and adapted from her testimony in Table 2 below.

5 **Table 2**
 6 **Estimated Energy & AS Benefits of the LEAPS and TE/Vs Projects**
 7 **using PLEXOS Modeling (\$M 2015 Nominal)**

	Cost			Benefit† (project case vs. base case)		
	Base Case	TE/Vs	LEAPS + TE/Vs	TE/Vs	LEAPS	LEAPS + TE/Vs
Customer Energy Payments from PLEXOS (M\$)	\$15,546	\$15,507	\$15,487	\$39	\$20	\$59
Customer AS Payment from PLEXOS (M\$)	\$189	\$188	\$160	\$1	\$28	\$29
less CAISO PTO Transmission Rent (M\$)	\$364	\$350	\$347	\$(15)*	\$(2)	\$(17)
less CAISO URG Margin (M\$)	\$3,238	\$3,239	\$3,232	\$1	\$(7)	\$(6)
less IOU Excess Loss Payments(M\$)	\$1,017	\$1,013	\$1,008	\$(4)	\$(5)	\$(9)
LEAPS Energy Storage Value (M\$)	-	-	(\$66)	-	\$66	\$66
LEAPS AS Margin to Consumers	-	-	(\$29)	-	\$29	\$29
Total Energy & AS Cost and Benefit (M\$)	\$11,116	11,093	10,965	\$23*	\$128*	\$151

8 * These total figures are not the exact sum of their inputs due to rounding.

9 † The Benefit calculation represents the difference between the total cost of the Base Case and the TE/Vs and LEAPS projects.

10 The TE/Vs transmission line alone provides an energy and AS benefit of \$23
 11 million. For the combined TE/Vs + LEAPS projects, Dr. Zhang’s PLEXOS market
 12 simulation yields a total energy and AS benefit, relative to the base case outcome, of
 13 \$151 million (nominal) for the year 2015.

14 The TE/Vs line reduces net LMP energy and AS payments by \$23 million
 15 annually by providing an additional 1000 MW of import capacity to the San Diego LCR
 16 area, thus permitting access for the area to lower cost generation. In addition, the

1 introduction of LEAPS further depresses net LMP energy and AS expenditures in the
2 relevant region by an additional \$33 million/year.

3 The combined TE/VS + LEAPS energy and AS benefit of \$151 million a year is
4 explained to a significant degree by the energy storage value of LEAPS of \$66
5 million/year.

6 Using the CAISO's cost-levelizing methodology¹¹ for the TE/VS and LEAPS
7 projects, I obtain an annual, levelized cost of \$145 million/year for the combined project
8 (i.e., \$51.33 million/year for the TE/VS transmission line and \$94 million/year for the
9 LEAPS project.)¹²

10 Thus, the 2015 energy and AS benefits quantified in Table 2 more than offset the
11 combined, levelized annual cost of LEAPS + TE/VS. This result is obtained before
12 accounting for the reliability benefits of TE/VS and the resource adequacy and other
13 benefits of LEAPS, which are not reflected in Table 2. I will discuss these other benefits
14 later in my testimony.

15 Examination of the LEAPS facility confirms that the \$66 million/year storage
16 value is a reasonable estimate. The LEAPS pumped storage facility will consume
17 electricity during off peak (low price) periods in order to generate electricity during peak
18 (high price) periods. It is this capability to consume electricity during off-peak and over-
19 generation periods when LMPs are very low and provide electricity during on-peak
20 periods, when LMPs are high, that allows LEAPS to obtain an energy margin of \$66

¹¹/ Second Errata to Initial Testimony, Part II, A.06-08-010, April 20, 2007 (CAISO).

¹²/ The capital cost for TE/VS is \$350 million and \$650 million the LEAPS project.

1 million/year on a continuous basis, unconstrained by the unpredictable, year-to-year
2 patterns of precipitation that dictate operation of conventional hydro resources.

3 A simple example can illustrate that the \$66 million/year figure is a reasonable
4 number. LEAPS can generate 500 MWh each hour for 12 hours, 365 days per year. The
5 technology does not face the “water for electricity” constraint faced by conventional
6 hydropower. An assumed average daytime LMP of \$52.40/MWh¹³ would yield a yearly
7 revenue stream of \$114.7 million.

8 On the other hand, LEAPS consumes power during the 12-hour period when
9 LMPs are expected to be significantly lower. Since the expected energy storage value of
10 LEAPS is the difference between the expected LMPs during the 12 hour peak period and
11 the expected LMPs during the 12 hour off-peak period, it is reasonable to assume that the
12 estimated storage value could be significant.

13 Q: Your expected storage benefit of LEAPS is based on expected on-peak/off-peak LMP
14 differentials during the life of the asset. Is it reasonable to expect that such differentials
15 between on-peak and off-peak energy prices will continue for the foreseeable future?

16 A. California continues to refine its wholesale market and retail-side designs. Neither I nor
17 any other observer can be certain of the impacts on future wholesale prices of new, real-
18 time retail pricing programs and possible retail direct access design elements. For
19 example, it is possible that, should all the market design elements now under
20 consideration be put in place, including forward contracting, spot market scarcity pricing
21 could become a reality. Nevertheless, I do not know of any spot commodity market

¹³/ Initial Testimony of the California Independent System Operator – Part I, A.06-08-010, January 26, 2007, page 50. The CAISO testimony calculates an average LMP of \$52.40/MWh over the entire period of the transmission study plan, including off-peak periods. Therefore, an assumption of \$52.40/MWh for the on-peak period is very conservative.

1 where, when short-term demand goes up, prices don't go up as well. I do not expect peak
2 and off-peak differences in demand for electricity to change significantly in the
3 foreseeable future.

4 Q. Please explain your assessment of the **AS benefits** of the LEAPS facility.

5 A. As mentioned earlier in my testimony, the AS value of LEAPS lies in its ability to
6 provide to the CAISO 500 MW in one minute, and to commence generating within 15
7 seconds after receiving a CAISO dispatch signal. These capabilities enable LEAPS to
8 provide regulation service and both spinning and non-spinning reserve capacity to the
9 CAISO.

10 Dr. Zhang's PLEXOS market simulation co-optimized the use of the LEAPS
11 facility for sales of energy vs. ancillary services. Her analysis indicates that LEAPS' AS
12 benefits would be approximately \$57 million in 2015 (nominal 2015\$). This LEAPS AS
13 benefit comprises two elements. First, LEAPS reduces AS expenditures by \$28 million a
14 year. Second, the PLEXOS simulation also yields a LEAPS AS margin of \$29 million a
15 year which TNHC proposes be credited back to consumers.

16 I note the CAISO's own preliminary estimates of the AS benefits of LEAPS in a
17 2006 presentation on the economic benefits of the LEAPS project.¹⁴ The following table
18 provides the estimates from the CAISO presentation.

19 **Table 3**
20 **CAISO Ancillary Service Benefits Preliminary Results**
21 **(\$M 2005 Nominal)**

AS Services	Benefit
Regulation Up	14.90
Regulation Down	7.93

^{14/} CAISO Presentation: Economic Benefits Assessment of the LEAPS Project, Regional Transmission South, September 19, 2006, at 20. (Copy attached as Exhibit TNHC-20.).

Spin	11.56
Non-Spin	1.67
Total	36.05

1
2 For the sake of consistency, I will utilize Dr. Zhang's estimated AS benefits in my
3 evaluation. In addition, the CAISO also evaluated the wind integration benefits of
4 LEAPS. Its 2006 presentation states:

5 LEAPS can provide additional regulation service to help with
6 increased regulation and load following needs due to (the) large
7 volume of wind generation. LEAPS can also reduce the magnitude
8 of wind generation curtailment.¹⁵

9 The CAISO estimated the wind integration benefit of LEAPS to be \$10.02 million
10 (2006\$) in 2015.

11 In addition, it is important to note that LEAPS will also provide a benefit during
12 low load periods by consuming the output of must-take plants during over-generation
13 conditions – conditions in which certain generation must be curtailed to allow the
14 continued operation of the must-take generation. Over-generation conditions take place
15 during the spring season. In its 2006 presentation on the economic benefits of the
16 LEAPS project, the CAISO stated:

- 17 • Adding LEAPS will reduce/eliminate the over-generation condition that
18 take[s] place during the spring season.
- 19 • The impact of over-generation on [the] market is that regulation down
20 prices spike.

¹⁵/ Id. at 31.

- In addition, over-generation [has] caused major operation difficulties, resulting in reliability criteria violations.¹⁶

LEAPS would therefore mitigate spikes in regulation down prices during over-generation periods. The CAISO, which characterizes this service as an Ancillary Service, estimates the over-generation benefit of LEAPS to be \$17.46 million (2006\$) in the year 2015.¹⁷

Therefore, for the year 2015, the total benefit derived from energy sales, ancillary and related services for the TE/VS and LEAPS projects approximates \$184.07 million in 2015. (Please see Table 4). This amount exceeds the combined levelized annual cost of the projects by about \$39 million.

Table 4
Energy, Ancillary Service & Related Benefits of LEAPS & TE/VS
(\$Million 2015 Nominal)¹⁸

Energy Benefits	\$93
Ancillary Services Benefits Over-Generation Wind Integration	\$58 \$20.86 \$12.21
Total Energy, AS & Related Benefits	\$184.07

Q. Please explain your assessment of the **Local Reliability Benefit** of TE/VS.

A. The TE/VS line provides reliability benefits to the San Diego Local Capacity Requirement area by providing an additional 1000 MW of transmission import capability. This additional capacity will reduce CAISO Reliability Must Run (RMR) contracts and

^{16/} Id. at 17.

^{17/} 17 Id. at 32.

^{18/} I converted the 2006 CAISO values to 2015 nominal dollars, assuming a two percent annual rate of inflation.

1 reduce the obligation of SDG&E to procure capacity to comply with the CPUC’s Local
2 Capacity Requirement (LCR).¹⁹

3 To obtain the LCR compliance benefits for the TE/VIS transmission line in 2015, I
4 rely on the local reliability benefit evaluation methodology the CAISO used in its April
5 20, 2007 testimony in the CPUC’s Sunrise Powerlink proceeding.²⁰²¹ However, I change
6 the increase in transmission import capacity attributable to the TE/VIS line from the
7 CAISO’s assumed 500 MW to 1000 MW to reflect TNHC’s estimate of the import
8 capacity of the line. Based on my observation that the LCR benefit of the CAISO’s
9 bundled Green Path+LEAPS+TE/VIS alternative is associated entirely with the TE/VIS
10 transmission line, and since this 1000 MW incremental import capacity is twice that
11 assumed by the CAISO testimony, I have assumed the LCR benefit of TE/VIS is twice the
12 benefit of \$63 million/year that the CAISO calculated for its bundled LEAPS-TE/VIS-
13 Green Path North project.

14 Accordingly, the LCR benefit of the TE/VIS line in 2015 is an annualized \$126
15 million/year. This is a conservative estimate because the Sunrise line would provide the
16 same additional import capacity to the San Diego region as the TE/VIS line. Since the
17 CAISO estimates the 2015 reliability benefits of Sunrise to be \$138 million/year in 2015,

^{19/} CAISO RMR contracts comply with the CPUC’s LCR. The CAISO intends to phase out the CAISO RMR contract and rely instead on the CPUC LCR contract.

^{20/} Initial Testimony of the California Independent System Operator Corporation – Part I, Application 06-08010, January 26, 2007; Second Errata to Initial Testimony, Part II, CAISO, Application 06-08-010, April 20, 2007.

^{21/} In response to a CPUC Energy Division staff request, the CAISO subsequently revised its local reliability benefit evaluation methodology to include the impact of its alternative resource plans on the LA LCR area, in addition to the San Diego LCR area. However, the structure of the new CAISO testimony “Two-LCR” (LA & SD) benefit evaluation methodology is not fully developed, is not sufficiently explained and is, in fact, internally inconsistent. As such, I have chosen to use the structure of the CAISO’s “One-LCR” local reliability benefit evaluation methodology in its April 20, 2007 testimony. My decision to do so is supported by the CAISO reliance on a “One-LCR” reliability benefit evaluation methodology in both its CSRTP and 2008 LCR

1 one should arguably conclude that the reliability benefits of TE/VS would also be \$138
2 million/year in 2015.

3 Q. What is the total annualized benefit of the TE/VS and TE/VS+LEAPS projects for the
4 year 2015 at this point of the analysis?

5 A: The total annualized benefit of the TE/VS transmission project for the year 2015 equals
6 the energy and AS benefits of \$23 million + the reliability compliance benefit of \$126
7 million, or \$149 million. Since the annualized cost of TE/VS is \$51.33 million, the
8 annualized net benefit of TE/VS for the year 2015 is \$97.67 million (\$149 million -
9 \$51.33 million). This net benefit amount is sufficient to recover the cost of TE/VS in
10 under five years.

11 The total annualized benefit of the combined TE/VS+LEAPS project equals the
12 energy benefit of \$93 million + the AS and related services benefits of \$91.07 million +
13 the reliability compliance benefit of \$126 million, or total benefits of \$310.07 million.
14 Against these benefits, one must net the annualized cost of the TE/VS and LEAPS
15 projects of \$51.33 million/year and \$94 million/year, respectively. Accordingly, the net
16 benefit of the TE/VS+LEAPS projects at this stage of the analysis is an annualized
17 \$164.74 million/year. That is, the energy benefits, reliability benefits and AS benefits
18 alone are expected to reduce CAISO consumer expenditures by \$164.74 million per year
19 in 2015.

20 Q. Please explain your assessment of the Resource Adequacy Capacity Benefit of the
21 LEAPS facility.

Study processes. I must note I am not questioning the validity of a two or more LCR benefit evaluation methodological framework, but rather how the CAISO testimony has structured it.

1 A. The CPUC's resource adequacy policy requires its jurisdictional load-serving entities
2 (LSEs) to procure the bulk of their wholesale electric needs through forward procurement
3 mechanisms. Moreover, the Commission has established a capacity-based, as opposed to
4 an energy-based, resource adequacy (RA) obligation. LEAPS would qualify as RA
5 capacity, thereby providing an RA capacity compliance benefit. Although I do not adopt
6 a value for this RA capacity compliance benefit, the CAISO has agreed in the Sunrise
7 proceeding with and adopted a value of \$27/kW-year (in 2006 dollars),²² or
8 \$27,000/MW-year, as a floor for RA payments. For LEAPS, this would amount to \$13.5
9 million/year (500MW x \$27,000/MW-year = \$13.5 million). Including this benefit
10 brings the total quantified net benefits of TE/VS+LEAPS to CAISO ratepayers to
11 \$178.24 million annually.

12 Q. Please explain your assessment of the **RPS Benefits** of the TE/VS and TE/VS +LEAPS
13 facilities.

14 A. I have not quantified an RPS compliance benefit for TE/VS and TE/VS+LEAPS.
15 Nevertheless, the TE/VS line will directly assist the state's LSEs in meeting their RPS
16 compliance requirements. As mentioned above, TE/VS will provide 1000 MW of
17 additional import capacity to permit SDG&E to access a varied portfolio of renewable
18 energy resources throughout California, the Pacific Northwest, and other parts of the
19 western United States, as well as western Canada. Since SDG&E will have a wider array
20 of renewable suppliers to choose from, one would reasonably expect its customers to
21 benefit from lower RPS procurement costs than they otherwise would incur.

^{22/} Rebuttal Testimony of the California Independent System Operator Corporation, A.06-08-010, June 15, 2007, p.35.

1 Although LEAPS does not qualify as an RPS resource under California law, it
2 nonetheless will be a crucial component of the grid for the purpose of integrating
3 intermittent wind energy resources. As such, LEAPS would greatly facilitate
4 implementation of the state's RPS policy. In addition, LEAPS will facilitate compliance
5 by one or more LSEs with California's Greenhouse Gas policy and associated carbon
6 emissions standard. In this respect, LEAPS will be a critical tool to help the State of
7 California realize its environmental policy objectives, while at the same time providing
8 much needed electricity to serve its growing economy.

9 Q. What is the total net benefit of the TE/VS and TE/VS+LEAPS projects?

10 A. The total annualized benefit of the TE/VS and TE/VS+LEAPS projects equals the energy
11 benefit of \$93 million + the AS benefits of \$58 million + the wind integration and over-
12 generation benefits of \$33 million + the reliability compliance benefit of \$126 million +
13 \$13.5 million of RA benefits. This equals \$323.5 million dollars/year. Since the
14 annualized cost of TE/VS and the LEAPS projects are \$51.33 million/year and \$94
15 million/year, respectively, the net benefit of the combined TE/VS and LEAPS projects is
16 an annualized \$323.5 million - \$145.33 million, or \$178.17 million/year.

17 The total benefit of the TE/VS project alone is the energy benefit of \$22
18 million/year + the AS benefit of \$ 1 million/year + the reliability benefit of \$126
19 million/year, or \$149 million/year. With an annualized cost of \$51.33 million/year, the
20 net benefit of the TE/VS transmission project alone is more than \$97.67 million/year.

21 Although I do not quantify the RPS compliance benefit for the proposed projects, it is
22 clear from my testimony above that TE/VS and LEAPS will provide significant RPS
23 benefits in addition to the calculated benefits I have provided in this testimony.

1 Q. Does this conclude your testimony?

2 A. Yes.