

Data Request 1

5 *What is the anticipated width of the new ROW to be acquired?*

Response: Fifty feet, except for the 751 foot span across the river. This span will require a 70 foot wide ROW.

This formal response was provided by PG&E via electronic mail on February 17, 2010.