

Southern California Edison
WODUP A.13-10-020

DATA REQUEST SET A.13-10-020 WODUP ED-SCE-01

To: ENERGY DIVISION
Prepared by: Scott Lacy, P.E.
Title: Project Engineer
Dated: 02/21/2014

Question PD-05 b:

Project Description

- PD-5 b** In SCE's preliminary design mapbook, it appears that an additional 220 kV double circuit structure (EC-SB 0) is added within the substation boundary.
- b. Would this structure be a LST or TSP?

Response to Question PD-05 b:

The current design anticipates that this location will require two separate single-circuit TSPs.