

Southern California Edison
Presidential Substation Project A.08-12-023

DATA REQUEST SET Presidential ED-03 (Part 1)

To: CPUC

Prepared by: Kendra Heinicke

Title: Estimator

Dated: 05/19/2009

Question 21:

Project Description

For the LWS and TSPs, what type of finish would they have? Dulled, self-weathering (i.e., turns brown over time)?

Response to Question 21:

All LWS and TSPs will have a dulled galvanized finish.