

PUBLIC UTILITIES COMMISSION

505 VAN NESS AVENUE
SAN FRANCISCO, CA 94102-3298



January 24, 2017

Jimmie Cho, Senior Vice President
Southern California Gas Company
Gas Operations and System Integrity
555 W 5th Street, GT21C3
Los Angeles CA 90013

SUBJECT: Safety and Enforcement Division Directive to SoCal Gas to Conduct Leak Survey of the Aliso Canyon Storage Facilities

The Safety and Enforcement Division (SED) of the CPUC hereby directs Southern California Gas Company (SoCal Gas) to perform the following:

1. Conduct immediate leak surveys of all underground storage facilities including wells, related compressor stations, and pipelines used for injection and withdrawal every time the storage facilities goes on withdrawal for the next 7 days. These leak surveys should be done with instruments that are appropriate for the operating conditions.
2. Conduct patrol of the withdrawal pipelines for abnormal operating conditions
3. Please provide SED your leak survey results at the end of each withdrawal period.

If you have any questions, please contact Matthewson Epuna at 213-576-4228 or Kenneth Bruno at 415-852-2936.

A handwritten signature in blue ink, appearing to read "Elizaveta Malashenko".

Elizaveta Malashenko
Director – Safety and Enforcement Division
California Public Utilities Commission