



---

**GILL RANCH STORAGE®**

---

February 5, 2016

David A. Weber  
President and CEO  
Tel: 503.220.2405  
Fax: 503.721.2490  
Toll Free: 1.866.537.9245  
E-mail: [dweber.nwngs@nwnatural.com](mailto:dweber.nwngs@nwnatural.com)

Elizaveta Malashenko  
Director, Safety and Enforcement Division  
California Public Utilities Commission  
505 Van Ness Avenue  
San Francisco, CA 94102-3298

**RE: Leak Survey Report**

Dear Ms. Malashenko:

In response to the January 26, 2016 Directive of the Safety and Enforcement Division of the California Public Utilities Commission to owners and operators of natural gas underground storage facilities, Gill Ranch Storage LLC (GRS) has completed the leak survey in accordance with the Leak Survey Plan submitted on January 27, 2016.

Leak surveys were conducted on 2/01/2016 and 2/02/2016. The following list provides details of the leaks found during the surveys, each categorized by leak grade and an estimated timeline for repair.

- **Grade 1 Gas Leaks:** Zero “hazardous leaks” found
- **Grade 2 Gas Leaks:** One leak found
  1. Wellhead 11-20-203 separator vent valve 1750
    - Scheduled to be repaired February 9, 2016
- **Grade 3 Gas Leaks:** Nine leaks found
  1. Wellhead flow control valve 7710 regulator gauge
    - to be repaired within 60 days
  2. Wellhead flow control valve 7110 regulator gauge
    - to be repaired within 60 days
  3. FV-2111 valve stem packing
    - to be repaired within 60 days

4. FV-2212 valve stem packing
  - to be repaired within 60 days
5. FV-2222 valve stem packing
  - to be repaired within 60 days
6. FV-2432 valve stem packing
  - to be repaired within 60 days
7. FV-2521 valve stem packing
  - to be repaired within 60 days
8. FV-2511 valve stem packing
  - to be repaired within 60 days
9. PR-305 door gasket
  - to be monitored and repaired on the next blowdown of unit

Please contact me if you have any questions regarding this submittal or if you require additional information.

Sincerely,



David A. Weber  
President & CEO

cc: Kenneth Bruno, CPUC (kab@cpuc.ca.gov)  
Ken Harris, DOGGR (ken.harris@conservation.ca.gov)