

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X
2	Utility Name	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes
3	PG&E	6/10/14	15.14	40.205990	-122.253300	Vegetation	Rural	< 0.25 Acres	Fire Agency	Red Bluff FD	101545144	12,000	Conductor	Overhead	Yes	6/10/14	15:14	Contact From Object	N.A.	Other	Electric Facility	Human Error	Conveyor belt contact	
4	PG&E	6/12/14	6.30	38.043750	-122.746240	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire et al	102230371	12,000	Conductor	Overhead	Yes	6/12/14	6:30	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown		
5	PG&E	6/13/14	9.19	36.933480	-121.388549	Vegetation	Rural	< 0.25 Acres	Fire Agency	Hollister FD	101703071	21,000	Conductor	Overhead	Yes	6/13/14	9:19	Contact From Object	N.A.	Vehicle	Pole	Unknown	Human Error	
6	PG&E	6/14/14	8.47	37.419050	-122.180770	Vegetation	Rural	< 3 meters	Unknown		100275552	12,000	Conductor	Overhead	Yes	6/14/14	8:47	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
7	PG&E	6/14/14	11.01	37.130915	-121.091918	Vegetation	Rural	10 - 99 Acres	Fire Agency	CAL Fire	Pole 000/013	70,000	Conductor	Overhead	Yes	6/14/14	11:01	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown		
8	PG&E	6/15/14	9.47	37.130774	-121.914100	Vegetation	Rural	< 0.25 Acres	Fire Agency	23863 Schullies Rd, Los Gatos	101500605	12,000	Conductor	Overhead	Yes	6/15/14	9:47	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
9	PG&E	6/15/14	17.28	37.970771	-121.984981	Vegetation	Urban	< 3 meters	Self Extinguished	4239 Teakwood Ct, Concord	101500605	0 - 750	Conductor	Overhead	Yes	6/15/14	17:28	Wire-Wire Contact	N.A.	N.A.	Unknown	Weather		
10	PG&E	6/15/14	20.55	39.887860	-122.197389	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	101500605	12,000	Conductor	Overhead	Yes	6/15/14	20:55	Contact From Object	N.A.	Vehicle	Pole	Unknown	Human Error	
11	PG&E	6/16/14	15.37	38.168170	-120.607460	Vegetation	Rural	< 0.25 Acres	Fire Agency		101280871	0 - 750	Conductor	Overhead	No			Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
12	PG&E	6/17/14	13.49	38.666794	-122.596397	Vegetation	Rural	< 3 meters	Fire Agency	Cal Fire	102247824	12,000	Conductor	Overhead	Yes	6/17/14	13:49	Contact From Object	N.A.	Vehicle	Pole	Unknown	Human Error	
13	PG&E	6/17/14	14.50	40.960580	-124.039590	Vegetation	Rural	< 0.25 Acres	Unknown		100979528	0 - 750	Conductor	Overhead	Yes	6/17/14	14:50	Wire-Wire Contact	N.A.	N.A.	N.A.	Unknown		
14	PG&E	6/17/14	16.47	34.686090	-120.432732	Vegetation	Rural	< 3 meters	Self Extinguished		101894765	12,000	Conductor	Overhead	Yes	6/17/14	16:47	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
15	PG&E	6/17/14	21.24	38.418040	-121.140461	Vegetation	Rural	10 - 99 Acres	Unknown		101894765	115,000	Conductor	Overhead	Yes	6/17/14	21:24	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
16	PG&E	6/18/14	10.01	37.801098	-121.202156	Vegetation	Urban	.26 - 9.99 Acres	Fire Agency	Manteca FD	102085311	17,000	Conductor	Overhead	Yes	6/18/14	10:01	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
17	PG&E	6/18/14	18.29	37.317590	-120.504950	Vegetation	Urban	< 0.25 Acres	Fire Agency	Cal Fire	101162090	0 - 750	Capacitor Bank	Overhead	No			Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown		
18	PG&E	6/19/14	16.32	37.939000	-121.219500	Vegetation	Urban	< 25 Acres	Unknown		102133758	12,000	Conductor	Overhead	No			Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	service conductor	
19	PG&E	6/19/14	18.54	38.780190	-121.500724	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency		101297449	12,000	Conductor	Overhead	Yes	6/19/14	18:54	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
20	PG&E	6/20/14	9.47	34.865090	-120.320672	Vegetation	Rural	< 0.25 Acres	Unknown		101862409	12,000	Conductor	Overhead	Yes	6/20/14	9:47	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
21	PG&E	6/20/14	12.00	39.666337	-122.196881	Vegetation	Rural	< 0.25 Acres	Unknown		100422609	0 - 750	Capacitor Bank	Overhead	No			Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown		
22	PG&E	6/20/14	14.15	40.780230	-121.502870	Vegetation	Rural	< 0.25 Acres	Fire Agency		101520035	12,000	Conductor	Overhead	Yes	6/20/14	14:15	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
23	PG&E	6/21/14	6.49	38.375300	-122.549400	Vegetation	Rural	< 0.25 Acres	Fire Agency	3111 WARM SPRINGS RD, GLEN ELLEN	101629033	12,000	Conductor	Overhead	Yes	6/21/14	6:49	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
24	PG&E	6/21/14	14.36	38.364440	-122.262649	Vegetation	Rural	< 3 meters	Fire Agency	Cal Fire	102286053	12,000	Conductor	Overhead	Yes	6/21/14	14:36	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
25	PG&E	6/22/14	8.19	34.894390	-120.424459	Vegetation	Urban	< 3 meters	Unknown		101864052	12,000	Conductor	Overhead	Yes	6/22/14	8:19	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
26	PG&E	6/23/14	6.04	37.504600	-120.007420	Vegetation	Rural	< 0.25 Acres	Unknown		Pole 007/019	70,000	Conductor	Overhead	Yes	6/23/14	6:04	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
27	PG&E	6/23/14	17.45	39.064020	-121.022480	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	BET. MTR# 1007517420 & FUCO 7495	101712215	12,000	Conductor	Overhead	Yes	6/23/14	17:45	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
28	PG&E	6/24/14	7.11	38.748540	-121.657060	Vegetation	Rural	< 0.25 Acres	Fire Agency	Salinas Fire	101712215	12,000	Conductor	Overhead	Yes	6/24/14	7:11	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
29	PG&E	6/24/14	7.48	37.903700	-121.679162	Other	Urban	< 3 meters	Fire Agency	Contra Costa FD	100485898	0 - 750	Conductor	Overhead	No			Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	dumpster burned	
30	PG&E	6/24/14	14.31	39.785680	-121.906590	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire	Mtr 36P580	12,000	Conductor	Overhead	Yes	6/24/14	14:31	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
31	PG&E	6/24/14	16.56	37.974014	-121.346462	Vegetation	Urban	< 0.25 Acres	Unknown		103190493	12,000	Conductor	Overhead	Yes	6/24/14	16:56	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
32	PG&E	6/24/14	17.12	38.110973	-122.564512	Vegetation	Urban	.26 - 9.99 Acres	Fire Agency	Novato Fire Department	102223842	0 - 750	Conductor	Overhead	No			Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
33	PG&E	6/25/14	1.36	36.890850	-121.717460	Vegetation	Rural	< 0.25 Acres	Unknown		101697469	0 - 750	Conductor	Overhead	No			Contact From Object	N.A.	Balloons	Electric Facility	Human Error		
34	PG&E	6/25/14	8.51	34.883040	-120.277619	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	LD SIDE MTR 1008835806	102286053	12,000	Conductor	Overhead	Yes	6/25/14	8:51	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
35	PG&E	6/25/14	8.53	39.011010	-120.890600	Vegetation	Rural	.26 - 9.99 Acres	Unknown		Main Line N/O buck to 20340 Spring Garden # 1004520726	12,000	Conductor	Overhead	Yes	6/25/14	8:53	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused	
36	PG&E	6/25/14	21.47	37.997860	-121.769180	Vegetation	Rural	< 0.25 Acres	Unknown		100455786	21,000	Conductor	Overhead	Yes	6/25/14	21:47	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
37	PG&E	6/26/14	0.15	36.800250	-119.737790	Vegetation	Urban	< 0.25 Acres	Fire Agency	Fresno Fire Dept	100854012	12,000	Conductor	Overhead	Yes	6/26/14	0:15	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
38	PG&E	6/28/14	29.37	38.892070	-121.823000	Vegetation	Rural	< 0.25 Acres	Unknown		100483886	21,000	Conductor	Overhead	Yes	6/28/14	23:34	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
39	PG&E	6/29/14	7.59	38.779400	-121.505549	Vegetation	Rural	< 0.25 Acres	Fire Agency		101297918	0 - 750	Transformer	Overhead	Yes	6/29/14	7:59	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown		
40	PG&E	6/29/14	8.23	39.091980	-121.543070	Vegetation	Urban	< 0.25 Acres	Unknown		SB 15745 ARBOGA RD 500' S/O FURNEAUX RD 2 SP EAST	12,000	Conductor	Overhead	Yes	6/29/14	8:23	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
41	PG&E	6/29/14	19.53	38.520800	-123.060670	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	3600 E. AUTSTIN CREEK RD	12,000	Conductor	Overhead	Yes	6/29/14	19:53	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
42	PG&E	6/30/14	14.08	38.449180	-122.872770	Vegetation	Rural	< 0.25 Acres	Unknown		102022582	0 - 750	Conductor	Overhead	No			Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
43	PG&E	6/30/14	18.25	39.144927	-122.131882	Vegetation	Rural	< 0.25 Acres	Unknown		101629033	12,000	Conductor	Overhead	Yes	6/30/14	18:25	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
44	PG&E	6/30/14	20.02	36.808020	-119.910139	Vegetation	Urban	< 0.25 Acres	Unknown		100625545	12,000	Conductor	Overhead	Yes	6/30/14	20:02	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
45	PG&E	7/1/14	3.46	37.900473	-121.260258	Vegetation	Rural	< 0.25 Acres	Unknown		2 POLES EAST OF C3412	21,000	Conductor	Overhead	Yes	7/1/14	3:46	Contact From Object	N.A.	Vehicle	Pole	Human Error		
46	PG&E	7/1/14	6.43	38.006230	-122.843030	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	West Marin Fire	102258915	12,000	Conductor	Overhead	Yes	7/1/14	6:43	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
47	PG&E	7/1/14	17.45	37.426690	-119.880950	Vegetation	Rural	.26 - 9.99 Acres	Unknown		101085832	12,000	Conductor	Overhead	Yes	7/1/14	17:45	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
48	PG&E	7/1/14	14.38	38.864870	-121.702550	Vegetation	Rural	< 0.25 Acres	Fire Agency	Yolo FD	101593404	12,000	Conductor	Overhead	Yes	7/1/14	14:38	Contact From Object	N.A.	Animal	Communication Facility	Human Error		
49	PG&E	7/1/14	18.43	37.085420	-121.760738	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	6770 Croy Rd, Morgan Hill	0 - 750	Conductor	Overhead	Yes	7/1/14	18:43	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
50	PG&E	7/2/14	13.17	38.254571	-122.050928	Vegetation	Urban	< 0.25 Acres	Fire Agency		101556512	12,000	Conductor	Overhead	Yes	7/2/14	13:17	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
51	PG&E	7/2/14	14.29	40.473660	-122.473730	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	101481261	12,000	Conductor	Overhead	Yes	7/2/14	14:29	Vandalism/Theft	N.A.	N.A.	N.A.	Human Error	Third-party caused	
52	PG&E	7/2/14	17.17	35.053351	-119.408790	Veget																		

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X			
1	Utility Name	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Column 17	Column 18	Column 19	Field Observations	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes		
119	PG&E	8/3/14	16.11	39.6443750	-121.7880330	Vegetation	Rural	< 0.25 Acres	Unknown		MTR 1007460127		12,000	Conductor	Overhead	Yes				16:11	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
120	PG&E	8/4/14	4.18	37.1062600	-121.6366690	Vegetation	Urban	< 0.25 Acres	Fire Agency	Cal Fire	100606026	Verizon	21,000	Conductor	Overhead	No					Contact From Object	N.A.	Vehicle	Communication Facility	Human Error		
121	PG&E	8/5/14	0.08	38.7804600	-121.4893690	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101297005		12,000	Conductor	Overhead	Yes				8/5/14	0:08	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
122	PG&E	8/5/14	2.57	38.5704300	-121.1022790	Vegetation	Rural	< 0.25 Acres	Unknown		7150 MEARS DR #A AUBURN		12,000	Conductor	Overhead	Yes				8/5/14	2:57	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
123	PG&E	8/5/14	12.03	39.2154990	-121.3029290	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	Str. 0101122		60,000	Conductor	Overhead	Yes				8/5/14	12:03	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
124	PG&E	8/5/14	14.50	37.9419700	-121.6319900	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	MTR 1009312709		0 - 750	Transformer	Overhead	Yes				8/5/14	14:50	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
125	PG&E	8/5/14	16.13	37.5634100	-119.9395000	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	MTR 1006385335		0 - 750	Conductor	Overhead	No						Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
126	PG&E	8/5/14	17.12	36.9187600	-119.6766700	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	100725159		0 - 750	Conductor	Overhead	No						Unknown	N.A.	N.A.	N.A.	Unknown	
127	PG&E	8/5/14	21.41	38.0031100	-122.3270500	Vegetation	Urban	< 0.25 Acres	Fire Agency	Contra Costa FD	101426924		0 - 750	Conductor	Overhead	No						Unknown	N.A.	N.A.	N.A.	Unknown	
128	PG&E	8/8/14	18.17	40.0011200	-122.2260790	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	101530848		12,000	Conductor	Overhead	Yes				8/8/14	18:17	Contact From Object	N.A.	Vehicle	Pole	Human Error	
129	PG&E	8/9/14	2.53	38.3011000	-122.8963300	Vegetation	Rural	< 0.25 Acres	Unknown		2 SPANS SOURCE SIDE OF 30501 SHORLINE HWY. FALLON		12,000	Conductor	Overhead	Yes				8/9/14	2:53	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
130	PG&E	8/9/14	15.36	36.6851770	-119.0449600	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	MTR#1005057583		12,000	Conductor	Overhead	Yes				8/9/14	15:36	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
131	PG&E	8/11/14	9.23	37.9118400	-120.3488900	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	2 SPAN LOADSIDE FCO 20835		17,000	Conductor	Overhead	Yes				8/11/14	9:23	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
132	PG&E	8/11/14	14.35	39.6725230	-121.4983170	Vegetation	Rural	< 0.25 Acres	Unknown		1wr 022146		230,000	Other	Overhead	Yes				8/11/14	14:35	Contact From Object	N.A.	Other	Electric Facility	Weather	lightning strike
133	PG&E	8/12/14	8.58	36.7405700	-121.7676400	Vegetation	Rural	< 3 meters	Unknown		S/S MONT RD 4 SPANS S/O NASHUA RD, CASTROVILLE		21,000	Other	Overhead	Yes				8/12/14	8:58	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
134	PG&E	8/12/14	9.42	39.2632400	-121.4298900	Other	Rural	Structure Only	Unknown		101287419		12,000	Conductor	Overhead	Yes				8/12/14	9:42	Contact From Object	N.A.	Vehicle	Human Error		
135	PG&E	8/12/14	15.38	38.7771100	-120.2657500	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	WEST SIDE OF SW 6161		21,000	Conductor	Overhead	Yes				8/12/14	15:38	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	vehicle burned
136	PG&E	8/14/14	10.46	38.0123950	-120.5860520	Vegetation	Rural	< 3 meters	Unknown		101272971	AT&T	17,000	Conductor	Overhead	Yes				8/14/14	10:46	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
137	PG&E	8/14/14	14.57	38.5099100	-122.8371300	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	102028597	AT&T	0 - 750	Conductor	Overhead	Yes				8/14/14	14:57	Wire-Wire Contact	N.A.	N.A.	N.A.	Unknown	
138	PG&E	8/15/14	11.01	40.5840531	-122.4446948	Vegetation	Rural	< 0.25 Acres	Fire Agency	Redding Fire Dept	101473764	AT&T	12,000	Conductor	Overhead	Yes				8/15/14	11:01	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
139	PG&E	8/16/14	7.30	39.2938500	-121.6378000	Vegetation	Rural	< 0.25 Acres	Unknown		mtr # 1007536106		12,000	Conductor	Overhead	Yes				8/16/14	7:30	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
140	PG&E	8/17/14	7.27	37.3220200	-119.6344690	Vegetation	Rural	< 0.25 Acres	Unknown		RISER 10393		12,000	Conductor	Overhead	Yes				8/17/14	7:27	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
141	PG&E	8/17/14	17.33	35.0578500	-118.9174880	Other	Rural	Structure Only	Unknown		100175838		12,000	Conductor	Overhead	Yes				8/17/14	17:33	Contact From Object	N.A.	Pole	Human Error	vehicle burned	
142	PG&E	8/19/14	3.06	37.6325800	-122.4526290	Other	Urban	Structure Only	Fire Agency	Unknown	100316145	AT&T	12,000	Conductor	Overhead	Yes				8/19/14	3:06	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	vehicle burned
143	PG&E	8/19/14	21.05	37.8150380	-120.3321820	Vegetation	Rural	< 3 meters	Unknown	Groveland Fire	23111 ELMORE RD, GROVELAND		17,000	Conductor	Overhead	Yes				8/19/14	21:05	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
144	PG&E	8/20/14	14.22	38.8305400	-121.2014190	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	100051560	AT&T	12,000	Conductor	Overhead	Yes				8/20/14	14:22	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
145	PG&E	8/20/14	16.07	40.1937990	-123.7677550	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	103316088		12,000	Conductor	Overhead	Yes				8/20/14	16:07	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
146	PG&E	8/21/14	0.00	37.3964600	-121.0715810	Vegetation	Rural	< 0.25 Acres	Unknown		Eastin Rd. south of Hwy 33, Crows Landing		12,000	Conductor	Overhead	No						Contact From Object	N.A.	Animal	Electric Facility	Unknown	
147	PG&E	8/23/14	8.36	37.9862600	-120.3918290	Vegetation	Urban	< 0.25 Acres	Fire Agency	Cal Fire	101049418	AT&T	17,000	Conductor	Overhead	No						Contact From Object	N.A.	Animal	Electric Facility	Unknown	
148	PG&E	8/24/14	11.08	37.9417917	-121.3182650	Vegetation	Urban	< 0.25 Acres	Fire Agency	Stockton FD	102109203	AT&T	12,000	Conductor	Overhead	Yes				8/24/14	11:08	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
149	PG&E	8/27/14	6.51	38.3603100	-122.0177800	Vegetation	Urban	< 0.25 Acres	Unknown		foothill w/o auburn, Vacaville		12,000	Conductor	Overhead	Yes				8/27/14	6:51	Contact From Object	N.A.	Vehicle	Pole	Human Error	
150	PG&E	8/27/14	15.19	38.5929500	-122.9183300	Vegetation	Rural	< 0.25 Acres	Unknown		3103 MILL CREEK RD		12,000	Conductor	Overhead	Yes				8/27/14	15:19	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
151	PG&E	8/28/14	0.00	40.3886240	-122.4068490	Vegetation	Rural	< 3 meters	Unknown		Gas Point Rd and Happy Valley Rd, Cottonwood	AT&T	0 - 750	Conductor	Overhead	No						Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
152	PG&E	8/28/14	13.51	36.207363	-119.8573300	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	Pole 003/003		70,000	Conductor	Overhead	Yes				8/28/14	13:51	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
153	PG&E	8/29/14	19.21	37.7871300	-120.7639490	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	1 SF NEP 6567		17,000	Conductor	Overhead	Yes				8/29/14	19:21	Contact From Object	N.A.	Vehicle	Pole	Human Error	
154	PG&E	8/30/14	14.22	38.8305400	-121.2014190	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	100349953	AT&T	0 - 750	Conductor	Overhead	Yes						Contact From Object	N.A.	N.A.	Unknown		
155	PG&E	8/30/14	15.40	37.8381467	-121.3334150	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	102052361		12,000	Fuse	Overhead	Yes				8/30/14	15:40	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
156	PG&E	8/30/14	18.34	37.3551100	-121.7978700	Vegetation	Rural	< 3 meters	Unknown		100575446	AT&T	0 - 750	Conductor	Overhead	No						Wire-Wire Contact	N.A.	N.A.	N.A.	Unknown	
157	PG&E	8/31/14	2.12	38.4193700	-122.9496400	Vegetation	Rural	< 0.25 Acres	Unknown		2520 StepsRd, Sebastopol		12,000	Conductor	Overhead	Yes				8/31/14	2:12	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
158	PG&E	9/1/14	15.58	37.0599600	-122.1662900	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	At FUCO 2541		12,000	Conductor	Overhead	Yes				9/1/14	15:58	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
159	PG&E	9/2/14	3.49	37.4946250	-122.1424080	Vegetation	Urban	< 0.25 Acres	Self Extinguished		Pole 000/003		115,000	Other	Overhead	Yes				9/2/14	3:49	Contamination	N.A.	N.A.	N.A.	Weather	
160	PG&E	9/3/14	7.05	38.3022350	-120.9474300	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	Fuse 8885		12,000	Transformer	Overhead	Yes				9/3/14	7:05	Unknown	N.A.	N.A.	N.A.	Unknown	
161	PG&E	9/3/14	13.21	37.9040960	-122.2296550	Vegetation	Rural	< 0.25 Acres	Fire Agency	Orinda FD	10N/OF Sw 8455, EAST OF WILDCAT CANYON		12,000	Conductor	Overhead	Yes				9/3/14	13:21	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
162	PG&E	9/4/14	0.34	39.1451000	-122.5817700	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	5 POLES E/O MTR 1007307850		12,000	Conductor	Overhead	Yes				9/4/14	0:34	Contact From Object	N.A.	Vehicle	Pole	Human Error	
163	PG&E	9/6/14	16.42	37.8708200	-121.3803367	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	102064435		0 - 750	Conductor	Overhead	No						Contact From Object	N.A.	N.A.	N.A.	Unknown	
164	PG&E	9/7/14	8.33	36.5907400	-119.5211590	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown																	

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X	
1	Utility Name	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	Field Observations	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes	
235	PG&E	11/8/14	15:02	38.1820870	-122.6692940	Vegetation	Rural	< 3 meters	Customer		5450 RED HILL RD		0 - 750	Conductor	Overhead	No			Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
236	PG&E	11/9/14	6:34	37.9419180	-122.3755040	Vegetation	Rural	< 3 meters	Fire Agency	RICHMOND PD	101443361		12,000	Conductor	Overhead	Yes	11/9/14	6:34	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
237	PG&E	11/14/14	12:37	37.6510500	-122.4540800	Vegetation	Urban	< 3 meters	Fire Agency	PACIFICA FD	ON #4 LINE SIDE OF 11949 & 6053	AT&T	12,000	Conductor	Overhead	Yes	11/14/14	12:37	Contact From Object	N.A.	N.A.	Electric Facility	Human Error		
238	PG&E	11/16/14	5:29	37.5305067	-122.5165317	Vegetation	Rural	< 3 meters	Fire Agency	Cal Fire	2186 Vallemar Moss beach		12,000	Conductor	Overhead	Yes	11/16/14	5:29	Contact From Object	N.A.	N.A.	Vegetation	Unknown		
239	PG&E	11/16/14	17:55	37.5118320	-121.9718010	Vegetation	Urban	< 0.25 Acres	Fire Agency	FREMONT FIRE DEPT	IREO #2979 EVERGLADES PARK DR		0 - 750	Conductor	Overhead	No			Contact From Object	N.A.	N.A.	Other	Unknown	Soccer ball?	
240	PG&E	11/17/14	17:15	38.0444400	-122.8605500	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	marin county fire	1 SPAN LN SIDE OF FUCO 6803		12,000	Conductor	Overhead	Yes	11/17/14	17:15	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown		
241	PG&E	11/18/14	14:16	37.0353400	-122.0865650	Vegetation	Rural	< 0.25 Acres	Fire Agency	Felton Fire Dept	101798988		21,000	Conductor	Overhead	Yes	11/18/14	14:16	Contact From Object	N.A.	N.A.	Electric Facility	Unknown		
242	PG&E	11/22/14	6:29	36.7472340	-119.7859090	Vegetation	Urban	< 3 meters	Fire Agency	FRESNO CITY FIRE	MTR #1008712302		12,000	Conductor	Overhead	Yes	11/22/14	6:29	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
243	PG&E	11/23/14	5:45	40.1627590	-122.2381560	Vegetation	Urban	< 3 meters	Self Extinguished		MTR #1008299414		12,000	Conductor	Overhead	Yes	11/23/14	5:45	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
244	PG&E	11/24/14	15:29	37.4401800	-121.9187970	Vegetation	Urban	< 0.25 Acres	Fire Agency	Milpitas Fire Department	back yard of 599 Redwood ave		0 - 750	Unknown	Overhead	No			Unknown	N.A.	N.A.	Unknown			
245	PG&E	11/28/14	1:17	37.9892410	-122.3146080	Vegetation	Urban	< 0.25 Acres	Fire Agency		101425748	AT&T	0 - 750	Conductor	Overhead	No			Unknown	N.A.	N.A.	Unknown			
246	PG&E	11/29/14	14:21	36.7278300	-119.7012190	Other	Urban	Structure Only	Fire Agency		100814277	AT&T	0 - 750	Conductor	Overhead	No			Unknown	N.A.	N.A.	Unknown	roof burned		
247	PG&E	12/8/14	9:51	36.8374800	-119.7899800	Vegetation	Urban	< 3 meters	Self Extinguished		101780312		21,000	Conductor	Overhead	Yes	12/8/14	9:51	Contact From Object	N.A.	N.A.	Animal	Electric Facility	Unknown	
248	PG&E	12/8/14	18:33	37.4630670	-122.2600940	Vegetation	Urban	< 0.25 Acres	Fire Agency		REDWOOD CITY FD		12,000	Conductor	Overhead	Yes	12/8/14	18:33	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
249	PG&E	12/12/14	4:07	36.6379500	-121.8124600	Vegetation	Rural	< 3 meters	Utility: PG&E		101762582	AT&T	12,000	Conductor	Overhead	Yes	12/12/14	4:07	Contact From Object	N.A.	N.A.	Vegetation	Electric Facility	Unknown	
250	PG&E	12/12/14	22:15	36.7278300	-122.2670467	Vegetation	Rural	< 3 meters	Unknown		IFO 75 RANCH RD WOODSIDE		12,000	Conductor	Overhead	Yes	12/12/14	22:15	Contact From Object	N.A.	N.A.	Vegetation	Electric Facility	Unknown	
251	PG&E	12/14/14	4:52	38.4200500	-120.8236890	Other	Rural	Structure Only	Fire Agency	Sutter creek fire		AT&T	12,000	Conductor	Overhead	Yes	12/14/14	4:52	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	vehicle burned	
252	PG&E	12/19/14	13:50	37.4609790	-122.1786810	Vegetation	Urban	< 3 meters	Fire Agency	MENLO PARK	100298576	AT&T	12,000	Conductor	Overhead	Yes	12/19/14	13:50	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
253	PG&E	12/25/14	10:50	36.3837160	-121.8663000	Vegetation	Rural	< 3 meters	Fire Agency	Mid Valley FD ?	101669474	AT&T	12,000	Conductor	Overhead	Yes	12/25/14	10:50	Contact From Object	N.A.	N.A.	Vegetation	Electric Facility	Unknown	
254	PG&E	12/29/14	11:58	38.1661300	-122.2536090	Other	Urban	Structure Only	Fire Agency	VALLEJO FD	1740 BROADWAY		12,000	Conductor	Overhead	Yes	12/29/14	11:58	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	mobile home burned	
255	PG&E	12/30/14	9:00	38.4058600	-120.5153240	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	674 SMITTY LN		12,000	Conductor	Overhead	Yes	12/30/14	9:00	Contact From Object	N.A.	N.A.	Vegetation	Unknown		
256	PG&E	12/30/14	15:53	38.0165160	-122.1366200	Other	Urban	Structure Only	Fire Agency	MARTINEZ FIRE	100444078		21,000	Conductor	Overhead	Yes	12/30/14	15:53	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	vehicle burned	
257	PG&E	01/08/15	15:18	37.36631	-121.88317	Other	Rural	< 0.25 Acres	Fire Agency	SJFD	100566657	None	12,000	Conductor	Subsurface	Yes	1/8/15	15:18	Contact From Object	N.A.	N.A.	Vehicle	Electric Facility	Human Error	
258	PG&E	01/10/15	13:07	38.08903	-122.20669	Vegetation	Urban	< 0.25 Acres	Utility: PG&E		102217759		12,000	Conductor	Overhead	Yes	1/10/15	13:07	Contact From Object	N.A.	N.A.	Animal	Electric Facility	Unknown	
259	PG&E	01/16/15	7:07	38.77533	-122.70044	Vegetation	Rural	< 3 meters	Fire Agency		102167494	Pacific Bell	0 - 750	Conductor	Overhead	No			Unknown	N.A.	N.A.	Unknown			
260	PG&E	01/28/15	3:51	37.05594	-122.15967	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE			12,000	Conductor	Overhead	Yes	1/28/15	3:51	Contact From Object	N.A.	N.A.	Vegetation	Electric Facility	Unknown	
261	PG&E	02/06/15	6:01	38.60589	-121.02213	Vegetation	Rural	< 3 meters	Fire Agency		6661 Ryan Ranch Road, El Dorado Hills		21,000	Conductor	Overhead	Yes	2/6/15	6:01	Contact From Object	N.A.	N.A.	Vegetation	Electric Facility	Unknown	
262	PG&E	02/06/15	14:08	36.40321	-121.91088	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	loadsides of 40283		12,000	Conductor	Overhead	Yes	2/6/15	14:08	Contact From Object	N.A.	N.A.	Vegetation	Electric Facility	Unknown	
263	PG&E	02/07/15	15:13	38.08712	-122.54963	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	NOVATO FIRE DEPARTMENT	103598139		12,000	Conductor	Overhead	Yes	2/7/15	15:13	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown		
264	PG&E	02/07/15	18:38	40.46741	-123.65446	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	mile marker 36.61, hwy 36, bridgeville		12,000	Conductor	Overhead	Yes	2/7/15	18:38	Contact From Object	N.A.	N.A.	Vegetation	Electric Facility	Unknown	
265	PG&E	02/13/15	16:01	35.36284	-118.96615	Vegetation	Urban	< 0.25 Acres	Fire Agency	Bakersfield FD	512 Wilma Street, Bakersfield		0 - 750	Conductor	Overhead	Yes	2/13/15	16:01	Contact From Object	N.A.	N.A.	Vegetation	Electric Facility	Unknown	
266	PG&E	02/16/15	11:08	37.35996	-120.85233	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	101206051		12,000	Conductor	Overhead	Yes	2/16/15	11:08	Contact From Object	N.A.	N.A.	Vehicle	Electric Facility	Human Error	Third-party caused
267	PG&E	02/17/15	16:46	39.76284	-121.58268	Vegetation	Urban	< 3 meters	Fire Agency	butte county	100324934	Pacific Bell	12,000	Conductor	Overhead	Yes	2/17/15	16:46	Contact From Object	N.A.	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused
268	PG&E	02/22/15	14:20	38.81600	-122.18318	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Capay	101592201		21,000	Conductor	Overhead	Yes	2/22/15	14:20	Contact From Object	N.A.	N.A.	Vehicle	Pole	Unknown	
269	PG&E	02/23/15	2:05	39.30273	-121.01749	Vegetation	Rural	< 3 meters	Fire Agency	NEVADA CITY FIRE	100096316		12,000	Conductor	Overhead	Yes	2/23/15	2:05	Contact From Object	N.A.	N.A.	Vegetation	Electric Facility	Unknown	
270	PG&E	02/23/15	13:25	38.50455	-122.30455	Vegetation	Rural	< 0.25 Acres	Fire Agency	RINCON VALLEY	BEHIND 4870 CARRIAGE LN SANTA ROSA		12,000	Conductor	Overhead	Yes	2/23/15	13:25	Contact From Object	N.A.	N.A.	Vegetation	Electric Facility	Unknown	
271	PG&E	02/25/15	2:34	36.75618	-119.78001	Vegetation	Urban	< 3 meters	Fire Agency	CITY OF FRESNO	100869017	Pacific Bell	12,000	Fuse	Overhead	Yes	2/25/15	2:34	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown		
272	PG&E	02/25/15	16:42	34.89210	-120.50397	Vegetation	Rural	< 3 meters	Customer				0 - 750	Conductor	Overhead	Yes	2/25/15	16:42	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
273	PG&E	03/04/15	18:44	38.99945	-122.75451	Vegetation	Rural	< 0.25 Acres	Fire Agency	Kelseyville FD	102156367	Pacific Bell	12,000	Conductor	Overhead	Yes	3/4/15	18:44	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
274	PG&E	03/07/15	13:35	38.79099	-122.64837	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	14417 western mine rd, Middletown		12,000	Conductor	Overhead	Yes	3/7/15	13:35	Contact From Object	N.A.	N.A.	Vegetation	Electric Facility	Unknown	
275	PG&E	03/09/15	9:36	38.73283	-120.75239	Building	Urban	Structure Only	Unknown		101399208	Pacific Bell	12,000	Conductor	Overhead	Yes	3/9/15	9:36	Contact From Object	N.A.	N.A.	Animal	Electric Facility	Unknown	
276	PG&E	03/14/15	2:30	38.90381	-122.75790	Vegetation	Rural	< 0.25 Acres	Unknown		9210 Wildcat Road, Kelseyville		12,000	Conductor	Overhead	Yes	3/14/15	2:30	Contact From Object	N.A.	N.A.	Vegetation	Electric Facility	Unknown	
277	PG&E	03/14/15	14:17	38.82525	-121.13632	Vegetation	Rural	< 3 meters	Fire Agency	LOOMIS FIRE	100051369	Pacific Bell	0 - 750	Conductor	Overhead	No			Contact From Object	N.A.	N.A.	Balloons	Electric Facility	Human Error	
278	PG&E	03/14/15	22:09	36.89154	-121.71191	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	103525395		21,000	Conductor	Overhead	Yes	3/14/15	22:09	Contact From Object	N.A.	N.A.	Vegetation	Electric Facility	Unknown	
279	PG&E	03/15/15	3:26	35.36933	-118.92044	Vegetation	Urban	< 0.25 Acres	Fire Agency	KERN COUNTY FIRE DEPT	100216241	Pacific Bell	0 - 750	Unknown	Overhead	No			Unknown	N.A.	N.A.	Unknown			
280	PG&E	03/15/15	3:38	36.93396	-119.78022	Vegetation	Rural	< 3 meters	Unknown		101121519	None	21,000	Conductor	Overhead	Yes	3/15/15	3:38	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown		
281	PG&E	03/15/15	22:47	38.33457	-120.53253	Vegetation	Rural	< 3 meters	Fire Agency	CAL FIRE	103106530		12,000	Conductor	Overhead	Yes	3/15/15	22:47	Contact From Object	N.A.	N.A.	Vehicle	Pole	Human Error	
282	PG&E	03/19/15	20:11	37.84163	-122.12176	Vegetation	Urban	< 3 meters	Fire Agency	moraga fire	100498544	Pacific Bell	12,000	Conductor	Overhead	Yes	3/19/15	20:11	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
283																									

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X
2	Utility Name	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes
351	PG&E	06/05/15	9:58	40.10703	-123.71422	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CAL FIRE	100986799		12,000	Conductor	Overhead	Yes	6/5/15	9:58	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	tie wire
352	PG&E	06/05/15	14:40	37.95777	-120.45191	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	101012484		17,000	Conductor	Overhead	Yes	6/5/15	14:40	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
353	PG&E	06/05/15	15:15	36.77591	-119.77027	Vegetation	Urban	< 0.25 Acres	Fire Agency	CITY OF FRESNO	100857009	Pacific Bell	0 - 750	Transformer	Overhead	Yes	6/5/15	15:15	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
354	PG&E	06/05/15	22:13	38.77290	-121.46992	Vegetation	Rural	< 3 meters	Fire Agency	WATER	100064053		12,000	Capacitor Bank	Overhead	Yes	6/5/15	22:13	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
355	PG&E	06/06/15	11:24	39.80295	-121.90643	Vegetation	Rural	< 3 meters	Unknown	Unknown	100433862	Pacific Bell	12,000	Conductor	Overhead	Yes	6/6/15	11:24	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
356	PG&E	06/06/15	12:30	36.96285	-120.03394	Vegetation	Rural	< 0.25 Acres	Unknown	Unknown	101014592		12,000	Conductor	Overhead	Yes	6/6/15	12:30	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
357	PG&E	06/06/15	15:38	39.04089	-123.40189	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	11480 ANDERSON VALLEY WAY @ BRIDGE		12,000	Lightning Arrestor	Overhead	Yes	6/6/15	15:38	Contact From Object	Lightning Arrestor	N.A.	N.A.	Unknown	
358	PG&E	06/06/15	21:17	38.00575	-121.23822	Vegetation	Rural	< 0.25 Acres	Fire Agency	COUNTY FIRE	102135759	Pacific Bell	12,000	Conductor	Overhead	Yes	6/6/15	21:17	Contact From Object	N.A.	N.A.	Unknown	Electric Facility	
359	PG&E	06/07/15	5:05	36.69060	-119.74880	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	FRESNO FIRE	103339346		12,000	Conductor	Overhead	Yes	6/7/15	5:05	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
360	PG&E	06/07/15	14:53	36.32160	-121.28363	Vegetation	Rural	< 0.25 Acres	Fire Agency	monterey county	peach and thorne greenfield	Pacific Bell	12,000	Unknown	Overhead	Yes	6/7/15	14:53	Unknown	N.A.	N.A.	Unknown		
361	PG&E	06/07/15	17:48	38.21794	-121.97524	Vegetation	Rural	100 - 299 Acres	Fire Agency	Suisun fire protection district.	c/o's 278361		21,000	Conductor	Overhead	Yes	6/7/15	17:48	Vandalism/Theft	N.A.	N.A.	Unknown	gun-shot conductor	
362	PG&E	06/08/15	14:18	38.17956	-120.95899	Vegetation	Rural	10 - 99 Acres	Fire Agency	CAL FIRE	102048579	Pacific Bell	12,000	Conductor	Overhead	Yes	6/8/15	14:18	Contact From Object	N.A.	N.A.	Unknown	Human Error	
363	PG&E	06/08/15	16:12	38.11554	-122.55622	Vegetation	Rural	< 3 meters	Fire Agency	novato fire	front yard 9 equestrian ct		0 - 750	Conductor	Overhead	No			Contact From Object	N.A.	N.A.	Unknown		
364	PG&E	06/08/15	16:15	39.82356	-123.60931	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CAL FIRE	2 spans loadside 1741		12,000	Conductor	Overhead	Yes	6/8/15	16:15	Contact From Object	N.A.	N.A.	Unknown		
365	PG&E	06/08/15	17:38	37.95200	-121.94406	Vegetation	Urban	< 3 meters	Unknown	Unknown	17325		0 - 750	Conductor	Overhead	Yes	6/8/15	17:38	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
366	PG&E	06/08/15	18:32	37.94040	-121.94949	Vegetation	Urban	< 3 meters	Fire Agency	CONTRA COSTA FIRE	100449348	Pacific Bell	12,000	Conductor	Overhead	Yes	6/8/15	18:32	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
367	PG&E	06/09/15	1:19	40.54242	-122.23906	Vegetation	Rural	< 3 meters	Customer	Customer	101490096	Frontier	12,000	Transformer	Overhead	Yes	6/9/15	1:19	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
368	PG&E	06/09/15	11:51	38.48868	-119.58237	Building	Rural	Structure Only	Fire Agency	tulare county fire	4390 ave 352		12,000	Conductor	Overhead	Yes	6/9/15	11:51	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
369	PG&E	06/09/15	13:10	38.11758	-121.15094	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	WATERLOO MORADA FIRE DISTRICT	102076487		21,000	Conductor	Overhead	Yes	6/9/15	13:10	Contact From Object	N.A.	N.A.	Unknown	Human Error	
370	PG&E	06/09/15	15:24	38.36510	-122.25410	Vegetation	Rural	10 - 99 Acres	Fire Agency	CAL FIRE	load side 2987	Yes	21,000	Conductor	Overhead	Yes	6/9/15	15:24	Contact From Object	N.A.	N.A.	Unknown		
371	PG&E	06/09/15	16:20	38.38222	-122.43156	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	102269716	Pacific Bell	21,000	Unknown	Overhead	Yes	6/9/15	16:20	Unknown	N.A.	N.A.	Unknown		
372	PG&E	06/09/15	21:21	38.93940	-121.24670	Vegetation	Rural	< 3 meters	Unknown	Unknown	100035304	Pacific Bell	12,000	Conductor	Overhead	Yes	6/9/15	21:21	Contact From Object	N.A.	N.A.	Unknown		
373	PG&E	06/10/15	12:00	39.13763	-121.63145	Vegetation	Urban	< 0.25 Acres	Fire Agency	YUBA CITY	101320887		12,000	Conductor	Overhead	Yes	6/10/15	12:00	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
374	PG&E	06/10/15	17:02	36.96710	-120.03052	Vegetation	Rural	< 3 meters	Unknown	Unknown	101216691	Pacific Bell	0 - 750	Conductor	Overhead	No			Unknown	N.A.	N.A.	Unknown		
375	PG&E	06/10/15	21:43	37.63912	-121.89433	Vegetation	Urban	< 3 meters	Fire Agency	PLEASANTON FIRE DEPT	100927124		12,000	Conductor	Overhead	Yes	6/10/15	21:43	Contact From Object	N.A.	N.A.	Unknown		
376	PG&E	06/11/15	18:32	38.82212	-121.30605	Vegetation	Urban	< 0.25 Acres	Fire Agency	CITY OF ROCKLIN CAL FIRE	103661493		21,000	Switch	Overhead	Yes	6/11/15	18:32	Equipment/ Facility Failure	Switch	N.A.	N.A.	Unknown	
377	PG&E	06/12/15	9:04	39.39398	-122.22991	Vegetation	Rural	< 0.25 Acres	Fire Agency	WILLOWS FIRE DEPT.	100326792		21,000	Conductor	Overhead	Yes	6/12/15	9:04	Contact From Object	N.A.	N.A.	Unknown		
378	PG&E	06/12/15	9:24	37.07609	-120.20027	Vegetation	Rural	< 3 meters	Self Extinguished	Self Extinguished	103204949		0 - 750	Conductor	Overhead	Yes	6/12/15	9:24	Unknown	N.A.	N.A.	Unknown		
379	PG&E	06/12/15	10:48	38.42732	-122.85903	Vegetation	Rural	< 0.25 Acres	Fire Agency	GRATON FIRE DEP.	102023459	Pacific Bell	12,000	Conductor	Overhead	Yes	6/12/15	10:48	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
380	PG&E	06/12/15	13:07	40.40775	-122.41037	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CAL FIRE	ACROSS STREET FROM 4139 OLD HAPPY VALLEY RD		12,000	Lightning Arrestor	Overhead	No			Equipment/ Facility Failure	Lightning Arrestor	N.A.	N.A.	Unknown	
381	PG&E	06/12/15	16:01	37.92517	-122.07817	Vegetation	Urban	< 3 meters	Fire Agency	WALNUT CREEK FIRE	100478251	Pacific Bell	0 - 750	Transformer	Overhead	Yes	6/12/15	16:01	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
382	PG&E	06/12/15	23:32	39.23077	-121.15594	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	10903 PROSPECTOR RD ROUGH AND READY	Pacific Bell	21,000	Conductor	Overhead	Yes	6/12/15	23:32	Contact From Object	N.A.	N.A.	Unknown		
383	PG&E	06/13/15	12:50	35.27221	-118.91221	Vegetation	Rural	< 3 meters	Fire Agency	Kern Co Fire Dept	103779942		0 - 750	Conductor	Overhead	No			Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
384	PG&E	06/14/15	12:19	39.74316	-121.84249	Vegetation	Urban	< 3 meters	Fire Agency	CHICO FIRE DEPT	100426686	Pacific Bell	0 - 750	Conductor	Overhead	No			Wire-Wire Contact	N.A.	N.A.	Unknown		
385	PG&E	06/14/15	13:50	36.93633	-119.87030	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CAL FIRE	12915 mesa, madera		21,000	Conductor	Overhead	Yes	6/14/15	13:50	Contact From Object	N.A.	N.A.	Unknown	Animal	
386	PG&E	06/15/15	18:35	38.98363	-121.76189	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	San Jose city	1006718	Pacific Bell	21,000	Conductor	Overhead	Yes	6/15/15	18:35	Contact From Object	N.A.	N.A.	Unknown	Human Error	
387	PG&E	06/16/15	10:40	38.00621	-122.10918	Vegetation	Urban	.26 - 9.99 Acres	Unknown	Unknown	Twr 009/058		115,000	Conductor	Overhead	Yes	6/16/15	10:40	Contact From Object	N.A.	N.A.	Unknown	Others	
388	PG&E	06/16/15	11:27	39.03816	-122.92637	Vegetation	Rural	< 0.25 Acres	Fire Agency	LAKEPORT FIRE	102165174	Pacific Bell	0 - 750	Conductor	Overhead	Yes	6/16/15	11:27	Contact From Object	N.A.	N.A.	Unknown	bird-dropped material	
389	PG&E	06/17/15	10:32	37.76881	-120.90776	Vegetation	Rural	< 3 meters	Fire Agency	Escalon fire dept.	Escalon fire dept.		17,000	Conductor	Overhead	Yes	6/17/15	10:32	Contact From Object	N.A.	N.A.	Unknown		
390	PG&E	06/17/15	15:49	37.35161	-120.64202	Vegetation	Rural	< 3 meters	Fire Agency	CAL FIRE	8503 LONGVIEW ATWATER		0 - 750	Conductor	Overhead	No			Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
391	PG&E	06/17/15	18:35	35.33024	-119.01164	Vegetation	Urban	< 3 meters	Fire Agency	BCFD	100155778	Pacific Bell	21,000	Conductor	Overhead	Yes	6/17/15	18:35	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
392	PG&E	06/19/15	12:14	34.83564	-120.38433	Vegetation	Rural	10 - 99 Acres	Fire Agency	SANTA BARBARA COUNTY FIRE DEPT	103015189		12,000	Conductor	Overhead	Yes	6/19/15	12:14	Contact From Object	N.A.	N.A.	Unknown	Animal	
393	PG&E	06/19/15	20:09	39.15973	-121.48652	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	101308410	Pacific Bell	0 - 750	Conductor	Overhead	Yes	6/19/15	20:09	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
394	PG&E	06/20/15	1:28	36.25480	-119.64349	Vegetation	Rural	< 3 meters	Fire Agency	CAL FIRE	100021218		12,000	Conductor	Overhead	Yes	6/20/15	1:28	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
395	PG&E	06/21/15	1:32	39.00797	-121.34400	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CAL FIRE	Transmission Sw 159 on the Pease - Rio-Oso 115kv line		115,000	Transformer	Overhead	Yes	6/21/15	1:32	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	Human Error
396	PG&E	06/21/15	3:17	39.09559	-121.54211	Vegetation	Rural	10 - 99 Acres	Fire Agency	Wheatland fire dept	100021218		115,000	Transformer	Overhead	Yes	6/21/15	3:17	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	Potential transformer
397	PG&E	06/21/15	12:07	36.72248	-121.76673	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	NORTH COUNTY FIRE DEPARTMENT #1428	100021218		21,000	Conductor	Overhead	No			Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
398	PG&E	06/21/15	12:10	37.92730	-122.31824	Vegetation	Urban	< 0.25 Acres	Fire Agency	RICHMOND	KEY BLVD.		4,000	Conductor	Overhead	Yes	6/21/15	12:10	Contact From Object	N.A.	N.A.	Unknown	Balloons	
399	PG&E	06/21/15	12:31	38.83173	-121.16423	Vegetation	Rural	< 3 meters	Fire Agency	pennyn fire dept	100050933	Pacific Bell	0 - 750	Transformer										

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X
2	Utility Name	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	Field Observations	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes
467	PG&E	07/16/15	19.11	37.19894	-119.77123	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CAL FIRE	20334 ROAD 400		12,000	Conductor	Overhead	Yes	7/16/15	19.11	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
468	PG&E	07/16/15	19.27	37.76190	-120.82127	Vegetation	Urban	< 3 meters	Self Extinguished		102333491	Pacific Bell	0 - 750	Conductor	Overhead	Yes	7/16/15	19.27	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
469	PG&E	07/17/15	0.20	36.96718	-119.64365	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	100651276		0 - 750	Conductor	Overhead	Yes	7/17/15	0.20	Wire-Wire Contact	N.A.	N.A.	Unknown		
470	PG&E	07/17/15	0.53	34.86820	-120.32300	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	SANTA BARBRA COUNTY FIRE DEPT	EAST OF SISQUOC SUB		12,000	Conductor	Overhead	Yes	7/17/15	0.53	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
471	PG&E	07/17/15	17.18	38.55961	-121.64346	Vegetation	Rural	< 3 meters	Unknown		in mid span between 2 poles. @t 46735 co. rd. 32B davis off HWY 1 PA		12,000	Conductor	Overhead	Yes	7/17/15	17.18	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
472	PG&E	07/18/15	17.99	38.83826	-123.82968	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CAL FIRE			12,000	Conductor	Overhead	Yes	7/18/15	17.99	Contact From Object	N.A.	N.A.	Electric Facility	Unknown	
473	PG&E	07/18/15	18.59	39.71199	-123.82836	Vegetation	Rural	.26 - 9.99 Acres	Unknown				12,000	Conductor	Overhead	Yes	7/18/15	18.59	Contact From Object	N.A.	N.A.	Electric Facility	Unknown	
474	PG&E	07/19/15	9.44	35.21489	-120.61437	Vegetation	Rural	< 3 meters	Fire Agency	CAL FIRE	101930875		12,000	Conductor	Overhead	Yes	7/19/15	9.44	Contact From Object	N.A.	Other	Electric Facility	Weather	lightning strike
475	PG&E	07/19/15	19.36	38.65629	-121.79353	Vegetation	Urban	< 3 meters	Fire Agency	WOODLAND FIRE DEPT.	BASE OF TRANSMISSION / DISTRIBUTION POLE = 1/P/S/O FUSES # 8973		0 - 750	Conductor	Overhead	No			Contact From Object	N.A.	Animal	Electric Facility	Unknown	
476	PG&E	07/20/15	15.15	37.76203	-120.86537	Vegetation	Urban	< 0.25 Acres	Fire Agency	WOODDALE CITY FIRE			0 - 750	Conductor	Overhead	No			Unknown	N.A.	N.A.	Unknown		
477	PG&E	07/21/15	8.44	39.11813	-123.20113	Vegetation	Rural	< 0.25 Acres	Fire Agency	UKIAH FIRE	102178810	Pacific Bell	0 - 750	Unknown	Overhead	No			Unknown	N.A.	N.A.	Unknown		
478	PG&E	07/21/15	10.46	37.18055	-121.06247	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	e/o dmc s/o cotterwood		12,000	Conductor	Overhead	Yes	7/21/15	10.46	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
479	PG&E	07/22/15	11.03	38.12063	-122.24813	Vegetation	Urban	< 3 meters	Fire Agency	VALLEJO FD	102308149		0 - 750	Conductor	Overhead	No			Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
480	PG&E	07/22/15	14.21	38.79354	-120.71402	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	si 3204 stope dr		12,000	Conductor	Overhead	Yes	7/22/15	14.21	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
481	PG&E	07/23/15	13.14	36.23963	-119.77674	Vegetation	Rural	< 0.25 Acres	Fire Agency	KINGS COUNTY	103242492		12,000	Conductor	Overhead	Yes	7/23/15	13.14	Contact From Object	N.A.	Vehicle	Pole	Human Error	
482	PG&E	07/23/15	20.04	38.02048	-121.36419	Vegetation	Rural	< 0.25 Acres	Unknown		Tower 0061081		60,000	Unknown	Overhead	Yes	7/23/15	20.04	Unknown	N.A.	N.A.	Unknown		
483	PG&E	07/24/15	4.10	38.45227	-121.71819	Vegetation	Rural	< 0.25 Acres	Fire Agency	Dixon fire dept	101575623	Pacific Bell	12,000	Conductor	Overhead	Yes	7/24/15	4.10	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
484	PG&E	07/24/15	14.30	36.69127	-119.03117	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CAL FIRE	46970 DUNLAP RD		0 - 750	Transformer	Overhead	Yes	7/24/15	14.30	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
485	PG&E	07/25/15	14.52	38.92645	-121.29455	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	wise rd west of gladding lincoln		12,000	Conductor	Overhead	Yes	7/25/15	14.52	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
486	PG&E	07/25/15	19.34	39.78477	-121.86082	Vegetation	Urban	< 0.25 Acres	Fire Agency	CAL FIRE	3668 hicks lane, chico		12,000	Conductor	Overhead	Yes	7/25/15	19.34	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
487	PG&E	07/26/15	12.25	39.15861	-121.06344	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	15499 ALLISON RANCH RD		12,000	Conductor	Overhead	Yes	7/26/15	12.25	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
488	PG&E	07/27/15	9.41	37.65653	-121.75705	Vegetation	Rural	< 0.25 Acres	Fire Agency	LPFD	100926006	Pacific Bell	0 - 750	Conductor	Overhead	No			Contact From Object	N.A.	Animal	Electric Facility	Unknown	
489	PG&E	07/27/15	13.07	37.76730	-121.41998	Vegetation	Rural	< 0.25 Acres	Fire Agency	TRACY FIRE DEPT	AT C258; S/S ARBOR W/ MACARTHUR		0 - 750	Other	Overhead	No			Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
490	PG&E	07/27/15	15.33	38.41829	-122.71671	Building	Urban	.26 - 9.99 Acres	Fire Agency		2180 Corby Ave, Santa Rosa		0 - 750	Conductor	Overhead	No			Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
491	PG&E	07/27/15	15.37	39.07114	-121.47278	Vegetation	Rural	< 0.25 Acres	Fire Agency		101334044	Pacific Bell	12,000	Conductor	Overhead	Yes	7/27/15	15.37	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	Booster
492	PG&E	07/28/15	12.15	40.90851	-124.07159	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	100973761	Pacific Bell	12,000	Lightning Arrestor	Overhead	Yes	7/28/15	12.15	Equipment/ Facility Failure	Lightning Arrestor	N.A.	N.A.	Unknown	
493	PG&E	07/28/15	12.19	37.76431	-121.34425	Vegetation	Rural	< 3 meters	Fire Agency	Tracy fire dept	w berry ave on canal Blvd	Pacific Bell	12,000	Conductor	Overhead	Yes	7/28/15	12.19	Contact From Object	N.A.	Vehicle	Pole	Human Error	
494	PG&E	07/28/15	12.32	37.94288	-120.94398	Vegetation	Rural	< 3 meters	Fire Agency	CAL FIRE	Waverly Road and HWY 4, Farmington		0 - 750	Conductor	Overhead	No			Contact From Object	N.A.	Animal	Electric Facility	Unknown	
495	PG&E	07/29/15	13.30	38.55494	-122.83032	Vegetation	Urban	< 3 meters	Unknown		1031 Starr View Drive, Windsor		0 - 750	Conductor	Overhead	No			Contact From Object	N.A.	Other	Electric Facility	Human Error	hit by boom of bucket t
496	PG&E	07/29/15	23.34	37.36622	-121.84381	Vegetation	Urban	< 3 meters	Fire Agency	SJFD	IRO 751 FLEMING AVE IN FIELD NEAR DRY CREEK BED		12,000	Conductor	Overhead	Yes	7/29/15	23.34	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
497	PG&E	07/30/15	14.26	38.34592	-122.31054	Vegetation	Urban	< 0.25 Acres	Unknown		In ditch at base of pole. 12 by 60	Pacific Bell	0 - 750	Unknown	Overhead	No			Unknown	N.A.	N.A.	Unknown		
498	PG&E	07/30/15	14.55	38.44481	-121.82892	Building	Urban	Structure Only	Fire Agency	dixon fire dept	103309947		12,000	Transformer	Overhead	Yes	7/30/15	14.55	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
499	PG&E	07/30/15	15.19	39.23214	-121.05674	Vegetation	Urban	.26 - 9.99 Acres	Fire Agency	GRASS VALLEY FIRE DEPT	BEHIND 272 HUGHES RD, GRASS VALLEY		12,000	Conductor	Overhead	Yes	7/30/15	15.19	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
500	PG&E	07/30/15	17.38	40.52027	-122.23259	Vegetation	Rural	< 0.25 Acres	Fire Agency		MTR 10061916		12,000	Conductor	Overhead	Yes	7/30/15	17.38	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
501	PG&E	07/30/15	17.56	37.90239	-120.41395	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CAL FIRE	101019808		17,000	Conductor	Overhead	Yes	7/30/15	17.56	Contact From Object	N.A.	Other	Electric Facility	Unknown	osprey nest
502	PG&E	07/30/15	18.11	39.20969	-120.81024	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CAL FIRE	101019808		17,000	Conductor	Overhead	Yes	7/30/15	18.11	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
503	PG&E	07/31/15	15.57	36.79744	-119.81889	Vegetation	Urban	< 3 meters	Fire Agency	fresno fire dept	100856564	Pacific Bell	0 - 750	Conductor	Overhead	No			Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
504	PG&E	07/31/15	19.36	35.39864	-118.98988	Vegetation	Urban	< 0.25 Acres	Fire Agency	CITY OF BAKERSFIELD	100184905	Pacific Bell	0 - 750	Conductor	Overhead	No			Unknown	N.A.	N.A.	Unknown		
505	PG&E	07/31/15	22.45	38.38045	-120.56283	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CAL FIRE	ACROSS FROM 1958 QUAIL LN WEST POINT		12,000	Conductor	Overhead	Yes	7/31/15	22.45	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
506	PG&E	08/01/15	7.15	36.40289	-121.90944	Vegetation	Rural	< 0.25 Acres	Fire Agency	fire com	3spans roadside of 40283		12,000	Conductor	Overhead	Yes	8/1/15	7.15	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
507	PG&E	08/01/15	14.30	34.95239	-120.29522	Vegetation	Rural	10 - 99 Acres	Unknown		10186639		12,000	Conductor	Overhead	Yes	8/1/15	14.30	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
508	PG&E	08/02/15	8.08	37.53385	-120.32769	Vegetation	Rural	< 0.25 Acres	Unknown		Pole 013002		70,000	Conductor	Overhead	Yes	8/2/15	8.08	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
509	PG&E	08/02/15	13.48	37.87996	-122.52679	Vegetation	Urban	< 0.25 Acres	Fire Agency	mill valley FD	102276049	Pacific Bell	0 - 750	Conductor	Overhead	No			Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
510	PG&E	08/02/15	16.24	37.63172	-120.15471	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	101076992		21,000	Conductor	Overhead	Yes	8/2/15	16.24	Unknown	N.A.	N.A.	Unknown		
511	PG&E	08/03/15	0.07	40.50560	-122.34702	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	COTTONWOOD FIRE DEPT	101503428	Pacific Bell	12,000	Conductor	Overhead	Yes	8/3/15	0.07	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
512	PG&E	08/03/15	17.53	39.38610	-121.18939	Vegetation	Rural	10 - 99 Acres	Fire Agency	CAL FIRE	Pole 0001008		80,000	Conductor	Overhead	Yes	8/3/15	17.53	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
513	PG&E	08/04/15	16.05	40.08216	-121.15383	Vegetation	Rural	< 0.25 Acres	Fire Agency	USFS	100441220		0 - 750	Fuse	Overhead	Yes	8/4/15	16.05	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
514	PG&E	08/04/15	17.57	37.58791	-120.22898	Vegetation	Rural	< 0.25 Acres	Unknown		Str. 007/019		70,000	Conductor	Overhead	Yes	8/4/15	17.57	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
515	PG&E	08/05/15	15.13	37.31997	-120.50507	Vegetation	Urban	< 0.25 Acres	Fire Agency	CAL FIRE	101162540		0 - 750	Capacitor Bank	Overhead	No			Equipment/ Facility Failure	Capacitor Bank	N.A.			

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X
2	Utility Name	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	Field Observations	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes
583	PG&E	09/06/15	13:37	40.16925	-122.25692	Vegetation	Urban	< 3 meters	Fire Agency	Red Bluff fire dept	at switch 3571		0 - 750	Conductor	Overhead	Yes	9/6/15	13:37	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
584	PG&E	09/06/15	19:27	34.61954	-120.25339	Vegetation	Rural	< 0.25 Acres	Fire Agency	Santa Barbara County Fire	meter# 1008400678	Verizon	12,000	Conductor	Overhead	Yes	9/6/15	19:27	Equipment / Facility Failure	Conductor	N.A.	Unknown		
585	PG&E	09/06/15	19:40	37.51330	-121.94693	Vegetation	Urban	< 3 meters	Customer		100943889	Pacific Bell	0 - 750	Conductor	Overhead	No			Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
586	PG&E	09/07/15	0:05	37.69131	-122.13884	Vegetation	Urban	< 0.25 Acres	Fire Agency	SAN LEANDRO			12,000	Conductor	Overhead	Yes	9/7/15	0:05	Contact From Object	N.A.	Vehicle	Pole	Human Error	
587	PG&E	09/08/15	8:19	37.41316	-121.88199	Vegetation	Urban	< 3 meters	Fire Agency	MILPITAS FD	100561024	Pacific Bell	0 - 750	Conductor	Overhead	No			Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
588	PG&E	09/09/15	6:44	38.82895	-123.01758	Vegetation	Rural	< 3 meters	Fire Agency	COVERDALE FIRE	102039039		0 - 750	Capacitor Bank	Overhead	No			Equipment / Facility Failure	Capacitor Bank	N.A.	Unknown		
589	PG&E	09/09/15	10:47	37.10405	-121.85526	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	100520291		12,000	Conductor	Overhead	Yes	9/9/15	10:47	Equipment / Facility Failure	Splice/Clamp/Connector	N.A.	Unknown		
590	PG&E	09/10/15	5:42	37.46093	-121.84342	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	100619766	None	0 - 750	Capacitor Bank	Overhead	No			Equipment / Facility Failure	Capacitor Bank	N.A.	Unknown		
591	PG&E	09/10/15	16:24	38.50487	-122.35346	Vegetation	Rural	10 - 99 Acres	Fire Agency	CAL FIRE	103159970	Pacific Bell	21,000	Conductor	Overhead	Yes	9/10/15	16:24	Equipment / Facility Failure	Conductor	N.A.	Unknown		
592	PG&E	09/10/15	18:39	40.75692	-123.79577	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	Pole 096/004		115,000	Conductor	Overhead	Yes	9/10/15	18:39	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
593	PG&E	09/11/15	6:38	37.52319	-122.26541	Other	Urban	Structure Only	Fire Agency	sc			12,000	Conductor	Overhead	Yes	9/11/15	6:38	Equipment / Facility Failure	Splice/Clamp/Connector	N.A.	Unknown		
594	PG&E	09/11/15	8:15	38.10938	-122.86999	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	102293992	Pacific Bell	12,000	Conductor	Overhead	Yes	9/11/15	8:15	Equipment / Facility Failure	Conductor	N.A.	Unknown		
595	PG&E	09/11/15	17:28	37.79722	-121.27472	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	MANTECALATHROP FIRE DEPT	102105463	Verizon	0 - 750	Capacitor Bank	Overhead	No			Equipment / Facility Failure	Capacitor Bank	N.A.	Unknown		
596	PG&E	09/12/15	9:51	39.11644	-121.06930	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	TOP OF AVALON PLACE, GRASS VALLEY TOWER NUMBER 19/152 40689729		115,000	Conductor	Overhead	Yes	9/12/15	9:51	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
597	PG&E	09/12/15	11:09	38.60304	-120.67409	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	101394996		0 - 750	Conductor	Overhead	No			Equipment / Facility Failure	Conductor	N.A.	Unknown		
598	PG&E	09/12/15	11:36	35.35748	-119.04590	Vegetation	Urban	< 3 meters	Fire Agency	Bakersfield FD	100194468	Pacific Bell	0 - 750	Conductor	Overhead	No			Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	Third-party caused
599	PG&E	09/13/15	8:48	37.72455	-121.32594	Vegetation	Rural	< 3 meters	Fire Agency	CAL FIRE	CRNR OF KASSON AND LORENZEN		12,000	Conductor	Overhead	Yes	9/13/15	8:48	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
600	PG&E	09/13/15	18:24	39.26731	-121.88308	Vegetation	Rural	< 0.25 Acres	Customer			None	0 - 750	Conductor	Overhead	No			Equipment / Facility Failure	Splice/Clamp/Connector	N.A.	Unknown		
601	PG&E	09/15/15	22:05	36.58739	-119.56865	Vegetation	Rural	< 0.25 Acres	Fire Agency	COUNTY FIRE	100878350	Pacific Bell	0 - 750	Conductor	Overhead	Yes	9/15/15	22:05	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
602	PG&E	09/16/15	0:18	37.99140	-121.66822	Vegetation	Rural	< 3 meters	Fire Agency	EAST COUNTY FIRE	100457468		21,000	Conductor	Overhead	Yes	9/16/15	0:18	Equipment / Facility Failure	Conductor	N.A.	Unknown		
603	PG&E	09/18/15	16:23	37.86909	-121.20633	Vegetation	Rural	< 0.25 Acres	Fire Agency	FRENCH CAMP FIRE	IN CANAL AT 5027 FRENCH CAMP RD		12,000	Conductor	Overhead	Yes	9/18/15	16:23	Equipment / Facility Failure	Conductor	N.A.	Unknown		
604	PG&E	09/18/15	17:05	37.89920	-120.45508	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	101019893		17,000	Conductor	Overhead	Yes	9/18/15	17:05	Contact From Object	N.A.	Vehicle	Pole	Human Error	
605	PG&E	09/19/15	9:51	38.47550	-122.90691	Vegetation	Rural	< 0.25 Acres	Fire Agency	FORESTVILLE	103334444		12,000	Conductor	Overhead	Yes	9/19/15	9:51	Equipment / Facility Failure	Splice/Clamp/Connector	N.A.	Unknown		
606	PG&E	09/20/15	18:53	39.86379	-121.65991	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE			12,000	Conductor	Overhead	Yes	9/20/15	18:53	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
607	PG&E	09/21/15	4:06	38.85987	-121.94035	Vegetation	Urban	< 0.25 Acres	Fire Agency	CAL FIRE	101361383		21,000	Conductor	Overhead	Yes	9/21/15	4:06	Wire-Wire Contact	N.A.	Vegetation	Electric Facility	Unknown	
608	PG&E	09/21/15	14:23	40.47863	-123.77105	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	2 POLES EAST OF MTR#1009626581 mile marker 29.1, e of hairpin turn		12,000	Conductor	Overhead	Yes	9/21/15	14:23	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
609	PG&E	09/21/15	16:33	38.24517	-122.04115	Vegetation	Urban	< 0.25 Acres	Fire Agency	FAIRFIELD FIRE DEPT	REAR OF 900 TAFT		12,000	Conductor	Overhead	Yes	9/21/15	16:33	Contact From Object	N.A.	Balloons	Electric Facility	Unknown	
610	PG&E	09/22/15	0:44	39.00780	-122.89376	Vegetation	Rural	< 0.25 Acres	Fire Agency	LAKEPORT FIRE	102159765		12,000	Conductor	Overhead	Yes	9/22/15	0:44	Contact From Object	N.A.	Vehicle	Pole	Human Error	
611	PG&E	09/22/15	15:55	39.12244	-121.63922	Vegetation	Urban	< 0.25 Acres	Fire Agency	YUBA CITY	101300036	Pacific Bell	12,000	Conductor	Overhead	Yes	9/22/15	15:55	Equipment / Facility Failure	Conductor	N.A.	Unknown		
612	PG&E	09/22/15	20:07	38.47786	-121.98948	Vegetation	Rural	< 0.25 Acres	Fire Agency	WINTERS?	101577611	Pacific Bell	12,000	Conductor	Overhead	Yes	9/22/15	20:07	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
613	PG&E	09/24/15	1:40	37.99362	-122.33375	Vegetation	Urban	< 0.25 Acres	Unknown		101426065	Pacific Bell	12,000	Conductor	Overhead	Yes	9/24/15	1:40	Contact From Object	N.A.	Vehicle	Pole	Human Error	
614	PG&E	09/24/15	3:58	39.92032	-122.38591	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	103132877		0 - 750	Unknown	Overhead	No			Unknown	N.A.	N.A.	Unknown		
615	PG&E	09/24/15	4:30	38.67690	-123.31398	Vegetation	Rural	< 0.25 Acres	Unknown		Str. 041/007		60,000	Conductor	Overhead	Yes	9/24/15	4:30	Equipment / Facility Failure	Conductor	N.A.	Unknown		
616	PG&E	09/24/15	13:56	39.35078	-121.24544	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	9692 Rices-Texas Hill rd.	Pacific Bell	12,000	Conductor	Overhead	Yes	9/24/15	13:56	Contact From Object	N.A.	Vehicle	Pole	Human Error	
617	PG&E	09/25/15	13:31	37.26100	-120.73739	Vegetation	Rural	10 - 99 Acres	Fire Agency	CAL FIRE	10 POLES EAST OF MTR#1009626581		12,000	Conductor	Overhead	Yes	9/25/15	13:31	Vandalism/Theft	N.A.	Vegetation	Electric Facility	Unknown	gun-shot conductor
618	PG&E	09/25/15	17:28	38.71680	-120.78334	Vegetation	Rural	< 0.25 Acres	Fire Agency	el dorado F D	101405900	Pacific Bell	12,000	Conductor	Overhead	Yes	9/25/15	17:28	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
619	PG&E	09/26/15	14:24	37.98601	-121.23012	Vegetation	Rural	< 0.25 Acres	Fire Agency	waterloo/morada	102135315	Pacific Bell	0 - 750	Conductor	Overhead	No			Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
620	PG&E	09/28/15	4:42	38.78772	-121.20832	Vegetation	Urban	< 3 meters	Fire Agency	n/a	100058887	Pacific Bell	0 - 750	Capacitor Bank	Overhead	No			Equipment / Facility Failure	Capacitor Bank	N.A.	Unknown		
621	PG&E	09/28/15	9:42	37.96233	-122.17651	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	100458692	Pacific Bell	12,000	Conductor	Overhead	Yes	9/28/15	9:42	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
622	PG&E	09/28/15	18:10	38.13502	-122.47704	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	1 mile north of 37 on lakeville		12,000	Conductor	Overhead	Yes	9/28/15	18:10	Contact From Object	N.A.	Vehicle	Pole	Human Error	
623	PG&E	09/29/15	2:52	38.33700	-121.86009	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	VACAVILLE FD	FRY RD @ CLARK		21,000	Conductor	Overhead	Yes	9/29/15	2:52	Equipment / Facility Failure	Splice/Clamp/Connector	N.A.	Unknown		
624	PG&E	09/29/15	19:05	35.41976	-118.94989	Vegetation	Urban	< 0.25 Acres	Fire Agency	KERN COUNTY FIRE DEPARTMENT	100193545		12,000	Conductor	Overhead	Yes	9/29/15	19:05	Vandalism/Theft	N.A.	Human Error	gun-shot conductor		
625	PG&E	09/29/15	19:46	37.97786	-121.71949	Vegetation	Urban	< 0.25 Acres	Fire Agency	OAKLEY FIRE DEPARTMENT	100470700	Pacific Bell	0 - 750	Conductor	Overhead	No			Contact From Object	N.A.	Animal	Electric Facility	Unknown	
626	PG&E	09/30/15	16:41	37.35421	-122.15916	Vegetation	Rural	< 3 meters	Utility, PG&E		100520776	Pacific Bell	12,000	Conductor	Overhead	Yes	9/30/15	16:41	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused
627	PG&E	09/30/15	17:25	38.57469	-120.68203	Vegetation	Rural	< 0.25 Acres	Fire Agency	el dorado county	7901 shenandoah ln		21,000	Conductor	Overhead	Yes	9/30/15	17:25	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
628	PG&E	09/30/15	19:38	39.21883	-122.24643	Vegetation	Rural	< 0.25 Acres	Fire Agency	williams fire demp	101641855	None	12,000	Conductor	Overhead	Yes	9/30/15	19:38	Equipment / Facility Failure	Conductor	N.A.	Unknown		
629	PG&E	10/01/15	2:43	39.66557	-121.77421	Vegetation	Rural	< 3 meters	Fire Agency	NOT KNOWN-GONE ON ARRIVAL	100345398	Pacific Bell	0 - 750	Capacitor Bank	Overhead	No			Equipment / Facility Failure	Capacitor Bank	N.A.	Unknown		
630	PG&E	10/01/15	11:28	37.50880	-120.34464	Vegetation	Rural	< 0.25 Acres	Unknown		Pole 019/007		70,000	Conductor	Overhead	Yes	10/1/15	11:28	Contamination	N.A.	N.A.	Weather		
631	PG&E	10/01/15	13:13	37.62911	-122.11534	Vegetation	Rural	< 0.25 Acres	Fire Agency	HAYWARD	X ST FROM 25920 EDEN LANDING RD		0 - 750	Conductor	Overhead	No			Equipment / Facility Failure	Conductor</				

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X	
1	Utility Name	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Column 17	Column 18	Column 19	Field Observations	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes
699	PG&E	3/28/16	12:16	39.74275	-121.82024	Vegetation	URBAN	< 3 meters	Fire Agency	Chico FD	100338028	PACIFIC BELL	12,000	Conductor	Overhead	Yes	3/28/16	12:16	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
700	PG&E	4/1/16	4:25	35.01641	-118.89213	Vegetation	RURAL	< 3 meters	Fire Agency	Kern County FD	100194594	None	12,000	Other	Overhead	Yes	4/1/16	4:25	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown		
701	PG&E	4/2/16	3:48	35.37034	-118.97521	Vegetation	URBAN	< 0.25 Acres	Fire Agency	KCFD	100244829	None	0 - 750	Conductor	Overhead	No	4/1/16	4:25	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
702	PG&E	4/2/16	7:06	35.03071	-120.52785	Vegetation	RURAL	< 3 meters	Fire Agency	SAN LUIS CO FIRE	101892796	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	4/2/16	7:06	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
703	PG&E	4/3/16	6:54	40.41751	-122.21052	Other	RURAL	Structure Only	Fire Agency	COTTONWOOD FIRE DEPT	101488627	PACIFIC BELL	12,000	Conductor	Overhead	Yes	4/3/16	6:54	Contact From Object	N.A.	Vehicle	Pole	Human Error		
704	PG&E	4/3/16	12:01	38.68944	-122.12498	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	101968191	None	12,000	Conductor	Overhead	Yes	4/3/16	12:01	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
705	PG&E	4/4/16	0:06	37.75674	-121.41933	Vegetation	URBAN	< 3 meters	Fire Agency	Tracy FD	102119421	PACIFIC BELL	12,000	Conductor	Overhead	Yes	4/4/16	0:06	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
706	PG&E	4/7/16	17:07	35.34199	-119.01752	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Bakersfield FD	100245953	None	0 - 750	Conductor	Overhead	Yes	4/7/16	17:07	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
707	PG&E	4/8/16	13:14	39.04293	-121.10020	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	100086751	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	4/8/16	13:14	Contact From Object	N.A.	Vehicle	Pole	Human Error		
708	PG&E	4/13/16	19:28	40.49535	-124.12191	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	100365913	None	12,000	Conductor	Overhead	Yes	4/13/16	19:28	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
709	PG&E	4/14/16	14:16	36.15837	-119.56502	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Kings County FD	100766367	None	12,000	Other	Overhead	Yes	4/14/16	14:16	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown		
710	PG&E	4/18/16	18:14	37.79381	-120.98419	Vegetation	URBAN	< 3 meters	Fire Agency	Escalon Fire	102332958	None	0 - 750	Other	Overhead	No	4/18/16	18:14	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown		
711	PG&E	4/20/16	16:39	39.40237	-122.01414	Vegetation	RURAL	< 3 meters	Unknown	Unknown	101641171	None	12,000	Conductor	Overhead	Yes	4/20/16	16:39	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown		
712	PG&E	4/21/16	3:20	38.19073	-122.24723	Vegetation	URBAN	< 0.25 Acres	Fire Agency	American Canyon FD	102295263	PACIFIC BELL	12,000	Conductor	Overhead	Yes	4/21/16	3:20	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
713	PG&E	4/21/16	9:25	39.29298	-123.76901	Vegetation	RURAL	< 3 meters	Customer	N.A.	103312287	None	0 - 750	Other	Overhead	No	4/21/16	9:25	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown		
714	PG&E	4/22/16	17:10	37.88750	-121.69948	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Brentwood FD	100502567	None	0 - 750	Transformer	Overhead	No	4/22/16	17:10	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown		
715	PG&E	4/22/16	22:02	35.34916	-119.05375	Vegetation	URBAN	< 3 meters	Customer	N.A.	100156969	Yes	0 - 750	Conductor	Overhead	Yes	4/22/16	22:02	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
716	PG&E	4/23/16	18:32	36.49064	-119.62925	Vegetation	RURAL	< 0.25 Acres	Fire Agency	City of Selma	100818205	None	12,000	Conductor	Overhead	Yes	4/23/16	18:32	Contact From Object	N.A.	Balloons	Electric Facility	Human Error		
717	PG&E	4/24/16	11:10	34.70896	-120.46117	Vegetation	URBAN	.26 - 9.99 Acres	Fire Agency	Santa Barbara County FD	101898989	None	12,000	Conductor	Overhead	Yes	4/24/16	11:10	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
718	PG&E	4/25/16	12:34	36.47607	-119.79041	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	100875278	None	12,000	Conductor	Overhead	Yes	4/25/16	12:34	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown		
719	PG&E	4/25/16	14:50	35.54445	-119.08687	Vegetation	RURAL	.26 - 9.99 Acres	Fire Agency	Kern County FD	100207184	None	12,000	Conductor	Overhead	Yes	4/25/16	14:50	Other	N.A.	N.A.	N.A.	Human Error		
720	PG&E	4/27/16	14:02	36.56122	-119.25966	Vegetation	RURAL	< 3 meters	Unknown	Unknown	100755216	Pacific Bell	12,000	Conductor	Overhead	Yes	4/27/16	14:02	Contact From Object	N.A.	Other	Electric Facility	Unknown	bird nest	
721	PG&E	4/30/16	17:59	38.31420	-120.90148	Vegetation	RURAL	< 3 meters	Fire Agency	Kern County FD	100295263	None	12,000	Conductor	Overhead	Yes	4/30/16	17:59	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
722	PG&E	4/30/16	16:40	37.00665	-120.63785	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Merced County FD	103083239	None	12,000	Conductor	Overhead	Yes	4/30/16	16:40	Unknown	N.A.	N.A.	N.A.	Unknown		
723	PG&E	4/30/16	13:41	38.25979	-122.02549	Vegetation	URBAN	< 3 meters	Fire Agency	Fairfield FD	101580133	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	4/30/16	13:41	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
724	PG&E	5/2/16	10:05	37.91481	-120.61782	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Cal Fire	101283625	PACIFIC BELL	17,000	Conductor	Overhead	Yes	5/2/16	10:05	Contact From Object	N.A.	Other	Electric Facility	Unknown	bird dropped snake	
725	PG&E	5/9/16	17:05	35.98605	-119.42935	Vegetation	RURAL	< 3 meters	Unknown	Unknown	100683426	None	0 - 750	Other	Overhead	No	5/9/16	17:05	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown		
726	PG&E	5/11/16	12:15	37.67808	-122.47884	Vegetation	URBAN	< 3 meters	Fire Agency	DALY CITY	103565907	None	0 - 750	Conductor	Overhead	Yes	5/11/16	12:15	Contact From Object	N.A.	Balloons	Electric Facility	Human Error		
727	PG&E	5/12/16	10:47	35.30243	-120.71591	Vegetation	RURAL	< 3 meters	Self Extinguished	N.A.	101937429	None	12,000	Conductor	Overhead	Yes	5/12/16	10:47	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
728	PG&E	5/12/16	13:35	40.45382	-124.04774	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	101006413	None	12,000	Conductor	Overhead	Yes	5/12/16	13:35	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
729	PG&E	5/12/16	20:15	35.19217	-120.45631	Vegetation	RURAL	< 3 meters	Self Extinguished	N.A.	101857280	None	12,000	Conductor	Overhead	Yes	5/12/16	20:15	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
730	PG&E	5/14/16	15:06	37.96876	-121.67042	Vegetation	RURAL	< 0.25 Acres	Unknown	Unknown	100472239	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	5/14/16	15:06	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
731	PG&E	5/14/16	22:06	39.16360	-121.56126	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Marysville FD	101312800	None	12,000	Switch	Overhead	Yes	5/14/16	22:06	Equipment/ Facility Failure	Switch	N.A.	N.A.	Unknown		
732	PG&E	5/15/16	15:54	36.79479	-119.39659	Vegetation	RURAL	100 - 299 Acres	Fire Agency	Cal Fire	100729685	None	12,000	Conductor	Overhead	Yes	5/15/16	15:54	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
733	PG&E	5/16/16	8:59	37.92526	-121.21642	Vegetation	URBAN	< 3 meters	Fire Agency	Unknown	102130215	PACIFIC BELL	12,000	Conductor	Overhead	Yes	5/16/16	8:59	Contact From Object	N.A.	Vehicle	Pole	Human Error		
734	PG&E	5/16/16	11:01	38.77343	-121.48542	Vegetation	RURAL	.26 - 9.99 Acres	Fire Agency	Cal Fire	103348287	None	12,000	Conductor	Overhead	Yes	5/16/16	11:01	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error		
735	PG&E	5/17/16	10:01	35.23788	-118.96390	Vegetation	RURAL	< 3 meters	Fire Agency	KCFD	100135809	None	0 - 750	Transformer	Overhead	Yes	5/17/16	10:01	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown		
736	PG&E	5/17/16	16:03	35.38565	-119.00746	Vegetation	URBAN	< 3 meters	Fire Agency	Bakersfield FD	100246655	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	5/17/16	16:03	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
737	PG&E	5/18/16	18:24	39.73815	-123.15874	Vegetation	RURAL	< 3 meters	Fire Agency	Cal Fire	100296825	None	12,000	Conductor	Overhead	Yes	5/18/16	18:24	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
738	PG&E	5/18/16	15:45	35.55502	-120.68032	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Atascadero FD	101901773	None	21,000	Conductor	Overhead	Yes	5/18/16	15:45	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown		
739	PG&E	5/18/16	20:04	40.47788	-122.40312	Vegetation	RURAL	< 3 meters	Fire Agency	County	102307139	PACIFIC BELL	12,000	Conductor	Overhead	Yes	5/18/16	20:04	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
740	PG&E	5/19/16	1:42	34.66450	-120.39999	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Santa Barbara County FD	101916587	VERIZON CALIFO	12,000	Conductor	Overhead	Yes	5/19/16	1:42	Contact From Object	N.A.	Vehicle	Pole	Human Error		
741	PG&E	5/19/16	18:33	37.74005	-120.80338	Vegetation	RURAL	< 3 meters	Fire Agency	OAKDALE F.D.	102342932	None	17,000	Conductor	Overhead	Yes	5/19/16	18:33	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
742	PG&E	5/19/16	16:54	38.81683	-123.58429	Vegetation	RURAL	< 3 meters	Fire Agency	Gualala Firw	102183917	PACIFIC BELL	12,000	Conductor	Overhead	Yes	5/19/16	16:54	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
743	PG&E	5/20/16	15:01	39.05589	-122.45813	Vegetation	RURAL	.26 - 9.99 Acres	Fire Agency	Cal Fire	102198323	None	12,000	Conductor	Overhead	Yes	5/20/16	15:01	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
744	PG&E	5/20/16	18:54	37.30348	-121.83985	Vegetation	URBAN	.26 - 9.99 Acres	Fire Agency	San Jose FD	103457021	None	21,000	Unknown	Overhead	Yes	5/20/16	18:54	Unknown	N.A.	N.A.	Unknown			
745	PG&E	5/20/16	20:43	35.49647	-120.68064	Vegetation	URBAN	.26 - 9.99 Acres	Fire Agency	Atascadero FD	101897769	PACIFIC BELL	0 - 750	Unknown	Overhead	No	5/20/16	20:43	Unknown	N.A.	N.A.	Unknown			
746	PG&E	5/21/16	17:44	37.36898	-120.67718	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	101162897	None	12,000	Other	Overhead	No	5/21								

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X			
2	Utility Name	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Column 17	Column 18	Column 19	Field Observations	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes		
815	PG&E	6/21/16	10.09	39.02942	-121.29275	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	100024816	PACIFIC BELL	0 - 750	Conductor	Overhead	No				Contact From Object	N.A.	Balloons	Electric Facility	Human Error			
816	PG&E	6/21/16	16.53	38.42328	-122.54477	Vegetation	RURAL	< 0.25 Acres	Fire Agency	KENWOOD FIRE XST	102036904	Yes	0 - 750	Conductor	Overhead	Yes	6/21/16	16.53		Contact From Object	N.A.	Vegetation	Electric Facility	Unknown			
817	PG&E	6/21/16	18.01	39.28517	-123.20530	Vegetation	RURAL	.26 - 9.99 Acres	Fire Agency	Cal Fire/Redwood Valley FD	102176908	PACIFIC BELL	12,000	Conductor	Overhead	Yes	6/21/16	18.01		Contact From Object	N.A.	Vegetation	Electric Facility	Unknown			
818	PG&E	6/22/16	19.13	36.38751	-119.83496	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Kings County FD	100848643		0 - 750	Conductor	Overhead	Yes	6/22/16	19.13		Contact From Object	N.A.	Vegetation	Electric Facility	Unknown			
819	PG&E	6/23/16	10.10	36.72434	-120.05634	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Fresno FD	100637712		0 - 750	Conductor	Overhead	Yes	6/23/16	10.10		Contact From Object	N.A.	Vegetation	Electric Facility	Unknown			
820	PG&E	6/23/16	19.89	35.82719	-120.36166	Vegetation	RURAL	< 3 meters	Fire Agency	Cal Fire	101937184		0 - 750	Conductor	Overhead	Yes	6/23/16	19.89		Contact From Object	N.A.	Vegetation	Electric Facility	Unknown			
821	PG&E	6/23/16	21.33	38.12063	-121.95450	Vegetation	RURAL	.26 - 9.99 Acres	Fire Agency	Suisun Fire Protection District.	101559702		0 - 750	Conductor	Overhead	Yes	6/23/16	21.33		Equipment / Facility Failure	Conductor	N.A.	Animal	Electric Facility	Unknown		
822	PG&E	6/24/16	3.07	38.71917	-121.05460	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire/EDH FIRE DEPT.	101378553		21,000	Conductor	Overhead	Yes	6/24/16	3.07		Equipment / Facility Failure	Conductor	N.A.	Animal	Electric Facility	Unknown		
823	PG&E	6/24/16	14.38	40.22003	-122.28299	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	101526647	PACIFIC BELL	0 - 750	Unknown	Overhead	Yes	6/24/16	14.38		Unknown	N.A.	N.A.	Animal	Electric Facility	Unknown		
824	PG&E	6/25/16	17.07	39.76026	-121.61876	Vegetation	URBAN	< 3 meters	Fire Agency	CAL FIRE/ PARADISE	100327279		12,000	Conductor	Overhead	Yes	6/25/16	17.07		Contact From Object	N.A.	Vehicle	Pole	Human Error			
825	PG&E	6/26/16	16.38	39.50417	-121.44753	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	100375810	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	6/26/16	16.38		Wire-Wire Contact	N.A.	N.A.	Animal	Electric Facility	Unknown		
826	PG&E	6/26/16	16.50	35.67721	-120.68396	Vegetation	RURAL	.26 - 9.99 Acres	Fire Agency	County	101869974	None	0 - 750	Conductor	Overhead	No				Vandalism/Theft	N.A.	N.A.	N.A.	Animal	Electric Facility	Human Error	gunshot
827	PG&E	6/26/16	17.59	38.80870	-121.51591	Vegetation	RURAL	< 0.25 Acres	Fire Agency	PLEASANT GROVE FD - SUTTER COUNTY	101340542		12,000	Conductor	Overhead	Yes	6/26/16	17.59		Contact From Object	N.A.	Animal	Electric Facility	Unknown			
828	PG&E	6/26/16	11.06	40.48320	-122.04660	Vegetation	RURAL	.26 - 9.99 Acres	Fire Agency	Cal Fire	101483777		12,000	Conductor	Overhead	Yes	6/26/16	11.06		Contact From Object	N.A.	Vegetation	Electric Facility	Unknown			
829	PG&E	6/27/16	11.12	36.90888	-119.52242	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	100726035	None	12,000	Lightning Arrestor	Overhead	Yes	6/27/16	11.12		Equipment / Facility Failure	Lightning Arrestor	N.A.	N.A.	Animal	Electric Facility	Unknown	
830	PG&E	6/28/16	11.40	37.29778	-121.97660	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Unknown	100593923	PACIFIC BELL	12,000	Conductor	Overhead	Yes	6/28/16	11.40		Equipment / Facility Failure	Conductor	N.A.	Animal	Electric Facility	Unknown		
831	PG&E	6/28/16	13.36	38.09613	-122.23043	Building	URBAN	Structure Only	Fire Agency	Structure Only	102278744	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	6/28/16	13.36		Equipment / Facility Failure	Conductor	N.A.	N.A.	Animal	Electric Facility	Unknown	
832	PG&E	6/28/16	9.11	37.10045	-120.22491	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Chowchilla FD	103810794	None	12,000	Conductor	Overhead	Yes	6/28/16	9.11		Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	third-party caused		
833	PG&E	6/29/16	12.55	36.50044	-121.43470	Vegetation	URBAN	< 0.25 Acres	Customer	N.A.	101754504		0 - 750	Other	Overhead	No				Equipment / Facility Failure	Other	N.A.	N.A.	Animal	Electric Facility	Unknown	
834	PG&E	6/30/16	0.03	39.81570	-121.59940	Vegetation	RURAL	< 3 meters	Fire Agency	Cal Fire	101528146		12,000	Conductor	Overhead	Yes	6/30/16	0.03		Contact From Object	N.A.	Vegetation	Electric Facility	Unknown			
835	PG&E	6/30/16	17.14	40.03530	-122.56939	Vegetation	RURAL	300 - 999 Acres	Fire Agency	Cal Fire	101528146		12,000	Conductor	Overhead	Yes	6/30/16	17.14		Contact From Object	N.A.	Vegetation	Electric Facility	Unknown			
836	PG&E	6/30/16	14.20	37.99268	-120.39962	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Cal Fire	102327111	PACIFIC BELL	17,000	Conductor	Overhead	Yes	6/30/16	14.20		Contact From Object	N.A.	Vegetation	Electric Facility	Unknown			
837	PG&E	7/1/16	22.03	37.92729	-122.31814	Vegetation	URBAN	.26 - 9.99 Acres	Fire Agency	CITY OF RICHMOND	101444612	PACIFIC BELL	4,000	Conductor	Overhead	Yes	7/1/16	22.03		Contact From Object	N.A.	Balloons	Electric Facility	Human Error			
838	PG&E	7/2/16	4.05	37.78048	-121.49741	Vegetation	RURAL	< 3 meters	Utility: PG&E	N.A.	102994598		12,000	Conductor	Overhead	Yes	7/2/16	4.05		Contact From Object	N.A.	Vehicle	Pole	Human Error			
839	PG&E	7/3/16	15.00	38.03483	-120.38088	Vegetation	RURAL	< 3 meters	Fire Agency	Cal Fire	101050507		12,000	Conductor	Overhead	Yes	7/3/16	15.00		Contact From Object	N.A.	Vegetation	Electric Facility	Unknown			
840	PG&E	7/4/16	7.43	38.76231	-121.21425	Vegetation	RURAL	< 0.25 Acres	Fire Agency	South Placer FD	103810320		12,000	Conductor	Overhead	Yes	7/4/16	7.43		Contact From Object	N.A.	Vegetation	Electric Facility	Unknown			
841	PG&E	7/5/16	8.35	36.23900	-120.30154	Vegetation	RURAL	.26 - 9.99 Acres	Fire Agency	Cal Fire	100743822		12,000	Conductor	Overhead	Yes	7/5/16	8.35		Equipment / Facility Failure	Conductor	N.A.	N.A.	Animal	Electric Facility	Unknown	
842	PG&E	7/5/16	10.36	36.28269	-120.26173	Vegetation	RURAL	.26 - 9.99 Acres	Fire Agency	Fresno County FD	100747232		0 - 750	Conductor	Overhead	Yes	7/5/16	10.36		Equipment / Facility Failure	Conductor	N.A.	N.A.	Animal	Electric Facility	Unknown	
843	PG&E	7/7/16	10.56	39.29658	-121.82628	Vegetation	RURAL	< 0.25 Acres	Fire Agency	LIVE OAK	101315522		12,000	Fuse	Overhead	Yes	7/7/16	10.56		Equipment / Facility Failure	Fuse	N.A.	N.A.	Animal	Electric Facility	Unknown	
844	PG&E	7/8/16	10.49	38.33731	-122.12112	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	102291118	PACIFIC BELL	12,000	Conductor	Overhead	Yes	7/8/16	10.49		Contact From Object	N.A.	Vegetation	Electric Facility	Unknown			
845	PG&E	7/8/16	15.13	33.61428	-117.11102	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Unknown	103070565	None	0 - 750	Conductor	Overhead	No				Contact From Object	N.A.	Vegetation	Electric Facility	Unknown			
846	PG&E	7/9/16	10.05	35.13105	-120.60887	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Unknown	101924844		12,000	Conductor	Overhead	Yes	7/9/16	10.05		Contact From Object	N.A.	Animal	Electric Facility	Unknown			
847	PG&E	7/9/16	14.57	38.90533	-121.78264	Vegetation	RURAL	.26 - 9.99 Acres	Fire Agency	Dixon FD	101599862	None	0 - 750	Conductor	Overhead	No				Equipment / Facility Failure	Conductor	N.A.	N.A.	Animal	Electric Facility	Unknown	
848	PG&E	7/9/16	15.42	38.89275	-121.97476	Vegetation	RURAL	< 0.25 Acres	Fire Agency	DUGGAGAN FIRE	101602162	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	7/9/16	15.42		Equipment / Facility Failure	Conductor	N.A.	N.A.	Animal	Electric Facility	Unknown	
849	PG&E	7/9/16	19.22	37.31038	-121.83127	Vegetation	URBAN	< 3 meters	Fire Agency	San Jose FD	100592926	PACIFIC BELL	0 - 750	Unknown	Overhead	Yes	7/9/16	19.22		Unknown	N.A.	N.A.	Animal	Electric Facility	Unknown		
850	PG&E	7/12/16	7.43	38.76231	-121.21425	Vegetation	RURAL	.26 - 9.99 Acres	Fire Agency	Cal Fire	101301195		21,000	Conductor	Overhead	Yes	7/12/16	7.43		Contact From Object	N.A.	Vegetation	Electric Facility	Unknown			
851	PG&E	7/13/16	10.20	37.32768	-122.07194	Vegetation	RURAL	.26 - 9.99 Acres	Fire Agency	Cal Fire/scd	103510668		115,000	Conductor	Overhead	Yes	7/13/16	10.20		Contact From Object	N.A.	Animal	Electric Facility	Unknown			
852	PG&E	7/14/16	13.44	35.38333	-118.92324	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Kern County FD	100119861		0 - 750	Capacitor Bank	Overhead	No				Equipment / Facility Failure	Capacitor Bank	N.A.	N.A.	Animal	Electric Facility	Unknown	
853	PG&E	7/15/16	5.19	35.18390	-120.50180	Vegetation	RURAL	< 3 meters	Fire Agency	Cal Fire	101846594		12,000	Conductor	Overhead	Yes	7/15/16	5.19		Equipment / Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Animal	Electric Facility	Unknown	
854	PG&E	7/15/16	14.09	38.69651	-120.85983	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	101412774	PACIFIC BELL	12,000	Conductor	Overhead	Yes	7/15/16	14.09		Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	third-party caused		
855	PG&E	7/15/16	14.26	38.13658	-122.70919	Vegetation	RURAL	.26 - 9.99 Acres	Fire Agency	NOVATO FIRE AND OTHERS	102013570	PACIFIC BELL	12,000	Conductor	Overhead	Yes	7/15/16	14.26		Contact From Object	N.A.	Vehicle	Pole	Human Error			
856	PG&E	7/15/16	17.09	35.35853	-119.04094	Vegetation	URBAN	< 3 meters	Fire Agency	CITY	100194332	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	7/15/16	17.09		Equipment / Facility Failure	Conductor	N.A.	N.A.	Animal	Electric Facility	Unknown	
857	PG&E	7/16/16	0.58	36.43790	-121.91983	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	101669758		12,000	Other	Overhead	Yes	7/16/16	0.58		Equipment / Facility Failure	Voltage Regulator	N.A.	N.A.	Animal	Electric Facility	Unknown	
858	PG&E	7/16/16	8.19	37.48278	-119.86599	Vegetation	RURAL	.26 - 9.99 Acres	Fire Agency	Cal Fire	101079104	None	0 - 750	Conductor	Overhead	No				Contact From Object	N.A.	Vegetation	Electric Facility	Unknown			
859	PG&E	7/16/16	20.26	38.49443	-122.49443	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Cal Fire	102265740		12,000	Conductor	Overhead	Yes	7/16/16	20.26		Contact From Object	N.A.	Animal	Electric Facility	Unknown			
860	PG&E	7/18/16	7.39	36.75720	-119.78072	Vegetation	URBAN	< 3 meters	Self Extinguished	N.A.	100898068	PACIFIC BELL	0 - 750	Capacitor Bank	Overhead	Yes	7/18/16	7.39		Contact From Object	N.A.	Animal	Electric Facility	Unknown			
861	PG&E</																										

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X
Utility Name	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes	
PG&E	8/16/16	13:18	40.34169	-123.88029	Vegetation	RURAL	< 0.25 Acres	Fire Agency	miranda/fruitland vol. calfire	100990019	None	12,000	Conductor	Overhead	Yes	8/16/16	13:18	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
PG&E	8/16/16	22:17	36.78689	-119.69569	Vegetation	URBAN	< 3 meters	Fire Agency	CLOVIS FIRE DEPT	100887618		12,000	Conductor	Overhead	Yes	8/16/16	22:17	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
PG&E	8/17/16	9:41	35.37087	-118.96842	Building	URBAN	Structure Only	Fire Agency	Kern County FD	100162417		21,000	Transformer	Overhead	Yes	8/17/16	9:41	Equipment/ Facility Failure	Transformer	N.A.	Electric Facility	Unknown		
PG&E	8/17/16	12:23	41.24946	-123.76707	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	103315791		12,000	Conductor	Overhead	Yes	8/17/16	12:23	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
PG&E	8/17/16	14:02	39.63610	-121.74794	Vegetation	RURAL	< 3 meters	Customer	N.A.	100437069		60,000	Conductor	Overhead	Yes	8/17/16	14:02	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
PG&E	8/17/16	18:37	37.30779	-119.85932	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	101049362		21,000	Conductor	Overhead	Yes	8/17/16	18:37	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error		
PG&E	8/18/16	15:22	36.81874	-119.44391	Vegetation	RURAL	< 3 meters	Self Extinguished	N.A.	100826791	VERIZON CALIFO	0 - 750	Conductor	Overhead	Yes	8/18/16	15:22	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
PG&E	8/18/16	18:12	37.59560	-122.08548	Vegetation	URBAN	< 3 meters	Fire Agency	union city fd	100935109	PACIFIC BELL	0 - 750	Fuse	Overhead	No			Equipment/ Facility Failure	Fuse	N.A.	Electric Facility	Unknown		
PG&E	8/18/16	18:36	36.97014	-121.54598	Vegetation	RURAL	< 3 meters	Fire Agency	Santa Clara county fire	103553473		0 - 750	Capacitor Bank	Overhead	No			Equipment/ Facility Failure	Capacitor Bank	N.A.	Electric Facility	Unknown		
PG&E	8/19/16	16:23	39.22351	-123.75500	Vegetation	RURAL	< 3 meters	Fire Agency	Albion-Little River FD	102206661		12,000	Conductor	Overhead	Yes	8/19/16	16:23	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error		
PG&E	8/20/16	18:51	36.45801	-119.34722	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Merced County FD	100729153	PACIFIC BELL	12,000	Conductor	Overhead	Yes	8/20/16	18:51	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error		
PG&E	8/21/16	13:02	38.44445	-122.24955	Vegetation	RURAL	.26 - 9.99 Acres	Fire Agency	Cal Fire	102291451	PACIFIC BELL	12,000	Conductor	Overhead	Yes	8/21/16	13:02	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
PG&E	8/22/16	16:10	37.96656	-120.23950	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Touloume City FD	101043683		17,000	Conductor	Overhead	Yes	8/22/16	16:10	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
PG&E	8/23/16	16:03	38.87411	-119.68648	Vegetation	RURAL	< 3 meters	Customer	N.A.	100731257	None	0 - 750	Conductor	Overhead	Yes	8/23/16	16:03	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
PG&E	8/24/16	12:11	36.46335	-121.71202	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	101750810	PACIFIC BELL	12,000	Conductor	Overhead	Yes	8/24/16	12:11	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error		
PG&E	8/24/16	14:18	36.84822	-119.87926	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Fresno FD	101750810		21,000	Conductor	Overhead	Yes	8/24/16	14:19	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
PG&E	8/25/16	12:04	36.97263	-119.38162	Vegetation	RURAL	< 3 meters	Utility: PG&E	N.A.	100651318	PONDEROSA	0 - 750	Conductor	Overhead	No			Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
PG&E	8/25/16	11:31	37.37341	-122.08696	Vegetation	URBAN	< 3 meters	Self Extinguished	N.A.	100516445	PACIFIC BELL	12,000	Conductor	Overhead	Yes	8/25/16	11:31	Contact From Object	N.A.	Balloons	Electric Facility	Human Error		
PG&E	8/27/16	5:37	36.04388	-120.11166	Vegetation	RURAL	.26 - 9.99 Acres	Fire Agency	Kings County FD	103246130		70,000	Conductor	Overhead	Yes	8/27/16	5:37	Equipment/ Facility Failure	Conductor	N.A.	Electric Facility	Unknown		
PG&E	8/27/16	19:33	36.96458	-122.05289	Vegetation	URBAN	< 0.25 Acres	Fire Agency	SC FIRE DEPT & CDF	101677596	PACIFIC BELL	21,000	Conductor	Overhead	Yes	8/27/16	19:33	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	Electric Facility	Unknown		
PG&E	8/28/16	16:49	36.56186	-119.71860	Vegetation	RURAL	< 3 meters	Fire Agency	Cal Fire	100683911		12,000	Conductor	Overhead	Yes	8/28/16	16:49	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error		
PG&E	8/29/16	16:25	38.26928	-121.60294	Vegetation	RURAL	< 0.25 Acres	Fire Agency	SAC FIRE	101583637	FRONTIER	21,000	Conductor	Overhead	Yes	8/29/16	16:25	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error		
PG&E	8/30/16	16:01	36.59413	-121.92120	Vegetation	RURAL	.26 - 9.99 Acres	Fire Agency	Unknown	101734977		21,000	Conductor	Overhead	Yes	8/30/16	16:01	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
PG&E	8/30/16	16:14	38.05755	-122.16390	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Benicia FD	102284159	PACIFIC BELL	21,000	Conductor	Overhead	Yes	8/30/16	16:14	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	third-party caused	
PG&E	8/30/16	19:27	39.92880	-122.12765	Vegetation	RURAL	< 0.25 Acres	Unknown	Unknown	103185395		12,000	Conductor	Overhead	Yes	8/30/16	19:27	Equipment/ Facility Failure	Other	N.A.	Electric Facility	Unknown		
PG&E	8/31/16	11:17	37.37206	-120.45039	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Merced County FD	101147802	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	8/31/16	11:17	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
PG&E	8/31/16	14:52	35.19180	-120.46971	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	101942860		12,000	Conductor	Overhead	Yes	8/31/16	14:52	Equipment/ Facility Failure	Conductor	N.A.	Electric Facility	Unknown		
PG&E	8/31/16	19:43	38.15100	-121.68037	Vegetation	RURAL	.26 - 9.99 Acres	Fire Agency	ISLETON	101665829	FRONTIER	21,000	Conductor	Overhead	Yes	8/31/16	19:43	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
PG&E	9/1/16	9:30	37.28144	-121.86030	Vegetation	URBAN	< 3 meters	Customer	N.A.	100617565	None	21,000	Conductor	Overhead	Yes	9/1/16	9:30	Contact From Object	N.A.	Balloons	Electric Facility	Human Error		
PG&E	9/1/16	13:08	38.46327	-122.81616	Vegetation	RURAL	< 3 meters	Fire Agency	WINDSOR AND SANTA ROSA FIRE	101956270	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/1/16	13:08	Equipment/ Facility Failure	Conductor	N.A.	Electric Facility	Unknown		
PG&E	9/2/16	12:42	38.38680	-122.75553	Vegetation	RURAL	< 3 meters	Fire Agency	Santa Rosa Fire	101969369	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	9/2/16	12:42	Equipment/ Facility Failure	Conductor	N.A.	Electric Facility	Unknown		
PG&E	9/2/16	13:50	37.66811	-121.76805	Vegetation	URBAN	< 0.25 Acres	Fire Agency	LPFD	100954399		21,000	Conductor	Overhead	Yes	9/2/16	13:50	Contact From Object	N.A.	Balloons	Electric Facility	Human Error		
PG&E	9/3/16	20:12	39.32230	-121.98490	Vegetation	RURAL	< 3 meters	Unknown	Unknown	101614478		12,000	Conductor	Overhead	Yes	9/3/16	20:12	Equipment/ Facility Failure	Conductor	N.A.	Electric Facility	Unknown		
PG&E	9/3/16	20:58	38.80805	-119.62789	Vegetation	RURAL	.26 - 9.99 Acres	Fire Agency	Unknown	103269240		12,000	Conductor	Overhead	Yes	9/3/16	20:58	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error		
PG&E	9/5/16	8:26	39.52329	-122.14519	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Unknown	100430321		21,000	Conductor	Overhead	Yes	9/5/16	8:26	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	Electric Facility	Unknown		
PG&E	9/7/16	10:56	39.95624	-122.54479	Vegetation	URBAN	< 3 meters	Fire Agency	San Rafael Fire	102249994	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	9/7/16	10:56	Equipment/ Facility Failure	N.A.	Conductor	Electric Facility	Unknown		
PG&E	9/7/16	9:56	39.55281	-121.64163	Vegetation	RURAL	.26 - 9.99 Acres	Unknown	Unknown	103653028		60,000	Conductor	Overhead	Yes	9/7/16	9:56	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
PG&E	9/8/16	14:39	38.00133	-122.32902	Vegetation	URBAN	< 0.25 Acres	Fire Agency	PINOLE FIRE DEPT	101426911		12,000	Conductor	Overhead	Yes	9/8/16	14:39	Equipment/ Facility Failure	Other	N.A.	Electric Facility	Unknown		
PG&E	9/8/16	22:04	37.29175	-121.87109	Vegetation	URBAN	< 0.25 Acres	Fire Agency	San Jose Fire	100598024	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	9/8/16	22:04	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
PG&E	9/9/16	10:57	36.85174	-119.62254	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Fresno County Fire	100746408	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/9/16	10:57	Equipment/ Facility Failure	Conductor	N.A.	Electric Facility	Unknown		
PG&E	9/9/16	13:22	37.28367	-120.47405	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Cal Fire	101018780	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	9/9/16	13:22	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	Electric Facility	Unknown		
PG&E	9/9/16	15:25	38.92020	-121.08588	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Cal Fire	100036304	PACIFIC BELL	12,000	Capacitor Bank	Overhead	Yes	9/9/16	15:25	Equipment/ Facility Failure	Capacitor Bank	N.A.	Electric Facility	Unknown		
PG&E	9/10/16	2:09	37.18617	-120.67754	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Merced County FD	101072400		12,000	Conductor	Overhead	Yes	9/10/16	2:09	Equipment/ Facility Failure	Conductor	N.A.	Electric Facility	Unknown		
PG&E	9/11/16	21:24	36.95261	-119.72629	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Unknown	100652942		21,000	Unknown	Overhead	Yes	9/11/16	21:24	Unknown	N.A.	Electric Facility	Unknown			
PG&E	9/12/16	4:24	36.39990	-121.90201	Vegetation	RURAL	< 3 meters	Fire Agency	Cal Fire Hwy 1 Carmel Hill	101669814		12,000	Conductor	Overhead	Yes	9/12/16	4:24	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
PG&E	9/12/16	12:38	38.78323	-120.60090	Vegetation	RURAL	.26 - 9.99 Acres	Fire Agency	Cal Fire	101421708	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	9/12/16	12:38	Equipment/ Facility Failure	Conductor	N.A.	Electric Facility	Unknown		
PG&E	9/12/16	18:47	36.53030	-119.30560	Vegetation	RURAL	< 0.25 Acres	Fire Agency	CUTLER FIRE	100807630	None	12,000	Conductor	Overhead	Yes	9/12/16	18:47	Equipment/ Facility Failure	Conductor	N.A.	Electric Facility	Unknown		
PG&E	9/12/16	20:42	37.35500	-121.93550	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Santa Clara county fire	100608192		12,000	Conductor	Overhead	Yes	9/12/16	20:42	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	Electric Facility	Unknown		
PG&E	9/12/16	15:08	39.52556	-123.76550	Vegetation	RURAL	.26 - 9.99 Acres	Fire Agency	Cal Fire	102185070		12,000	Conductor	Overhead	Yes	9/12/16	15:08	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
PG&E	9/13/16	10:26	39.19131	-121.18186	Vegetation	RURAL	< 3 meters	Fire Agency	Cal Fire	100082849	PACIFIC BELL	2												

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X
Utility Name	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes	
1047	PG&E	10/31/16	17.04	36.66385	-119.74626	Vegetation	RURAL	.26 - 9.99 Acres	Fire Agency	Fresno County FD	100808306	12,000	Conductor	Overhead	Yes	10/31/16	17:04	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1048	PG&E	11/8/16	9.06	37.45316	-119.64132	Vegetation	RURAL	< 0.25 Acres	Fire Agency	US FOREST SERVICE	101017062	12,000	Conductor	Overhead	Yes	11/9/16	9:06	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	third-party caused	
1049	PG&E	11/14/16	3.25	35.43969	-120.89022	Vegetation	URBAN	< 3 meters	Fire Agency	Cayucos fire	101853338	0 - 750	Conductor	Overhead	Yes	11/14/16	3:25	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown		
1050	PG&E	11/14/16	13.15	35.45772	-120.46186	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	101895511	21,000	Conductor	Overhead	Yes	11/14/16	13:15	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown		
1051	PG&E	11/15/16	17.27	39.72747	-121.65571	Vegetation	RURAL	< 0.25 Acres	Fire Agency	CAL FIRE/BUTTE COUNTY FIRE DEPT.	100327525	12,000	Conductor	Overhead	Yes	11/15/16	17:27	Contact From Object	N.A.	Vehicle	Pole	Human Error		
1052	PG&E	11/20/16	11.94	39.83982	-123.78298	Vegetation	RURAL	< 3 Meters	Fire Agency	Cal Fire	102020173	12,000	Conductor	Overhead	Yes	11/20/16	11:04	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1053	PG&E	11/28/16	12.10	35.32208	-118.78900	Vegetation	RURAL	< 0.25 Acres	Utility: PG&E	N.A.	102300399	12,000	Conductor	Overhead	Yes	11/28/16	12:10	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown		
1054	PG&E	01/01/17	15.57	38.66287	-121.74803	Vegetation	Urban	< 3 Meters	Fire Agency	Woodland fire dept 530-666-8920	101589774	Unknown	0 - 750	Conductor	Overhead	Yes	1/1/17	15:57	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1055	PG&E	01/10/17	15.55	38.75380	-121.15641	Building	Urban	Structure Only	Unknown	N.A.	100050679	Unknown	12,000	Conductor	Overhead	Yes	1/10/17	15:55	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1056	PG&E	01/18/17	15.34	37.38388	-121.80884	Building	Urban	Structure Only	Unknown	N.A.	100564835	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	1/18/17	15:34	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1057	PG&E	01/29/17	09.45	38.36159	-121.95091	Building	Urban	Structure Only	Fire Agency	Unknown	8550	Unknown	12,000	Transformer	Subsurface	Yes	1/29/17	09:45	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
1058	PG&E	02/03/17	10.00	37.56153	-122.02772	Vegetation	Urban	< 3 Meters	Fire Agency	jeff	100938466	Unknown	12,000	Conductor	Overhead	Yes	2/3/17	10:00	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1059	PG&E	02/07/17	04.50	38.43314	-122.71902	Building	Urban	Structure Only	Fire Agency	Santa Rosa Fire Dept	102014637	PACIFIC BELL	12,000	Conductor	Overhead	Yes	2/7/17	04:50	Other	N.A.	N.A.	Unknown		
1060	PG&E	03/16/17	12.43	38.27175	-122.01971	Other	Urban	< 0.25 Acres	Fire Agency	Unknown	101561532	PACIFIC BELL	12,000	Conductor	Overhead	Yes	3/16/17	12:43	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1061	PG&E	03/17/17	09.37	38.11532	-121.42216	Other	Rural	Structure Only	Fire Agency	911	102444732	PACIFIC BELL	21,000	Conductor	Overhead	Yes	3/17/17	09:37	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	third-party caused
1062	PG&E	03/20/17	10.09	39.76239	-121.85247	Vegetation	Urban	< 3 Meters	Fire Agency	CHICO FIRE DEPT 911	101205903	PACIFIC BELL	0 - 750	Transformer	Subsurface	Yes	3/20/17	10:09	Equipment/ Facility Failure	N.A.	Vegetation	Electric Facility	Unknown	
1063	PG&E	03/23/17	07.04	37.36975	-121.85218	Other	Urban	< 3 Meters	Fire Agency	SJFD disp 408-277-8950 Incident # F170829041	103485262	Unknown	12,000	Transformer	Subsurface	Yes	3/23/17	07:04	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
1064	PG&E	03/28/17	12.15	34.88092	-120.41992	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	103397961	YES	12,000	Conductor	Overhead	Yes	3/28/17	12:15	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1065	PG&E	04/01/17	14.54	37.18823	-120.95764	Vegetation	Rural	< 0.25 Acres	Fire Agency	engine 74 mrced fire agency	102318665	Unknown	12,000	Conductor	Overhead	Yes	4/1/17	14:54	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1066	PG&E	04/04/17	13.29	35.68851	-120.76533	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	101945026	None	12,000	Conductor	Overhead	Yes	4/4/17	13:29	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1067	PG&E	04/04/17	14.54	37.29584	-121.93295	Vegetation	Urban	< 3 Meters	Customer	N.A.	100591136	None	12,000	Conductor	Overhead	Yes	4/4/17	14:54	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1068	PG&E	04/10/17	16.35	35.61751	-119.74296	Vegetation	Rural	< 3 Meters	Self Extinguished	N.A.	100128630	Unknown	21,000	Conductor	Overhead	No			Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1069	PG&E	04/13/17	14.21	37.99671	-121.25210	Other	Urban	Structure Only	Fire Agency	MANTECA CITY	102104500	VERIZON CALIFO	17,000	Conductor	Overhead	Yes	4/13/17	14:21	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1070	PG&E	04/16/17	15.14	35.58053	-119.14227	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103833904	Unknown	12,000	Conductor	Overhead	Yes	4/16/17	15:14	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
1071	PG&E	04/20/17	20.14	37.37407	-120.71688	Vegetation	Urban	< 3 Meters	Fire Agency	209-965-3621	101205903	Unknown	12,000	Transformer	Overhead	No			Contact From Object	N.A.	Transformer	Electric Facility	Unknown	
1072	PG&E	04/23/17	7.10	36.07345	-120.93450	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101728333	Unknown	12,000	Conductor	Overhead	Yes	4/23/17	7:10	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1073	PG&E	04/24/17	11.52	36.18990	-121.15129	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101718856	None	12,000	Conductor	Overhead	Yes	4/24/17	11:52	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	tie wire
1074	PG&E	04/25/17	12.38	38.65832	-120.97622	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	101376746	Unknown	0 - 750	Transformer	Overhead	Yes	4/25/17	12:38	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
1075	PG&E	04/25/17	18.26	36.23725	-119.78071	Other	Rural	Structure Only	Self Extinguished	N.A.	100716676	Unknown	0 - 750	Conductor	Overhead	Yes	4/25/17	18:26	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1076	PG&E	04/26/17	15.55	38.15608	-121.67886	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAPT KENNY WILLIAMS (707)374-2233	103826165	Unknown	21,000	Conductor	Overhead	Yes	4/26/17	15:55	Contact From Object	N.A.	Other	Electric Facility	Other	bird's nest
1077	PG&E	04/28/17	5.55	34.58848	-120.10568	Vegetation	Rural	< 0.25 Acres	Fire Agency	805-683-2724	101900122	Unknown	12,000	Conductor	Overhead	Yes	4/28/17	5:55	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1078	PG&E	04/28/17	14.35	37.12469	-121.62488	Vegetation	Urban	< 0.25 Acres	Fire Agency	Cal Fire	103098414	Unknown	0 - 750	Conductor	Overhead	Yes	4/28/17	14:35	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
1079	PG&E	04/28/17	15.49	38.76786	-120.96253	Vegetation	Rural	< 0.25 Acres	Fire Agency	chris paper fire investigator, 530/677-1868. Incident #caeeu011821	101409833	PACIFIC BELL	21,000	Conductor	Overhead	Yes	4/28/17	15:49	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1080	PG&E	04/29/17	15.07	37.03488	-119.52423	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	101878861	Unknown	12,000	Conductor	Overhead	Yes	4/29/17	15:07	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1081	PG&E	04/30/17	37.06	37.63491	-118.95628	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100161301	Unknown	21,000	Transformer	Overhead	No			Contact From Object	N.A.	Other	N.A.	Unknown	
1082	PG&E	05/01/17	14.20	36.02269	-119.95837	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CORCORAN STATION 559-992-2156	100760105	Unknown	70,000	Conductor	Overhead	Yes	5/1/17	14:20	Contact From Object	N.A.	Other	Electric Facility	Other	bird's nest
1083	PG&E	05/03/17	10.04	36.81613	-119.63202	Vegetation	Rural	< 0.25 Acres	Fire Agency	eng 44 Eric connors 559-324-2294	100770906	PACIFIC BELL	12,000	Conductor	Overhead	Yes	5/3/17	10:04	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1084	PG&E	05/03/17	12.51	38.19080	-121.66150	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103834798	None	21,000	Conductor	Overhead	Yes	5/3/17	12:51	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1085	PG&E	05/04/17	16.19	35.55728	-120.75348	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101934476	Unknown	21,000	Conductor	Overhead	Yes	5/4/17	16:19	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1086	PG&E	05/05/17	15.52	40.37758	-123.00187	Vegetation	Rural	< 3 Meters	Self Extinguished	N.A.	101501566	None	12,000	Conductor	Overhead	Yes	5/5/17	15:52	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1087	PG&E	05/06/17	1.56	37.32997	-120.83297	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103834182	Unknown	12,000	Conductor	Overhead	Yes	5/6/17	1:56	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1088	PG&E	05/06/17	11.18	40.79512	-124.02902	Vegetation	Rural	< 3 Meters	Fire Agency	chief rick harden 7074423352	103661154	Unknown	12,000	Conductor	Overhead	Yes	5/6/17	11:18	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1089	PG&E	05/06/17	12.43	40.76227	-124.16195	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	100959152	Unknown	12,000	Conductor	Overhead	Yes	5/6/17	12:43	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1090	PG&E	05/06/17	15.00	39.24580	-120.77854	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	102185559	PACIFIC BELL	12,000	Conductor	Overhead	Yes	5/6/17	15:00	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1091	PG&E	05/06/17	23.46	36.16537	-120.37372	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire	100741510	PACIFIC BELL	12,000	Conductor	Overhead	Yes	5/6/17	23:46	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1092	PG&E	05/09/17	11.15	40.05970	-122.18895	Vegetation	Rural	< 3 Meters	Self Extinguished	N.A.	101531151	PACIFIC BELL	12,000	Conductor	Overhead	Yes	5/9/17	11:15	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1093	PG&E	05/09/17	15.57	39.54650	-121.85667	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100404826	Unknown	12,000	Conductor	Overhead	No			Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
1094	PG&E	05/09/17	18.26	40.86892	-123.5																			

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X	
Utility Name	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes		
1160	PG&E	06/17/17	15.49	36.93896	-119.68463	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	103406061	Unknown	21,000	Conductor	Overhead	Yes	6/17/17	15:49	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
1161	PG&E	06/18/17	23.49	39.19494	-122.96321	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	102160857	Unknown	12,000	Conductor	Overhead	Yes	6/18/17	23:49	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1162	PG&E	06/18/17	12.22	36.72578	-119.79068	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	100894729	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	6/18/17	12:22	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1163	PG&E	06/18/17	13.10	38.23703	-122.67015	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	102007208	PACIFIC BELL	12,000	Conductor	Overhead	Yes	6/18/17	13:10	Equipment/ Facility Failure	Insulator	N.A.	Vegetation	Electric Facility	Unknown	
1164	PG&E	06/18/17	18.09	37.55165	-122.29253	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	100309893	Unknown	21,000	Conductor	Overhead	Yes	6/18/17	18:09	Equipment/ Facility Failure	Guy/Span Wire	N.A.	Vegetation	Electric Facility	Unknown	
1165	PG&E	06/18/17	20.16	38.88844	-122.02044	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	101650987	Unknown	12,000	Conductor	Overhead	Yes	6/18/17	20:16	Equipment/ Facility Failure	Insulator	N.A.	Vegetation	Electric Facility	Unknown	
1166	PG&E	06/18/17	21.07	37.83974	-121.28643	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	102058809	Unknown	12,000	Lightning Arrestor	Overhead	Yes	6/18/17	21:07	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused	
1167	PG&E	06/18/17	22.12	38.53900	-122.79203	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	102029435	Unknown	12,000	Other	Overhead	Yes	6/18/17	22:12	Equipment/ Facility Failure	Voltage Regulator	N.A.	Vegetation	Electric Facility	Unknown	
1168	PG&E	06/18/17	23.12	36.75747	-119.66456	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	100780126	PACIFIC BELL	12,000	Conductor	Overhead	No		Equipment/ Facility Failure	Conductor	N.A.	Vegetation	Electric Facility	Unknown		
1169	PG&E	06/18/17	23.31	38.89731	-121.29467	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	103782395	Unknown	12,000	Conductor	Overhead	Yes	6/18/17	23:31	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused	
1170	PG&E	06/19/17	01.23	35.36762	-118.95621	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	100252360	PACIFIC BELL	21,000	Conductor	Overhead	Yes	6/19/17	01:23	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	Vegetation	Electric Facility	Unknown	
1171	PG&E	06/19/17	13.51	39.90633	-122.17660	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	103841797	YES	12,000	Conductor	Overhead	Yes	6/19/17	13:51	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused	
1172	PG&E	06/19/17	16.18	37.92722	-121.23058	Other	Urban	Structure Only	Utility, PG&E	N.A.	103582825	Unknown	17,000	Transformer	Subsurface	Yes	6/19/17	16:18	Equipment/ Facility Failure	Transformer	N.A.	Vegetation	Electric Facility	Unknown	
1173	PG&E	06/19/17	16.26	37.93783	-120.60897	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101282825	Unknown	17,000	Other	Overhead	No		Equipment/ Facility Failure	Recloser	N.A.	Vegetation	Electric Facility	Unknown		
1174	PG&E	06/19/17	17.31	36.76268	-120.37580	Vegetation	Rural	< 3 Meters	Unknown	N.A.	101094343	Unknown	12,000	Transformer	Overhead	Yes	6/19/17	17:31	Equipment/ Facility Failure	Transformer	N.A.	Vegetation	Electric Facility	Unknown	
1175	PG&E	06/19/17	18.30	38.45498	-121.82116	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	10085621	PACIFIC BELL	12,000	Conductor	Overhead	Yes	6/19/17	18:30	Equipment/ Facility Failure	Lightning Arrestor	N.A.	Vegetation	Electric Facility	Unknown	
1176	PG&E	06/19/17	20.22	38.10123	-120.86989	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101233468	Unknown	12,000	Transformer	Overhead	Yes	6/19/17	20:22	Equipment/ Facility Failure	Transformer	N.A.	Vegetation	Electric Facility	Unknown	
1177	PG&E	06/20/17	00.49	39.74900	-121.89975	Vegetation	Rural	< 3 Meters	Fire Agency	Cal Fire	100437523	PACIFIC BELL	12,000	Conductor	Overhead	Yes	6/20/17	00:49	Equipment/ Facility Failure	Conductor	N.A.	Vegetation	Electric Facility	Unknown	
1178	PG&E	06/20/17	09.12	39.19754	-121.49499	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101306700	Unknown	12,000	Conductor	Overhead	Yes	6/20/17	09:12	Equipment/ Facility Failure	Conductor	N.A.	Vegetation	Electric Facility	Unknown	
1179	PG&E	06/20/17	10.08	39.03668	-121.07630	Vegetation	Urban	< 3 Meters	Fire Agency	JERRY GOOD 530 268-0844	100023174	None	12,000	Conductor	Overhead	Yes	6/20/17	10:08	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1180	PG&E	06/20/17	13.37	37.92473	-122.08954	Vegetation	Urban	< 3 Meters	Fire Agency	contra costa fire	100478159	PACIFIC BELL	12,000	Capacitor Bank	Overhead	Yes	6/20/17	13:37	Equipment/ Facility Failure	Capacitor Bank	N.A.	Vegetation	Electric Facility	Unknown	
1181	PG&E	06/20/17	15.17	40.11262	-123.76774	Vegetation	Rural	< 3 Meters	Fire Agency	Cal Fire	100987107	Unknown	12,000	Conductor	Overhead	Yes	6/20/17	15:17	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1182	PG&E	06/20/17	11.51	40.31566	-124.06111	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	101006039	Unknown	12,000	Conductor	Overhead	Yes	6/20/17	11:51	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1183	PG&E	06/20/17	18.32	37.92910	-121.23323	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	102132644	Unknown	12,000	Conductor	Overhead	Yes	6/20/17	18:32	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	Vegetation	Electric Facility	Unknown	
1184	PG&E	06/20/17	20.46	38.90764	-121.26030	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	10085621	PACIFIC BELL	12,000	Conductor	Overhead	Yes	6/20/17	20:46	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1185	PG&E	06/20/17	23.16	35.63750	-120.85660	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101873622	Unknown	12,000	Conductor	Overhead	Yes	6/20/17	23:16	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	Vegetation	Electric Facility	Unknown	
1186	PG&E	06/21/17	08.41	39.16997	-122.15731	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101637081	Unknown	12,000	Conductor	Overhead	Yes	6/21/17	08:41	Contact From Object	N.A.	Other	Electric Facility	Human Error	helicopter	
1187	PG&E	06/21/17	14.23	38.99208	-121.35362	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	100027499	PACIFIC BELL	12,000	Transformer	Overhead	Yes	6/21/17	14:23	Equipment/ Facility Failure	Transformer	N.A.	Vegetation	Electric Facility	Unknown	
1188	PG&E	06/22/17	9.36	38.39647	-120.47274	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	101251777	Unknown	12,000	Conductor	Overhead	Yes	6/22/17	9:36	Equipment/ Facility Failure	Crossarm	N.A.	Vegetation	Electric Facility	Unknown	
1189	PG&E	06/22/17	16.30	39.61307	-121.68724	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire	100347529	None	12,000	Conductor	Overhead	Yes	6/22/17	16:30	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
1190	PG&E	06/22/17	18.07	38.75831	-120.71764	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	101401088	Unknown	12,000	Conductor	Overhead	Yes	6/22/17	18:07	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused	
1191	PG&E	06/22/17	19.29	35.58886	-120.66910	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101912249	Unknown	21,000	Conductor	Overhead	Yes	6/22/17	19:29	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused	
1192	PG&E	06/23/17	13.00	39.30510	-122.48618	Vegetation	Rural	10 - 99 Acres	Fire Agency	Unknown	100329817	Unknown	0 - 750	Conductor	Overhead	Yes	6/23/17	13:00	Vandalism/Theft	N.A.	N.A.	N.A.	Human Error	power theft	
1193	PG&E	06/23/17	20.09	40.38565	-122.28408	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	101505644	Unknown	12,000	Conductor	Overhead	Yes	6/23/17	20:09	Equipment/ Facility Failure	Other	N.A.	Vegetation	Electric Facility	Unknown	
1194	PG&E	06/23/17	18.23	39.78294	-121.86790	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100397376	None	12,000	Conductor	Overhead	Yes	6/23/17	18:23	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
1195	PG&E	06/24/17	12.33	38.93736	-121.04466	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100301311	PACIFIC BELL	12,000	Transformer	Overhead	Yes	6/24/17	12:33	Equipment/ Facility Failure	Transformer	N.A.	Vegetation	Electric Facility	Unknown	
1196	PG&E	06/24/17	14.51	38.36218	-120.76381	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	101255656	Unknown	12,000	Fuse	Overhead	Yes	6/24/17	14:51	Equipment/ Facility Failure	Fuse	N.A.	Vegetation	Electric Facility	Unknown	
1197	PG&E	06/24/17	22.27	38.29083	-120.84900	Vegetation	Rural	10 - 99 Acres	Fire Agency	CONTACT BOBBY BOWMAN	101238865	None	12,000	Conductor	Overhead	Yes	6/24/17	22:27	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
1198	PG&E	06/25/17	18.18	37.32357	-120.55914	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101159230	Unknown	12,000	Conductor	Overhead	Yes	6/25/17	0.7625	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1199	PG&E	06/25/17	0.23	39.40434	-123.36867	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	102193088	PACIFIC BELL	12,000	Conductor	Overhead	Yes	6/25/17	0.23	Equipment/ Facility Failure	Crossarm	N.A.	Vegetation	Electric Facility	Unknown	
1200	PG&E	06/25/17	6.02	39.07743	-121.52937	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101314125	Unknown	12,000	Conductor	Overhead	Yes	6/25/17	6:02	Equipment/ Facility Failure	Pole	N.A.	Vegetation	Electric Facility	Unknown	
1201	PG&E	06/25/17	15.37	34.93950	-119.69246	Vegetation	Rural	100 - 299 Acres	Fire Agency	805-686-5074	100191652	None	12,000	Conductor	Overhead	Yes	6/25/17	15:37	Equipment/ Facility Failure	Pole	N.A.	Vegetation	Electric Facility	Unknown	
1202	PG&E	06/25/17	22.14	39.02503	-121.57873	Vegetation	Rural	< 3 Meters	Fire Agency	Oliverhurst FD	101314072	Unknown	21,000	Conductor	Overhead	Yes	6/25/17	22:14	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1203	PG&E	06/26/17	8.18	37.27331	-120.52573	Vegetation	Rural	< 0.25 Acres	Self Extinguished	N.A.	103218794	Unknown	12,000	Conductor	Overhead	Yes	6/26/17	8:18	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused	
1204	PG&E	06/26/17	14.29	36.97187	-120.11694	Vegetation	Urban	.26 - 9.99 Acres	Fire Agency	HENNAGIN 569 386 555	100243976	Unknown	21,000	Conductor	Overhead	Yes	6/26/17	14:29	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
1205	PG&E	06/27/17	9.23	37.95588	-122.61762	Vegetation	Rural	10 - 99 Acres	Fire Agency	UNFILED	102260068	UNFILED	12,000	Conductor	Overhead	Yes	6/27/17	9:23	Other	N.A.	Vegetation	Electric Facility	Unknown		
1206	PG&E	06/27/17	17.47	39.51264	-122.203																				

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X	
2	Utility Name	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes	
1273	PG&E	07/19/17	17:19	39.41242	-123.81234	Vegetation	Rural	< 0.25 Acres	Fire Agency	DRUE RHOADS 707 964 5673	102201550	YES	12,000	Conductor	Overhead	Yes	7/19/17	17:19	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1274	PG&E	07/20/17	20:57	37.73609	-122.49208	Building	Urban	Structure Only	Unknown	N.A.	101813719	Unknown	0 - 750	Conductor	Overhead	Yes	7/20/17	20:57	Wire-Wire Contact	N.A.	N.A.	N.A.	Unknown		
1275	PG&E	07/20/17	01:46	36.52545	-119.68200	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	100830639	Unknown	0 - 750	Lightning Arrestor	Overhead	Yes	7/20/17	01:46	Equipment/ Facility Failure	Lightning Arrestor	N.A.	N.A.	Unknown		
1276	PG&E	07/20/17	04:27	38.06420	-120.87106	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	chris costales 209 754 2735	102142834	Unknown	12,000	Conductor	Overhead	Yes	7/20/17	04:27	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
1277	PG&E	07/20/17	13:45	35.08036	-120.55583	Vegetation	Rural	10 - 99 Acres	Fire Agency	PAUL LEE 805 903-3416 INC # 8291	101941116	Unknown	12,000	Conductor	Overhead	Yes	7/20/17	13:45	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown		
1278	PG&E	07/20/17	13:20	37.82984	-121.29303	Vegetation	Urban	< 3 Meters	Customer	N.A.	103943880	PACIFIC BELL	12,000	Capacitor Bank	Overhead	Yes	7/20/17	13:20	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown		
1279	PG&E	07/21/17	13:27	36.26954	-120.93718	Vegetation	Rural	.26 - 9.99 Acres	Unknown	N.A.	101245524	Unknown	12,000	Conductor	Overhead	Yes	7/21/17	13:27	Contact From Object	N.A.	Vehicle	Human Error	Third-party caused		
1280	PG&E	07/21/17	20:26	41.06550	-121.39320	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	101549629	Unknown	12,000	Conductor	Overhead	Yes	7/21/17	20:26	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
1281	PG&E	07/22/17	12:25	40.87950	-123.76380	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Josh ,comander chief of forest service.	100980577	Unknown	12,000	Conductor	Overhead	Yes	7/22/17	12:25	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused	
1282	PG&E	07/22/17	14:38	37.29945	-122.16306	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	100265488	Unknown	12,000	Conductor	Overhead	Yes	7/22/17	14:38	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1283	PG&E	07/22/17	16:01	40.83143	-124.05389	Vegetation	Rural	< 0.25 Acres	Fire Agency	BATTALION CHIEF CURT WATKINS, 707-825-2000	100983827	PACIFIC BELL	12,000	Conductor	Overhead	Yes	7/22/17	16:01	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused	
1284	PG&E	07/23/17	09:22	40.64201	-122.23025	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAPT?7	101459708	FRONTIER COMM	12,000	Conductor	Overhead	Yes	7/23/17	09:22	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
1285	PG&E	07/23/17	16:32	36.24055	-119.81283	Vegetation	Rural	< 0.25 Acres	Fire Agency	Brandon Jones (559) 852-2884	100783832	Unknown	12,000	Conductor	Overhead	Yes	7/23/17	16:32	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
1286	PG&E	07/23/17	16:25	39.67233	-123.53360	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	103823226	Unknown	12,000	Conductor	Overhead	Yes	7/23/17	16:25	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1287	PG&E	07/23/17	19:41	36.21544	-119.90973	Vegetation	Rural	< 0.25 Acres	Fire Agency	Brandon Jones (559) 852-2884	101946905	Unknown	12,000	Conductor	Overhead	Yes	7/23/17	19:41	Contact From Object	N.A.	Vehicle	Human Error	Third-party caused		
1288	PG&E	07/24/17	14:01	37.26349	-122.33643	Vegetation	Rural	< 0.25 Acres	Fire Agency	mike klinck 650-879-0121	100322130	Unknown	0 - 750	Conductor	Overhead	Yes	7/24/17	14:01	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
1289	PG&E	07/24/17	16:07	37.25369	-121.96760	Vegetation	Urban	< 0.25 Acres	Fire Agency	C1702050039	103447162	Unknown	0 - 750	Conductor	Overhead	Yes	7/24/17	16:07	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1290	PG&E	07/24/17	19:31	38.35192	-120.71029	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	101263632	Unknown	12,000	Conductor	Overhead	Yes	7/24/17	19:31	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1291	PG&E	07/24/17	21:45	35.60243	-120.92107	Vegetation	Rural	10 - 99 Acres	Fire Agency	Unknown	101860186	Unknown	12,000	Conductor	Overhead	Yes	7/24/17	21:45	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1292	PG&E	07/25/17	15:51	38.37795	-122.53878	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	102031447	Unknown	12,000	Conductor	Overhead	Yes	7/25/17	15:51	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1293	PG&E	07/25/17	19:12	39.59970	-121.44490	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100403612	Unknown	12,000	Conductor	Overhead	Yes	7/25/17	19:12	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
1294	PG&E	07/26/17	06:55	36.78124	-119.75525	Vegetation	Urban	< 3 Meters	Fire Agency	FRESNO FIRE, BATALION 1, FULMER 559 993 2661	100866522	PACIFIC BELL	12,000	Conductor	Overhead	Yes	7/26/17	06:55	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused	
1295	PG&E	07/26/17	14:02	40.99973	-121.95793	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	101512624	Unknown	12,000	Conductor	Overhead	Yes	7/26/17	14:02	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
1296	PG&E	07/28/17	16:57	35.47270	-120.99800	Vegetation	Rural	10 - 99 Acres	Fire Agency	TOM MCEWEEN 805-903-3409	101933868	Unknown	12,000	Conductor	Overhead	Yes	7/28/17	16:57	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
1297	PG&E	07/28/17	19:20	35.72756	-120.99030	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	San Luis Obispo CDF	101945496	None	21,000	Conductor	Overhead	Yes	7/28/17	19:20	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1298	PG&E	07/29/17	13:18	39.46313	-121.45951	Vegetation	Rural	< 0.25 Acres	Fire Agency	nuss fowler 530 521 8056	103846783	Unknown	12,000	Conductor	Overhead	Yes	7/29/17	13:18	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused	
1299	PG&E	07/29/17	13:28	35.45229	-120.38344	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101889516	Unknown	0 - 750	Conductor	Overhead	Yes	7/29/17	13:28	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
1300	PG&E	07/29/17	14:52	37.05999	-122.00113	Vegetation	Urban	< 0.25 Acres	Fire Agency	Scotts Valley Fire Dept.	101679068	PACIFIC BELL	21,000	Conductor	Overhead	Yes	7/29/17	14:52	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
1301	PG&E	07/29/17	17:56	37.02507	-121.53583	Vegetation	Rural	< 3 Meters	Fire Agency	GEORGE MARSHALL	100610842	Unknown	21,000	Conductor	Overhead	Yes	7/29/17	17:56	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
1302	PG&E	07/29/17	18:08	37.94875	-121.34571	Vegetation	Rural	< 0.25 Acres	Fire Agency	911	102126507	Unknown	12,000	Conductor	Overhead	Yes	7/29/17	18:08	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused	
1303	PG&E	07/29/17	20:45	35.45171	-120.61711	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	101941008	Unknown	0 - 750	Conductor	Overhead	Yes	7/29/17	20:45	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	Third-party caused	
1304	PG&E	07/30/17	09:46	38.91318	-122.61788	Vegetation	Rural	< 0.25 Acres	Fire Agency	mike wink	102151066	None	0 - 750	Conductor	Overhead	Yes	7/30/17	09:46	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1305	PG&E	07/31/17	12:58	37.09707	-122.27965	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	101679025	Unknown	0 - 750	Conductor	Overhead	No	7/31/17	12:58	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
1306	PG&E	07/31/17	13:26	35.97865	-120.11139	Vegetation	Urban	< 0.25 Acres	Customer	N.A.	100681314	Unknown	21,000	Conductor	Overhead	No	7/31/17	14:10	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
1307	PG&E	07/31/17	14:41	38.79675	-121.13288	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	100782414	Unknown	12,000	Conductor	Overhead	Yes	7/31/17	14:41	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1308	PG&E	08/01/17	12:23	36.04123	-119.50529	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	100661556	Unknown	0 - 750	Other	Overhead	Yes	8/1/17	12:23	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown		
1309	PG&E	08/02/17	9:42	39.22744	-123.10811	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	100974913	None	60,000	Conductor	Pole 5/0	Overhead	Yes	8/2/17	9:42	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1310	PG&E	08/02/17	5:54	40.79856	-123.39614	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire	100974913	Unknown	12,000	Conductor	Overhead	Yes	8/2/17	5:54	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1311	PG&E	08/02/17	8:58	37.56179	-121.94860	Vegetation	Rural	< 0.25 Acres	Fire Agency	FREMONT FIRE DEPT. 911	100940374	PACIFIC BELL	12,000	Other	Overhead	Yes	8/2/17	8:58	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown		
1312	PG&E	08/02/17	17:04	37.31632	-122.07225	Vegetation	Urban	< 0.25 Acres	Fire Agency	TONY RAINIERI 408-378-4010	100534186	Unknown	12,000	Conductor	Overhead	No	8/2/17	17:04	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
1313	PG&E	08/02/17	18:16	37.39296	-120.62127	Vegetation	Urban	< 3 Meters	Fire Agency	2099663621	101190510	PACIFIC BELL	12,000	Transformer	Overhead	Yes	8/2/17	18:16	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown		
1314	PG&E	08/03/17	10:53	39.07320	-121.08679	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	100727242	PACIFIC BELL	12,000	Conductor	Overhead	Yes	8/3/17	10:53	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused	
1315	PG&E	08/03/17	11:16	38.11924	-122.50154	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	SSR172150008	102227219	Unknown	12,000	Conductor	Overhead	Yes	8/3/17	11:16	Contact From Object	N.A.	Pole	Human Error	Third-party caused		
1316	PG&E	08/03/17	22:44	39.07110	-121.48700	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	ART PAQUETTE 530-633-0861	101335644	PACIFIC BELL	12,000	Unknown	Overhead	No	N/A	Unknown	N.A.	N.A.	Unknown	N.A.	Unknown		
1317	PG&E	08/04/17	09:54	38.60394	-121.05918	Vegetation	Rural	< 3 Meters	Fire Agency	D. Franks 530-622-3858, Incident #022602	101411052	PACIFIC BELL	21,000	Capacitor Bank	Overhead	Yes	8/4/17	09:54	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown		
1318	PG&E	08/04/17	18:14	35.61928	-120.65890	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101912293	PACIFIC BELL	12,000	Fuse	Overhead	Yes	8/4/17	18:14	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown		
1319	PG&E																								

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X	
2	Utility Name	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Column 17	Column 18	Column 19	Field Observations	Equipment / Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes
1386	PG&E	09/02/17	12:01	37.66445	-121.92227	Vegetation	Rural	< 3 Meters	Customer	N.A.	100956020	PACIFIC BELL	21,000	Conductor	Overhead	Yes	9/2/17	12:01	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1387	PG&E	09/02/17	16:18	37.26897	-121.80564	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	100584311	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	9/2/17	16:18	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
1388	PG&E	09/02/17	18:00	37.93380	-122.40690	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	102347407	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/2/17	18:00	Contact From Object	N.A.	Vehicle	N.A.	Human Error	Third-party caused	
1389	PG&E	09/03/17	7:12	37.37432	-122.21838	Vegetation	Rural	< 0.25 Acres	Fire Agency	Local	100270106	Unknown	12,000	Conductor	Overhead	Yes	9/3/17	7:12	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1390	PG&E	09/03/17	12:52	37.21616	-119.48067	Vegetation	Rural	1000 - 4999 Acres	Fire Agency	Cal Fire	103345573	Unknown	0 - 750	Conductor	Overhead	Yes	9/3/17	12:52	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1391	PG&E	09/03/17	17:52	37.49595	-119.83967	Vegetation	Rural	26 - 99 Acres	Fire Agency	209-986-3621	101086221	Unknown	21,000	Transformer	Overhead	Yes	9/3/17	17:52	Contact From Object	N.A.	Other	Electric Facility	Unknown	lightning strike	
1392	PG&E	09/03/17	22:57	36.09533	-120.51699	Vegetation	Rural	100 - 299 Acres	Fire Agency	CHRIS CHRISTOPHERSON 559-281-4320	100739435	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/3/17	22:57	Contact Between Third Party Facility	N.A.	N.A.	Electric Facility	Unknown		
1393	PG&E	09/04/17	0:57	36.80240	-119.82540	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	100856132	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	9/4/17	0:57	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1394	PG&E	09/04/17	3:29	39.83171	-121.84441	Vegetation	Rural	26 - 99 Acres	Fire Agency	Cal Fire	102300100	PACIFIC BELL	12,000	Conductor	Overhead	No			Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
1395	PG&E	09/04/17	6:43	37.45463	-121.93311	Other	Rural	Structure Only	Customer	N.A.	100557780	PACIFIC BELL	21,000	Conductor	Overhead	Yes	09/04/17	6:43	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
1396	PG&E	09/05/17	1:24	39.43168	-121.55285	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100420238	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/5/17	1:24	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1397	PG&E	09/05/17	6:58	39.67273	-123.51279	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	102194697	VERIZON CALIFOR	12,000	Conductor	Overhead	Yes	9/5/17	6:58	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1398	PG&E	09/05/17	7:20	39.71095	-121.79724	Vegetation	Rural	< 3 Meters	Fire Agency	(530) 538-6841	100355255	Unknown	12,000	Conductor	Overhead	Yes	9/5/17	7:20	Wire-Wire Contact	N.A.	N.A.	N.A.	Unknown		
1399	PG&E	09/05/17	13:51	38.18972	-121.31746	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103218208	Unknown	12,000	Conductor	Overhead	Yes	9/5/17	13:51	Contact From Object	N.A.	Vehicle	N.A.	Human Error	Third-party caused	
1400	PG&E	09/05/17	17:51	38.34067	-122.25777	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	102294869	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/5/17	17:51	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
1401	PG&E	09/11/17	9:50	36.95146	-121.84204	Vegetation	Rural	< 3 Meters	Self Extinguished	N.A.	101793954	PACIFIC BELL	21,000	Fuse	Overhead	Yes	9/11/17	8:50	Contact From Object	N.A.	Other	Electric Facility	Unknown		
1402	PG&E	09/06/17	20:08	37.29255	-122.29403	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	100256917	Unknown	12,000	Conductor	Overhead	Yes	9/6/17	20:08	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1403	PG&E	09/08/17	4:47	38.74778	-120.85905	Vegetation	Rural	26 - 99 Acres	Fire Agency	Cal Fire	101391575	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/8/17	4:47	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1404	PG&E	09/08/17	17:21	38.60388	-120.92748	Vegetation	Rural	26 - 99 Acres	Fire Agency	Cal Fire	101379094	PACIFIC BELL	21,000	Conductor	Overhead	Yes	9/8/17	17:21	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1405	PG&E	09/08/17	21:14	37.96038	-120.37636	Vegetation	Rural	26 - 99 Acres	Fire Agency	John Lite 209-984-5623	101042521	Unknown	17,000	Conductor	Overhead	Yes	9/8/17	21:14	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1406	PG&E	09/09/17	18:36	36.66181	-121.54766	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101769870	Unknown	12,000	Conductor	Overhead	Yes	9/9/17	18:36	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
1407	PG&E	09/10/17	1:22	39.25988	-121.49023	Vegetation	Rural	26 - 99 Acres	Fire Agency	TYLER LOPEZ	101289867	None	12,000	Conductor	Overhead	Yes	9/10/17	1:22	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
1408	PG&E	09/10/17	16:30	37.30393	-120.52747	Vegetation	Rural	10 - 99 Acres	Fire Agency	Merced County FD	101161316	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	9/10/17	16:30	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
1409	PG&E	09/11/17	7:18	37.00083	-121.66574	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	100621936	VERIZON CALIFOR	0 - 750	Conductor	Overhead	No			Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1410	PG&E	09/11/17	8:50	36.95146	-121.84204	Vegetation	Rural	< 3 Meters	Self Extinguished	N.A.	101793954	PACIFIC BELL	21,000	Fuse	Overhead	Yes	9/11/17	8:50	Contact From Object	N.A.	Other	Electric Facility	Unknown	lightning strike	
1411	PG&E	09/11/17	23:50	40.8724	-124.08827	Vegetation	Urban	< 3 Meters	Fire Agency	BOB	100984579	Unknown	12,000	Conductor	Overhead	Yes	9/11/17	23:50	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
1412	PG&E	09/12/17	9:24	39.74095	-121.80787	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100330302	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/12/17	9:24	Contact From Object	N.A.	Vehicle	N.A.	Human Error	Third-party caused	
1413	PG&E	09/12/17	17:18	38.45106	-121.60519	Vegetation	Rural	26 - 99 Acres	Fire Agency	tom klage 530 538-7888	100419482	Unknown	12,000	Conductor	Overhead	Yes	9/12/17	17:18	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1414	PG&E	09/14/17	11:02	39.11112	-121.55647	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	101320308	None	12,000	Switch	Overhead	Yes	9/14/17	11:02	Equipment/ Facility Failure	Switch	N.A.	N.A.	Unknown		
1415	PG&E	09/14/17	12:09	39.50393	-121.54528	Vegetation	Urban	< 0.25 Acres	Fire Agency	530-538-2448	100372805	Unknown	12,000	Conductor	Overhead	Yes	9/14/17	12:09	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
1416	PG&E	09/14/17	14:06	40.29421	-123.81736	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	100898497	Unknown	12,000	Conductor	Overhead	Yes	9/14/17	14:06	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1417	PG&E	09/15/17	14:55	39.74607	-121.48853	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	100335239	Unknown	12,000	Conductor	Overhead	Yes	9/15/17	14:55	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1418	PG&E	09/17/17	15:05	36.64729	-119.38613	Vegetation	Rural	< 3 Meters	Customer	N.A.	100738741	VERIZON CALIFOR	0 - 750	Conductor	Overhead	Yes	9/17/17	15:05	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1419	PG&E	09/17/17	17:38	38.99459	-121.02607	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100029537	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/17/17	17:38	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
1420	PG&E	09/18/17	13:01	38.38858	-121.40368	Vegetation	Rural	< 3 Meters	Fire Agency	Cal Fire	103780557	Unknown	0 - 750	Conductor	Overhead	Yes	9/18/17	13:01	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
1421	PG&E	09/18/17	18:01	38.60135	-122.05551	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103849876	Unknown	12,000	Conductor	Overhead	Yes	9/18/17	18:01	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1422	PG&E	09/18/17	18:01	38.21975	-122.54300	Vegetation	Rural	26 - 99 Acres	Fire Agency	Cal Fire	101997149	Unknown	12,000	Conductor	Overhead	Yes	9/18/17	18:01	Contact From Object	N.A.	Vehicle	N.A.	Human Error	Third-party caused	
1423	PG&E	09/18/17	19:01	38.07423	-122.82861	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	102229215	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/18/17	19:01	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1424	PG&E	09/18/17	23:50	37.90879	-120.48652	Vegetation	Rural	10 - 99 Acres	Fire Agency	incident comander geoff marshall 209-419-4407	101040882	Unknown	12,000	Conductor	Overhead	Yes	9/18/17	23:50	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
1425	PG&E	09/19/17	19:13	35.47836	-119.29591	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	102007112	Unknown	12,000	Conductor	Overhead	Yes	9/19/17	19:13	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused	
1426	PG&E	09/20/17	2:06	37.25968	-122.32223	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100322388	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/20/17	2:06	Contact From Object	N.A.	Vehicle	N.A.	Human Error	Third-party caused	
1427	PG&E	09/20/17	8:41	36.94037	-120.90142	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire	100898497	None	70,000	Conductor	Overhead	Yes	9/20/17	8:41	Contact From Object	N.A.	Other	Electric Facility	Unknown	bird's nest	
1428	PG&E	09/21/17	8:39	39.61470	-121.72582	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	100347380	Unknown	0 - 750	Conductor	Overhead	Yes	9/21/17	8:39	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
1429	PG&E	09/22/17	14:28	36.09612	-120.05766	Vegetation	Rural	< 0.25 Acres	Fire Agency	ARRIVAL	100663084	Unknown	12,000	Capacitor Bank	Overhead	No			Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown		
1430	PG&E	09/23/17	9:16	37.01267	-120.62562	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	101181497	Unknown	12,000	Conductor	Overhead	Yes	9/23/17	9:16	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown		
1431	PG&E	09/23/17	14:17	40.65090	-122.29740	Vegetation	Rural	26 - 99 Acres	Fire Agency	DARREN STEWART 448-2421	101467221	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/23/17	14:17	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused	
1432	PG&E	09/24/17	2:13	38.10460	-120.98901	Vegetation	Rural	10 - 99 Acres	Fire Agency	Pole 016/297	100608102	Unknown	60,000	Conductor	Overhead	Yes	9/24/17	2:13	Equipment/ Facility Failure						

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X
2	Utility Name	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	Field Observations	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes
1498	PG&E	10/17/17	18:22	35.42566	-119.02972	Vegetation	Urban	< 3 Meters	Self Extinguished	N.A.	100144662	PACIFIC BELL	12,000	Capacitor Bank	Overhead	Yes	10/17/17	18:22	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
1499	PG&E	10/18/17	13:58	37.63605	-122.07925	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	100952408	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	10/18/17	13:58	Contact From Object	N.A.	Vehicle	N.A.	Human Error	
1500	PG&E	10/20/17	5:59	36.74749	-119.76295	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	100859697	Unknown	12,000	Conductor	Overhead	Yes	10/20/17	5:59	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
1501	PG&E	10/20/17	6:18	39.29221	-121.01573	Vegetation	Rural	< 3 Meters	Fire Agency	PHILLIP NUNNINK INCIDENT # 27272	100087647	PACIFIC BELL	12,000	Conductor	Overhead	Yes	10/20/17	6:18	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1502	PG&E	10/20/17	9:06	36.03599	-120.05797	Vegetation	Rural	300 - 999 Acres	Fire Agency	Unknown	Pole 009/009	Unknown	70,000	Conductor	Overhead	Yes	10/20/17	9:06	Contact From Object	N.A.	Other	Electric Facility	Other	bird's nest
1503	PG&E	10/20/17	13:43	35.35300	-119.98730	Vegetation	Rural	10 - 99 Acres	Fire Agency	Kevin McLean Office(805)593-3421, Cell(805)903-3421	100136483	Unknown	12,000	Conductor	Overhead	Yes	10/20/17	13:43	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1504	PG&E	10/20/17	13:45	34.55317	-120.53029	Vegetation	Rural	100 - 299 Acres	Fire Agency	Unknown	101921492	Unknown	12,000	Conductor	Overhead	Yes	10/20/17	13:45	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
1505	PG&E	10/20/17	14:00	36.92155	-119.72828	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100727124	Unknown	21,000	Fuse	Overhead	Yes	10/20/17	14:00	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
1506	PG&E	10/21/17	15:08	39.06400	-122.77645	Vegetation	Rural	< 3 Meters	Fire Agency	Cal Fire	102155186	PACIFIC BELL	12,000	Conductor	Overhead	Yes	10/21/17	15:08	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1507	PG&E	10/21/17	16:05	37.59108	-122.00995	Vegetation	Urban	.26 - 9.99 Acres	Fire Agency	Unknown	103516949	Unknown	0 - 750	Conductor	Overhead	Yes	10/21/17	16:05	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	Third-party caused
1508	PG&E	10/23/17	19:34	36.07720	-121.01900	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	101763398	Unknown	12,000	Conductor	Overhead	Yes	10/23/17	19:34	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1509	PG&E	10/23/17	21:24	37.37133	-122.34799	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	100270421	Unknown	12,000	Conductor	Overhead	Yes	10/23/17	21:24	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1510	PG&E	10/24/17	15:23	36.85988	-121.79474	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101789001	PACIFIC BELL	21,000	Conductor	Overhead	Yes	10/24/17	15:23	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1511	PG&E	10/26/17	10:53	36.40356	-121.91219	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	101777002	Unknown	12,000	Conductor	Overhead	Yes	10/26/17	10:53	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
1512	PG&E	10/28/17	15:26	39.45162	-123.38381	Vegetation	Rural	< 3 Meters	Fire Agency	Cal Fire	102209084	Unknown	12,000	Conductor	Overhead	Yes	10/28/17	15:26	Contact From Object	N.A.	Vehicle	Communication Facility	Human Error	
1513	PG&E	10/28/17	20:08	35.02222	-118.76915	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	100223850	Unknown	12,000	Fuse	Overhead	Yes	10/28/17	20:08	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
1514	PG&E	10/31/17	18:56	39.00345	-121.69065	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	Pole 010/208	Unknown	60,000	Conductor	Overhead	Yes	10/31/17	18:56	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	Third-party caused
1515	PG&E	10/31/17	21:02	39.11189	-122.91633	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	Structure 020/003	Unknown	60,000	Conductor	Overhead	Yes	10/31/17	21:02	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
1516	PG&E	11/06/17	9:59	37.14600	-121.66753	Vegetation	Rural	< 0.25 Acres	Fire Agency	INCIDENT # 1717CASC008183	103570543	YES	21,000	Conductor	Overhead	Yes	11/6/17	9:59	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1517	PG&E	11/06/17	15:06	38.29980	-122.50300	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	101982913	PACIFIC BELL	12,000	Conductor	Overhead	Yes	11/6/17	15:06	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1518	PG&E	11/08/17	07:11	37.73669	-120.34587	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	101191714	PACIFIC BELL	12,000	Conductor	Overhead	Yes	11/8/17	07:11	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1519	PG&E	11/08/17	14:53	37.79198	-122.22211	Building	Urban	Structure Only	Fire Agency	Unknown	101352529	Unknown	4,000	Conductor	Overhead	Yes	11/8/17	14:53	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1520	PG&E	11/11/17	11:57	35.11908	-120.39364	Vegetation	Rural	< 0.25 Acres	Fire Agency	Jordan Dayley ph#929-3911,engine#3467	101931190	PACIFIC BELL	12,000	Conductor	Overhead	Yes	11/11/17	11:57	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1521	PG&E	11/12/17	19:44	36.73779	-119.77691	Building	Urban	< 0.25 Acres	Fire Agency	capt #0 johnson	100871063	Unknown	12,000	Capacitor Bank	Overhead	Yes	11/12/17	19:44	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
1522	PG&E	11/14/17	07:43	37.32400	-120.81456	Vegetation	Rural	< 3 Meters	Fire Agency	cammu #023223	103853299	Unknown	12,000	Transformer	Overhead	Yes	11/14/17	07:43	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
1523	PG&E	11/17/17	09:53	37.08016	-120.01945	Other	Rural	< 3 Meters	Utility PG&E	N.A.	101029626	Unknown	12,000	Fuse	Overhead	Yes	11/17/17	09:53	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
1524	PG&E	11/20/17	08:32	38.75835	-120.84385	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	101389405	PACIFIC BELL	12,000	Conductor	Overhead	Yes	11/20/17	08:32	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1525	PG&E	11/20/17	20:05	35.49951	-118.90994	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	661-324-6551	103782809	None	0 - 750	Conductor	Overhead	Yes	11/20/17	20:05	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1526	PG&E	11/21/17	11:55	37.61013	-121.33324	Vegetation	Rural	< 0.25 Acres	Fire Agency	tracy fire dept	102053617	PACIFIC BELL	12,000	Conductor	Overhead	Yes	11/21/17	11:55	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1527	PG&E	11/22/17	13:44	36.75202	-121.66363	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	103154362	Unknown	12,000	Conductor	Overhead	Yes	11/22/17	13:44	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
1528	PG&E	11/23/17	16:29	35.77554	-120.69413	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101860971	Unknown	12,000	Conductor	Overhead	Yes	11/23/17	16:29	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1529	PG&E	11/24/17	10:33	36.62133	-120.06165	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	KERMAN FIRE DEP.	100700900	Unknown	12,000	Conductor	Overhead	Yes	11/24/17	10:33	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1530	PG&E	11/25/17	6:29	36.01436	-119.95559	Vegetation	Rural	< 3 Meters	Utility PG&E	N.A.	100693913	Unknown	12,000	Conductor	Overhead	Yes	11/25/17	6:29	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1531	PG&E	11/26/17	10:10	36.70981	-119.56321	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	100815464	VERIZON CALIFO	0 - 750	Conductor	Overhead	Yes	11/26/17	10:10	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused
1532	PG&E	11/27/17	08:23	36.69419	-121.65832	Vegetation	Rural	< 3 Meters	Fire Agency	831-758-7261	101723997	Unknown	12,000	Conductor	Overhead	Yes	11/27/17	08:23	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1533	PG&E	11/27/17	11:11	37.12962	-122.31244	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100282624	Unknown	12,000	Conductor	Overhead	Yes	11/27/17	11:11	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1534	PG&E	11/28/17	15:49	36.49743	-119.79086	Vegetation	Rural	< 3 Meters	Self Extinguished	N.A.	100806272	Unknown	12,000	Other	Overhead	Yes	11/28/17	15:49	Equipment/ Facility Failure	Voltage Regulator	N.A.	N.A.	Unknown	
1535	PG&E	11/29/17	17:34	38.68410	-120.65461	Vegetation	Rural	< 3 Meters	Fire Agency	Cal Fire	101419450	PACIFIC BELL	21,000	Conductor	Overhead	Yes	11/29/17	17:34	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1536	PG&E	12/07/17	12:26	34.71151	-120.17715	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	Pole 015/220	Unknown	115,000	Unknown	Overhead	No			Unknown	N.A.	N.A.	N.A.	Unknown	
1537	PG&E	12/12/17	4:40	39.77107	-121.59727	Building	Urban	Structure Only	Fire Agency	paradise fire city department	100324902	PACIFIC BELL	12,000	Fuse	Overhead	Yes	12/12/17	4:40	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
1538	PG&E	12/13/17	12:13	35.59220	-120.64741	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103390807	Unknown	21,000	Other	Overhead	Yes	12/13/17	12:13	Equipment/ Facility Failure	Recloser	N.A.	N.A.	Unknown	
1539	PG&E	12/14/17	1:33	37.19789	-121.83746	Building	Rural	Structure Only	Fire Agency	Unknown	100622323	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	12/14/17	1:33	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1540	PG&E	12/14/17	17:16	34.58783	-120.35663	Vegetation	Rural	10 - 99 Acres	Fire Agency	Unknown	101911004	VERIZON CALIFO	12,000	Conductor	Overhead	Yes	12/14/17	17:16	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1541	PG&E	12/16/17	7:01	39.74474	-122.19612	Building	Urban	Structure Only	Fire Agency	ORLAND CITY FIRE DEPT	100428554	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	12/16/17	7:01	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1542	PG&E	12/16/17	11:51	38.81708	-122.70412	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Shawn Ohare	102167231	PACIFIC BELL	12,000	Conductor	Overhead	Yes	12/16/17	11:51	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1543	PG&E	12/16/17	13:39	37.97022	-121.64092	Vegetation	Rural	< 0.25 Acres	Fire Agency	FIRE CAPTAIN ON DUTY	100473121	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	12/16/17	13:39	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1544	PG&E	12/16/17	16:03	35.65929	-120.49459	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103131190	Unknown</												