

A		B		C		D		E		F		G		H		I		J		K		L		M		N		O		P		Q		R		S		T		U		V		W		X	
Utility Name	Fire Start	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Utility Facility	Equipment Involved With Ignition	Type	Was There an Outage	Date2	Time3	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes																									
Column1	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Utility Facility	Equipment Involved With Ignition	Type	Was There an Outage	Date2	Time3	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes																								
3	SCE	5/29/14	18:00	33.9036301	-118.0386983	Other	Urban	Less Than .25 Acres	Fire Agency	Santa Fe Springs	None	66kV	Other	Overhead	No			Contact From Object																													
4	SCE	6/5/14	9:20	34.5550460	-118.1177890	Other	Rural	Less Than .25 Acres	Fire Agency	LA County	None	12kV	Conductor	Overhead	No			Contact From Object																													
5	SCE	6/8/14	18:00	33.6808854	-117.9487188	Other	Urban	Less Than .25 Acres	Fire Agency	Huntington Beach	None	12kV	Other	Overhead	No			Contact From Object																													
6	SCE	6/13/14	13:00	35.7151000	-118.5110670	Vegetation	Rural	1000 - 4999 Acres	Fire Agency	None	None	66kV	Other	Overhead	No			Contact From Object																													
7	SCE	6/18/14	15:00	34.1626420	-118.6767220	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	LA County	None	16kV	Conductor	Overhead	Yes	6/18/14	Unknown	Contact From Object																													
8	SCE	6/23/14	13:15	Not Provided	-118.72947	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire	None	12kV	Conductor	Overhead	Yes	6/23/2014	16:20	Contact From Object																													
9	SCE	6/27/14	11:06	34.6094170	-119.5002740	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Ventura County	None	16kV	Conductor	Overhead	Yes	6/27/14	11:06	Contact From Object																													
10	SCE	7/8/14	11:30	34.4529320	-117.7547730	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Fire Department	None	16kV	Conductor	Overhead	No			Contact From Object																													
11	SCE	7/24/14	13:00	33.5444395	-117.1158394	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Not provided	None	12kV	Lightning Arrestor	Overhead	No			Lightning Arrestor																													
12	SCE	7/27/14	18:00	36.0501990	-119.0574840	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Tulare County Fire	None	12kV	Conductor	Overhead	No			Contact From Object																													
13	SCE	7/29/14	8:23	34.4529320	-117.1827110	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Riverside County	None	12kV	Conductor	Overhead	No			Contact From Object																													
14	SCE	7/30/14	15:00	34.1593370	-117.2908080	Vegetation	Urban	26 - 9.99 Acres	Fire Agency	San Bernardino Fire	None	12kV	Other	Overhead	Yes	7/30/14	15:00	Contact From Object				Tree trimmer dropped palm frond on wires.																									
15	SCE	7/31/14	16:00	33.7927568	-117.2831691	Other	Rural	Less Than .25 Acres	Fire Agency	Perris Fire Department	None	12kV	Other	Overhead	No			Contact From Object																													
16	SCE	8/3/14	20:00	36.3425640	-119.3756970	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Visalia Fire Department	None	12kV	Conductor	Overhead	No			Contact From Object																													
17	SCE	8/12/14	13:29	34.3867900	-119.3145000	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Ventura County	None	16kV	Conductor	Overhead	Yes	8/12/14	12:05	Contact From Object																													
18	SCE	8/12/14	9:20	33.7339323	-117.152318	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Fire Agency	None	12kV	Other	Overhead	Yes	8/18/14	9:00	Contact From Object																													
19	SCE	8/17/14	15:00	33.7469820	-117.7992737	Vegetation	Urban	Less Than .25 Acres	Fire Agency	OC Fire Authority	None	12kV	Transformer	Overhead	Yes	8/17/14	16:00	Contact From Object																													
20	SCE	8/24/14	8:30	34.0087540	-117.4021760	Building	Urban	26 - 9.99 Acres	Fire Agency	Riverside County FD	None	12kV	Other	Overhead	Yes	8/24/14	8:30	Contact From Object																													
21	SCE	8/30/14	15:30	34.1709350	-117.2956550	Vegetation	Urban	26 - 9.99 Acres	Fire Agency	San Bernardino Fire	None	4kV	Other	Overhead	No			Contact From Object																													
22	SCE	9/5/14	14:00	34.0276135	-117.9071504	Other	Urban	Less Than .25 Acres	Fire Agency	West Covina FD	None	12kV	Other	Subsurface	Yes	9/5/14	14:00	Contact From Object																													
23	SCE	9/6/14	14:00	33.8780461	-117.5195693	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Riverside County	None	12kV	Conductor	Overhead	Yes	9/6/14	14:00	Contact From Object																													
24	SCE	9/8/14	11:55	34.5600120	-118.0410940	Vegetation	Urban	Less Than .25 Acres	Fire Agency	LA County	None	12kV	Conductor	Overhead	No			Contact From Object																													
25	SCE	9/15/14	16:00	34.1740188	-118.0575900	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Sierra Madre FD	None	16kV	Other	Overhead	Yes	9/15/14	15:54	Contact From Object																													
26	SCE	9/19/14	23:20	34.0382540	-118.8719920	Vegetation	Rural	Less Than .25 Acres	Fire Agency	LA County	None	16kV	Transformer	Overhead	No			Contact From Object																													
27	SCE	10/3/14	15:00	34.0489195	-117.9851278	Other	Urban	Less Than .25 Acres	Unknown	1180454e 15e corner of p	None	12kV	Other	Overhead	No			Contact From Object																													
28	SCE	10/4/14	16:00	34.1652250	-117.3566230	Other	Urban	Less Than .25 Acres	Fire Agency	San Bernardino Fire	None	4kV	Other	Overhead	Yes	10/4/14	16:00	Contact From Object																													
29	SCE	10/10/14	16:24	34.2049210	-118.8746730	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Thousand Oaks	None	16kV	Conductor	Overhead	Yes	10/10/14	16:24	Contact From Object																													
30	SCE	11/7/14	17:00	Not Provided	Not Provided	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Redondo Beach Fire Dept	None	16kV	Conductor	Overhead	Yes	11/7/2014	19:00	Contact From Object																													
31	SCE	11/10/14	Not Provided	Not Provided	Not Provided	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Arcadia Fire Department	None	4kV	Conductor	Overhead	Yes	11/10/14	Not Provided	Contact From Object																													
32	SCE	11/13/14	12:00	34.4934020	-117.1863970	Building	Urban	Less Than .25 Acres	Fire Agency	Apple Valley Fire Department	None	12kV	Other	Overhead	No			Contact Between Third Party Facility on Pole and Supply Lines																													
33	SCE	11/16/14	13:30	34.0480460	-118.6829900	Vegetation	Urban	Less Than .25 Acres	Fire Agency	LA County	None	16kV	Conductor	Overhead	Yes	11/16/14	13:30	Contact From Object																													
34	SCE	11/17/14	4:30	34.3128590	-118.8983360	Other	Rural	Less Than .25 Acres	Fire Agency	Ventura County	None	16kV	Transformer	Overhead	No			Contact From Object																													
35	SCE	11/21/14	4:41	34.0891120	-117.3711820	Vegetation	Urban	Less Than .25 Acres	Fire Agency	RIALTO FD	None	12kV	Other	Overhead	No			Contact From Object																													
36	SCE	12/2/14	10:00	34.1058474	-117.7881530	Other	Urban	Less Than .25 Acres	Fire Agency	La Verne Fire Department	None	12kV	Capacitor Bank	Overhead	Yes	12/2/14	10:00	Contact From Object																													
37	SCE	12/3/14	13:00	34.0376880	-117.7567471	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Comona Fire Department	None	12kV	Conductor	Overhead	Yes	12/3/14	19:00	Contact From Object																													
38	SCE	12/4/14	1:00	34.0119775	-117.9708170	Vegetation	Urban	Less Than .25 Acres	Fire Agency	LA County	None	12kV	Conductor	Overhead	Yes	12/4/14	4:00	Contact From Object																													
39	SCE	12/5/14	2:52	33.9397026	-117.6114641	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Chino Fire Department	None	12kV	Other	Overhead	No			Contact From Object																													
40	SCE	12/12/14	1:30	35.9219806	-119.0178838	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Tulare County Fire Department	None	12kV	Conductor	Overhead	No			Contact From Object																													
41	SCE	12/27/14	8:17	34.0719543	-117.8389807	Vegetation	Urban	Less Than .25 Acres	Fire Agency	LA County	None	12kV	Switch	Overhead	Yes			Contact From Object																													
42	SCE	1/4/15	13:00	33.9539015	-118.3682332	Other	Urban	Less Than .25 Acres	Fire Agency	Los Angeles County Fire	None	16kV	Conductor	Overhead	Yes	1/4/15	13:00	Contact From Object																													
43	SCE	1/26/15	17:30	34.1314861	-117.8376444	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Glendora Fire Department	None	12kV	Conductor	Overhead	Yes	1/26/15	17:30	Contact From Object																													
44	SCE	2/6/15	13:15	37.4539600	-118.5841960	Vegetation	Rural	Greater than 5000 Acres	Fire Agency	Various Fire Agencies	None	12kV	Conductor	Overhead	Yes	2/6/15	13:15	Contact From Object																													
45	SCE	2/22/15	9:52	34.2848680	-119.2172930	Vegetation	Rural	10 - 99 Acres	Fire Agency	Ventura Fire Department	None	16kV	Other	Overhead	Yes	2/22/15	10:49	Contact From Object																													
46	SCE	3/23/15	17:20	34.4354600	-119.8226270	Other	Urban	Less Than .25 Acres	Fire Agency	Santa Barbara County Fire	None	16 kV	Conductor	Overhead	Yes	3/23/15	19:19	Contact From Object																													
47	SCE	3/28/15	14:09	34.0489195	-117.9247230	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Los Angeles County Fire	None	12kV	Conductor	Overhead	Yes	3/28/15	14:09	Contact From Object																													
48	SCE	3/28/15	17:57	33.8513739	-117.5872299	Other	Urban	Less Than .25 Acres	Fire Agency	Corona Fire Department	None	33kV	Other	Overhead	Yes	3/28/15	17:57	Contact From Object																													
49	SCE	3/30/15	15:14	33.9010580	-117.8533700	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Orange County Fire Authority	None	12kV	Conductor	Overhead	Yes	3/30/15	15:24	Contact From Object																													
50	SCE	4/6/15	14:00	36.1065620	-119.0314670	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Tulare County Fire	None	12kV	Other	Overhead	Yes	4/8/15	14:10	Contact From Object																													
51	SCE	4/8/15	13:05	34.1781090	-118.8684250	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Ventura County Fire	None	16kV	Conductor	Overhead	Yes	4/8/15	13:05	Contact From Object																													
52	SCE	4/8/15	16:52	36.1059070	-119.0416470	Other	Rural	Less Than .25 Acres	Fire Agency	Tulare County Fire	None	12kV	Conductor	Overhead	Yes	4/8/15	16:52	Contact From Object																													
53	SCE	4/11/15	14:27	34.0354730	-118.1327740	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Monterey Park Fire Department	None	4kV	Other	Overhead	Yes	4/11/15	14:27	Contact From Object																													
54	SCE	4/12/15	6:32	34.0771960	-117.4996530	Other	Urban	Less Than .25 Acres	Unknown	Elwanda-Galvanizing-Strip	66kV, PS451	66kV	Switch	Overhead	No			Contact From Object																													
55	SCE	4/13/15	15:00	33.7902510	-117.0323730	Other	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	None	12kV	Fuse	Overhead	No			Contact From Object																													
56	SCE	4/14/15	14:35	36.6281194	-117.6817528	Other	Urban	26 - 9.99 Acres	Fire Agency	Kern County Fire Department	None	12 kV	Conductor	Overhead	Yes	4/14/15	14:35	Contact From Object																													
57	SCE	4/17/15	9:41	33.6397130	-118.903																																										

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X
Utility Name	Fire Start				Location Info			Fire Specifics				Utility Facility			Outage Info			Suspected Initiating Event	Equipment / Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes
2	Column#1	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date#	Time#3					
119	SCE	8/12/15	12:00	35.1772470	-118.3373190	Vegetation	Rural	Less Than .25 Acres	Self Extinguished		Pole 2135290E		120 V	Conductor	Subsurface	Yes	8/12/15	11:07	Other			Human Error	Third Party dug into marked SCE secondary cables.
120	SCE	8/21/15	23:10	35.2355530	-119.3528250	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Tulare Fire Department	43353366 - J STREET S/O CARTMILL AVE		12kV	Other	Overhead	Yes	8/22/15	2:19	Wandallism/Theft			Outside Force	
121	SCE	8/24/15	22:30	33.8639290	-118.2115660	Building	Urban	Less Than .25 Acres	Fire Agency	Compton Fire Department	2299232E MAYO AVE P/L	Phone & Cable	46kV	Conductor	Overhead	Yes	8/24/15	21:41	Unknown			Unknown	
122	SCE	8/27/15	20:21	34.0644690	-117.8910950	Vegetation	Urban	Less Than .25 Acres	Fire Agency	West Covina Fire Department	Pole 534400E		12kV	Conductor	Overhead	Yes	8/27/15	6:21	Contact From Object	Vegetation	Electric Facility	Unknown	
123	SCE	8/27/15	10:20	34.2538130	-118.8660450	Other	Urban	Less Than .25 Acres	Fire Agency	Ventura County Fire	Morganstein 16kV out of Moorpark Hill		16kV	Conductor	Overhead	Yes	8/27/15	10:20	Contact From Object	Animal	Electric Facility	None	
124	SCE	9/3/15	17:00	36.8936000	-119.4571000	Vegetation	Rural	10 - .99 Acres	Fire Agency	Cal Fire	East of Watts Valley Rd and Pittman Sub Rd. East		220kV	Conductor	Overhead	Yes	9/3/15	16:15	Contact From Object	Balloons	Electric Facility	None	
125	SCE	9/7/15	17:58	35.8554700	-119.0944400	Vegetation	Rural	Less Than .25 Acres	Self Extinguished		Welch 12kV at Vestal Sub		12kV	Conductor	Overhead	Yes	9/7/15	17:58	Contact From Object	Balloons	Electric Facility	None	
126	SCE	9/9/15	13:22	34.0414910	-118.7724050	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Los Angeles County Fire	Pole 899836E	Phone & Cable	12kV	Other	Overhead	Yes	9/9/15	13:22	Equipment/Facility Failure	Splice/Clamp/Connector		Unknown	
127	SCE	9/9/15	13:59	33.5499250	-117.1251500	Other	Urban	Less Than .25 Acres	Fire Agency	Murrieta Fire Department	Tackle Line out of Stadler Sub		12kV	Conductor	Overhead	Yes	9/9/15	13:59	Other			Unknown	
128	SCE	9/11/15	3:10	34.0875990	-117.4330630	Other	Urban	Less Than .25 Acres	Fire Agency	Fontana Fire Department	Pole 1554125E beyond RC	Phone & Cable	12kV	Lightning Arrestor	Overhead	Yes	9/11/15	3:10	Equipment/Facility Failure	Lightning Arrestor		Unknown	
129	SCE	9/20/15	19:07	34.0243510	-118.1178780	Other	Urban	Less Than .25 Acres	Unknown		1270852E MIERLE DR. SA	Phone & Cable	16kV	Transformer	Overhead	Yes	9/20/15	19:07	Equipment/Facility Failure	Transformer		Unknown	
130	SCE	9/20/15	18:31	34.0632990	-118.6791980	Other	Urban	Less Than .25 Acres	Fire Agency	Los Angeles County Fire	Pole 1578714E	Phone & Cable	16kV	Conductor	Overhead	Yes	9/20/15	18:31	Contact From Object	Vehicle	Pole	None	
131	SCE	9/26/15	13:48	34.0772940	-118.6935880	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Los Angeles County Fire	Pole 770514E		16kV	Conductor	Overhead	Yes	9/26/15	13:48	Contact From Object	Vegetation	Electric Facility	Human Error	
132	SCE	10/9/15	14:00	33.5752390	-117.1700440	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Riverside Fire Department	BEHIND ADDRESS 28151 CELIA RD / PROPERTY		12kV	Other	Overhead	No			Equipment/Facility Failure	Insulator		Unknown	
133	SCE	10/9/15	11:39	33.9333110	-117.8530940	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Los Angeles County Fire	Acapulco 12kv out of Brea Sub.		12kV	Conductor	Overhead	Yes	10/9/15	11:39	Contact From Object	Other	Electric Facility	Unknown	
134	SCE	10/11/15	10:02	33.9440460	-116.4750350	Other	Urban	Less Than .25 Acres	Fire Agency	Cal Fire	Cafe 12kv Line at Coffee Sub. Pole in Desert Hot		12kV	Conductor	Overhead	Yes	10/11/15	10:02	Contact From Object	Vehicle	Pole	None	
135	SCE	10/12/15	13:02	33.6318500	-117.3378472	Other	Urban	Less Than .25 Acres	Fire Agency	Riverside County Fire	4844065E: 18193 BRIGHTMAN AVE. LAKE ELSIN		12kV	Transformer	Overhead	Yes	10/12/15	13:02	Equipment/Facility Failure	Transformer		Unknown	
136	SCE	10/27/15	19:47	33.5350600	-117.7687930	Vegetation	Urban	Less Than .25 Acres	Unknown		4139544E: 818 BLUEBIRD	Phone & Cable	33kV	Conductor	Overhead	Yes	10/27/15	19:47	Equipment/Facility Failure	Splice/Clamp/Connector		Unknown	
137	SCE	10/30/15	12:45	34.0538200	-117.2678850	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Loma Linda Fire Department	pole 16090w	Phone & Cable	12kV	Conductor	Overhead	No			Contact From Object	Vegetation	Electric Facility	Weather	
138	SCE	10/30/15	22:23	33.7902580	-116.9605090	Vegetation	Urban	Less Than .25 Acres	Unknown		Pole 108493E	Phone & Cable	12kV	Other	Overhead	Yes	10/30/15	22:23	Unknown			Unknown	
139	SCE	11/2/15	18:07	34.2969760	-118.3763390	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Los Angeles County Fire	Lopez 16kV out of San Fernando Sub		16kV	Conductor	Overhead	Yes	11/2/15	18:07	Contact From Object	Balloons	Electric Facility	None	
140	SCE	11/7/15	15:24	34.2056970	-118.8448930	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Ventura County Fire	Pole No. 4510362E		16kV	Switch	Overhead	Yes	11/7/15	15:24	Contact From Object	Vehicle	Pole	Unknown	
141	SCE	11/13/15	7:04	34.2199580	-119.0382170	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Ventura County Fire	Crosson 16kV at Camarillo Sub		16kV	Conductor	Overhead	Yes	11/13/15	7:04	Contact From Object	Animal	Electric Facility	None	
142	SCE	11/13/15	7:31	33.6394980	-117.7609780	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Orange County Fire	Santiago-Borrego 66 kV		66kV	Conductor	Overhead	Yes	11/13/15	7:31	Contact From Object	Animal	Electric Facility	None	
143	SCE	11/18/15	6:31	34.1283510	-117.6895780	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Upland Fire Department	Padua-Layfair 66kV		66kV	Conductor	Overhead	Yes	11/18/15	6:31	Contact From Object	Other	Electric Facility	Unknown	
144	SCE	11/20/15	20:07	34.015535	-117.953436	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Los Angeles County Fire	1860773E 15930 E VALLEY BLVD. city of industry		12kV	Conductor	Overhead	Yes	11/20/15	20:07	Unknown			Unknown	
145	SCE	11/20/15	20:07	34.0155350	-117.9534360	Other	Urban	Less Than .25 Acres	Fire Agency	Los Angeles County Fire	Grazide 12kV out of Walnut Sub		12kV	Conductor	Overhead	Yes	11/20/15	20:07	Contact From Object	Animal	Electric Facility	None	
146	SCE	11/24/15	1:17	33.7443170	-118.4070210	Other	Urban	Less Than .25 Acres	Fire Agency	Los Angeles County Fire	Ambersky 16kV at Marymount Sub. Pole in Rancho Palos Verdes		16kV	Conductor	Overhead	Yes	11/24/15	1:17	Equipment/Facility Failure	Conductor		Unknown	
147	SCE	12/8/15	19:08	34.2188030	-119.2492490	Vegetation	Rural	Less Than .25 Acres	Customer		Pole 1748639E	Phone & Cable	16kV	Transformer	Overhead	No			Contamination			Unknown	
148	SCE	12/11/15	12:21	34.0380730	-118.7701600	Other	Urban	26 - 9.99 Acres	Fire Agency	Los Angeles County Fire	Cuthbert 12kV at Latigo Sub. Near Latigo Canyon		12kV	Conductor	Overhead	Yes	12/11/15	12:21	Wire-Wire Contact			Weather	
149	SCE	1/11/16	10:13	34.0007670	-118.0812670	Vegetation	Urban	Less Than .25 Acres	Fire Agency	LACFD	OH-4815530E	FRONTIER COMMUNI	12 kV	Conductor	Overhead	Yes	1/11/16	10:13	Contact From Object	Balloons	Electric Facility	Unknown	
150	SCE	1/16/16	20:51	34.0627270	-118.0528890	Other	Urban	Less Than .25 Acres	Fire Agency	LACFD	9900 block of East Garvey Ave, El Monte		4 kV	Conductor	Overhead	Yes	1/16/16	20:51	Equipment/Facility Failure	Pole		Unknown	
151	SCE	1/16/16	15:20	34.4095710	-118.6815700	Vegetation	Rural	Less Than .25 Acres	Fire Agency	LACFD	OH-848266E		16 kV	Conductor	Overhead	Yes	1/16/16	15:20	Equipment/Facility Failure	Other		Unknown	
152	SCE	1/28/16	22:07	33.9842210	-118.1488130	Vegetation	Urban	Less Than .25 Acres	Fire Agency	LACFD	OH-820509E	FRONTIER COMMUNI	16 kV	Conductor	Overhead	Yes	1/28/16	22:07	Contact From Object			None	
153	SCE	2/3/16	17:46	34.7182510	-118.3025180	Vegetation	Rural	Less Than .25 Acres	Fire Agency	LACFD	OH-1355070E	FRONTIER COMMUNI	120/240 V	Conductor	Overhead	No			Unknown			Unknown	
154	SCE	2/7/16	9:31	34.1370600	-117.5141240	Vegetation	Rural	Less Than .25 Acres	Fire Agency	SBCFD	OH-4275464E	FRONTIER COMMUNI	12 kV	Conductor	Overhead	Yes	2/7/16	9:31	Equipment/Facility Failure	Conductor		Unknown	
155	SCE	2/8/16	8:22	34.1060570	-117.4402780	Vegetation	Urban	Less Than .25 Acres	Fire Agency	SBCFD	OH-1420896E	AT&T WIRELESS SER I	12 kV	Conductor	Overhead	Yes	2/8/16	8:22	Equipment/Facility Failure	Conductor		Unknown	
156	SCE	2/9/16	19:13	33.7790240	-118.1401670	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Long Beach Fire Department	OH-2381948E	FRONTIER COMMUNI	12 kV	Other	Overhead	Yes	2/9/16	19:13	Equipment/Facility Failure	Other		Unknown	
157	SCE	2/10/16	18:56	34.2186560	-119.2539580	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Ventura County FD	OH-4423101E		16 kV	Other	Overhead	Yes	2/10/16	18:56	Equipment/Facility Failure	Other		Unknown	
158	SCE	2/12/16	20:02	33.9680310	-118.0717540	Vegetation	Urban	Less Than .25 Acres	Fire Agency	LACFD	OH-845479E	FRONTIER COMMUNI	12 kV	Conductor	Overhead	Yes	2/12/16	20:02	Contact From Object	Vegetation	Electric Facility	Unknown	
159	SCE	2/18/16	15:18	34.2056970	-118.8448930	Vegetation	Urban	Less Than .25 Acres	Fire Agency	LACFD	OH-8448930E		16 kV	Conductor	Overhead	Yes	2/18/16	15:18	Contact From Object	Conductor		Unknown	
160	SCE	2/22/16	17:04	34.4491640	-119.5844980	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Montecito Fire Department	OH-1082380E	FRONTIER COMMUNI	16 kV	Conductor	Overhead	Yes	2/22/16	17:04	Equipment/Facility Failure			Unknown	
161	SCE	2/24/16	15:06	34.9470000	-118.1417210	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Kern County Fire Department	OH-706814E	AT&T CALIFORNIA	16 kV	Conductor	Overhead	No			Contact From Object	Animal	Electric Facility	Unknown	
162	SCE	2/27/16	0:49	33.9134180	-116.8003250	Other	Rural	Less Than .25 Acres	Fire Agency	Cal Fire	OH-1989045E		12 kV	Conductor	Overhead	Yes	2/27/16	0:49	Contact From Object	Vehicle	Pole	Unknown	
163	SCE	3/11/16	7:53	33.9059430	-117.9237840	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Fullerton Fire Department	OH-7403254E	TIME WARNER CABL	12 kV	Conductor	Overhead	Yes	3/11/16	7:53	Contact From Object	Vegetation	Electric Facility	Unknown	
164	SCE	3/17/16	14:53	34.0059170	-117.9663880	Vegetation	Urban	Less Than .25 Acres	Fire Agency	LACFD	OH-1892254E	TIME WARNER CABL	12 kV	Conductor	Overhead	Yes	3/17/16	14:53	Contact From Object	Vehicle	Pole	Unknown	
165	SCE	3/23/16	11:45	34.1369140	-117.5061030	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Rancho Cucamonga Fire Department	OH-4300709E	FRONTIER COMMUNI	12 kV	Conductor	Overhead	Yes	3/23/16	11:45	Contact From Object	Other	Electric Facility	Unknown	
166	SCE	4/7/16	7:43	34.2995640	-118.4392500	Vegetation	Urban	Less Than .25 Acres	Unknown		OH-4339019E	FRONTIER COMMUNI	12 kV	Conductor	Overhead	Yes	4/7/16	7:43	Contact Between Third Party Facility on Pole and Supply Lines			Unknown	
167	SCE	4/14/16	11:58	34.4460250	-119.7321380	Other	Urban	Less Than .25 Acres	Fire Agency	Santa Barbara City Fire Department	OH-4721910E	FRONTIER COMMUNI	4kV	Conductor	Overhead	Yes	4/14/16	11:58	Contact From Object			Unknown	
168	SCE	4/15/16	8:04	34.2908030	-118.8619000	Vegetation	Urban	Less Than .25 Acres	Self Extinguished		Mount. Sinal Dr and Kuehner Dr		16 kV	Conductor	Overhead	Yes	4/15/16	8:04	Equipment/Facility Failure	Splice/Clamp/Connector		Unknown	
169	SCE	4/15/16	7:12	34.4491640	-119.5844980	Vegetation	Urban	10 - .99 Acres	Fire Agency	LACFD	Northall Ranch Road and Copper Hill Drive in Santa Barbara		16 kV	Conductor	Overhead	Yes	4/15/16	7:12	Contact From Object	Vegetation	Communication Facility	Unknown	
170	SCE	4/16/16	23:14	33.8708166	-118.3824908	Other	Urban	Less Than .25 Acres	Fire Agency	Manhattan Beach Fire Department	OH-1578603E	FRONTIER COMMUNI	16 kV	Conductor	Overhead	Yes	4/16/16	23:14	Contact From Object	Vehicle	Pole	Unknown	
171	SCE	4/18/16	12:23	36.1962630	-119.0639980	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Tulare County Fire Department	OH-4589776E	FRONTIER COMMUNI	12 kV	Conductor	Overhead	Yes	4/18/16	12:23	Contact From Object	Vehicle	Pole	Unknown	
172	SCE	4/20/16	14:06	34.6781850	-118.1257530	Vegetation	Urban	26 - 9.99 Acres	Fire Agency	LACFD	OH-1121181E	FRONTIER COMMUNI	12 kV	Conductor	Overhead	Yes	4/20/16	14:06	Contact From Object	Balloons	Electric Facility	Unknown	
173	SCE	4/21/16	12:20	34.3339270	-119.2748250	Vegetation	Rural	26 - 9.99 Acres	Fire Agency														

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S			T			V	W	X		
																			Utility Name	Fire Start	Latitude	Longitude	Material at Origin	Land Use at Origin				Size	Suppressed by
2	Column#1	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date2	Time3	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes					
230	SCE	10/23/16	9:40	34.4602810	-119.2852650	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Ventura County FD	900 Rice Road Ojai		120/240 V	Conductor	Overhead	No			Equipment/Facility Failure	Conductor			Unknown						
231	SCE	10/26/16	12:19	34.7081290	-118.5367490	Vegetation	Rural	26 - 99 Acres	Fire Agency	LACFD	ELIZABETH LAKE ROAD AND KINGS CANYON R		12 kV	Conductor	Overhead	Yes	10/26/16	12:19	Contact From Object				Unknown						
232	SCE	10/28/16	10:13	34.1020580	-117.8206030	Other	Urban	Less Than .25 Acres	Fire Agency	LACFD	OH-1180540E		120/240 V	Conductor	Overhead	Yes	10/28/16	10:13	Equipment/Facility Failure	Conductor			Unknown						
233	SCE	10/29/16	18:42	34.2149030	-119.1889710	Other	Urban	Less Than .25 Acres	Self Extinguished		940 Huntswood Way, Oxnard		16 kV	Conductor	Overhead	No			Equipment/Facility Failure	Other			Unknown						
234	SCE	11/3/16	22:37	33.7300240	-117.9839590	Other	Urban	Less Than .25 Acres	Fire Agency	Huntington Fire Department	OH-1787899E		12 kV	Conductor	Overhead	Yes	11/3/16	22:37	Contact From Object				Unknown						
235	SCD	11/11/16	4:18	33.6309420	-117.9348070	Other	Urban	Structure Only	Fire Agency	Newport Fire Department	884 Production Pl., Newport Beach		12 kV	Conductor	Overhead	Yes	11/16/16	4:18	Equipment/Facility Failure	Conductor			Unknown						
236	SCE	11/16/16	13:45	33.9196360	-118.0030950	Vegetation	Urban	Less Than .25 Acres	Fire Agency	LACFD	OH-144521E	TIME WARNER CABL	16 kV	Conductor	Overhead	No	11/16/16	13:45	Equipment/Facility Failure	Conductor			Unknown						
237	SCE	11/20/16	11:15	34.1883400	-118.8742520	Vegetation	Rural	Less Than .25 Acres	Self Extinguished		OH-1473501E	TIME WARNER CABL	16 kV	Conductor	Overhead	No			Contact From Object				Unknown						
238	SCE	11/22/16	15:20	36.3134220	-119.1710520	Vegetation	Rural	Less Than .25 Acres	Unknown		1970 North Anderson Road, Exeter		12 kV	Conductor	Overhead	Yes	11/22/16	15:20	Contact From Object				Unknown						
239	SCE	12/11/16	8:54	33.6919790	-117.7031110	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Orange County Fire Authority	OH-2257796E		12 kV	Conductor	Overhead	No			Contact From Object				Unknown						
240	SCE	12/2/16	21:26	34.3812290	-118.4131810	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Orange County Fire Authority	OH-4572770E		66 kV	Conductor	Overhead	No			Contact From Object				Unknown						
241	SCE	12/16/16	19:31	33.8120810	-118.0238250	Building	Urban	Structure Only	Fire Agency	Orange County Fire Authority	10332 Florence Ave., Buena Park		120/240 V	Conductor	Overhead	Yes	12/16/16	19:31	Equipment/Facility Failure	Other			Unknown						
242	SCE	12/19/16	8:18	34.0231980	-117.8529840	Vegetation	Urban	Less Than .25 Acres	Unknown		UG-5048396		12 kV	Conductor	Subsurface	Yes	12/19/16	8:18	Equipment/Facility Failure	Conductor			Unknown						
243	SCE	12/26/16	8:02	34.1675510	-116.1070320	Vegetation	Rural	Less Than .25 Acres	Utility		OH-4803462E		33 kV	Conductor	Overhead	Yes	12/26/16	8:02	Contact From Object				Unknown						
244	SCE	12/30/16	11:42	34.1231260	-118.7229630	Vegetation	Rural	26 - 99 Acres	Fire Agency	LACFD	OH-1927507E	AT&T CALIFORNIA	16 kV	Conductor	Overhead	Yes	12/30/16	11:42	Contact From Object				Unknown						
245	SCE	1/13/17	11:05	33.7610280	-116.6947930	Vegetation	Rural	Less Than .25 Acres	Unknown		OH-2206325	FRONTIER COMMUNI	12kV	Conductor	Overhead	Yes	1/13/17	11:05	Contact From Object				Unknown						
246	SCE	1/14/17	1:21	34.2655510	-118.9950720	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Barstow Fire Department	OH-328443S		12kV	Conductor	Overhead	Yes	1/14/17	1:21	Contact From Object				Unknown						
247	SCE	1/28/17	18:15	33.9900380	-118.3702570	Vegetation	Urban	Less Than .25 Acres	Self Extinguished		OH-X5037878		120/240 V	Conductor	Overhead	Yes	1/28/17	18:15	Equipment/Facility Failure	Conductor			Unknown						
248	SCE	1/31/17	2:10	33.9900380	-118.3702570	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Hesperia FD	PS 522		115 kV	Conductor	Overhead	No			Equipment/Facility Failure	Other			Unknown						
249	SCE	2/8/17	2:20	33.6897030	-117.8527880	Other	Urban	Less Than .25 Acres	Fire Agency	Orange County Fire Authority	OH-1838346E	XO COMMUNICATION	66kV	Conductor	Overhead	Yes	2/8/17	2:20	Unknown				Unknown						
250	SCE	3/10/17	15:46	33.7871030	-117.9122940	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Garden Grove FD	OH-2095620E		12kV	Conductor	Overhead	Yes	3/10/17	15:46	Contact From Object				Unknown						
251	SCE	3/11/17	17:22	34.1284770	-117.2522540	Vegetation	Rural	Less Than .25 Acres	Self Extinguished		OH-4067378E	FRONTIER COMMUNI	12kV	Lightning Arrestor	Overhead	Yes	3/11/17	17:22	Equipment/Facility Failure	Lightning Arrestor			Unknown						
252	SCE	3/13/17	13:42	33.9536060	-118.0666250	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Santa Fe Springs Fire Department	OH-4209839E		12kV	Conductor	Overhead	Yes	3/13/17	13:42	Contact From Object				Unknown						
253	SCE	3/15/17	13:23	34.0534485	-116.9710052	Vegetation	Rural	Less Than .25 Acres	Fire Agency	CalFire	OH-2326555E	FRONTIER COMMUNI	12kV	Conductor	Overhead	Yes	3/15/17	13:23	Contact From Object				Unknown						
254	SCE	3/17/17	17:14	34.5759060	-118.2629170	Vegetation	Rural	Less Than .25 Acres	Fire Agency	LACFD	OH-4493863E		12kV	Conductor	Overhead	Yes	3/17/17	17:14	Contact From Object				Unknown						
255	SCE	3/20/17	14:37	34.8900380	-117.9150329	Vegetation	Rural	Structure Only	Fire Agency	Barstow Fire Department	OH-328443S		12kV	Conductor	Overhead	Yes	3/20/17	14:37	Equipment/Facility Failure				Unknown						
256	SCE	4/9/17	1:51	33.9900380	-118.3702570	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Barstow Fire Department	OH-328443S		12kV	Conductor	Overhead	Yes	4/9/17	1:51	Contact From Object				Unknown						
257	SCE	4/16/17	15:39	34.4556008	-119.2557185	Vegetation	Rural	26 - 99 Acres	Fire Agency	Ventura County FD	OH-4495331E	AT&T CALIFORNIA	16kV	Conductor	Overhead	Yes	4/16/17	15:39	Contact From Object				Unknown						
258	SCE	4/22/17	11:23	35.8628425	-119.2525648	Vegetation	Rural	Structure Only	Self Extinguished		OH-1501428E		12kV	Conductor	Overhead	Yes	4/22/17	11:23	Unknown				Unknown						
259	SCE	4/23/17	16:24	34.5961900	-118.2426980	Vegetation	Rural	26 - 99 Acres	Fire Agency	Palmdale Fire Department	OH-4336106E	AT&T CALIFORNIA	12kV	Conductor	Overhead	Yes	4/23/17	16:24	Unknown				Unknown						
260	SCE	4/28/17	23:15	33.9900380	-118.3702570	Vegetation	Rural	Less Than .25 Acres	Unknown		PS533		16kV	Conductor	Overhead	Yes	4/28/17	23:15	Contact From Object				Unknown						
261	SCE	4/28/17	10:59	33.9266440	-116.6421190	Vegetation	Rural	26 - 99 Acres	Fire Agency	Riverside Fire Department	OH-1905185E		4 kV	Conductor	Overhead	Yes	4/28/17	10:59	Unknown				Unknown						
262	SCE	4/28/17	10:37	36.4356275	-119.1907857	Vegetation	Rural	26 - 99 Acres	Fire Agency	Tulare Fire Department	OH-4600865E	AT&T CALIFORNIA	12kV	Conductor	Overhead	Yes	4/28/17	10:37	Contact From Object				Unknown						
263	SCE	4/29/17	16:08	33.8983710	-117.2207070	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Riverside Fire Department	OH-3129233	FRONTIER COMMUNI	12kV	Conductor	Overhead	Yes	4/29/17	16:08	Equipment/Facility Failure	Conductor			Unknown						
264	SCE	4/29/17	3:17	34.1268230	-118.0734630	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Monrovia Fire Department	OH-695124H	AT&T CALIFORNIA	16kV	Conductor	Overhead	Yes	4/29/17	3:17	Contact From Object	Conductor			Unknown						
265	SCE	5/1/17	20:04	34.1371170	-118.9444480	Vegetation	Rural	Less Than .25 Acres	Fire Agency	LACFD	OH-X30359E	NEXTG NETWORKS,	16kV	Conductor	Overhead	Yes	5/1/17	20:04	Contact From Object				Unknown						
266	SCE	5/1/17	1:51	33.9900380	-118.3702570	Vegetation	Rural	26 - 99 Acres	Fire Agency	CAiFire	OH-1405576E		16kV	Conductor	Overhead	Yes	5/1/17	1:51	Contact From Object				Unknown						
267	SCE	5/3/17	7:01	33.8718439	-118.2882003	Vegetation	Urban	Less Than .25 Acres	Fire Agency	LACFD	OH-X5500253		16kV	Conductor	Overhead	Yes	5/3/17	7:01	Contact From Object				Unknown						
268	SCE	5/3/17	5:40	34.2644820	-118.7690480	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Ventura County FD	OH-1840416E		16kV	Conductor	Overhead	Yes	5/3/17	5:40	Contact From Object				Unknown						
269	SCE	5/11/17	12:27	34.4127010	-118.6702310	Vegetation	Urban	26 - 99 Acres	Fire Agency	LACFD	OH-848255E		16kV	Conductor	Overhead	Yes	5/11/17	12:27	Contact From Object				Unknown						
270	SCE	5/14/17	11:15	33.6416147	-117.1676704	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Riverside Fire Department	OH-2283870E		115 kV	Conductor	Overhead	Yes	5/14/17	11:15	Contact From Object				Unknown						
271	SCE	5/15/17	13:54	35.427678	-118.8050080	Vegetation	Rural	100 - 299 Acres	Fire Agency	CalFire	OH-1840416E	VERIZON WIRELESS	166kV	Conductor	Overhead	No			Contact From Object				Unknown						
272	SCE	5/19/17	17:57	33.8693010	-117.8315319	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Placentia Fire Department	OH-1789272E		12kV	Conductor	Overhead	Yes	5/19/17	17:57	Contact From Object				Unknown						
273	SCE	5/19/17	15:51	33.6443658	-117.8573583	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Newport Fire Department	OH-4248432E		12kV	Conductor	Overhead	Yes	5/19/17	15:51	Contact From Object				Unknown						
274	SCE	5/20/17	17:28	33.7667865	-117.1386210	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Riverside Fire Department	OH-4788465E		12kV	Conductor	Overhead	Yes	5/20/17	17:28	Contact From Object				Unknown						
275	SCE	5/20/17	15:24	33.7816957																									

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X
2	Utility Name	Fire Start		Location Info			Fire Specifics			Utility Facility		Outage Info			Field Observations									
	Column1	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Utility Facility Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date2	Time3	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes
344	SCE	11/11/17	10:32	34.4271160	-119.6440520	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Santa Barbara Fire Department	OH-4255539E	NEXTG NETWORKS,	64 kV	Conductor	Overhead	Yes	11/11/17	10:32:00	Contact From Object		Vegetation	Electric Facility	Unknown	
345	SCE	11/11/17	3:27	34.0044624	-117.6486625	Vegetation	Urban	Less Than .25 Acres	Utility		OH-4019309E		66kV	Conductor	Overhead	No			Contact From Object		Balloons	Electric Facility	Unknown	
346	SCE	11/13/17	13:49	33.7390980	-117.2777800	Vegetation	Rural	Less Than .25 Acres	Unknown		OH-4059962E	FRONTIER COMMUN	12kV	Conductor	Overhead	Yes	11/13/17	13:49	Equipment/Facility Failure	Splice/Clamp/Connector			Unknown	
347	SCE	12/1/17	14:29	33.7614500	-117.2666690	Vegetation	Rural	26 - 9.99 Acres	Unknown		OH-4404592e	FRONTIER COMMUN	12kV	Conductor	Overhead	Yes	12/1/17	14:29	Equipment/Facility Failure	Crossarm			Unknown	
348	SCE	12/5/17	11:38	33.9570100	-117.8613240	Vegetation	Urban	Less Than .25 Acres	Fire Agency	LACFD	OH-788945H	NEXTG NETWORKS,	12kV	Conductor	Overhead	Yes	12/5/17	11:38	Contact From Object		Balloons	Electric Facility	Unknown	
349	SCE	12/21/17	23:40	34.1795290	-118.1337690	Vegetation	Urban	Less Than .25 Acres	Fire Agency	LACFD	OH-4513407E		120/240 V	Conductor	Overhead	Yes	12/21/17	23:40	Contact From Object		Vegetation	Electric Facility	Unknown	