

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X
2	Utility Name	Fire Start		Location Info			Fire Specifics			Facility Identification		Other Companies	Utility Facility	Equipment Involved With Ignition		Type	Outage Info		Field Observations					
	Utility Name	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date2	Time3	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes
112	SDG&E	10/16/17	10:20	33.0697000	-116.8813000	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CALFIRE	P112774 / c236		12kV	Conductor	Overhead	No			Contact From Object			Electric Facility	Other	
113	SDG&E	10/18/17	7:20	33.9932254	-117.1232409	Vegetation	Urban	Less Than 25 Acres	Unknown		P10506 Cr 859		12kV	Conductor	Overhead	No			Contact From Object		Vehicle	Pole	Human Error	
114	SDG&E	10/22/17	10:22	33.0990000	-117.1350000	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Rnch Snta Fe	P250055 Circuit 182		12kV	Conductor	Overhead	Yes	10/22/17	10:22	Contact From Object		Other	Electric Facility	Human Error	
115	SDG&E	10/25/17	13:02	33.2856840	-117.0275340	Vegetation	Rural	Less Than 25 Acres	Fire Agency	CALFIRE	P416197 Circuit 908		12kV	Other	Overhead	No			Equipment/Facility Failure	Other			Weather	
116	SDG&E	12/10/17	2:58	33.2738680	-116.9536750	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CALFIRE	P813516		12kV	Transformer	Overhead	No			Equipment/Facility Failure	Splice/Clamp/Connector			None	
117	SDG&E	12/10/17	5:26	33.2800000	-116.9550000	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CALFIRE	P32240		12kV	Conductor	Overhead	Yes	12/10/17	5:26	Contact From Object		Vegetation	Electric Facility	Weather	