



Clay Faber
Director – Regulatory Affairs
8330 Century Park Court
San Diego, CA 92123-1548

Tel: 858-654-3563
Fax: 858-654-1788
cfaber@semprautilities.com

December 3, 2019

Mr. Leslie Palmer
Director, Safety and Enforcement Division
California Public Utilities Commission
505 Van Ness Avenue
San Francisco, CA 94102

SUBJECT: SAN DIEGO GAS & ELECTRIC COMPANY (SDG&E) PUBLIC SAFETY POWER SHUTOFF REPORT

Dear Mr. Palmer:

In accordance with Ordering Paragraph (OP) 2 of Decision (D) 12-04-024 and Section II.A of CPUC Resolution ESRB-8, and D.19-05-042, SDG&E is submitting this report in response to the Public Safety Power Shutoff (PSPS) event that occurred in SDG&E's service territory on November 17–18, 2019. As noted in the reporting requirements, this report has been verified by an SDG&E officer in accordance with Rule 1.11 of the Commission's Rules of Practice and Procedure.

In accordance with D.19-05-042, this report has also been distributed to the service lists for the following CPUC Rulemaking (R.) Proceedings: R.18-10-007 and R.18-12-005.

If you have any questions regarding this report, please contact Elizabeth Beaver at 858-654-1787, or ebeaver@sdge.com.

Sincerely,

/s/ Clay Faber
Clay Faber
Director—Regulatory Affairs

Attachment

SDG&E Report on Public Safety Power Shutoff Event: November 17–18, 2019

The following report is submitted in response to the Public Safety Power Shutoff (PSPS) events that occurred in SDG&E's service territory from November 17 through November 18, 2019. SDG&E hereby submits this report to the Director of Safety and Enforcement Division (SED) and the service lists for CPUC Rulemaking (R.) proceedings R.18-12-005 and R.18-10-007. This report includes all information required pursuant to D.12-04-024, Section II.A of CPUC Resolution ESRB-8 and D.19-05-042.

1. An explanation of SDG&E's decision to de-energize, including an explanation of alternatives considered and mitigation measures used to decrease the risk of utility-caused wildfires in de-energized areas

Response:

The decision to de-energize for public safety was made at SDG&E's Emergency Operations Center (EOC), which was fully staffed by a cross-functional team of electric operations, customer service, safety, engineering, external affairs, communications and other personnel, as well as a designated Utility Commander (UC) for the incident. SDG&E activated its EOC to provide response coordination, ensure there was informed decision-making, coordinate customer, agency and elected official notifications, and coordinate as-needed logistical support.

Based on advanced weather forecasts from SDG&E Meteorologists, weather conditions that could warrant initiating Public Safety Power Shutoffs (PSPS) were expected to occur in a very small portion of the region starting on Sunday, November 17, with potential impacts to fewer than 50 customers in unincorporated areas of Descanso. Forecasts in fire-prone communities of far eastern and northern parts of San Diego County included wind gusts of 25–35 mph, with isolated gusts up to 40 mph.

As forecast conditions were refined in the hours approaching the event, the National Weather Service (NWS) made the decision on the morning of Saturday, November 16, to issue a Red Flag Warning (RFW) to go into effect about 15 hours later, at 0100 on Sunday, November 17. The issuance of the RFW was not initially anticipated for this weather event. SDG&E's EOC was activated on Sunday, November 17, 2019 at 0000 to respond to the Santa Ana weather conditions and RFW weather event in effect 0100–1800 on November 17.

Official NWS forecasts included the potential for wind gusts of 40–50 mph in wind-prone areas of San Diego County. SDG&E Meteorologists' forecasts were similar, predicting widespread wind gusts of 25–35 mph across the backcountry, with isolated higher gusts in the most wind-prone locations. The Red Flag Warning, in combination with available data including vegetation moisture levels and weather conditions, indicated a threat of large and destructive wildfires with moderate to rapid rates of spread and long-range spotting, should an ignition occur in isolated windy locations. SDG&E determined that conditions warranted de-energizing certain facilities which might otherwise provide a source of ignition of a fire.

Based on weather forecasts for increasing winds, extremely low humidity levels and elevated fire danger, as well as real-time observations of weather conditions, de-energizations were the best method to mitigate the risk of potential utility-caused wildfires. SDG&E strategically placed field observers in the areas expected to experience the most severe weather. These observers monitored SDG&E's overhead power lines as well as the local weather in order to ensure PSPS was implemented only when necessitated.

SDG&E Report on Public Safety Power Shutoff Event: November 17–18, 2019

In order to mitigate the risk of a utility-caused wildfire, SDG&E disabled automatic reclosing devices in these areas during the event. Additionally, SDG&E canceled all non-essential maintenance work in fire-prone areas. SDG&E pre-staged resources, including contract firefighters and field personnel to coordinate response to an emergency, if needed.

SDG&E Report on Public Safety Power Shutoff Event: November 17–18, 2019

2. All factors considered by SDG&E in its decision to de-energize, including wind speed, temperature, humidity and vegetation moisture in the vicinity of the de-energized circuits.

Response:

The decision to de-energize for public safety is not based on a single factor; numerous criteria are considered when making this decision.

Key bases for these decisions included, but were not limited to:

- The RFW issued by the NWS indicated that the combination of strong winds and low relative humidity may result in conditions favorable for extreme fire behavior;
- The localized nature of the weather event and the use of sectionalizing devices would significantly reduce the number of customers impacted by PSPS;
- The potential existed for isolated wind gusts exceeding 40 mph in the San Diego County mountains;
- The Santa Ana Wildfire Threat Index (SAWTI) was rated Moderate (“Upon ignition, fires will grow rapidly and will be difficult to control”);
- The National Oceanic and Atmospheric Administration’s (NOAA) Storm Prediction Center’s Fire Weather Outlook indicated “Critical Fire Weather” conditions for portions of the SDG&E service territory;
- SDG&E’s Fire Potential Index (FPI) was at the highest end of Elevated for inland districts, indicating the potential for large fires should an ignition occur;
- Live Fuel Moisture values were critically dry (~60%) and Dead Fuel Moisture values were low (5%);
- Recorded wind gusts along the de-energized circuit were in excess of 40 mph, in combination with humidity near 15%;
- Wind climatology of each circuit or circuit segment to include the 95th and 99th percentile winds from nearly 10 years of collecting weather data every 10 minutes from every station;
- Infrastructure in temporary configurations due to construction activities;
- Observer reports of imminent threats to power lines, including tree branches encroaching overhead lines, wire movement, debris blown into lines;
- Fire-suppression air resources were potentially unavailable due to high winds and time of day should an ignition occur;
- Accessibility could be constrained should an ignition occur;
- The outages could be targeted to minimize impacts to customers; and
- A review of active outages on SDG&E’s system.

SDG&E Report on Public Safety Power Shutoff Event: November 17–18, 2019

3. An explanation of how the utility determined that the benefit of de-energization outweighed potential public safety risks

Response:

At the time of de-energization, the area impacted by the PSPS was experiencing wind gusts over 50 mph, warm temperatures and relative humidity levels of 17%. Based on weather forecasts at that time, winds were expected to strengthen through the mid-morning hours of November 17. Based on this, SDG&E determined initiating PSPS in this area was the best method to mitigate the risk of a fast-spreading wildfire.

The RFW and increased winds, in combination with available data including vegetation moisture levels and weather conditions, indicated a threat of large and destructive wildfires with rapid rates of spread and long-range spotting, should an ignition occur. SDG&E determined that conditions warranted de-energizing certain facilities which might otherwise provide a source of ignition of a fire.

SDG&E Report on Public Safety Power Shutoff Event: November 17–18, 2019

4. The time, place and duration of the event and whether the areas affected by the de-energization are classified as Zone 1, Tier 2, or Tier 3 per the definition in General Order 95, Rule 21.2-D.

Response:

Circuit/ Device	Communities	Start Date/Time	Restoration Date/Time	Duration	GO 95, Rule 21.2D Classification
79-799R	Viejas, West Descanso, Boulder Creek	11/17/19 5:01	11/17/19 13:35	08:34	Tier 3
F2280111	Viejas, West Descanso, Boulder Creek	11/17/19 5:01	11/18/19 8:42	27:41	Tier 3
TL626	Santa Ysabel, Wynola, Pine Hills	11/17/19 5:07	11/17/19 15:53	10:45	Tier 3

SDG&E Report on Public Safety Power Shutoff Event: November 17–18, 2019

5. Describe how sectionalization was considered/ implemented and the extent to which it impacted the size and scope of the de-energization event

Response:

SDG&E was able to implement sectionalization during this PSPS event to reduce customer impacts. SDG&E de-energized portions of circuit 79-799R during this event, as opposed to the entire circuit. By de-energizing only portions of this circuit, customer impacts of this PSPS event were reduced by 803.

SDG&E also used sectionalizing devices to send warning messages and notifications of potential PSPS impacts to specific, more precise customer groups.

SDG&E Report on Public Safety Power Shutoff Event: November 17–18, 2019

6. The number of affected customers, broken down by residential, medical baseline, commercial/industrial and other.

Response:

Circuit/ Device	Total # Impacted Customers	Residential	Commercial/ Industrial	Medical Baseline	Other
79-799R	18	13	5	2	0
F2280111	1	0	1	0	0
TL626	2	1	1	0	0
Total	21	14	7	2	0

SDG&E Report on Public Safety Power Shutoff Event: November 17–18, 2019

- 7. Describe any wind-related damage to SDG&E's overhead powerline facilities in the areas where power was shutoff.**

Response:

There was no wind related damage in the areas where power was shut off during this event.

SDG&E Report on Public Safety Power Shutoff Event: November 17–18, 2019

8. Provide a description of the customer notice and any other mitigation provided by SDG&E. Include a copy of all notifications, the timing of notifications, the methods of notifications and who (IOU or public safety partner) made the notification. If SDG&E failed to provide notifications according to the timelines set forth in the CPUC PSPS Guidelines (see D.19-05-042), include an explanation of the circumstances that resulted in such failure.

Response:

- a. SDG&E proactively notified customers in areas that would potentially be impacted by PSPS. Notifications were made via outbound dialer, email and personal phone calls. Helpful information was also shared on SDG&E’s websites (SDGEnews.com and SDGE.com), SDG&E’s social media channels (Twitter, Facebook, Instagram) and with local, state and national news media outlets.
- b. For customers’ whose power was turned off overnight, SDG&E did not provide notification in the 1–4-hours prior. This notification was not made in order to prevent waking up customers in the middle of the night.
- c. Due to an omission on the preliminary circuit forecast, SDG&E failed to provide notifications according to the timelines set forth in the CPUC PSPS Guidelines for customers served by one device. The device serves one customer with two meters (one residential and one commercial). This customer was shutoff on Sunday, November 17 at approximately 2:00, without advanced notification. SDG&E contacted this customer on November 17 at 8:56 to explain why they were shutoff and to answer any questions. All communication to this customer was handled by SDG&E’s Customer Contact Center. See below for details:

Circuit/ Device	Total Customers	Residential	Commercial /Industrial	Medical Baseline	Critical Facilities
TL626	2	1	1	0	0

See Appendix 1 for details of notifications to customers
See Appendix 2 for details of notifications to Public Safety and Community Partners
See Appendix 3 for details of notifications to the CPUC
See Appendix 4 for details of notifications to Government Officials/Representatives
See Appendix 5 for details of notifications to Cal OES

SDG&E Report on Public Safety Power Shutoff Event: November 17–18, 2019

- 9. For those customers where positive or affirmative notification was attempted, an accounting of the customers (which tariff and/or access and functional needs population designation), the number of notification attempts made, the timing of attempts, who made the notification attempt (utility or public safety partner) and the number of customers for whom positive notification was achieved**

Response:

Please see Appendix 1 for detailed information regarding customer notifications. The notifications were made by SDG&E. Affirmative notifications were made by SDG&E to all affected medical baseline customers.

SDG&E Report on Public Safety Power Shutoff Event: November 17–18, 2019

- 10. The address of each community assistance location during a de-energization event, describe the location (building, trailer, etc.), describe the assistance available at each location, and the days and hours it was open.**

Response:

SDG&E did not open any Community Resource Centers during this event.

SDG&E Report on Public Safety Power Shutoff Event: November 17–18, 2019

11. A description and evaluation of engagement with local and state public safety partners in providing advanced outreach/notification during the PSPS event

Response:

SDG&E communicated with local and state public safety partners and jurisdictions as outlined in Appendix 2. During the event SDG&E did not receive any calls or emails from public safety partners or jurisdictions seeking additional information during this event.

SDG&E Report on Public Safety Power Shutoff Event: November 17–18, 2019

12. The local communities’ representatives SDG&E contacted prior to de-energization and the date on which they were contacted.

Response:

Please see below for details regarding notifications made to Public Safety Partners and Community Partners prior to de-energization:

Organization/Jurisdiction	Title	Date
San Diego County OES	Duty Officer	11/16/19
San Diego County Sheriff Dispatch	Supervisor	11/16/19
Monte Vista Fire Dispatch	Supervisor	11/16/19
Heartland Fire Dispatch	Supervisor	11/16/19
San Diego Fire Dispatch	Supervisor	11/16/19
NorthComm Fire Dispatch	Supervisor	11/16/19
2-1-1 San Diego	Crisis Communications Director 2	11/16/19
2-1-1 San Diego	VP of Community & Govt. Relations	11/16/19
2-1-1 San Diego	Duty Officer	11/16/19
American Red Cross	Regional Disaster Office	11/16/19
American Red Cross	Disaster Program Manager	11/16/19
American Red Cross	Regional Planning & Recovery Manager	11/16/19
County of San Diego	Vice Chair County Board of Supervisors	11/16/19
County of San Diego	Chief of Staff	11/16/19
County of San Diego	CAO	11/16/19
County of San Diego	Public Works	11/16/19
County of San Diego	Media & Public Relations	11/16/19
County of San Diego & Orange	T-Mobile	11/16/19
County of San Diego & Orange	AT&T	11/16/19
County of San Diego & Orange	AT&T - Director, Regulatory Affairs	11/16/19
County of San Diego & Orange	AT&T - Director, External Affairs	11/16/19
County of San Diego & Orange	AT&T - Director of External Affairs	11/16/19
County of San Diego & Orange	AT&T	11/16/19
County of San Diego & Orange	AT&T	11/16/19
County of San Diego & Orange	AT&T	11/16/19
County of San Diego & Orange	AT&T	11/16/19
County of San Diego & Orange	AT&T	11/16/19
County of San Diego & Orange	AT&T	11/16/19
County of San Diego & Orange	Verizon Wireless	11/16/19
County of San Diego & Orange	Verizon Wireless	11/16/19
Federal Legislator	Congressman	11/16/19
Federal Legislator	District Chief of Staff	11/16/19
Federal Legislator	Field Representative	11/16/19
State Legislator	Assemblymember	11/16/19
State Legislator	State Senator	11/16/19
State Legislator	State Senate District Director	11/16/19
State Legislator	Field Representative	11/16/19
State Legislator	Chief of Staff	11/16/19
San Diego County OES	Duty Officer	11/17/19

SDG&E Report on Public Safety Power Shutoff Event: November 17–18, 2019

Organization/Jurisdiction	Title	Date
San Diego County Sheriff Dispatch	Supervisor	11/17/19
Monte Vista Fire Dispatch	Supervisor	11/17/19
Heartland Fire Dispatch	Supervisor	11/17/19
San Diego Fire Dispatch	Supervisor	11/17/19
NorthComm Fire Dispatch	Supervisor	11/17/19
2-1-1 San Diego	Crisis Communications Director 2	11/17/19
2-1-1 San Diego	VP of Community & Govt. Relations	11/17/19
2-1-1 San Diego	Duty Officer	11/17/19
American Red Cross	Regional Disaster Office	11/17/19
American Red Cross	Disaster Program Manager	11/17/19
American Red Cross	Regional Planning & Recovery Manager	11/17/19
County of San Diego	Vice Chair County Board of Supervisors	11/17/19
County of San Diego	Chief of Staff	11/17/19
County of San Diego	CAO	11/17/19
County of San Diego	Public Works	11/17/19
County of San Diego	Media & Public Relations	11/17/19
County of San Diego & Orange	T-Mobile	11/17/19
County of San Diego & Orange	AT&T	11/17/19
County of San Diego & Orange	AT&T - Director, Regulatory Affairs	11/17/19
County of San Diego & Orange	AT&T - Director, External Affairs	11/17/19
County of San Diego & Orange	AT&T - Director of External Affairs	11/17/19
County of San Diego & Orange	AT&T	11/17/19
County of San Diego & Orange	AT&T	11/17/19
County of San Diego & Orange	AT&T	11/17/19
County of San Diego & Orange	AT&T	11/17/19
County of San Diego & Orange	AT&T	11/17/19
County of San Diego & Orange	AT&T	11/17/19
County of San Diego & Orange	AT&T	11/17/19
County of San Diego & Orange	Verizon Wireless	11/17/19
County of San Diego & Orange	Verizon Wireless	11/17/19
Federal Legislator	Congressman	11/17/19
Federal Legislator	District Chief of Staff	11/17/19
Federal Legislator	Field Representative	11/17/19
State Legislator	Assemblymember	11/17/19
State Legislator	State Senator	11/17/19
State Legislator	State Senate District Director	11/17/19
State Legislator	Field Representative	11/17/19
State Legislator	Chief of Staff	11/17/19
San Diego County OES	Duty Officer	11/18/19
San Diego County Sheriff Dispatch	Supervisor	11/18/19
Monte Vista Fire Dispatch	Supervisor	11/18/19

SDG&E Report on Public Safety Power Shutoff Event: November 17–18, 2019

Organization/Jurisdiction	Title	Date
Heartland Fire Dispatch	Supervisor	11/18/19
San Diego Fire Dispatch	Supervisor	11/18/19
NorthComm Fire Dispatch	Supervisor	11/18/19
2-1-1 San Diego	Crisis Communications Director 2	11/18/19
2-1-1 San Diego	VP of Community & Govt. Relations	11/18/19
2-1-1 San Diego	Duty Officer	11/18/19
American Red Cross	Regional Disaster Office	11/18/19
American Red Cross	Disaster Program Manager	11/18/19
American Red Cross	Regional Planning & Recovery Manager	11/18/19
County of San Diego	Vice Chair County Board of Supervisors	11/18/19
County of San Diego	Chief of Staff	11/18/19
County of San Diego	CAO	11/18/19
County of San Diego	Public Works	11/18/19
County of San Diego	Media & Public Relations	11/18/19
County of San Diego & Orange	T-Mobile	11/18/19
County of San Diego & Orange	AT&T	11/18/19
County of San Diego & Orange	AT&T - Director, Regulatory Affairs	11/18/19
County of San Diego & Orange	AT&T - Director, External Affairs	11/18/19
County of San Diego & Orange	AT&T - Director of External Affairs	11/18/19
County of San Diego & Orange	AT&T	11/18/19
County of San Diego & Orange	AT&T	11/18/19
County of San Diego & Orange	AT&T	11/18/19
County of San Diego & Orange	AT&T	11/18/19
County of San Diego & Orange	AT&T	11/18/19
County of San Diego & Orange	AT&T	11/18/19
County of San Diego & Orange	AT&T	11/18/19
County of San Diego & Orange	Verizon Wireless	11/18/19
County of San Diego & Orange	Verizon Wireless	11/18/19
Federal Legislator	Congressman	11/18/19
Federal Legislator	District Chief of Staff	11/18/19
Federal Legislator	Field Representative	11/18/19
State Legislator	Assemblymember	11/18/19
State Legislator	State Senator	11/18/19
State Legislator	State Senate District Director	11/18/19
State Legislator	Field Representative	11/18/19
State Legislator	Chief of Staff	11/18/19

See Appendix 2 for details of notifications to Public Safety and Community Partners

SDG&E Report on Public Safety Power Shutoff Event: November 17–18, 2019

13. Summarize the number and nature of complaints received as a result of the de-energization event and include claims that are filed against SDG&E because of the de-energization.

Response:

As of December 3, SDG&E has received five complaints related to the November 17–18 PSPS event. All five of these complaints were forwarded to SDG&E by the San Diego County Supervisor’s office. Please see below for details regarding the complaints:

#	Brief Description	Resolution Steps	Date Received
1	Customer voiced concern that power was interrupted due to safety while Sunrise Powerlink remained energized. Customer states PSPS is a stunt manufactured by utility to garner support from the media.	Attempted to contact customer via phone; left voicemail.	11/20/19
2	Customer suggests that utility should provide affected customers with vouchers to purchase generators and battery powered uninterruptible power source.	Attempted to contact customer via phone; left voicemail.	11/22/19
3	Customer is concerned with the welfare of the elderly and those with medical conditions, stating many customers rely on electricity for medical equipment and air conditioning.	Customer was contacted and again expressed concerns for her neighbors stating some did not receive notification before the PSPS. SDG&E advised the customer that this information would be sent to communications group.	11/22/19
4	Customer concerned that he is unable to use medical equipment during outage. Customer states in October they were without power for 80 hours, unable to charge phones and lost food.	Customer was contacted and requested to correspond by email instead of over the phone. A follow-up email was sent to address customer concerns.	11/22/19
5	Claims due to outages, more residents are using gas powered generators which are very noisy and affecting the air quality.	Customer contacted via phone with follow-up mailing of information regarding PSPS.	11/25/19

As of December 3, SDG&E has received 84 claims related to the PSPS events that took place November 17–18:

- 14 claims: Property damage
- 0 claims: Solar related
- 53 claims: Food loss
- 9 claims: Inconvenience of being without power
- 3 claims: Business loss
- 5 claims: Hotel stays

SDG&E Report on Public Safety Power Shutoff Event: November 17–18, 2019

14. Provide detailed timeline and description of the steps taken to restore power.

Response:

SDG&E considers and implements the following steps to restore power:

- a. Meteorology forecasted wind gusts have peaked and are trending downward;
- b. Real-time observer reports confirming no impacts to system, no debris and no vegetation impacts;
- c. Full patrol of the de-energized distribution circuit or transmission tie-line to inspect for damages;
- d. Electric Troubleshooter, observers and/or line crews on-site during re-energization process at key locations;
- e. Contract Fire-Fighting Resources on-site during re-energization process;
- f. Check and ensure all personnel are in the clear before re-energization;
- g. Approval by OIC, Deputy Ops, and Field Utility Commander to restore device/circuit/tie-line; and
- h. Electric Distribution Operations/Electric Grid Operations notifies EOC of time reenergization was completed.

SDG&E Report on Public Safety Power Shutoff Event: November 17–18, 2019

15. Lessons learned by SDG&E from the PSPS event.

Response:

With the exception of the unanticipated declaration of a Red Flag Warning by the NWS, the localized nature of this event required minimal staffing in SDG&E's EOC, and the process followed standard protocols.

SDG&E Report on Public Safety Power Shutoff Event: November 17–18, 2019

16. Recommended updates/modifications the PSPS guidelines adopted in ESRB-8 and D.19-05-042

Response:

This was SDG&E's third PSPS event utilizing the de-energization guidelines from D.19-05-42. SDG&E's recommendations based on these initial experiences implementing PSPS under the new guidelines are as follows:

1. Critical facilities should be clearly defined. Today this definition is overly broad and captures facilities that would not cause public harm if de-energization occurred;
2. Explore an "opt-out" option process for customer segments that the utilities are required to communicate with who do not wish to receive communication. SDG&E has already been asked about an "opt out" option from certain Public Safety Partners.
3. The required eight languages (English, Spanish, Mandarin, Cantonese, Tagalog, Vietnamese, Korean, and Russian) do not adequately reflect the demographics of SDG&E's community. SDG&E recommends the language requirement be modified to align with the San Diego County and Orange County Registrar of Voters language requirements (English, Spanish, Chinese, Vietnamese, Tagalog, and Korean), which would ensure SDG&E's notifications mirror the non-English/limited English populations within its service territory.

SDG&E Report on Public Safety Power Shutoff Event: November 17–18, 2019

17. Include any other matters that SDG&E believes are relevant to the Commission’s assessment of the reasonableness of SDG&E’s decision to de-energize.

Response:

At the times SDG&E implemented PSPS throughout this event, weather conditions included high winds, relatively low humidity and warm temperatures. These conditions, combined with relatively dry vegetation, could have resulted in a widespread wildfire, had an ignition occurred.


The available data supported an extreme threat of large and destructive wildfires with rapid rates of spread and long-range spotting, should an ignition occur. Based on the weather forecasts, as well as real-time observations of weather conditions and reports from field observers, de-energizations were determined to be the best method to mitigate the risk of potential utility-caused wildfires.

SDG&E Report on Public Safety Power Shutoff Event: November 17–18, 2019

VERIFICATION

I am an officer of the applicant corporation herein, and am authorized to make this verification on its behalf. I am informed and believe that the matters stated in the foregoing document are true.

I declare under penalty of perjury that the foregoing is true and correct. Executed this 3rd day of December 2019, at San Diego, California.



John D. Jenkins
Vice President, Electric System Operations
San Diego Gas & Electric Company

Appendix 1
Customer Communications: Dates, Times and Type

SDG&E Report on Public Safety Power Shutoff Event: November 17–18, 2019

Overview of Communications by Method

Method	Total # Notifications	Source
Cell phone	10	SDG&E
Email	34	SDG&E
Landline/Home phone	16	SDG&E
		Total: 60*

***The total number of notifications does not represent unique customers. Some customers may have received notifications through multiple channels**

**Advanced Notifications
Detailed Communications**

Message	Date	Time of First Call	Home	Cell	Email
M2: 24–48 hours prior	11/16/19	12:53	5	4	11
M12: Patrols for restoration	11/17/19	12:11	5	2	13
M15: Power Restored	11/17/19	14:30	6	4	10

Message Glossary

Message	Content
M2: 24–48 hours prior; PSPS possible	Alert: Forecasted weather conditions could affect the power lines that serve your community. We are currently monitoring the potential for adverse weather conditions to begin within 24 hours. These conditions may require us to turn off the power for public safety in your community. If you do experience an outage, the power will stay off until we can safely restore it. Please be prepared to activate your personal family emergency plan. For more information, visit SDGE.com/Ready
M12: Patrols for restoration started	Conditions have improved, and SDG&E crews have begun patrolling power lines to determine when power can be restored to affected communities. Please be aware that some inspections could take place on your property. For up-to-date information on outages and restoration times, visit SDGE.com/Outages , check our mobile app, or follow us on Twitter.
M15: Power restored	Your power should now be fully restored. If the power is still out, please call us at 800-411-7343. Visit SDGENews.com for up-to-date information. We appreciate your cooperation during this time of adverse weather conditions.

Appendix 2
Public Safety and Community Partner Communications: Dates, Times and Type

SDG&E Report on De-Energization Events: November 17–18, 2019

The below table includes notifications sent to the following entities: San Diego County OES, San Diego County Sheriff Dispatch, Monte Vista Fire Dispatch, Heartland Fire Dispatch, San Diego Fire Dispatch, North County (NorthComm) Fire Dispatch

Timing/ General Content	Date/ Time	Method	Source	Content
Initial	11/16/19 11:11	Email	SDG&E Liaison Officer	<p>This is an important safety message from SDG&E. Forecasted weather conditions could affect the power lines that serve local communities. In response, SDG&E may activate its Emergency Operations Center to monitor adverse weather conditions throughout the duration of the event. These conditions may require us to turn off the power for public safety. The following communities that could be impacted include: unincorporated Descanso.</p> <p>The estimated start time of event is early Sunday morning. We anticipate that under these conditions, the event could last throughout the day with full restoration estimated around 6:00 p.m. Sunday. We estimate 2 Medical Baseline (MBL) customers reside in impacted areas. If you have obtained geographic information systems (GIS) data access from SDG&E, you will be able to receive GIS data via secure data transfer. If you have not set up access or have problems accessing this link, please see SDGE.com/Outages.</p> <p>The following contacts are available if you need additional information, SDGELiaisonOfficerNotifications@semprautilities.com or 858-503-5450, or Emergency Management Duty Officer eseodsge@semprautilities.com or 858-503-5450. Please do not forward this contact information beyond your government or public safety teams.</p> <p>If residents have questions, please have them call 1-800-411-7343 for more information and visit our website to update account information.</p> <p>We will send another notification when conditions change or if we turn off power for safety. For more information, please visit SDGE.com/Ready.</p>

SDG&E Report on De-Energization Events: November 17–18, 2019

Timing/ General Content	Date/ Time	Method	Source	Content
PSPS Initiated	11/17/19 5:35	Email	SDG&E Liaison Officer	<p>This is an important safety message from SDG&E.</p> <p>Due to adverse weather conditions affecting power lines, the power has been turned off for public safety in impacted communities. The following communities that could be impacted include: unincorporated Descanso. We estimate 21 total customers, including 2 Medical Baseline (MBL) customers, reside in impacted area. The National Weather Service has indicated that the current Red Flag Warning is set to expire at 6:00pm on Sunday, November 17, 2019. When conditions improve, our crews will assess the safety of the electrical system and determine when power can be restored. For location details and updated information on outages and restoration times, visit SDGE.com/Outages, check our mobile app, or follow us on Twitter.</p> <p>As a public safety partner, the following contacts are available to you if you need additional information, SDGELiaisonOfficerNotifications@semprautilities.com or 858-503-5450 or Emergency Management Duty Officer eseodsge@semprautilities.com or 858-503-5450. Please do not forward this contact information beyond your government or public safety teams. If residents have questions, please have them call 1-800-411-7343 for more information and visit our website to update account information.</p> <p>Thank you for your understanding while we work together to keep our communities safe.</p>
Restoration Efforts Started	11/17/19 12:02	Email	SDG&E Liaison Officer	<p>This is an important safety message from SDG&E. Conditions have improved, and SDG&E crews have begun patrolling power lines to determine when power can be restored to affected communities including unincorporated Descanso. For up-to-date information on outages and restoration times, visit sdge.com/outages, check our mobile app, or follow us on Twitter.</p> <p>As a public safety partner, the following contacts are available to you if you need additional information, SDGELiaisonOfficerNotifications@semprautilities.com or 858-503-5450 or Emergency Management Duty Officer eseodsge@semprautilities.com or 858-503-5450. Please do not forward this contact information beyond your government or public safety teams.</p> <p>If residents have questions, please have them call 1-800-411-7343 for more information and visit our website to update account information.</p> <p>Thank you for your understanding while we work together to keep our communities safe.</p>

SDG&E Report on De-Energization Events: November 17–18, 2019

Timing/ General Content	Date/ Time	Method	Source	Content
Restoration Update	11/17/19 14:17	Email	SDG&E Liaison Officer	<p>Our crews have restored power to a portion of unincorporated Descanso resulting in the restoration of approximately 18 customers, including two Medical Baseline customers, as a result of our proactive patrols. Our crews are continuing their efforts to restore service to the remaining customers.</p> <p>For up-to-date information on outages and restoration times, visit SDGE.com/Outages, check our mobile app, or follow us on Twitter. We appreciate your cooperation during this time of extreme weather conditions.</p> <p>As a public safety partner the following contacts are available to you if you need additional information, SDGELiaisonOfficerNotifications@semprautilities.com or 858-503-5450 or Emergency Management Duty Officer eseodsdge@semprautilities.com or 858-503-5450. Please do not forward this contact information beyond your government or public safety teams.</p> <p>If residents have questions, please have them call 1-800-411-7343 for more information and visit our website to update account information.</p> <p>Thank you for your patience while we work together to keep our communities safe.</p>

SDG&E Report on De-Energization Events: November 17–18, 2019

Timing/ General Content	Date/ Time	Method	Source	Content
Restoration Update	11/17/19 15:59	Email	SDG&E Liaison Officer	<p>Our crews have restored power to certain areas of the unincorporated Descanso resulting in the restoration of approximately 20 customers, as a result of our proactive patrols. One non-critical communications facility will remain out overnight and we will begin our aerial patrol at 7:00am in the morning.</p> <p>For up-to-date information on outages and restoration times, visit SDGE.com/Outages, check our mobile app, or follow us on Twitter. We appreciate your cooperation during this time of extreme weather conditions.</p> <p>As a public safety partner the following contacts are available to you if you need additional information, SDGELiaisonOfficerNotifications@semprautilities.com or 858-503-5450 or Emergency Management Duty Officer eseodsdge@semprautilities.com or 858-503-5450. Please do not forward this contact information beyond your government or public safety teams.</p> <p>If residents have questions, please have them call 1-800-411-7343 for more information and visit our website to update account information.</p> <p>Thank you for your patience while we work together to keep our communities safe.</p>
Restoration	11/18/19 09:01	Email	SDG&E Liaison Officer	<p>This is an important safety message from SDG&E.</p> <p>Final notification: Adverse weather conditions have passed and service has been restored to all customers. The Public Safety Power Shutoff event has concluded and SDG&E's Emergency Operations Center has de-activated. For more information, visit sdgenews.com.</p> <p>We appreciate your cooperation during this time of adverse weather conditions.</p>

Appendix 3
CPUC Notifications: Dates, Times and Type

SDG&E Report on De-Energization Events: November 17–18, 2019

The below table includes notifications sent to the following CPUC contacts: ESRB Compliance Filings, Lee Palmer, Elizaveta Malashenko, Anthony Noll, Charlotte Terkeurst, Fadi Daye, James Miller, Kristin Ralff Douglas, Saul Gomez

Notification Type	Date/Time	Method	Source	Content
Initial	11/16/19 11:11	Email	SDG&E Regulatory Affairs	<p>Hello,</p> <p>Today, the National Weather Service issued a Red Flag Warning for portions of the SDG&E service territory. As a result, SDG&E initiated Public Safety Power Shutoff (PSPS) protocols based on Santa Ana weather conditions forecasted to impact San Diego County and Orange County starting in the late in the evening on Saturday, November 16, 2019. SDG&E has not yet activated its Emergency Operations Center (EOC). SDG&E's EOC staff will remain in a monitoring and planning mode until further notice.</p> <p>At this time, SDG&E is analyzing the latest available data and may provide advanced notification to potentially impacted customers starting this afternoon, November 16.</p> <p>Weather event details</p> <ul style="list-style-type: none"> • Santa Ana weather conditions are impacting the SDG&E's service area and are expecting to peak on Sunday, November 17. Winds are expected to gradually decrease by Sunday evening. • Additional information including possibly impacted areas/communities will be provided in our next notification. • Fire Potential Index (FPI) on Sunday is expected to be elevated in portions of San Diego County. <p>Thank you, SDG&E Regulatory Affairs</p>

SDG&E Report on De-Energization Events: November 17–18, 2019

Notification Type	Date/Time	Method	Source	Content
Secondary (prior to PSPS)	11/16/19 14:26	Email	SDG&E Regulatory Affairs	<p>Good afternoon,</p> <p>SDG&E plans to activate its EOC at midnight tonight. We provided advanced notification today, November 16, to 19 customers—including 2 Medical Baseline (MBL) customers—in the following community: unincorporated area of Descanso.</p> <p>Unless there are changes requiring immediate notification, we will provide another general update later tomorrow, Sunday, November 17.</p> <p>Thank you, SDG&E Regulatory Affairs</p>
PSPS initiated	11/17/19 5:20	Email	SDG&E Regulatory Affairs	<p>Good morning,</p> <p>SDG&E has initiated Public Safety Power Shutoffs (PSPS) in areas of San Diego County due to Santa Ana conditions and a Red Flag Warning in effect in the region.</p> <p>Please see the attached spreadsheet on PSPS-related outages. As of 05:15 hours, there are 21 customers, including 2 medical baseline customers, impacted by PSPS in the unincorporated area of Descanso. Please note, estimated restoration times are subject to change based on field patrol observations and weather conditions.</p> <p>Additional information, including maps with PSPS boundaries, is available at SDGE.com.</p> <p>Thank you, SDG&E Regulatory Affairs</p>

SDG&E Report on De-Energization Events: November 17–18, 2019

Notification Type	Date/Time	Method	Source	Content
Restoration Efforts Started	11/17/19 12:09	Email	SDG&E Regulatory Affairs	<p>Good afternoon,</p> <p>SDG&E is starting to patrol de-energized lines for customers impacted by this PSPS event.</p> <p>We will provide another update at the time of full restoration or at the end of the next operating period at 6pm today, whichever is earliest.</p> <p>Thank you, SDG&E Regulatory Affairs</p>
Restoration Status	11/17/19 16:21	Email	SDG&E Regulatory Affairs	<p>Good evening,</p> <p>SDG&E has restored service to 20 of 21 customers, including all medical baseline customers, impacted by this PSPS event as of 15:54. The remaining customer without power is a non-critical communications facility in the vicinity of Mt. Cuyamaca. Due to high winds and impending darkness, a helicopter was unable to inspect the related section of line for damage, which is a critical step in the restoration process. This inspection is expected to occur tomorrow morning. The remaining customer has been notified and has operable backup generation.</p> <p>SDG&E is de-escalating its Emergency Operations Center to Level 4 – Monitoring. Next update is expected to occur around 10 a.m. tomorrow (Monday, November 18).</p> <p>Thank you, SDG&E Regulatory Affairs</p>

SDG&E Report on De-Energization Events: November 17–18, 2019

Notification Type	Date/ Time	Method	Source	Content
Restoration Complete	11/18/19 9:17	Email	SDG&E Regulatory Affairs	<p>Good morning,</p> <p>SDG&E has restored service to all customers impacted by this PSPS event as of approximately 9:00 am today, November 18.</p> <p>SDG&E will distribute its post-event report within 10 business days of the conclusion of this event in accordance with the guidelines set forth in Resolution ESRB-8 and D.19-05-042.</p> <p>SDG&E is de-activating its Emergency Operations Center. This is the final notification related to this event.</p> <p>Thank you, SDG&E Regulatory Affairs</p>

Appendix 4
Government Notifications: Dates, Times and Type

SDG&E Report on De-Energization Events: November 17–18, 2019

The below table includes notifications sent via text message to the following representatives/officials by Mitch Mitchell—**SDG&E Vice President, State Governmental Affairs & External Affairs:** Senator Toni Atkins, Senator Ben Hueso, Senator Brian Jones, Senator Pat Bates, Assemblymember Todd Gloria, Assemblymember Lorena Gonzalez, Assemblymember Shirley Weber, Assemblymember Brian Maienschein, Assemblymember Tasha Boerner Horvath, Assemblymember Marie Waldron, Assemblymember Bill Brough, Assemblymember Randy Voepel


Date/ Time	Source	Message
11/17/19 9:36	SDG&E	<p>Weather event details:</p> <ul style="list-style-type: none"> • A Red Flag Warning will be in effect from 1 a.m. Sunday through 6 p.m. Sunday for San Diego County valleys & mountains and inland Orange County. • Weak to locally moderate Santa Ana winds developed across the SDG&E service area this morning and are expected to peak Sunday morning, November 17th. Winds are forecast to gradually decrease through Sunday afternoon. • The Fire Potential Index (FPI) on Sunday is expected to be Elevated (14) in inland portions of San Diego County and Elevated (13) for inland Orange County. • During the peak of the winds Sunday morning, wind gusts of 25-35 mph are expected across the backcountry with isolated gusts over 40 mph possible in the most wind prone locations. <p>Today, SDG&E made notifications to 19 customers who live in high fire risk areas that could potentially be impacted by a public safety power shutoff. These notifications were made via multiple channels: outbound dialer calls, text messages, and emails.</p> <ul style="list-style-type: none"> • Based on current weather trends, SDG&E currently projects that the unincorporated area of Descanso could experience Public Safety Power Shutoffs.
11/17/19 21:03	SDG&E	<p>Power has been restored to 20 of 21 customers in unincorporated areas of Descanso and Alpine, where power was turned off for public safety due to fire danger associated with high winds.</p> <p>Prior to restoring power, SDG&E crews inspected power lines in those unincorporated areas to ensure that it was safe to re-energize them</p> <p>The last customer that remains de-energized is a non-critical communications facility on Cuyamaca Peak.</p> <p>This facility is expected to be re-energized tomorrow. Due to high winds in the area, it was not possible to fly a helicopter to inspect the power line in that area for damage – a critical step that must be completed before we re-energize.</p>

Appendix 5
Cal OES Phone Notifications, Completed Forms

SDG&E Report on De-Energization Events: November 17–18, 2019

Telephone Notifications

Date/ Time	Contact	General Content/Brief Description
11/16/19 9:31	Cal OES (Staff)	SDG&E activating PSPS protocols; initial Cal OES form to follow
11/16/19 13:10	Cal OES Warning Center	Please find update #1, which includes the potential scope. Please call if you have any questions or need any further information
11/17/19 12:20	Cal OES Warning Center	Please find update #2, which includes the potential scope and start of activation. Please let me know if you have any questions.
11/17/19 5:07	Cal OES (Staff)	SDGE has de-energized 19 customers in unincorporated Descanso with 2 MBL.
11/17/19 5:10	Cal OES (Staff)	SDGE has de-energized 2 customers in unincorporated Descanso with 0 MBL.
11/17/19 6:00	Cal OES Warning Center	Please find update #3 which includes the potential scope. Please let me know if you have any questions.
11/17/19 8:00	Cal OES Warning Center San Diego County OES California Highway Patrol CAL FIRE—Sacramento Command Center	Operational Briefing
11/17/19 11:56	Cal OES (Staff)	Patrolling beginning
11/17/19 12:25	Cal OES Warning Center	Attached, please find update #4 Please contact me if you have any questions.
11/17/19 12:24	Cal OES (Staff)	Verification of message received
11/17/19 13:45	Cal OES (Staff)	Informed 18 of 21 customers have been re-energized
11/17/19 15:49	Cal OES (Staff)	Notification one customer (two meters) out overnight
11/17/19 16:00	Cal OES Warning Center San Diego County OES CAL FIRE Sacramento Command Center	Operational Briefing
11/17/19 16:13	Cal OES Warning Center	Attached, please find PSPS Update #5. If you have any questions, please feel free to contact me.
11/17/19 16:13	Cal OES (Staff)	Verification of message received
11/18/19 8:57	Cal OES (Staff)	Notification of full restoration and EOC deactivation



Public Safety Power Shutoff (PSPS) State Notification Form

Utility Submitting Report: San Diego Gas & Electric (SDG&E)

Date Report Prepared by Utility: 11/16/2019 Time Report Prepared by Utility: 10:50AM

Please complete this form per instructions provided and send to the California State Warning Center at warning.center@oes.ca.gov. Upon submission of form, call the CSWC at (916) 845-8911 to confirm receipt. Please call with any questions.

1.a | Notification Type*

Activating PSPS Protocols/ Potential to De-energize <input checked="" type="checkbox"/>	Decision to De-energize <input type="checkbox"/>	De-energization Initiated <input type="checkbox"/>
Initiating Re-energization Patrols <input type="checkbox"/>	All PSPS Lines Re-energized <input type="checkbox"/>	EOC Activated? YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
Is this an update notification?	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	
If Yes, provide update number:	SDGEPSPS111619	
Update Details:		
The National Weather Service has issued a Red Flag Warning, to be in effect from 1 AM until 6 PM Sunday (11/16) for Inland Orange County and the San Diego County Valleys and Mountains (Zones 554, 258, &250).		
SDG&E activated our PSPS protocols at 0930 in anticipation of the wind event. The CalOES Warning Center and County OES Duty Officer were notified of the PSPS protocol activation at 0931.		
Attachments Included?	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	# of Attachments?

1.b | Utility Information*

Utility Contact: Augie Ghio – EM Advisor	Email Address: ESEODSDGE@semprautilities.com
Phone Number: Augie: 619-961-5681	Additional Contact Information: 24/7 Emergency On-Duty Officer – 858-503-5173
Utility Operational Period: 11/16 2400 – 11/17 0600; 11/17 0600 – 1800	
Proposed Briefing Times: TBD	

Confidentiality Notice

This document is for the sole use of the intended recipient(s) and may contain confidential and privileged information. Any unauthorized review, use, disclosure, or distribution is prohibited without the express, written consent of the Cal OES Executive Office.

Please attach additional information, including:

- PDF maps or links to datasources



Public Safety Power Shutoff (PSPS) State Notification Form

Utility Submitting Report: San Diego Gas & Electric (SDG&E)

Date Report Prepared by Utility: 11/16/2019

Time Report Prepared by Utility: 10:50AM

1.c | GIS Data Information*

GIS Data Delivery Method

ArcGIS Online (AGOL)


URL:

Secure File Download Site

URL:

Data Access Information – Notes:

****For security purposes this information is provided separately****



Public Safety Power Shutoff (PSPS) State Notification Form

Utility Submitting Report: San Diego Gas & Electric (SDG&E)

Date Report Prepared by Utility: 11/16/2019 Time Report Prepared by Utility: 10:50AM

Please complete this form per instructions provided and send to the California State Warning Center at warning.center@oes.ca.gov. Upon submission of form, call the CSWC at (916) 845-8911 to confirm receipt. Please call with any questions.

1.a | Notification Type*

Activating PSPS Protocols/ Potential to De-energize <input checked="" type="checkbox"/>	Decision to De-energize <input type="checkbox"/>	De-energization Initiated <input type="checkbox"/>
Initiating Re-energization Patrols <input type="checkbox"/>	All PSPS Lines Re-energized <input type="checkbox"/>	EOC Activated? YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
Is this an update notification?	YES <input type="checkbox"/> NO <input type="checkbox"/>	
If Yes, provide update number:	SDGEPSPS111619	
Update Details:		
The National Weather Service has issued a Red Flag Warning, to be in effect from 1 AM until 6 PM Sunday (11/16) for Inland Orange County and the San Diego County Valleys and Mountains (Zones 554, 258, &250).		
SDG&E activated our PSPS protocols at 0930 in anticipation of the wind event. The CalOES Warning Center and County OES Duty Officer were notified of the PSPS protocol activation at 0931.		
Attachments Included?	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	# of Attachments?

1.b | Utility Information*

Utility Contact: Augie Ghio – EM Advisor	Email Address: ESEODSDGE@semprautilities.com
Phone Number: Augie: 619-961-5681	Additional Contact Information: 24/7 Emergency On-Duty Officer – 858-503-5173
Utility Operational Period: 11/16 2400 – 11/17 0600; 11/18 0600 – 1800	
Proposed Briefing Times: TBD	

Confidentiality Notice

This document is for the sole use of the intended recipient(s) and may contain confidential and privileged information. Any unauthorized review, use, disclosure, or distribution is prohibited without the express, written consent of the Cal OES Executive Office.



Public Safety Power Shutoff (PSPS) State Notification Form

Utility Submitting Report: San Diego Gas & Electric (SDG&E)

Date Report Prepared by Utility: 11/16/2019

Time Report Prepared by Utility: 10:50AM

4. | Public Alert & Notification Information

4.a | Proposed Public Alert & Notification Language (List by Customer Type)


Notifications are in process, they will be included in update #1

4.b | Method of Public Notification (Check All That Apply)

Automated Notification System: SMS/Text Message	<input type="checkbox"/>	Automated Notification System: Voice Message/Phone	<input type="checkbox"/>
Automated Notification System: Email	<input type="checkbox"/>	Operator Conducted Phone Call/Live Call	<input type="checkbox"/>
News Media / News Release	<input type="checkbox"/>	Social Media	<input type="checkbox"/>
Field Visit	<input type="checkbox"/>		<input type="checkbox"/>

Other – Please Specify:

4.c | Entities to Be Notified



Public Safety Power Shutoff (PSPS) State Notification Form

Utility Submitting Report: San Diego Gas & Electric (SDG&E)

Date Report Prepared by Utility: 11/16/2019 Time Report Prepared by Utility: 12:45 PM

Please complete this form per instructions provided and send to the California State Warning Center at warning.center@oes.ca.gov. Upon submission of form, call the CSWC at (916) 845-8911 to confirm receipt. Please call with any questions.

1.a | Notification Type*

Activating PSPS Protocols/ Potential to De-energize <input checked="" type="checkbox"/>	Decision to De-energize <input type="checkbox"/>	De-energization Initiated <input type="checkbox"/>
Initiating Re-energization Patrols <input type="checkbox"/>	All PSPS Lines Re-energized <input type="checkbox"/>	EOC Activated? YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
Is this an update notification?	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	
If Yes, provide update number:	SDGEPSPS111619 – Update #1	
Update Details:		
The National Weather Service has issued a Red Flag Warning, to be in effect from 1 AM until 6 PM Sunday (11/16) for Inland Orange County and the San Diego County Valleys and Mountains (Zones 554, 258, &250).		
Update includes potential impact area.		
Attachments Included?	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	# of Attachments?

1.b | Utility Information*

Utility Contact: Augie Ghio – EM Advisor	Email Address: ESEODSDGE@semprautilities.com
Phone Number: Augie: 619-961-5681	Additional Contact Information: 24/7 Emergency On-Duty Officer – 858-503-5173
Utility Operational Period: 11/16 2400 – 11/17 0600; 11/17 0600 – 1800	
Proposed Briefing Times: TBD	

Confidentiality Notice

This document is for the sole use of the intended recipient(s) and may contain confidential and privileged information. Any unauthorized review, use, disclosure, or distribution is prohibited without the express, written consent of the Cal OES Executive Office.

Please attach additional information, including:

- PDF maps or links to data sources



Public Safety Power Shutoff (PSPS) State Notification Form

Utility Submitting Report: San Diego Gas & Electric (SDG&E)

Date Report Prepared by Utility: 11/16/2019

Time Report Prepared by Utility: 12:45 PM

1.c | GIS Data Information*

GIS Data Delivery Method

ArcGIS Online (AGOL)


URL:

Secure File Download Site

URL:

Data Access Information – Notes:

****For security purposes this information is provided separately****



Public Safety Power Shutoff (PSPS) State Notification Form

Utility Submitting Report: San Diego Gas & Electric (SDG&E)

Date Report Prepared by Utility: 11/16/2019

Time Report Prepared by Utility: 12:45 PM

Please complete this form per instructions provided and send to the California State Warning Center at warning.center@oes.ca.gov. Upon submission of form, call the CSWC at (916) 845-8911 to confirm receipt. Please call with any questions.

1.a | Notification Type*

Activating PSPS Protocols/ Potential to De-energize <input checked="" type="checkbox"/>	Decision to De-energize <input type="checkbox"/>	De-energization Initiated <input type="checkbox"/>
Initiating Re-energization Patrols <input type="checkbox"/>	All PSPS Lines Re-energized <input type="checkbox"/>	EOC Activated? YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
Is this an update notification?	YES <input type="checkbox"/> NO <input type="checkbox"/>	
If Yes, provide update number:	SDGEPSPS111619	
Update Details:		
The National Weather Service has issued a Red Flag Warning, to be in effect from 1 AM until 6 PM Sunday (11/16) for Inland Orange County and the San Diego County Valleys and Mountains (Zones 554, 258, &250).		
Update includes potential impact area.		
Attachments Included?	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	# of Attachments?

1.b | Utility Information*

Utility Contact: Augie Ghio – EM Advisor	Email Address: ESEODSDGE@semprautilities.com
Phone Number: Augie: 619-961-5681	Additional Contact Information: 24/7 Emergency On-Duty Officer – 858-503-5173
Utility Operational Period: 11/16 2400 – 11/17 0600; 11/18 0600 – 1800	
Proposed Briefing Times: TBD	

Confidentiality Notice

This document is for the sole use of the intended recipient(s) and may contain confidential and privileged information. Any unauthorized review, use, disclosure, or distribution is prohibited without the express, written consent of the Cal OES Executive Office.



Public Safety Power Shutoff (PSPS) State Notification Form

Utility Submitting Report: San Diego Gas & Electric (SDG&E)

Date Report Prepared by Utility: 11/16/2019 Time Report Prepared by Utility: 12:45 PM

4. | Public Alert & Notification Information

4.a | Proposed Public Alert & Notification Language (List by Customer Type)

The following message was sent to Public Safety Partners 11/16/19 @ 1245:

This is an important safety message from SDG&E. Forecasted weather conditions could affect the power lines that serve local communities. In response, SDG&E may activate its Emergency Operations Center to monitor adverse weather conditions throughout the duration of the event. These conditions may require us to turn off the power for public safety. The following communities that could be impacted include: unincorporated Descanso.

The estimated start time of event is early Sunday morning.

We anticipate that under these conditions, the event could last throughout the day with full restoration estimated around 6:00 p.m. Sunday.

We estimate 2 Medical Baseline (MBL) customers reside in impacted areas.

If you have obtained geographic information systems (GIS) data access from SDG&E, you will be able to receive GIS data via [secure data transfer](#). If you have not set up access or have problems accessing this link, please see [SDGE.com/Outages](#).

The following contacts are available if you need additional information, Emergency Management Duty Officer eseodsge@semprautilities.com or 858-503-5450, or SDGELiaisonOfficerNotifications@semprautilities.com or 858-503-5450. Please do not forward this contact information beyond your government or public safety teams.

If residents have questions, please have them call 1-800-411-7343 for more information and visit our website to update account information.

We will send another notification when conditions change or if we turn off power for safety. For more information, please visit [SDGE.com/Ready](#).

The following message was sent to customers 11/16/19 @ 12:50:

This is SDG&E calling with an important message. Press any key to continue. Alert: Forecasted weather conditions could affect the power lines that serve your community. We are currently monitoring the potential for adverse weather conditions to begin within 24 hours. These conditions may require us to turn off the power for public safety in your community. If you do experience an outage, the power will stay off until we can safely restore it. Please be prepared to activate your personal family emergency plan. For more information, visit [SDGE.com/Ready](#) Additional languages prompts: Press 1 for Spanish, 2 for Mandarin, 3 for Tagalog, 4 for Vietnamese, 5 for Russian, 6 for Korean, 7 for Cantonese

4.b | Method of Public Notification (Check All That Apply)

Automated Notification System: SMS/Text Message	<input checked="" type="checkbox"/>	Automated Notification System: Voice Message/Phone	<input checked="" type="checkbox"/>
Automated Notification System: Email	<input checked="" type="checkbox"/>	Operator Conducted Phone Call/Live Call	<input type="checkbox"/>
News Media / News Release	<input type="checkbox"/>	Social Media	<input type="checkbox"/>
Field Visit	<input type="checkbox"/>		<input type="checkbox"/>

Other – Please Specify:

4.c | Entities to Be Notified



Public Safety Power Shutoff (PSPS) State Notification Form

Utility Submitting Report: San Diego Gas & Electric (SDG&E)

Date Report Prepared by Utility: 11/16/2019 **Time Report Prepared by Utility:** 12:45 PM

[Empty rectangular box for report content]

For Official Use Only – FOUO

** = Required Information*

Page 6

	Public Safety Power Shutoff (PSPS) State Notification Form		
	Utility Submitting Report:	San Diego Gas & Electric (SDG&E)	
	Date Report Prepared by Utility:	11/17/2019	Time Report Prepared by Utility: 0000 hrs

Please complete this form per instructions provided and send to the California State Warning Center at warning.center@oes.ca.gov. Upon submission of form, call the CSWC at (916) 845-8911 to confirm receipt. Please call with any questions.

1.a | Notification Type*

Activating PSPS Protocols/ Potential to De-energize <input checked="" type="checkbox"/>	Decision to De-energize <input type="checkbox"/>	De-energization Initiated <input type="checkbox"/>
Initiating Re-energization Patrols <input type="checkbox"/>	All PSPS Lines Re-energized <input type="checkbox"/>	EOC Activated? YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
Is this an update notification?	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	
If Yes, provide update number:	SDGEPSPS111619 – Update #2	
Update Details:		
The EOC activated at a modified level 3 at 0000 hrs on 11/16/2019.		
The National Weather Service has issued a Red Flag Warning, to be in effect from 1 AM until 6 PM Sunday (11/16) for Inland Orange County and the San Diego County Valleys and Mountains (Zones 554, 258, &250).		
Update includes potential impact area.		
Attachments Included?	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	# of Attachments?

1.b | Utility Information*

Utility Contact: Augie Ghio – EM Advisor	Email Address: ESEODSDGE@semprautilities.com
Phone Number: Augie: 619-961-5681	Additional Contact Information: 24/7 Emergency On-Duty Officer – 858-503-5173
Utility Operational Period: 11/16 2400 – 11/17 0600; 11/17 0600 – 1800	
Proposed Briefing Times: TBD	

Confidentiality Notice

This document is for the sole use of the intended recipient(s) and may contain confidential and privileged information. Any unauthorized review, use, disclosure, or distribution is prohibited without the express, written consent of the Cal OES Executive Office.

Please attach additional information, including:

- PDF maps or links to data sources



Public Safety Power Shutoff (PSPS) State Notification Form

Utility Submitting Report: San Diego Gas & Electric (SDG&E)

Date Report Prepared by Utility: 11/17/2019

Time Report Prepared by Utility: 0000 hrs

1.c | GIS Data Information*

GIS Data Delivery Method

ArcGIS Online (AGOL)


URL:

Secure File Download Site

URL:

Data Access Information – Notes:

****For security purposes this information is provided separately****



Public Safety Power Shutoff (PSPS) State Notification Form

Utility Submitting Report: San Diego Gas & Electric (SDG&E)

Date Report Prepared by Utility: 11/17/2019 Time Report Prepared by Utility: 0000 hrs

Please complete this form per instructions provided and send to the California State Warning Center at warning.center@oes.ca.gov. Upon submission of form, call the CSWC at (916) 845-8911 to confirm receipt. Please call with any questions.

1.a | Notification Type*

Activating PSPS Protocols/ Potential to De-energize <input checked="" type="checkbox"/>	Decision to De-energize <input type="checkbox"/>	De-energization Initiated <input type="checkbox"/>
Initiating Re-energization Patrols <input type="checkbox"/>	All PSPS Lines Re-energized <input type="checkbox"/>	EOC Activated? YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
Is this an update notification?	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	
If Yes, provide update number:	SDGEPSPS111619 – Update #2	
Update Details:		
The EOC activated at a modified level 3 at 0000 hrs on 11/17/2019.		
The National Weather Service has issued a Red Flag Warning, to be in effect from 1 AM until 6 PM Sunday (11/16) for Inland Orange County and the San Diego County Valleys and Mountains (Zones 554, 258, &250).		
Update includes potential impact area.		
Attachments Included?	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	# of Attachments?

1.b | Utility Information*

Utility Contact: Augie Ghio – EM Advisor	Email Address: ESEODSDGE@semprautilities.com
Phone Number: Augie: 619-961-5681	Additional Contact Information: 24/7 Emergency On-Duty Officer – 858-503-5173
Utility Operational Period: 11/16 2400 – 11/17 0600; 11/18 0600 – 1800	
Proposed Briefing Times: TBD	

Confidentiality Notice

This document is for the sole use of the intended recipient(s) and may contain confidential and privileged information. Any unauthorized review, use, disclosure, or distribution is prohibited without the express, written consent of the Cal OES Executive Office.



Public Safety Power Shutoff (PSPS) State Notification Form

Utility Submitting Report: San Diego Gas & Electric (SDG&E)

Date Report Prepared by Utility: 11/17/2019

Time Report Prepared by Utility: 0000 hrs

4. | Public Alert & Notification Information

4.a | Proposed Public Alert & Notification Language (List by Customer Type)

The following message was sent to Public Safety Partners 11/16/19 @ 1245:

This is an important safety message from SDG&E. Forecasted weather conditions could affect the power lines that serve local communities. In response, SDG&E may activate its Emergency Operations Center to monitor adverse weather conditions throughout the duration of the event. These conditions may require us to turn off the power for public safety. The following communities that could be impacted include: unincorporated Descanso.

The estimated start time of event is early Sunday morning.

We anticipate that under these conditions, the event could last throughout the day with full restoration estimated around 6:00 p.m. Sunday.

We estimate 2 Medical Baseline (MBL) customers reside in impacted areas.

If you have obtained geographic information systems (GIS) data access from SDG&E, you will be able to receive GIS data via [secure data transfer](#). If you have not set up access or have problems accessing this link, please see [SDGE.com/Outages](#).

The following contacts are available if you need additional information, Emergency Management Duty Officer eseodsge@semprautilities.com or 858-503-5450, or SDGELiaisonOfficerNotifications@semprautilities.com or 858-503-5450. Please do not forward this contact information beyond your government or public safety teams.

If residents have questions, please have them call 1-800-411-7343 for more information and visit our website to update account information.

We will send another notification when conditions change or if we turn off power for safety. For more information, please visit [SDGE.com/Ready](#).

The following message was sent to customers 11/16/19 @ 12:50:

This is SDG&E calling with an important message. Press any key to continue. Alert: Forecasted weather conditions could affect the power lines that serve your community. We are currently monitoring the potential for adverse weather conditions to begin within 24 hours. These conditions may require us to turn off the power for public safety in your community. If you do experience an outage, the power will stay off until we can safely restore it. Please be prepared to activate your personal family emergency plan. For more information, visit [SDGE.com/Ready](#) Additional languages prompts: Press 1 for Spanish, 2 for Mandarin, 3 for Tagalog, 4 for Vietnamese, 5 for Russian, 6 for Korean, 7 for Cantonese

4.b | Method of Public Notification (Check All That Apply)

Automated Notification System: SMS/Text Message	<input checked="" type="checkbox"/>	Automated Notification System: Voice Message/Phone	<input checked="" type="checkbox"/>
Automated Notification System: Email	<input checked="" type="checkbox"/>	Operator Conducted Phone Call/Live Call	<input type="checkbox"/>
News Media / News Release	<input type="checkbox"/>	Social Media	<input type="checkbox"/>
Field Visit	<input type="checkbox"/>		<input type="checkbox"/>

Other – Please Specify:

4.c | Entities to Be Notified



Public Safety Power Shutoff (PSPS) State Notification Form

Utility Submitting Report: San Diego Gas & Electric (SDG&E)

Date Report Prepared by Utility: 11/17/2019

Time Report Prepared by Utility: 0000 hrs

--

For Official Use Only – FOUO

** = Required Information*

Page 6

	Public Safety Power Shutoff (PSPS) State Notification Form		
	Utility Submitting Report:	San Diego Gas & Electric (SDG&E)	
	Date Report Prepared by Utility:	11/17/2019	Time Report Prepared by Utility:

Please complete this form per instructions provided and send to the California State Warning Center at warning.center@oes.ca.gov. Upon submission of form, call the CSWC at (916) 845-8911 to confirm receipt. Please call with any questions.

1.a | Notification Type*

Activating PSPS Protocols/ Potential to De-energize <input checked="" type="checkbox"/>	Decision to De-energize <input checked="" type="checkbox"/>	De-energization Initiated <input checked="" type="checkbox"/>
Initiating Re-energization Patrols <input type="checkbox"/>	All PSPS Lines Re-energized <input type="checkbox"/>	EOC Activated? YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
Is this an update notification?	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	
If Yes, provide update number:	SDGEPSPS111619 – Update #3	
Update Details:		
<p>The decision to de-energize was given at 0457 hrs on 11/17/2019. 19 customers in unincorporated Descanso were de-energized at 0501 hrs, with 2 additional customers de-energized at 0510.</p> <p>The National Weather Service has issued a Red Flag Warning, to be in effect from 1 AM until 6 PM Sunday (11/16) for Inland Orange County and the San Diego County Valleys and Mountains (Zones 554, 258, &250).</p> <p>Update includes potential impact area.</p>		
Attachments Included?	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	# of Attachments?

1.b | Utility Information*

Utility Contact: Mona Freels – EM Advisor	Email Address: ESEODSDGE@semprautilities.com
Phone Number: 619-250-6121	Additional Contact Information: 24/7 Emergency On-Duty Officer – 858-503-5173
Utility Operational Period: 11/17 0600 – 1800	
Proposed Briefing Times: 0800- Will send calendar invite	

Confidentiality Notice

This document is for the sole use of the intended recipient(s) and may contain confidential and privileged information. Any unauthorized review, use, disclosure, or distribution is prohibited without the express, written consent of the Cal OES Executive Office.

Please attach additional information, including:

- PDF maps or links to data sources



Public Safety Power Shutoff (PSPS) State Notification Form

Utility Submitting Report: San Diego Gas & Electric (SDG&E)

Date Report Prepared by Utility: 11/17/2019

Time Report Prepared by Utility: 0600 hrs

1.c | GIS Data Information*

GIS Data Delivery Method

ArcGIS Online (AGOL)

URL:

Secure File Download Site

URL:

Data Access Information – Notes:

****For security purposes this information is provided separately****

	Public Safety Power Shutoff (PSPS) State Notification Form		
	Utility Submitting Report:	San Diego Gas & Electric (SDG&E)	
	Date Report Prepared by Utility:	11/17/2019	Time Report Prepared by Utility: 0600 hrs

Please complete this form per instructions provided and send to the California State Warning Center at warning.center@oes.ca.gov. Upon submission of form, call the CSWC at (916) 845-8911 to confirm receipt. Please call with any questions.

1.a | Notification Type*

Activating PSPS Protocols/ Potential to De-energize <input checked="" type="checkbox"/>	Decision to De-energize <input checked="" type="checkbox"/>	De-energization Initiated <input checked="" type="checkbox"/>
Initiating Re-energization Patrols <input type="checkbox"/>	All PSPS Lines Re-energized <input type="checkbox"/>	EOC Activated? YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
Is this an update notification?	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	
If Yes, provide update number:	SDGEPSPS111619 – Update #3	
Update Details:		
<p>The decision to de-energize was given at 0457 hrs on 11/17/2019. 19 customers in unincorporated Descanso were de-energized at 0501 hrs, with 2 additional customers de-energized at 0510.</p> <p>The National Weather Service has issued a Red Flag Warning, to be in effect from 1 AM until 6 PM Sunday (11/16) for Inland Orange County and the San Diego County Valleys and Mountains (Zones 554, 258, &250).</p> <p>Update includes potential impact area.</p>		
Attachments Included?	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	# of Attachments?

1.b | Utility Information*

Utility Contact: Mona Freels – EM Advisor	Email Address: ESEODSDGE@semprautilities.com
Phone Number: 619-250-6121	Additional Contact Information: 24/7 Emergency On-Duty Officer – 858-503-5173
Utility Operational Period: 11/18 0600 – 1800	
Proposed Briefing Times: 0800- Will send calendar invite	

Confidentiality Notice

This document is for the sole use of the intended recipient(s) and may contain confidential and privileged information. Any unauthorized review, use, disclosure, or distribution is prohibited without the express, written consent of the Cal OES Executive Office.



Public Safety Power Shutoff (PSPS) State Notification Form

Utility Submitting Report: San Diego Gas & Electric (SDG&E)

Date Report Prepared by Utility: 11/17/2019

Time Report Prepared by Utility: 0600 hrs

4. | Public Alert & Notification Information

4.a | Proposed Public Alert & Notification Language (List by Customer Type)

The following message was sent to Public Safety Partners 11/17/19 @ 0547:

This is an important safety message from SDG&E.

Due to adverse weather conditions affecting power lines, the power has been turned off for public safety in impacted communities. The following communities that could be impacted include: unincorporated Descanso. We estimate 21 total customers, including 2 Medical Baseline (MBL) customers, reside in impacted area. The National Weather Service has indicated that the current Red Flag Warning is set to expire at 6:00pm on Sunday, November 17, 2019. When conditions improve, our crews will assess the safety of the electrical system and determine when power can be restored. For location details and updated information on outages and restoration times, visit SDGE.com/Outages, check our mobile app, or follow us on Twitter.

As a public safety partner, the following contacts are available to you if you need additional information, SDGELiaisonOfficerNotifications@semprautilities.com or 858-503-5450 or Emergency Management Duty Officer eseodsdge@semprautilities.com or 858-503-5450. Please do not forward this contact information beyond your government or public safety teams. If residents have questions, please have them call 1-800-411-7343 for more information and visit our website to update account information.


Thank you for your understanding while we work together to keep our communities safe

4.b | Method of Public Notification (Check All That Apply)

Automated Notification System: SMS/Text Message	<input checked="" type="checkbox"/>	Automated Notification System: Voice Message/Phone	<input checked="" type="checkbox"/>
Automated Notification System: Email	<input checked="" type="checkbox"/>	Operator Conducted Phone Call/Live Call	<input type="checkbox"/>
News Media / News Release	<input type="checkbox"/>	Social Media	<input type="checkbox"/>
Field Visit	<input type="checkbox"/>		<input type="checkbox"/>

Other – Please Specify:

4.c | Entities to Be Notified

	Public Safety Power Shutoff (PSPS) State Notification Form		
	Utility Submitting Report:	San Diego Gas & Electric (SDG&E)	
	Date Report Prepared by Utility:	11/17/2019	Time Report Prepared by Utility: 1210 hrs

Please complete this form per instructions provided and send to the California State Warning Center at warning.center@oes.ca.gov. Upon submission of form, call the CSWC at (916) 845-8911 to confirm receipt. Please call with any questions.

1.a | Notification Type*

Activating PSPS Protocols/ Potential to De-energize <input type="checkbox"/>	Decision to De-energize <input type="checkbox"/>	De-energization Initiated <input type="checkbox"/>
Initiating Re-energization Patrols <input checked="" type="checkbox"/>	All PSPS Lines Re-energized <input type="checkbox"/>	EOC Activated? YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
Is this an update notification?	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	
If Yes, provide update number:	SDGEPSPS111619 – Update #4	
Update Details:		
SDG&E has begun patrolling of the affected lines de-energized due to the PSPS event.		
Attachments Included?	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	# of Attachments?

1.b | Utility Information*

Utility Contact: Mona Freels – EM Advisor	Email Address: ESEODSDGE@semprautilities.com
Phone Number: 619-250-6121	Additional Contact Information: 24/7 Emergency On-Duty Officer – 858-503-5173
Utility Operational Period: 11/17 0600 – 1800	
Proposed Briefing Times: As needed	

Confidentiality Notice

This document is for the sole use of the intended recipient(s) and may contain confidential and privileged information. Any unauthorized review, use, disclosure, or distribution is prohibited without the express, written consent of the Cal OES Executive Office.

Please attach additional information, including:

- PDF maps or links to datasources



Public Safety Power Shutoff (PSPS) State Notification Form

Utility Submitting Report: San Diego Gas & Electric (SDG&E)

Date Report Prepared by Utility: 11/17/2019

Time Report Prepared by Utility: 1210 hrs

1.c | GIS Data Information*

GIS Data Delivery Method

ArcGIS Online (AGOL)


URL:

Secure File Download Site

URL:

Data Access Information – Notes:

****For security purposes this information is provided separately****

	Public Safety Power Shutoff (PSPS) State Notification Form		
	Utility Submitting Report:	San Diego Gas & Electric (SDG&E)	
	Date Report Prepared by Utility:	11/17/2019	Time Report Prepared by Utility: 1210 hrs

Please complete this form per instructions provided and send to the California State Warning Center at warning.center@oes.ca.gov. Upon submission of form, call the CSWC at (916) 845-8911 to confirm receipt. Please call with any questions.

1.a | Notification Type*


Activating PSPS Protocols/ Potential to De-energize <input type="checkbox"/>	Decision to De-energize <input type="checkbox"/>	De-energization Initiated <input type="checkbox"/>
Initiating Re-energization Patrols <input checked="" type="checkbox"/>	All PSPS Lines Re-energized <input type="checkbox"/>	EOC Activated? YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
Is this an update notification?	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	
If Yes, provide update number:	SDGEPSPS111619 – Update #4	
Update Details:		
SDG&E has begun patrolling of the affected lines de-energized due to the PSPS event.		
Attachments Included?	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	# of Attachments?

1.b | Utility Information*

Utility Contact: Mona Freels – EM Advisor	Email Address: ESEODSDGE@semprautilities.com
Phone Number: 619-250-6121	Additional Contact Information: 24/7 Emergency On-Duty Officer – 858-503-5173
Utility Operational Period: 11/18 0600 – 1800	
Proposed Briefing Times: As needed	

Confidentiality Notice

This document is for the sole use of the intended recipient(s) and may contain confidential and privileged information. Any unauthorized review, use, disclosure, or distribution is prohibited without the express, written consent of the Cal OES Executive Office.



Public Safety Power Shutoff (PSPS) State Notification Form

Utility Submitting Report: San Diego Gas & Electric (SDG&E)

Date Report Prepared by Utility: 11/17/2019

Time Report Prepared by Utility: 1210 hrs

4. | Public Alert & Notification Information

4.a | Proposed Public Alert & Notification Language (List by Customer Type)

The following message was sent to Public Safety Partners 11/17/19 @1201:

This is an important safety message from SDG&E. Conditions have improved, and SDG&E crews have begun patrolling power lines to determine when power can be restored to affected communities including unincorporated Descanso. For up-to-date information on outages and restoration times, visit sdge.com/outages, check our mobile app, or follow us on Twitter.

As a public safety partner, the following contacts are available to you if you need additional information, SDGELiaisonOfficerNotifications@semprautilities.com or 858-503-5450 or Emergency Management Duty Officer eseodsge@semprautilities.com or 858-503-5450. Please do not forward this contact information beyond your government or public safety teams.

If residents have questions, please have them call 1-800-411-7343 for more information and visit our website to update account information.

Thank you for your understanding while we work together to keep our communities safe.

Notifications sent to Customers on 11/17/19 @1210

This is SDG&E calling with an important message. Press any key to continue. Conditions have improved, and SDG&E crews have begun patrolling power lines to determine when power can be restored to affected communities. Please be aware that some inspections could take place on your property. For up-to-date information on outages and restoration times, visit SDGE.com/Outages, check our mobile app, or follow us on Twitter. Additional languages prompts: Press 1 for Spanish, 2 for Mandarin, 3 for Tagalog, 4 for Vietnamese, 5 for Russian, 6 for Korean, 7 for Cantonese

4.b | Method of Public Notification (Check All That Apply)

Automated Notification System: SMS/Text Message	<input checked="" type="checkbox"/>	Automated Notification System: Voice Message/Phone	<input checked="" type="checkbox"/>
Automated Notification System: Email	<input checked="" type="checkbox"/>	Operator Conducted Phone Call/Live Call	<input type="checkbox"/>
News Media / News Release	<input type="checkbox"/>	Social Media	<input type="checkbox"/>
Field Visit	<input type="checkbox"/>		<input type="checkbox"/>

Other – Please Specify:

4.c | Entities to Be Notified

	Public Safety Power Shutoff (PSPS) State Notification Form		
	Utility Submitting Report:	San Diego Gas & Electric (SDG&E)	
	Date Report Prepared by Utility:	11/17/2019	Time Report Prepared by Utility: 1611 hrs

Please complete this form per instructions provided and send to the California State Warning Center at warning.center@oes.ca.gov. Upon submission of form, call the CSWC at (916) 845-8911 to confirm receipt. Please call with any questions.

1.a | Notification Type*

Activating PSPS Protocols/ Potential to De-energize <input type="checkbox"/>	Decision to De-energize <input type="checkbox"/>	De-energization Initiated <input type="checkbox"/>
Initiating Re-energization Patrols <input type="checkbox"/>	All PSPS Lines Re-energized <input type="checkbox"/>	EOC Activated? YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
Is this an update notification?	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	
If Yes, provide update number:	SDGEPSPS111619 – Update #5	
Update Details:		
SDG&E has re-energized all circuits except for one customer which is a non-critical communications tower.		
De-escalating EOC Level 3 to staff duty officer monitoring level 4 status. Final Update for the evening. Expect next update @ 10:00 11/18/19.		
Attachments Included?	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	# of Attachments?

1.b | Utility Information*

Utility Contact: Mona Freels – EM Advisor	Email Address: ESEODSDGE@semprautilities.com
Phone Number: 619-250-6121	Additional Contact Information: 24/7 Emergency On-Duty Officer – 858-503-5173
Utility Operational Period: 11/17 0600 – 1800	
Proposed Briefing Times:	SDG&E has scheduled a 1600 brief to County OES and Cal Warning Center

Confidentiality Notice

This document is for the sole use of the intended recipient(s) and may contain confidential and privileged information. Any unauthorized review, use, disclosure, or distribution is prohibited without the express, written consent of the Cal OES Executive Office.

Please attach additional information, including:

- PDF maps or links to datasources



Public Safety Power Shutoff (PSPS) State Notification Form

Utility Submitting Report: San Diego Gas & Electric (SDG&E)

Date Report Prepared by Utility: 11/17/2019

Time Report Prepared by Utility: 1611 hrs

1.c | GIS Data Information*

GIS Data Delivery Method

ArcGIS Online (AGOL)


URL:

Secure File Download Site

URL:

Data Access Information – Notes:

****For security purposes this information is provided separately****

	Public Safety Power Shutoff (PSPS) State Notification Form		
	Utility Submitting Report:	San Diego Gas & Electric (SDG&E)	
	Date Report Prepared by Utility:	11/17/2019	Time Report Prepared by Utility: 1611 hrs

Please complete this form per instructions provided and send to the California State Warning Center at warning.center@oes.ca.gov. Upon submission of form, call the CSWC at (916) 845-8911 to confirm receipt. Please call with any questions.

1.a | Notification Type*


Activating PSPS Protocols/ Potential to De-energize <input type="checkbox"/>	Decision to De-energize <input type="checkbox"/>	De-energization Initiated <input type="checkbox"/>
Initiating Re-energization Patrols <input type="checkbox"/>	All PSPS Lines Re-energized <input type="checkbox"/>	EOC Activated? YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
Is this an update notification?	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	
If Yes, provide update number:	SDGEPSPS111619 – Update #5	
Update Details:		
SDG&E has re-energized all circuits except for one customer which is a non-critical communications tower.		
De-escalating EOC Level 3 to staff duty officer monitoring level 4 status. Final Update for the evening. Expect next update @ 10:00 11/18/19.		
Attachments Included?	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	# of Attachments?

1.b | Utility Information*

Utility Contact: Mona Freels – EM Advisor	Email Address: ESEODSDGE@semprautilities.com
Phone Number: 619-250-6121	Additional Contact Information: 24/7 Emergency On-Duty Officer – 858-503-5173
Utility Operational Period: 11/18 0600 – 1800	
Proposed Briefing Times:	SDG&E has scheduled a 1600 brief to County OES and Cal Warning Center

Confidentiality Notice

This document is for the sole use of the intended recipient(s) and may contain confidential and privileged information. Any unauthorized review, use, disclosure, or distribution is prohibited without the express, written consent of the Cal OES Executive Office.



Public Safety Power Shutoff (PSPS) State Notification Form

Utility Submitting Report: San Diego Gas & Electric (SDG&E)

Date Report Prepared by Utility: 11/17/2019

Time Report Prepared by Utility: 1611 hrs

4. | Public Alert & Notification Information

4.a | Proposed Public Alert & Notification Language (List by Customer Type)

The following message was sent to Public Safety Partners 11/17/19 @1418:

Our crews have restored power to a portion of unincorporated Descanso resulting in the restoration of approximately 18 customers, including two Medical Baseline customers, as a result of our proactive patrols. Our crews are continuing their efforts to restore service to the remaining customers.

For up-to-date information on outages and restoration times, visit SDGE.com/Outages, check our mobile app, or follow us on Twitter. We appreciate your cooperation during this time of extreme weather conditions.

As a public safety partner the following contacts are available to you if you need additional information, SDGELiaisonOfficerNotifications@semprautilities.com or 858-503-5450 or Emergency Management Duty Officer eseodsge@semprautilities.com or 858-503-5450. Please do not forward this contact information beyond your government or public safety teams.

If residents have questions, please have them call 1-800-411-7343 for more information and visit our website to update account information.

Thank you for your patience while we work together to keep our communities safe.

The following message was sent to Public Safety Partners 11/17/19 @1559:

Our crews have restored power to certain areas of the unincorporated Descanso resulting in the restoration of approximately 20 customers, as a result of our proactive patrols. One non-critical communications facility will remain out overnight and we will begin our aerial patrol at 7:00am in the morning.

For up-to-date information on outages and restoration times, visit SDGE.com/Outages, check our mobile app, or follow us on Twitter. We appreciate your cooperation during this time of extreme weather conditions.

As a public safety partner the following contacts are available to you if you need additional information, SDGELiaisonOfficerNotifications@semprautilities.com or 858-503-5450 or Emergency Management Duty Officer eseodsge@semprautilities.com or 858-503-5450. Please do not forward this contact information beyond your government or public safety teams.

If residents have questions, please have them call 1-800-411-7343 for more information and visit our website to update account information.

Thank you for your patience while we work together to keep our communities safe.

Notifications sent to Customers on 11/17/19 @1420

This is SDG&E calling with an important message. Press any key to continue. Your power should now be fully restored. If the power is still out, please call us at 1-800-411-7343. Visit SDGENews.com for up-to-date information. We appreciate your cooperation during this time of adverse weather conditions. Additional languages prompts: Press 1 for Spanish, 2 for Mandarin, 3 for Tagalog, 4 for Vietnamese, 5 for Russian, 6 for Korean, 7 for Cantonese

Notifications sent to Customers on 11/17/19 @1610

This is SDG&E calling with an important message. Press any key to continue. Due to adverse weather conditions affecting power lines that serve your community, the power has been turned off for public safety. Our crews are still actively assessing the damage to the electric system to determine how quickly power can be restored. They will continue to work as long as conditions are safe however your power will remain off overnight. For updated information on outages and restoration times, visit SDGE.com/Outages, check our mobile app, or follow us on Twitter. Additional



Public Safety Power Shutoff (PSPS) State Notification Form

Utility Submitting Report: San Diego Gas & Electric (SDG&E)

Date Report Prepared by Utility: 11/17/2019

Time Report Prepared by Utility: 1611 hrs

languages prompts: Press 1 for Spanish, 2 for Mandarin, 3 for Tagalog, 4 for Vietnamese, 5 for Russian, 6 for Korean, 7 for Cantonese

4.b | Method of Public Notification (Check All That Apply)

Automated Notification System: SMS/Text Message	<input checked="" type="checkbox"/>	Automated Notification System: Voice Message/Phone	<input checked="" type="checkbox"/>
Automated Notification System: Email	<input checked="" type="checkbox"/>	Operator Conducted Phone Call/Live Call	<input type="checkbox"/>
News Media / News Release	<input type="checkbox"/>	Social Media	<input type="checkbox"/>
Field Visit	<input type="checkbox"/>		<input type="checkbox"/>
Other – Please Specify:			

4.c | Entities to Be Notified

	Public Safety Power Shutoff (PSPS) State Notification Form		
	Utility Submitting Report:	San Diego Gas & Electric (SDG&E)	
	Date Report Prepared by Utility:	11/18/2019	Time Report Prepared by Utility:

Please complete this form per instructions provided and send to the California State Warning Center at warning.center@oes.ca.gov. Upon submission of form, call the CSWC at (916) 845-8911 to confirm receipt. Please call with any questions.

1.a | Notification Type*

Activating PSPS Protocols/ Potential to De-energize <input type="checkbox"/>	Decision to De-energize <input type="checkbox"/>	De-energization Initiated <input type="checkbox"/>
Initiating Re-energization Patrols <input type="checkbox"/>	All PSPS Lines Re-energized <input checked="" type="checkbox"/>	EOC Activated? YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
Is this an update notification?	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	
If Yes, provide update number:	SDGEPSPS111619 – Update #6	
Update Details:		
SDG&E has re-energized all circuits		
Attachments Included?	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	# of Attachments?

1.b | Utility Information*

Utility Contact: Mona Freels – EM Advisor	Email Address: ESEODSDGE@semprautilities.com
Phone Number: 619-250-6121	Additional Contact Information: 24/7 Emergency On-Duty Officer – 858-503-5173
Utility Operational Period:	
Proposed Briefing Times:	

Confidentiality Notice

This document is for the sole use of the intended recipient(s) and may contain confidential and privileged information. Any unauthorized review, use, disclosure, or distribution is prohibited without the express, written consent of the Cal OES Executive Office.

Please attach additional information, including:

- PDF maps or links to datasources



Public Safety Power Shutoff (PSPS) State Notification Form

Utility Submitting Report: San Diego Gas & Electric (SDG&E)

Date Report Prepared by Utility: 11/18/2019

Time Report Prepared by Utility: 0900 hrs

1.c | GIS Data Information*

GIS Data Delivery Method

ArcGIS Online (AGOL)

URL:

Secure File Download Site

URL:

Data Access Information – Notes:

****For security purposes this information is provided separately****



Public Safety Power Shutoff (PSPS) State Notification Form

Utility Submitting Report: San Diego Gas & Electric (SDG&E)

Date Report Prepared by Utility: 11/18/2019 Time Report Prepared by Utility: 0900 hrs

Please complete this form per instructions provided and send to the California State Warning Center at warning.center@oes.ca.gov. Upon submission of form, call the CSWC at (916) 845-8911 to confirm receipt. Please call with any questions.

1.a | Notification Type*

Activating PSPS Protocols/ Potential to De-energize <input type="checkbox"/>	Decision to De-energize <input type="checkbox"/>	De-energization Initiated <input type="checkbox"/>
Initiating Re-energization Patrols <input type="checkbox"/>	All PSPS Lines Re-energized <input checked="" type="checkbox"/>	EOC Activated? YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
Is this an update notification?	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	
If Yes, provide update number:	SDGEPSPS111619 – Update #6	
Update Details:		
SDG&E has re-energized all circuits		
Attachments Included?	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	# of Attachments?

1.b | Utility Information*

Utility Contact: Mona Freels – EM Advisor	Email Address: ESEODSDGE@semprautilities.com
Phone Number: 619-250-6121	Additional Contact Information: 24/7 Emergency On-Duty Officer – 858-503-5173
Utility Operational Period:	
Proposed Briefing Times:	

Confidentiality Notice

This document is for the sole use of the intended recipient(s) and may contain confidential and privileged information. Any unauthorized review, use, disclosure, or distribution is prohibited without the express, written consent of the Cal OES Executive Office.



Public Safety Power Shutoff (PSPS) State Notification Form

Utility Submitting Report: San Diego Gas & Electric (SDG&E)

Date Report Prepared by Utility: 11/18/2019

Time Report Prepared by Utility: 0900 hrs

4. | Public Alert & Notification Information

4.a | Proposed Public Alert & Notification Language (List by Customer Type)

The following message was sent to Public Safety Partners 11/18/19 @0900:

This is an important safety message from SDG&E. Final notification: Adverse weather conditions have passed, and service have been restored to all customers. The Public Safety Power Shutoff event has concluded, and SDG&E's Emergency Operations Center has de-activated. For more information, visit sdgenews.com.

We appreciate your cooperation during this time of adverse weather conditions.

4.b | Method of Public Notification (Check All That Apply)

Automated Notification System: SMS/Text Message	<input checked="" type="checkbox"/>	Automated Notification System: Voice Message/Phone	<input checked="" type="checkbox"/>
Automated Notification System: Email	<input checked="" type="checkbox"/>	Operator Conducted Phone Call/Live Call	<input type="checkbox"/>
News Media / News Release	<input type="checkbox"/>	Social Media	<input type="checkbox"/>
Field Visit	<input type="checkbox"/>		<input type="checkbox"/>

Other – Please Specify:

4.c | Entities to Be Notified

