

24-Slice of Day Implementation Presentation





- ♦Planning Reserve Margin Calibration
- ♦Wind/Solar Exceedance
- ♦Thermal Counting UCAP Light
- Elimination of MCC Buckets
- ♦Test Year



◆Loss of Load Expectation analysis needs to be run for 2024 – January 2023 –Utilize 2024 load forecast, expected supply mix and resource constraints

- Resulting annual portfolio should be calibrated to meet monthly demand + annualized PRM while maintaining 1-in-10 year LOLE standard throughout the year
 - -ED's approach to add load during various months will result in the necessary annual PRM and 0.1 LOLE but may not yield the monthly portfolio that the 24-SOD conversion tool is expecting
 - -Resulting annual portfolio should be converted to monthly portfolios so that conversion tool can properly yield a 24-SOD PRM
 - Possible middle step is to translate the amount of load added per month as the amount of capacity that must be removed
- Process needs to ensure 0.1 LOLE for the full year and not simply for July through September months
- ◆LOLE and PRM process should be revisited every 2 to 4 years as load and supply mix change over time



♦MRP reviewed PG&E's exceedance proposal, steps 1-3

- ◆Top 5 days, even with 2015-2020 years, provides small sample to solve for exceedance threshold
- Reviewed top 2.5%, 5% and 10% of hours from data used by PG&E

Currently considering days that fall in the top 5% of hour



Wind/Solar Exceedance Preliminary Findings



Seasonal Construct

- ♦Summer Months: May Oct
- ♦Non-Summer: Nov Apr
- ♦Aligns with CPUC's year ahead showing months

Solar

Summer Months: 80% ExceedanceNon-Summer Months: 60% Exceedance

NP/SP-15 Wind

♦NP-15

–Summer: 75%

–Non-Summer: 50%

♦SP-15

-Summer: 75%

-Non-Summer: 60%

Preliminary Profiles

_	MIDDLE								
4	RIVER								
	POWER								
	22 22	-							

		-	1 3	23	4	5	6	7	8	9	10	11	L 1	2	13	14	15	16	17	18	31	9 2	0 21	22	23	24	
60%	1 Jan	0%	6 0%	6 0%	0%	0%	0%	0%	7%	29%	43%	50%	53%	6 53	8% 5	51%	43%	28%	6%	0%	09	% 0%	6 0%	0%	0%	0%	
60%	2 Feb	0%	6 0%	6 0%	0%	0%	0%	0%	17%	48%	62%	66%	679	68	3% 6	66%	60%	51%	22%	1%	09	% 0%	6 0%	0%	0%	0%	
60%	3 Mar	0%	6 0%	6 0%	0%	0%	0%	0%	9%	40%	62%	69%	69%	6 70	0% 6	58%	65%	60%	44%	21%	49	% 0%	6 0%	0%	0%	0%	
60%	4 Apr	0%	6 0%	6 0%	0%	0%	0%	1%	22%	53%	69%	76%	5 78%	6 79	9% 7	78%	77%	71%	64%	48%	169	% 19	6 0%	0%	0%	0%	
80%	5 May	0%	6 0%	6 0%	0%	0%	0%	6%	31%	53%	64%	72%	5 749	6 74	1% 7	73%	72%	68%	60%	45%	219	% 2%	6 0%	0%	0%	0%	
80%	6 Jun	0%	6 0%	6 0%	0%	0%	0%	9%	36%	58%	71%	78%	819	6 81	1% 7	79%	78%	74%	66%	52%	299	% 6%	6 0%	0%	0%	0%	
80%	7 Jul	0%	6 0%	6 0%	0%	0%	0%	5%	28%	54%	68%	76%	80%	6 81	L% 7	79%	77%	73%	65%	52%	299	% 6%	6 0%	0%	0%	0%	
80%	8 Aug	0%	6 0%	6 0%	0%	0%	0%	1%	19%	48%	65%	73%	5 779	6 78	3% 7	76%	74%	69%	59%	44%	169	% 19	6 0%	0%	0%	0%	
80%	9 Sep	0%	6 0%	6 0%	0%	0%	0%	0%	13%	43%	60%	68%	5 729	6 73	3% 7	72%	69%	63%	51%	27%	49	% 0%	6 0%	0%	0%	0%	
80%	10 Oct	0%	6 0%	6 0%	0%	0%	0%	0%	6%	32%	54%	63%	65%	65	5% 6	55%	64%	58%	39%	10%	09	% 0%	6 0%	0%	0%	0%	
60%	11 Nov	0%	6 0%	6 0%	0%	0%	0%	1%	19%	46%	59%	62%	62%	61	1% 5	59%	52%	29%	3%	0%	09	% 0%	6 0%	0%	0%	0%	
60%	12 Dec	0%	6 0%	6 0%	0%	0%	0%	0%	8%	29%	44%	48%	49%	6 50	0% 4	18%	41%	21%	2%	0%	09	% 0%	6 0%	0%	0%	0%	
												NP-1	5 Win	d Exceedance Profile													
NP-15	Wind	_	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	
50%	1 Jan		6%	5%	4%	4%	4%	4%	4%	4%	4%	4%	3%	4%	4%	3%	3%	3%	3%	3%	4%	5%	5%	5%	6%	6%	
50%	2 Feb		13%	13%	12%	10%	10%	9%	10%	11%	9%	8%	9%	8%	8%	8%	9%	9%	8%	8%	9%	10%	10%	11%	12%	13%	
50%	3 Mar		16%	14%	14%	13%	11%	10%	8%	8%	8%	7%	7%	7%	6%	7%	7%	8%	10%	10%	12%	14%	17%	15%	16%	17%	
50%	4 Apr		36%	34%	34%	30%	29%	25%	23%	18%	15%	16%	14%	13%	11%	12%	15%	21%	25%	27%	29%	31%	35%	35%	36%	40%	
75%	5 May		37%	37%	36%	32%	28%	24%	22%	17%	13%	12%	9%	8%	7%	8%	11%	17%	23%	28%	33%	32%	37%	38%	40%	38%	
75%	6 Jun		46%	48%	45%	40%	40%	36%	32%	23%	17%	13%	9%	6%	5%	7%	8%	15%	22%	34%	41%	39%	42%	44%	43%	46%	
75%	7 Jul		62%	61%	57%	53%	50%	46%	43%	36%	30%	21%	15%	12%	10%	12%	16%	25%	35%	43%	47%	49%	56%	57%	61%	62%	
75%	8 Aug		57%	58%	53%	47%	45%	43%	37%	30%	22%	18%	12%	8%	8%	8%	10%	18%	26%	32%	40%	47%	54%	57%	58%	57%	
75%	9 Sep		23%	24%	22%	19%	17%	13%	11%	8%	6%	5%	3%	2%	2%	2%	2%	3%	6%	10%	13%	17%	20%	19%	21%	21%	
75%	10 Oct		9%	9%	7%	5%	4%	4%	3%	3%	3%	2%	1%	1%	1%	1%	1%	1%	1%	1%	3%	4%	5%	6%	7%	9%	
50%	11 Nov		8%	6%	6%	6%	5%	5%	4%	5%	3%	3%	2%	2%	2%	2%	2%	2%	2%	3%	3%	4%	4%	5%	7%	7%	
50%	12 Dec		7%	7%	7%	7%	6%	6%	6%	6%	6%	5%	5%	5%	4%	4%	4%	4%	4%	5%	6%	7%	8%	8%	8%	8%	
_				-	_		_	_	_	-	-	SP-2	15 Wir		eedar	nce Pro	ofile									-	
Excee	dance %	ſ	1	. 2	3	4	5	6	5 7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	
60%	1 Jan		4%	4%	4%	4%	5%	4%	5%	4%	4%	4%	4%	4%	4%	4%	5%	4%	4%	4%	5%	4%	4%	4%	4%	4%	
60%	2 Feb		7%	6%	7%	6%	6%	6%	6%	6%	5%	4%	5%	5%	5%	7%	8%	9%	10%	9%	9%	9%	10%	8%	8%	9%	
60%	3 Mar		16%	16%	14%	15%	14%	13%	11%	9%	7%	8%	9%	10%	10%	11%	13%	15%	18%	18%	20%	20%	18%	18%	18%	17%	
60%	4 Apr		31%	31%	30%	27%	25%	22%	19%	16%	13%	12%	13%	13%	14%	15%	21%	25%	30%	31%	33%	34%	32%	31%	31%	31%	
75%	5 May		28%	28%	26%	25%	21%	17%	14%	10%	7%	7%	6%	6%	6%	7%	9%	16%	23%	28%	30%	30%	31%	32%	31%	29%	
75%	6 Jun		34%	33%	29%	27%	24%	21%	16%	12%	8%	6%	5%	5%	7%	7%	10%	16%	22%	26%	31%	34%	35%	35%	35%	35%	
75%	7 Jul		28%	26%	25%	21%	18%	15%	12%	8%	5%	3%	3%	4%	5%	6%	9%	13%	19%	23%	27%	28%	30%	31%	30%	29%	
75%	8 Aug		25%	24%	21%	18%	15%	12%	9%	7%	4%	3%	2%	3%	4%	5%	7%	11%	15%	20%	23%	26%	28%	30%	27%	27%	
75% 75%	9 Sep		10%	8%	6%	5%	5%	4%	4%	3%	2%	2%	2%	3%	4%	5%	5%	5%	6%	9%	12%	13%	12%	11%	11%	10%	
75%	10 Oct	1	5%	4%	4%	4%	4%	3%	3%	3%	2%	2%	2%	3%	3%	3%	3%	3%	4%	4%	5%	5%	5%	4%	5%	5%	
60%	11 Nov		4%	4%	4%	4%	4%	4%	3%	3%	3%	4%	4%	4%	5%	4%	4%	4%	3%	4%	4%	5%	5%	4%	4%	4%	
60%	12 Dec		5%	5%	5%	5%	5%	5%	5%	4%	4%	4%	4%	4%	5%	5%	5%	5%	5%	6%	6%	6%	6%	6%	6%	6%	

Solar Exceedance Profile

Middle River Power



Parties and Energy Division should work with CAISO on future of RA Enhancements to eliminate RA Availability Incentive Mechanism (RAAIM) and improve outage replacement process

Additional work is needed and UCAP is not implementable at this time



- Energy Division presented on elimination of MCC buckets
- Potentially keep DR bucket and eliminate all other buckets
- ◆Unclear how usage of imports will be monitored under 24-SOD -6x16 imports do not cover all days of the month and unclear if LOLE analysis models imports similarly -CAISO allows imports to be shown as subset of days
- Consider whether ED should monitor impact of imports under 24-SOD

Test Year Details



♦Year Ahead SOD Showing

- -Due November 30 to CPUC
- -If CAISO supply plan is ready or needed, then suppliers would also submit such information, potentially not in CIRA but maybe CIDI

Month Ahead SOD Showing

- –Due 1st day of each compliance month to CPUC
- -If CAISO supply plan is ready/needed, also submit to CAISO, potentially not in CIRA but maybe CIDI
- ♦ED should monitor showing templates and fix issues as necessary
- ◆If CIRA changes are needed, LSEs & suppliers will most likely wait until September/October 2024 for market simulation

-May need to test CIRA uploads, outage substitutions in CIRA, bid insertion, RAAIM(?)

- Possible CIRA changes are necessary because if LSE shows single max hour MW value to CAISO to validate against the 24-SOD PRM, then CAISO will have surplus capacity due to stacking of capacity of various hour
 - -Could be solved if CAISO uses different PRM than the 24-SOD PRM, more in line with the annual LOLE PRM

Example of Test Year Showing to CAISO



- ◆If LSEs/Suppliers show max MW shown of 24-SOD to CAISO who's validating only single hour peak demand+PRM, then total shown capacity will likely be greater than demand+PRM
- ◆ISO may need different non 24-SOD PRM or use different shown NQC value to meet demand+PRM

MIDDLE

RIVER POWER