

From: [USRB](#)
To: [Palmer, Leslie L.](#); [SED - Gas Section - North](#); [SED - Gas Section - South](#); [SED - Electric Safety and Reliability Branch - South](#); [SED - Electric Safety and Reliability Branch - North](#); [SED - Wildfire Safety and Enforcement Branch](#); compliance@energysafety.ca.gov
Subject: FW: Electric Safety Incident Reported- Southern California Edison Company Incident No: 260405-17553
Date: Sunday, April 5, 2026 7:30:45 PM

From: webmaster@cpuc.ca.gov <webmaster@cpuc.ca.gov>
Sent: Sunday, April 5, 2026 7:30:36 PM (UTC-08:00) Pacific Time (US & Canada)
To: USRB <usrb@cpuc.ca.gov>
Cc: bernice.cordero@sce.com <bernice.cordero@sce.com>
Subject: Electric Safety Incident Reported- Southern California Edison Company Incident No: 260405-17553

The Following information regarding this incident has been reported:

Reporting Date: 4/5/2026 7:13:40 PM
Incident Date: 4/5/2026 @ 2:50 p.m.
Reported By: Bernice Cordero , Senior Manager
Utility Name: Southern California Edison Company
Phone Number: (626)993-8676
Email Address: bernice.cordero@sce.com

Incident Location: 11800 Championship Drive Moorpark , Ventura County

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? No (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? Yes
- Media Coverage? No

Cause of Incident: Unknown (Other Cause:)

Agencies on Scene:

Facilities Affected:

- Utilities Facilities: Gabbert
- Voltage (KV): 16kv
- Customer's Facilities:

DigIn Information:

- Excavator Name:
- Contact:
- Phone: () -

Incident Recovery:

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

Summary: SCE submits this report as it involves an event that meets the reporting requirements of a governmental entity investigating a utility-caused wildfire. Preliminary information indicates SCE equipment was possibly involved in the ignition of a brush fire known as the Champion Fire that consumed approximately 2 to 3 acres. The fire was extinguished earlier this afternoon, and there were no reports of any structures destroyed. The investigation is ongoing.?