

From: webmaster@cpuc.ca.gov
To: [USRB](#)
Cc: paul.pimentel@sce.com
Subject: Electric Safety Incident Reported- Southern California Edison Company Incident No: 260527-17713
Date: Wednesday, May 27, 2026 9:49:45 PM

The Following information regarding this incident has been reported:

Reporting Date: 5/27/2026 9:42:39 PM
Incident Date: 5/27/2026 @ 9:30 a.m.
Reported By: Paul C. Pimentel, Principal Manager
Utility Name: Southern California Edison Company
Phone Number: (626)302-5830
Email Address: paul.pimentel@sce.com

Incident Location: Near Mulholland Highway and Las Virgenes Road Calabasas, Los Angeles County

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? No (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? Yes
- Media Coverage? Yes

Cause of Incident: Unknown (Other Cause:)

Agencies on Scene:

Facilities Affected:

- Utilities Facilities: Moorpark-Crater-Malibu
- Voltage (KV): 66 kV
- Customer's Facilities:

DigIn Information:

- Excavator Name:
- Contact:
- Phone: () -

Incident Recovery:

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

Summary: SCE submits this report out of an abundance of caution because the event may fall under the reporting requirement for incidents involving media coverage that are attributable, or allegedly attributable, to utility electrical facilities. The Moorpark-Crater-Malibu 66 kV circuit relayed at 9:23 a.m. A vegetation fire, identified as the Jasper Fire, was reported at approximately 9:28 a.m. today. Our personnel responded to the area and observed animal

remains on an insulator on Pole No. 718776E. There was no wire down attributed to the animal contact. It appears a portion of the animal body fell to the ground and ignited vegetation in the vicinity of the pole. The Jasper Fire consumed approximately 5.6 acres and there have been no reports of any injuries nor structures damaged/destroyed. No fire agency has requested the removal or preservation of utility facilities. The investigation is ongoing