

**From:** [webmaster@cpuc.ca.gov](mailto:webmaster@cpuc.ca.gov)  
**To:** [USRB](#)  
**Cc:** [dsmith7@sdge.com](mailto:dsmith7@sdge.com)  
**Subject:** Electric Safety Incident Reported- San Diego Gas & Electric Incident No: 260516-17676  
**Date:** Saturday, May 16, 2026 7:05:06 PM

---

**The Following information regarding this incident has been reported:**

**Reporting Date:** 5/16/2026 6:56:11 PM  
**Incident Date:** 5/16/2026 @ 2:30 p.m.  
**Reported By:** Drew Smith, Fire Science and Coordination Mgr  
**Utility Name:** San Diego Gas & Electric  
**Phone Number:** (619)509-6182  
**Email Address:** dsmith7@sdge.com

**Incident Location:** 16390 DIA DEL SOL VALLEY CENTER, San Diego

**Reasons For Reporting:**

- Fatalities? No (Utility: , Others: )
- Names of Fatalities:
- Injuries? (Utility: , Others: )
- Names of Injured:
- Damage? No (Utility: , Others: )
- Interruption? (Total Customers: , Total Hours: )
- Operator Judgement? No
- Media Coverage? No

**Cause of Incident:** Animal (Other Cause: )

**Agencies on Scene:** Fire,

**Facilities Affected:**

- Utilities Facilities: P816370
- Voltage (KV): 12
- Customer's Facilities:

**DigIn Information:**

- Excavator Name:
- Contact:
- Phone: ( ) -

**Incident Recovery:**

- On Scene Date & Time: 5/16/2026 @ 4:15 p.m.
- Service Restored: @ 00:00 a.m.

**Summary:** Cal Fire responded to a vegetation fire and requested SDG&E assistance. A bird nest and dead bird was found near the electric facility. Cal Fire provided SDG&E employee with LE-38 form. Incident Name - Sunset. Incident Number - CASDV011707