

<u>Loc #</u>	<u>RWM Pkg#</u>	<u>Pole</u>	<u>Issue Description (PUC Eng)</u>
2	1376774	P127041	The conduit for AT&T risers missing or not properly secured
6	1376773	P126460	The conduit for AT&T risers missing or not properly secured
9	1377087	P126281	Abandoned Drops
10	1376770	P23390	The conduit for AT&T risers missing or not properly secured
12	1376769	P23389	AT&T down guy wire need to be taut Guy wire need to be tightened
15	1377089	P221558	AT&T terminal box on the pole was not closed or locked.
23	1376768	P229482	The conduit for AT&T risers missing or not properly secured
25	1376772	P28832	The AT&T facilities on the following buddy poles need to be transferred to the new poles:
27	1377088	P222910	Abandoned Drops
28	1376771	P28831	The conduit for AT&T risers missing or not properly secured
36	1377090	1060834H	Abandoned Drops
41	1376776	Z15456	The conduit for AT&T risers missing or not properly secured
42	1376966	P253644S	The ground moulding attached to Pole P253644S was damaged
44	1376970	P14412	The conduit for AT&T risers missing or not properly secured
45	1376973	P167239	The conduit for AT&T risers missing or not properly secured
48	1376969	P10390	The conduit for AT&T risers missing or not properly secured
49	1376971	P3111460	The conduit for AT&T risers missing or not properly secured
50	1376964	P612370	The conduit for AT&T risers missing or not properly secured
53	1376968	825132H	The conduit for AT&T risers missing or not properly secured
55	1376963	Z117302L	an AT&T terminal box was not attached to the pole
55	1376963	Z117302	The conduit for AT&T risers missing or not properly secured
57	868302	P208365	Abandoned Drops
58	1376775	P510015	The AT&T facilities on the following buddy poles need to be transferred to the new poles:

63	1383350	P510018	An AT&T service drop attached to pole P510018 had an above ground clearance of less than 10 feet going across a driveway of a private property.
71	1376965	P513246	The AT&T facilities on the following buddy poles need to be transferred to the new poles:
74	1376967	P19802J	AT&T conductor was hanging significantly below the other conductors
75	1376972	P19803	The conduit for AT&T risers missing or not properly secured
78	1376958	570413H	The conduit for AT&T risers missing or not properly secured
89	1376962	P325212	The conduit for AT&T risers missing or not properly secured
91	1376960	1046003H	The conduit for AT&T risers missing or not properly secured
93	1376961	Pole Behind 614 Cleveland St.	The conduit for AT&T risers missing or not properly secured
102	1376779	P27997	The AT&T facilities on the following buddy poles need to be transferred to the new poles:
103	1376954	P137059	The conduit for AT&T risers missing or not properly secured
105	1383344	pole located behind 914 Cleveland Street	Vegetation - Climbing space obstructed by vegetation from the ground
106	1383347	Pole Behind 908 Cleveland St	Abandoned Drops
111	1376778	P419757	AT&T down guy wire need to be taut Guy wire need to be tightened
112	1376777	P419777	AT&T down guy wire need to be taut Guy wire need to be tightened
117	1383345	P419779	Abandoned Drops
119	1376888	P199744S	AT&T down guy wire need to be taut Guy wire need to be tightened
122	1383346	P129561	Abandoned Drops
130	1376901	P129927	AT&T down guy wire need to be taut Guy wire need to be tightened
134	1376957	P129567	AT&T down guy wire need to be taut Guy wire need to be tightened
139	1378868	P215510	AT&T down guy anchor near this pole was completely buried.
142	1376959	466554H	The conduit for AT&T risers missing or not properly secured

56/57	1377091	P215921 & P208365	The AT&T conductor supported on Poles numbered P215921 and P208365 was strained by vegetation
-------	---------	-------------------	--

<u>Address</u>	<u>City</u>	<u>GPS</u>	<u>Completed</u>
748 DEL RIO	Encinitas	33.06213715,-117.28641687	x
814 Del Rio Ave	Encinitas	33.06353118,-117.28635548	x
864 DEL RIO AVE S/O LEUCA	Encinitas	33.06455395,-117.2863104	x
265 Hemlock Ave	Carlsbad	33.15006641,-117.34420757	x
3805 GARFIELD ST	Carlsbad	33.14958061,-117.34502889	x
141 HEMLOCK AVE	Carlsbad	33.14918827,-117.34570552	x
2665 WILSON ST. S/O FORES	Carlsbad	33.17220192,-117.33828449	x
2726 Wilson St.	Carlsbad	33.17151182,-117.33763732	x
2725 Wilson St	Carlsbad	33.17109485,-117.33738564	x
A/F 2771 WILSON ST	Carlsbad	33.17077575,-117.33701294	x
325 E Elder	Fallbrook		x
304 Elbrook Dr	Fallbrook	33.380154 -117.246907	x
521 E Elder St	Fallbrook	33.3801389999, -117.24660999	x
325 N Brandon Rd	Fallbrook	33.3844955,-117.24310978	x
800 MISSION RD	Fallbrook	33.38438868,-117.24337903	x
665 E Mission Rd.	Fallbrook	33.3844934100, -117.24508928	x
627 E MISSION RD.	Fallbrook	33.38454573,-117.24542089	x
1399 Old Stage Rd	Fallbrook	33.36760796,-117.24933394	x
1316 Old Stage Rd	Fallbrook	33.36910628 -117.24942454	x
1275 OLD STAGE RD, FALLBROOK	Fallbrook	33.36937365, -117.249405	x
1275 OLD STAGE RD	Fallbrook	33.36937365, -117.249405	x
1223 Old Stage Rd,	Fallbrook	33.37037785,-117.2494079	x
2309 RAINBOW VLY BL	Rainbow	33.41396917,-117.14758837	

5418 5th St	Rainbow	33.41398354,-117.14507874	x
427-451 Yucca Rd	Fallbrook	33.3821534,-117.18803358 ?	
407 Grand Vista Ln	Fallbrook	33.38209884,-117.18901794	x
401 ABC LOS HERMANOS RD	Fallbrook	33.38211939,-117.19004126	x
R 616 TREMONT ST IN ALLEY ?	Oceanside	33.1889891 -117.37448	x
S/O 431 WASHINGTON IN ALLEY Behind 506 Cleveland St	Oceanside	33.18975939,-117.37620441	x
875 Cleveland St	Oceanside	33.18658182 -117.3740545	x
614 Cleveland St	Oceanside	33.1885255 , -117.3750667 ?	x
999 Cleveland St	Oceanside	33.18584431,-117.37346741	
307 WEST ST	Oceanside	33.18590287,-117.37297559	x
914 Cleveland Street	Oceanside	33.1864659, -117.37351	x
908 Cleveland St	Oceanside	33.18666870 , -117.3736517	x
4150 Lewis St	Oceanside	33.19577989,-117.28437254 ?	x
2825 ANNETTE ST	Oceanside	33.19617667,-117.284365 ?	x
2822 LOUISE ST @ JONATHON	Oceanside	33.19634847,-117.28186555	x
4200 Lewis St	Oceanside	33.19559199, -117.281879 ?	
131 Frontier Rd ?	Oceanside	33.21680976,-117.33937653 ?	x
132 TROPICANA DR ?	Oceanside	33.21700959,-117.3377377	x
156 TROPICANA DR	Oceanside	33.21529824,-117.33882438 ?	x
30401 Via Puerta Del Sol	Oceanside	33.26734156,-117.24505625	x
30418 N River Rd	Oceanside	33.267572528, -117.24399682	x

1223 Old Stage Rd

Fallbrook



33.37037785,-117.249407

x

Closure / Notification

Date / ECD

11/30/2023

11/30/2023

11/22/2023

11/30/2023

11/30/2023

11/27/2023

11/30/2023

11/30/2023

11/21/2023

11/30/2023

11/21/2023

11/30/2023

11/30/2023

11/30/2023

11/30/2023

11/30/2023

11/30/2023

11/30/2023

11/30/2023

11/30/2023

11/30/2023

11/22/2023

ECD: 1/31/2024

11/27/2023

ECD: 1/31/2024

11/30/2023

11/30/2023

11/30/2023

11/30/2023

11/30/2023

11/30/2023

ECD: 1/31/2024

11/30/2023

11/27/2023

11/21/2023

11/30/2023

11/30/2023

11/22/2023

ECD: 1/31/2024

11/22/2023

11/30/2023

11/30/2023

11/30/2023

11/30/2023

11/27/2023