



Stacy Lovell-Garra
Program Management
Compliance Advisor

8680 Balboa Ave. CPE2D
San Diego, CA 92123

Tel: 619.676.8511
Cell: 619.990.1493
Email: slovell@sdge.com

October 21, 2025

Fadi Daye
CA Public Utilities Commission
320 West 4th Street, Suite 500
Los Angeles, CA 90013-1105

SUBJECT: Electric Distribution Audit of SDG&E Orange County District - No. EA2025-1357

Mr. Daye:

An electric distribution audit/inspection of SDG&E's Orange County Construction and Operation District (conducted by SED Engineer James Miller) was held from July 28, 2025, to August 1, 2025. During the field inspection your staff identified a total of four Communication Infrastructure Providers (CIPs) overhead findings, five SDG&E overhead findings and one SDG&E underground finding.

SDG&E has fully addressed the six SDG&E field findings. The six findings were repaired the same week they were discovered during the audit. SDG&E has sent the appropriate notifications to the third-party responsible for the four Communication Infrastructure Providers (CIPs) overhead findings.

The field inspection findings included one finding that SDG&E had previously identified during SDG&E's latest inspection and had open repair work orders to remediate. D130315 was inspected on 7/11/2025 and repair workorder 'I016 External Corrosion Replace (Severe)' on notification 100027819197 was on file and completed 07/31/2025 during the audit.

SDG&E appreciates the communication and dialogue shared with your engineering team during the audit.

Sincerely,

Stacy Lovell-Garra

Stacy Lovell-Garra
Program Management Compliance Advisor