

West Coast Gas Company Inc.

9203 Beatty Drive, Sacramento, CA 95826

916-364-4100 / Fax 916-364-4200

Email: westgas@aol.com / www.westcoastgas.com

29 August 2025

Terence Eng, PE
Program Manager
Gas Safety and Reliability Branch
Safety and Enforcement Division
California Public Utilities Commission
505 Van Ness Avenue
San Francisco, CA 94102

RE: Response to SED Audit Letter dated August 4, 2025

Dear Mr. Eng,

Following is West Coast Gas Company Inc.'s response to the SED findings for the GO 112-F Compliance Inspection which occurred between June 16 through June 20, 2025.

If you have any questions, please feel free to contact me at 916-364-4100, Monday through Friday, 7 am to 3:30 pm.

Sincerely,

Mark Williams

Mark Williams
President

cc:

Mohammad Nouredine, SED/GSRB

Dennis Lee, SED/GSRB

Jason McMillan SED/GSRB

Claudia Almengor, SED

Cynthia Morris, WCG

Chad LeBlanc, WCG

Post-Inspection Written Preliminary Findings

Date of Transmittal: 06/20/2025

Dates of Inspection: [06/16/2025-06/20/2025]

Operator: WEST COAST GAS CO INC

Operator ID: 31267 (primary)

Inspection Systems: [WCG Damage Prevention Program]

Assets (Unit IDs) with results in this report: West Coast Gas (88675)

System Type: GD

Inspection Name: 2025 West Coast Gas Damage Prevention

Lead Inspector: Mohammad Nouredine

Operator Representative: [Chad Leblanc, Cynthia Morris]

Unsatisfactory Results

No Preliminary Findings.

Concerns

Public Awareness and Damage Prevention : Damage Prevention (PD.DP)

Question Title, ID Documented Damage Prevention Program - TPD/One Call, PD.DP.TPDONECALL.P

Question 5. Does the process specify how reports of TPD are checked against One-Call tickets?

References 192.614(c)(3)

Assets Covered West Coast Gas (88675 (34))

Issue Summary SED reviewed a sample of WCG's One-Call Tickets for years 2022-2024. WCG has a practice of checking for USA tickets when third party damage occurs, but it is not included in their current procedures. SED recommends that WCG include their practice of checking for USA tickets when there is third party damage in the Damage Prevention procedure, since they are already performing the checks.

WCG RESPONSE:

WCG will update its OME to reflect this practice during our annual review of the OME.