From: webmaster@cpuc.ca.gov <webmaster@cpuc.ca.gov>
Sent: Tuesday, April 30, 2024 4:48:32 PM (UTC-08:00) Pacific Time (US & Canada)
To: USRB <usrb@cpuc.ca.gov>
Cc: ElectricDataRequests@pge.com <ElectricDataRequests@pge.com>
Subject: Electric Safety Incident Reported- PG&E Incident No: 240430-15787

The Following information regarding this incident has been reported:

Reporting Date: 4/30/2024 4:46:12 PM
Incident Date: 5/20/2022 @ 2:40 p.m.
Reported By: Meredith Allen, Vice President
Utility Name: PG&E
Phone Number: (415)828-5765
Email Address: ElectricDataRequests@pge.com

Incident Location: Bill Owens Road and Highway 1 Point Arena, Mendocino

Reasons For Reporting:
- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? Yes (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? No
- Media Coverage? No

Cause of Incident: Falling Tree (Other Cause:)

Agencies on Scene:

Facilities Affected:
- Utilities Facilities: POINT ARENA 1101
- Voltage (KV): 12
- Customer's Facilities:

DigIn Information:
- Excavator Name:
- Contact:
- Phone: (___)___-____

Incident Recovery:
- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

Summary: CPUC Electric Incident ? EI220520A ? On April 30, 2024, PG&E Law Claims received a claim exceeding $50,000 from a customer in the area of Bill Owens Road and Highway 1, Point Arena of Mendocino County, a Tier-2 HFTD. This area is served by the POINT ARENA 1101 12kV overhead distribution circuit. The claim alleges that on May 20, 2022, PG&E facilities caused a vegetation fire resulting in property damage exceeding $50,000.00. This incident is being reported under the property damage criterion. This information is preliminary.