

Introduction

In compliance with the California Public Utilities Commission General Order (G.O.) 165, Liberty Utilities (CalPeco Electric LLC) (“Liberty”) submits its annual G.O. 165 Compliance Maintenance Program Report.

The Compliance Maintenance Program at Liberty is administered by the electric operations group. The required inspections are performed by Liberty inspectors in accordance with G.O. 165 requirements, and any necessary follow-up maintenance work to correct deficiencies is completed by line crews.

This report contains the results of Liberty’s inspection, patrol, and maintenance of electric distribution facilities covering the period from January 1, 2020 through December 31, 2020.

Summary of the 2020 G.O. 165 Report

Type of Inspection	Due	Outstanding
Patrols	55	0
OH Detailed Inspection	51	0
UG Detailed Inspection	51	0
Wood Pole Intrusive	3111	0

Section 1 – Detailed Inspections:

In 2020, Liberty performed detailed circuit inspections of its entire overhead electrical distribution system encompassing 51 entire circuits in accordance with the requirements of G.O. 165.

A. Outstanding Inspections:

None.

Section 2 – Patrols:

In 2020, Liberty patrolled 55 of 55 scheduled circuits in accordance with the requirements of G.O. 165.

A. Outstanding Patrols:

None.

Definitions of Units Reported:

Patrol units are defined as entire circuits of which Liberty has a total of 43 distribution circuits and 12 transmission circuits for a combined total of 55.

For overhead and underground detailed inspections, the number of units are the actual circuits in their entirety. Liberty makes no distinction between overhead and underground, as one

circuit might include both types of facilities. To comply with the G.O. 165 timelines for overhead versus underground inspection schedules, the stricter underground timelines are chosen when the circuit has submersible transformers or underground switches.

Lastly, wood pole intrusive units are defined as number of poles inspected.