Utility Name	Fire Start		Location			Land Use at Origin	Fire			Utility Facility					Outage			Field Observations					
	Date	Time	Latitude	Longitude	Material at Origin		Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes
PG&E	12/27/2020	08:18	37.73173	-122.38293	Other	Urban	1 meter - < 3 meters	Fire Agency	San Francisco FD	101811027	Y	12,000	Conductor - Primary	Overhead	Y	12/27/2020	09:18	Vandalism	N.A.	N.A.	N.A.	Vandalism	
PG&E	12/27/2020	10:13	38.073917	-122.224228	Vegetation	Urban	3 meters - 0.25 Acres	Fire Agency	Vallejo FD	103163440	N	12,000	Conductor - Primary	Overhead	Y	12/27/2020	10:46	Equipment - PG&E	Conductor failure-all	N.A.	N.A.	N.A.	
PG&E	12/22/2020	13:32	39.1663083	-122.1618717	Vegetation	Agriculture	1 meter - < 3 meters	Fire Agency	Williams FD	Circuit ID: 0L2051102	N	12,000	Conductor - Primary	Overhead	Y	12/22/2020	13:13	Equipment - PG&E	Conductor failure-all	N.A.	N.A.	N.A.	
PG&E	12/17/2020	08:50	39.3857619	-120.2158811	Vegetation	Herbaceous	0.25 - 10 Acres	Cal Fire	Customer / Cal Fire	Circuit ID: 1B2562102	N	12,000	Conductor - Primary	Overhead	N	N.A.	N.A.	N.A.	Contact from object	N.A.	Balloon	Conductor - M	N.A.
PG&E	12/13/2020	12:50	35.33042165	-119.0934186	Other	Urban	3 meters - 0.25 Acres	Fire Agency	Bakersfield FD	Pole ID: 100155908	Y	21,000	Insulator	Overhead	Y	12/13/2020	13:46	Equipment - PG&E	Insulator	N.A.	N.A.	N.A.	
PG&E	12/12/2020	07:42	35.4475052	-119.5810392	Agriculture	Agriculture	3 meters - 0.25 Acres	Fire Agency	Kings County FD	Pole ID: 100788572	N	12,000	Insulator	Overhead	Y	12/12/2020	7:28	Equipment - PG&E	Insulator	N.A.	N.A.	N.A.	
PG&E	12/11/2020	23:31	36.5895483	-122.2980917	Other	Agriculture	3 meters - 0.25 Acres	Cal Fire	N.A.	Circuit ID: 1B2521104; SAP ID: 101484847	Y	12,000	Grounding Wire	Overhead	Y	12/11/2020	23:56	Equipment - PG&E	Groundline Wire	N.A.	N.A.	N.A.	
PG&E	12/11/2020	14:37	35.664139	-121.3915654	Vegetation	Herbaceous	3 meters - 0.25 Acres	Cal Fire	N.A.	129190279	Y	12,000	Conductor - Primary	Overhead	Y	12/11/2020	14:37	Equipment - PG&E	Conductor failure-all	N.A.	N.A.	N.A.	
PG&E	12/7/2020	11:52	35.433662	-120.6314885	Vegetation	Herbaceous	0.25 - 10 Acres	Cal Fire	Cal Fire SLO	Circuit ID: 1B2631104	Y	12,000	Jumper	Overhead	Y	12/7/2020	11:46	Weather	N.A.	N.A.	N.A.	Weather	High Winds
PG&E	12/7/2020	10:16	37.07051639	-121.9771868	Vegetation	Hardwood Woodla	0.25 - 10 Acres	Cal Fire	Cal Fire Felton	Circuit ID: 1B2622102; SAP ID: 101393700	Y	12,000	Conductor - Primary	Overhead	Y	12/7/2020	10:01	Contact from object	N.A.	Vegetation	Conductor - M	N.A.	
PG&E	12/7/2020	09:34	39.3281717	-121.7334526	Vegetation	Conifer Forest	0.25 - 10 Acres	Cal Fire	N.A.	Circuit ID: 1D2071111; SAP ID: 101357398	N	12,000	Conductor - Primary	Overhead	Y	12/7/2020	9:11	Contact from object	N.A.	Vegetation	Conductor - M	N.A.	
PG&E	12/4/2020	12:38	34.88932554	-120.4241288	Building	Urban	1 meter - < 3 meters	Self Extinguished	N.A.	Circuit ID: 1B2061104	Y	750	Conductor - Secondary	Overhead	Y	12/4/2020	12:38	Equipment - PG&E	Conductor failure-all	N.A.	N.A.	N.A.	
PG&E	12/3/2020	14:11	35.3473909	-119.0519067	Vegetation	Urban	1 meter - < 3 meters	Customer	N.A.	2537051172	Y	750	Splice/Clamp/Connector	Overhead	N	N.A.	N.A.	Equipment - PG&E	Splice/Clamp/Connector	N.A.	N.A.	N.A.	
PG&E	12/2/2020	16:18	34.85596132	-120.4519052	Other	Agriculture	3 meters - 0.25 Acres	Fire Agency	Santa Barbara County FD	101952201	Y	12,000	Jumper	Overhead	N	N.A.	N.A.	Equipment - PG&E	Conductor failure-all	N.A.	N.A.	N.A.	
PG&E	12/2/2020	2:14	35.4535617	-118.9910133	Vegetation	Urban	3 meters - 0.25 Acres	Fire Agency	Bakersfield FD	Circuit ID: 2L1071401; SAP ID: 100164830; Fpe: Conductor	Y	12,000	Conductor - Secondary	Overhead	Y	12/2/2020	3:07	Equipment - PG&E	Conductor failure-all	N.A.	N.A.	N.A.	
PG&E	11/30/2020	20:53	36.56469	-121.91182	Vegetation	Conifer Forest	3 meters - 0.25 Acres	Cal Fire	N.A.	Circuit ID: 1B2291101; Between riser 1463 and cutout 1-71	N	12,000	Conductor - Primary	Underground	Y	11/30/2020	20:53	Equipment - PG&E	Conductor failure-all	N.A.	N.A.	N.A.	
PG&E	11/30/2020	20:47	35.3831607	-120.4516583	Vegetation	Hardwood Woodla	1 meter - < 3 meters	Self Extinguished	N.A.	Meter: 1006281774	Y	750	Service Drop	Overhead	Y	11/30/2020	20:36	Equipment - PG&E	Conductor failure-all	N.A.	N.A.	N.A.	
PG&E	11/30/2020	14:07	39.3622500	-121.8226132	Other	Agriculture	100 - 300 Acres	Cal Fire	N.A.	Pole ID: 100777646	N	12,000	Pole	Overhead	Y	11/30/2020	8:44	Contact from object	N.A.	Vehicle	Pole	N.A.	
PG&E	11/30/2020	13:37	35.664139	-121.3915654	Vegetation	Herbaceous	3 meters - 0.25 Acres	Cal Fire	N.A.	129190279	Y	12,000	Conductor - Primary	Overhead	Y	11/30/2020	13:37	Equipment - PG&E	Conductor failure-all	N.A.	N.A.	N.A.	
PG&E	11/23/2020	13:03	36.70513	-121.65557	Building	Urban	Structure Only	Fire Agency	Salinas FD	N.A.	N.A.	12,000	N.A.	Overhead	N	N.A.	N.A.	Under Investigation	N.A.	N.A.	N.A.	N.A.	PG&E has included the following ignition that meets Electric Incident Report criteria, defined by Appendix B to CPUC D.06-04-055. PG&E has not formed a conclusion about the origin or cause of this particular ignition.
PG&E	11/21/2020	17:17	37.48748	-122.20799	Vegetation	Urban	3 meters - 0.25 Acres	Fire Agency	Redwood City FD	100264583	Y	12,000	Conductor - Primary	Overhead	Y	11/21/2020	17:17	Contact from object	N.A.	Animal	Conductor - M	N.A.	
PG&E	11/21/2020	16:34	37.2820617	-121.8845167	Other	Urban	1 meter - < 3 meters	Fire Agency	San Jose FD	Pole ID: 100621989	Y	750	Fuse	Overhead	Y	11/21/2020	16:32	Equipment - PG&E	Fuse Failure	N.A.	N.A.	N.A.	
PG&E	11/20/2020	16:45	39.4630267	-122.1842067	Vegetation	Agriculture	3 meters - 0.25 Acres	Cal Fire	N.A.	Circuit ID: 1D1031102	Y	12,000	Conductor - Primary	Overhead	Y	11/20/2020	16:39	Contact from object	N.A.	Vegetation	Conductor - M	N.A.	
PG&E	11/17/2020	10:04	38.7241913	-122.5981	Other	Wetland	1 meter - < 3 meters	Self Extinguished	N.A.	100171496	N	12,000	Pole	Overhead	Y	11/17/2020	9:51	Equipment - PG&E	Pole failure	N.A.	N.A.	N.A.	
PG&E	11/17/2020	9:55	37.3677326	-122.116696	Vegetation	Urban	3 meters - 0.25 Acres	Fire Agency	Santa Clara County FD	Circuit ID: 3B2161102	Y	750	Conductor - Secondary	Overhead	Y	11/17/2020	9:58	Contact from object	N.A.	Vegetation	Conductor - M	N.A.	
PG&E	11/12/2020	13:38	38.2105	-122.13832	Building	Urban	Unknown	Self Extinguished	N.A.	63801102	N	12,000	Fortheid	Overhead	Y	11/12/2020	13:06	Equipment - PG&E	Insulator failure	N.A.	N.A.	N.A.	Unknown whether meets reportability threshold, but confirmed to be attributable to PG&E.
PG&E	11/12/2020	18:19	39.5379767	-121.6465867	Vegetation	Agriculture	3 meters - 0.25 Acres	Cal Fire	N.A.	Circuit ID: 1D3511101	N	12,000	Conductor - Primary	Overhead	Y	11/12/2020	18:11	Contact from object	N.A.	Animal	Conductor - M	N.A.	
PG&E	11/12/2020	14:51	38.3918617	-122.3979367	Vegetation	Urban	3 meters - 0.25 Acres	Fire Agency	Solid Ridge FD	Circuit ID: 0K2571101	Y	12,000	Service Drop	Overhead	N	N.A.	N.A.	Equipment - PG&E	Conductor failure-all	N.A.	N.A.	N.A.	
PG&E	11/12/2020	08:10	38.3928	-121.58311	Other	Urban	3 meters - 0.25 Acres	Fire Agency	Clarksburg FD	62462227	Y	21,000	Insulator	Overhead	Y	11/12/2020	7:53	Unknown	Insulator failure	N.A.	N.A.	Unknown	Unknown as to what caused the initial failure, but initial investigation found the ignition to be attributable to PG&E facilities.
PG&E	11/11/2020	10:22	40.495691	-121.946736	Vegetation	Hardwood Forest	0.25 - 10 Acres	Cal Fire	N.A.	021/108	N	500,000	Other	Overhead	N	N.A.	N.A.	Equipment - PG&E	Other	N.A.	N.A.	Other	Induction caused ignition.
PG&E	11/10/2020	14:34	37.3025767	-120.7535526	Other	Agriculture	3 meters - 0.25 Acres	Cal Fire	N.A.	Circuit ID: 2L2161106	N	12,000	Conductor - Primary	Overhead	Y	11/10/2020	13:23	Contact from object	N.A.	Vehicle	Conductor - M	N.A.	
PG&E	11/10/2020	12:36	39.31647	-122.01605	Other	Urban	Unknown	Unknown	N.A.	62021101	Y	12,000	Jumper	Overhead	N	N.A.	N.A.	Equipment - PG&E	Splice/Clamp/Connector	N.A.	N.A.	N.A.	Unknown whether meets reportability threshold, but confirmed to be attributable to PG&E.
PG&E	11/8/2020	13:36	38.960939	-121.493464	Vegetation	Herbaceous	0.25 - 10 Acres	Cal Fire	N.A.	Circuit ID: 1C2811104	Y	12,000	Conductor - Primary	Overhead	N	N.A.	N.A.	Equipment - PG&E	Conductor failure-all	N.A.	N.A.	N.A.	
PG&E	11/8/2020	17:06	38.5642433	-122.0516503	Other	Urban	1 meter - < 3 meters	Utility - PG&E	N.A.	Circuit ID: 0L3642104	N	21,000	Conductor - Primary	Overhead	Y	11/8/2020	17:04	Contact from object	N.A.	Balloon	Conductor - M	N.A.	
PG&E	11/7/2020	12:15	37.958649	-122.37411	Vegetation	Herbaceous	0.25 - 10 Acres	Cal Fire	N.A.	913/073	N	115,000	Jumper	Overhead	Y	11/7/2020	17:50	Equipment - PG&E	#N/A	N.A.	N.A.	N.A.	
PG&E	11/7/2020	12:35	36.87535913	-120.3013827	Other	Agriculture	Unknown	Unknown	N.A.	101124349	N	12,000	Pole	Overhead	Y	11/7/2020	11:20	Equipment - PG&E	Pole failure	N.A.	N.A.	N.A.	Unknown whether meets reportability threshold, but confirmed to be attributable to PG&E.
PG&E	11/6/2020	10:23	38.72952752	-121.2790144	Vegetation	Herbaceous	3 meters - 0.25 Acres	Cal Fire	Cal Fire Hollister	Pole ID: 103419216	N	21,000	Pole	Overhead	Y	11/6/2020	10:20	Equipment - PG&E	Pole failure	N.A.	N.A.	N.A.	
PG&E	11/6/2020	07:23	39.3557238	-121.3672338	Vegetation	Urban	3 meters - 0.25 Acres	Fire Agency	Woodland FD	Circuit ID: 0K2571103	N	12,000	Conductor - Primary	Overhead	Y	11/6/2020	6:07	Weather	Conductor failure-all	N.A.	N.A.	Weather	High Winds
PG&E	11/5/2020	15:28	37.2014223	-120.4515363	Other	Urban	1 meter - < 3 meters	Fire Agency	Merced FD	Pole ID: 101142488	Y	12,000	Pole	Overhead	Y	11/5/2020	15:23	Contact from object	N.A.	Vehicle	Pole	N.A.	
PG&E	11/5/2020	13:59	39.2545	-120.6854	Vegetation	Hardwood Woodla	1 meter - < 3 meters	Fire Agency	SLO FD	Circuit ID: 1B2951102	Y	750	Conductor - Secondary	Overhead	Y	11/5/2020	13:43	Contact from object	N.A.	Vegetation	Conductor - M	N.A.	
PG&E	11/4/2020	20:42	37.1114867	-121.9893067	Other	Herbaceous	0.25 - 10 Acres	Cal Fire	N.A.	Circuit ID: 2L4611106	N	12,000	Conductor - Primary	Overhead	Y	11/4/2020	21:40	Contact from object	N.A.	Balloon	Conductor - M	N.A.	
PG&E	11/2/2020	15:24	37.2829817	-120.5864565	Other	Herbaceous	0.25 - 10 Acres	Cal Fire	N.A.	Pole ID: 3564701	N	115,000	Insulator	Overhead	Y	11/2/2020	15:14	Contact from object	N.A.	Animal	Insulator	N.A.	
PG&E	11/2/2020	14:35	38.265208	-121.2954068	Vegetation	Agriculture	3 meters - 0.25 Acres	Fire Agency	Clements FD	Circuit ID: 1C3682102; SAP ID: 100078887	Y	12,000	Conductor - Primary	Overhead	Y	11/2/2020	14:12	Contact from object	N.A.	Vegetation	Conductor - M	N.A.	
PG&E	11/2/2020	12:15	34.4617500	-119.6954967	Vegetation	Herbaceous	3 meters - 0.25 Acres	Fire Agency	Santa Barbara FD	Circuit ID: 1B3101102; SAP ID: 101012403	Y	12,000	Splice/Clamp/Connector	Overhead	Y	11/2/2020	11:58	Equipment - PG&E	Splice/Clamp/Connector	N.A.	N.A.	N.A.	
PG&E	10/31/2020	18:33	37.67998999	-121.90572	Vegetation	Urban	3 meters - 0.25 Acres	Unknown	N.A.	100953498	Unknown	21,000	Riser	Underground	Y	10/31/2020	18:22	Equipment - PG&E	Riser Failure	N.A.	N.A.	N.A.	
PG&E	10/31/2020	16:58	37.342387	-120.784127	Vegetation	Conifer Forest	0.25 - 10 Acres	Cal Fire	Kern County FD	Circuit ID: 2L2611102	N	60,000	Conductor - Transmission	Overhead	Y	10/31/2020	9:53	Equipment - PG&E	Conductor failure-all	N.A.	N.A.	N.A.	
PG&E	10/31/2020	10:23	40.180987	-122.20135	Vegetation	Urban	Unknown	Cal Fire	N.A.	Meter: 1008635705	Y	750	Service Drop	Overhead	N	N.A.	N.A.	Contact from object	N.A.	Vegetation	Service Drop	N.A.	Unknown whether meets reportability threshold, but confirmed to be attributable to PG&E.
PG&E	10/30/2020	07:37	36.39936715	-121.2162969	Vegetation	Barren/Other	3 meters - 0.25 Acres	Fire Agency	Greenfield FD	Pole ID: 105781308	N	21,000	Pole	Overhead	Y	10/30/2020	6:51	Contact from object	N.A.	Vehicle	Pole	N.A.	
PG&E	10/28/2020	01:50	35.62775795	-120.2742111	Vegetation	Herbaceous	3 meters - 0.25 Acres	Fire Agency	Eastline FD	Pole ID: 101476516	Y	12,000	Pole	Overhead	Y	10/28/2020	1:40	Equipment - PG&E	Pole Failure	N.A.	N.A.	N.A.	
PG&E	10/28/2020	00:17	39.3281545	-121.7334526	Vegetation	Conifer Forest	0.25 - 10 Acres	Cal Fire	Carmel Highlands and Cypress FPD, Pebble	Circuit ID: 1B2291102; SAP ID: 101758299	Y	12,000	Conductor - Primary	Overhead	Y	10/28/2020	00:15	Contact from object	N.A.	Vegetation	Conductor - M	N.A.	
PG&E	10/27/2020	23:38	37.89804376	-121.7615529	Vegetation	Herbaceous	0.25 - 10 Acres	Fire Agency	East Contra Costa FD	Pole ID: 100498278	Y	21,000	Pole	Overhead	Y	10/27/2020	23:23	Contact from object	N.A.	Vehicle	Pole	N.A.	
PG&E	10/27/2020	18:45	38.58788411	-122.6601852	Vegetation	Herbaceous	3 meters - 0.25 Acres	Cal Fire	N.A.	Circuit ID: 0K2711101; SAP ID: 102220160	Y	12,000	Conductor - Primary	Overhead	Y	10/27/2020	18:40	Contact from object	N.A.	Vegetation	Conductor - M	N.A.	
PG&E	10/27/2020	13:14	38.3543039	-121.7493258	Vegetation	Agriculture	3 meters - 0.25 Acres	Fire Agency	Dixon FD	Circuit ID: 0K2061103	Y	750	Grounding Wire	Overhead	N	N.A.	N.A.	Equipment - PG&E	#N/A	N.A.	N.A.	N.A.	
PG&E	10/27/2020	10:41	37.333577	-121.91711	Vegetation	Hardwood Woodla	3 meters - 0.25 Acres	Fire Agency	San Jose FD	Circuit ID: 0B3912110	Y	21,000	Conductor - Primary	Overhead	Y	10/27/2020	10:27	Equipment - PG&E	Conductor failure-all	N.A.	N.A.	N.A.	
PG&E	10/26/2020	6:38	37.660745	-122.423083	Building	Urban	Structure Only	Fire Agency	South San Francisco	N.A.	Y	12,000	Service Drop	Overhead	Y	10/26/2020	6:38	Under Investigation	N.A.	N.A.	N.A.	N.A.	PG&E has included the following ignition that meets Electric Incident Report criteria, defined by Appendix B to CPUC D.06-04-055. PG&E has not formed a conclusion about the origin or cause of this particular ignition.
PG&E	10/26/2020	16:31	38.43356358	-122.3082086	Vegetation	Conifer Forest	3 meters - 0.25 Acres	Fire Agency	Graton FD	Pole ID: 102025462	Y	12,000	Tie Wire	Overhead	Y	10/26/2020	16:29	Equipment - PG&E	Tie wire failure	N.A.	N.A.	N.A.	
PG&E	10/26/2020	13:50	40.61851	-124.16208	Vegetation	Herbaceous	3 meters - 0.25 Acres	Cal Fire	N.A.	1727-1334814/2017	Y	750	Splice/Clamp/Connector	Overhead	Y	10/26/2020	13:44	Equipment - PG&E	Splice/Clamp/Connector	N.A.	N.A.	N.A.	
PG&E	10/26/2020	12:59	38.909134	-123.439374	Vegetation	Conifer Forest	0.25 - 10 Acres	Fire Agency	The Oswald Tudor FD	Circuit ID: 0L3711101; SAP ID: 101298959; 101298558	Y	12,000	Conductor - Primary	Overhead	Y	10/26/2020	12:00	Contact from object	N.A.	Vegetation	Conductor - M	N.A.	
PG&E	10/26/2020	06:05	37.27256	-121.884359	Building	Urban	1 meter - < 3 meters	Fire Agency	San Jose FD	Circuit ID: 0B2111102	Y	12,000	Conductor - Primary	Overhead	Y	10/26/2020	4:55	Contact from object	N.A.	Vegetation	Conductor - M	N.A.	
PG&E	10/26/2020	4:44	38.3577241	-122.6914588	Vegetation	Urban	3 meters - 0.25 Acres	Fire Agency	Fairfield FD	Circuit ID: 0K2611106; SAP ID: 101691458	Y	12,000	Conductor - Primary	Overhead	Y	10/26/2020	4:40	Contact from object	N.A.	Vegetation	Conductor - M	N.A.	
PG&E	10/26/2020	3:16	38.3658877	-122.8163198	Vegetation	Herbaceous	0.25 - 10 Acres	Fire Agency	Solid Ridge FD	Circuit ID: 0K2571104; SAP ID: 101989515	Y	12,000	Conductor - Primary	Overhead	Y	10/26/2020	3:11	Contact from object	N.A.	Vegetation	Conductor - M	N.A.	
PG&E	10/26/2020	00:16	37.454187	-121.877271	Vegetation	Urban	1 meter - < 3 meters	Fire Agency	San Jose FD	Circuit ID: 0B3111108	Y	12,000	Conductor - Primary	Overhead	Y	10/26/2020	2:53	Weather	Conductor failure-all	N.A.	N.A.	Weather	High Winds
PG&E	10/26/2020	00:08	38.369508	-122.032843	Other	Urban	3 meters - 0.25 Acres	Fire Agency	Fairfield FD	Circuit ID: 0K2311102	Y	12,000	Conductor - Primary	Overhead	Y	10/25/2020	23:53	Weather	Conductor failure-all	N.A.	N.A.	Weather	High Winds
PG&E	10/25/2020	17:31	38.3648611	-121.397012	Vegetation	Urban	1 meter - < 3 meters	Cal Fire	N.A.	Circuit ID: 1K2571102	N	12,000	Conductor - Primary	Overhead	N	N.A.	N.A.	Equipment - PG&E	Conductor failure-all	N.A.	N.A.	N.A.	
PG&E	10/24/2020	14:42	38.010305	-121.639517	Other	Herbaceous	3 meters - 0.25 Acres	Fire Agency	Contra Costa FD	Pole ID: 100760889	Y	21,000	Insulator	Overhead	Y	10/24/2020	13:28	Equipment - PG&E	Insulator	N.A.	N.A.	N.A.	
PG&E	10/23/2020	21:43	38.8850136	-122.6023075	Other	Herbaceous	1 meter - < 3 meters	Self Extinguished	N.A.	Pole ID: 101187737	N	12,000	Fuse	Overhead	N	N.A.	N.A.	Equipment - PG&E	Fuse	N.A.	N.A.	N.A.	
PG&E	10/22/2020	15:23	39.38679	-121.05692	Vegetation	Conifer Forest	1 meter - < 3 meters	Cal Fire	N.A.	Circuit ID: 1C2481104; SAP Equ ID: 100077383	Y	12,000	Conductor - Primary	Overhead	Y	10/22/2020	15:06	Contact from object	N.A.	Vegetation	Conductor - M	N.A.	
PG&E	10/22/2020	15:09	38.600174	-120.1610388	Vegetation	Herbaceous	1 meter - < 3 meters	Customer	N.A.	Pole ID: 101837638	Y	12,000	Splice/Clamp/Connector	Overhead	Y	10/22/2020	14:55	Equipment - PG&E	#N/A	N.A.	N.A.	N.A.	
PG&E	10/22/2020	09:02	39.56865247	-120.627737K	Vegetation	Conifer Forest	3 meters - 0.25 Acres	Fire Agency	Sierra City FD	Pole ID: 103110621	N	12,000	Fuse	Overhead	Y	10/22/2020	8:54	Equipment - PG&E	Fuse Failure - all	N.A.	N.A.	N.A.	
PG&E	10/22/2020	00:02	38.14979	-122.23167	Vegetation	Herbaceous	3 meters - 0.25 Acres	Fire Agency	Red Bluff FD	Pole ID: 101137275	Y	750	Grounding Wire	Overhead	N	N.A.	N.A.	Equipment - PG&E	Groundline Wire	N.A.	N.A.	Weather	High Winds
PG&E	10/22/2020	07:39	38.478856	-121.317753	Vegetation	Urban	0.25 - 10 Acres	Cal Fire	N.A.	Pole ID: 100045052/101/001	Y	12,000	Pole	Overhead	Y	10/22/2020	7:06	Contact from object	N.A.	Vehicle	Pole	N.A.	
PG&E	10/21/2020	15:52	38.2567310	-121.7129917	Other	Urban	1 meter - < 3 meters	Fire Agency	Rio Vista FD	Circuit ID: 0K3642107	Y	12,000	Splice/Clamp/Connector	Overhead	Y	10/21/2020	15:43	Equipment - PG&E	#N/A	N.A.	N.A.	N.A.	
PG&E	10/21/2020	14:50	38.1585390	-121.9317667	Vegetation	Urban	3 meters - 0.25 Acres	Fire Agency	Rio Vista FD	Circuit ID: 0K3672215	Y	12,000	Service Drop	Overhead	Y	10/21/2020	14:32	Contact from object	N.A.	Vegetation	Service Drop	N.A.	
PG&E	10/19/2020	20:02	38.101348	-121.581958	Vegetation	Urban	1 meter - < 3 meters	Fire Agency	Elkhorn FD	Circuit ID: 1C2821101	Y	12,000	Conductor - Primary	Overhead	Y	10/19/2020	19:53	Equipment - PG&E	Conductor failure-all	N.A.	N.A.	N.A.	
PG&E	10/19/2020	15:23	35.5972683	-120.6578606	Other	Barren/Other	3 meters - 0.25 Acres	Fire Agency	Paso Robles FD	Circuit ID: 1B2611106; SAP: 41123146	Y	21,000	Jumper	Overhead	Y	10/19/2020	15:21	Equipment - PG&E	#N/A	N.A.	N.A.	N.A.	
PG&E	10/19/2020	15:20	37.9455645	-121.8663629	Other	Herbaceous	0.25 - 10 Acres	Cal Fire	N.A.	Pole ID: 103101988	N	750	Riser	Overhead	Y	10/19/2020	15:13	Equipment - PG&E	Riser Failure	N.A.	N.A.	N.A.	
PG&E	10/19/2020	13:30	38.9155916	-121.2403217	Other	Herbaceous	0.25 - 10 Acres	Fire Agency	Lincoln FD	Pole ID: 100089748	N	12,000	Lightning Arrester	Overhead	Y	10/19/2020	13:20	Contact from object	N.A.	Animal	Lightning Arres	N.A.	

PG&E	10/17/2020	13:27	38.420363	-122.954797	Building	Hardwood Forest	1 meter - < 3 meters	Cal Fire	N.A.	N.A.	N.A.	12,000	N.A.	Overhead	N	N.A.	N.A.	Under Investigation	N.A.	N.A.	N.A.	N.A.	PG&E has included the following ignition that meets Electric Incident Report criteria, defined by Appendix B to CPUC D.06-04-055. PG&E has not formed a conclusion about the origin or cause of this particular ignition.
PG&E	10/17/2020	15:10	36.726413	-119.767777	Vegetation	Urban	3 meters - 0.25 Acres	Fire Agency	Fresno FD	Meter: 1010546607	Y	750	Service Drop	Overhead	Y	10/17/2020	15:10	Equipment - PG&E	Conductor failure-all	N.A.	N.A.	N.A.	
PG&E	10/16/2020	11:01	36.956586	-121.727017	Other	Urban	3 meters - 0.25 Acres	Customer	N.A.	LR: 135762	Y	21,000	Recloser	Overhead	Y	10/16/2020	11:01	Contact from object	N.A.	Animal	Recloser	N.A.	
PG&E	10/16/2020	04:23	38.41125	-122.9801	Vegetation	Conifer Forest	3 meters - 0.25 Acres	Cal Fire	N.A.	Circuit ID: 042571102, SAP: 101974096	Y	12,000	Conductor - Primary	Overhead	Y	10/16/2020	4:13	Contact from object	N.A.	Vegetation	Conductor - Pr	N.A.	
PG&E	10/15/2020	19:39	39.0272439	-121.8666465	Vegetation	Agriculture	0.25 - 10 Acres	Fire Agency	Colusa FD	Pole ID: 103689220	N	12,000	Splice/Clamp/Connector	Overhead	Y	10/15/2020	19:34	Equipment - PG&E	Splice/Clamp/Connector	N.A.	N.A.	N.A.	
PG&E	10/15/2020	07:08	40.32359121	-122.4294287	Vegetation	Hardwood Woodla	1 meter - < 3 meters	Cal Fire	N.A.	Circuit ID: 101511399, SAP Eqp ID: 101511399	Y	12,000	Conductor - Primary	Overhead	Y	10/15/2020	7:02	Contact from object	N.A.	Vehicle	Conductor - Pr	N.A.	
PG&E	10/15/2020	12:44	40.3614283	-122.3492700	Vegetation	Hardwood Woodla	1 meter - < 3 meters	Cal Fire	N.A.	Circuit ID: 102931101	Y	12,000	Conductor - Primary	Overhead	Y	10/15/2020	13:56	Contact from object	N.A.	Vegetation	Conductor - Pr	N.A.	
PG&E	10/15/2020	13:01	40.594253	-122.238678	Vegetation	Herbaceous	3 meters - 0.25 Acres	Cal Fire	N.A.	Circuit ID: 103351104	N	750	Service Drop	Overhead	N	N.A.	N.A.	Contact from object	N.A.	Vegetation	Service Drop	N.A.	
PG&E	10/14/2020	19:22	38.8072617	-121.2052067	Other	Urban	3 meters - 0.25 Acres	Fire Agency	Rocklin FD	Pole ID: 100058463	N	12,000	Pole	Overhead	Y	10/14/2020	20:00	Contact from object	N.A.	Vehicle	Pole	N.A.	
PG&E	10/14/2020	18:45	39.67734879	-121.843927	Vegetation	Agriculture	0.25 - 10 Acres	Cal Fire	N.A.	103081107	Y	12,000	Conductor - Primary	Overhead	Y	10/14/2020	18:45	Contact from object	N.A.	Vegetation	Conductor - Pr	N.A.	
PG&E	10/13/2020	16:21	35.554244	-119.805426	Other	Herbaceous	0.25 - 10 Acres	Cal Fire	N.A.	252321103	Y	12,000	Conductor - Primary	Overhead	Y	10/13/2020	16:21	Contact from object	N.A.	Balloon	Conductor - Pr	N.A.	
PG&E	10/13/2020	14:34	38.034359	-121.650673	Other	Herbaceous	1 meter - < 3 meters	Fire Agency	Contra Costa FD	Circuit ID: 014592112 Pole ID: 100457182	Y	21,000	Conductor - Primary	Overhead	Y	10/13/2020	14:27	Equipment - PG&E	Insulator failure	N.A.	N.A.	N.A.	
PG&E	10/13/2020	00:02	37.8028847	-122.2789089	Vegetation	Urban	1 meter - < 3 meters	Fire Agency	Oakland FD	Circuit ID: 012011113	Y	750	Service Drop	Overhead	N	N.A.	N.A.	Equipment - PG&E	Conductor failure-all	N.A.	N.A.	N.A.	
PG&E	10/12/2020	00:05	40.513569	-124.128161	Vegetation	Agriculture	3 meters - 0.25 Acres	Fire Agency	Rio Dell FD	Circuit ID: 192251101, between Pole ID: 100998306 and 10316848	N	12,000	Splice/Clamp/Connector	Overhead	Y	10/11/2020	23:57	Equipment - PG&E	Splice/Clamp/Connector	N.A.	N.A.	N.A.	
PG&E	10/11/2020	23:29	37.02175	-120.0712	Vegetation	Urban	1 meter - < 3 meters	Cal Fire	N.A.	254611111	Y	12,000	Conductor - Primary	Overhead	Y	10/11/2020	23:29	Contact from object	N.A.	Vegetation	Conductor - Pr	N.A.	
PG&E	10/10/2020	01:13	35.38734	-118.93934	Vegetation	Urban	3 meters - 0.25 Acres	Fire Agency	Bakersfield FD	Circuit ID: 253951109, SAP ID: 102296159	Y	12,000	Conductor - Primary	Overhead	Y	10/10/2020	1:11	Equipment - PG&E	Splice/Clamp/Connector	N.A.	N.A.	N.A.	
PG&E	10/7/2020	13:08	39.1488650	-122.2519667	Vegetation	Agriculture	3 meters - 0.25 Acres	Fire Agency	Williams FD	Circuit ID: 062051102	N	12,000	Conductor - Primary	Overhead	Y	10/7/2020	12:49	Contact from object	N.A.	Animal	Conductor - Pr	N.A.	
PG&E	10/5/2020	14:44	38.11667999	-120.89073	Vegetation	Herbaceous	0.25 - 10 Acres	Cal Fire	Cal Fire and Calaveras Consolidated Fire	Circuit ID: 162991102	Y	12,000	Conductor - Primary	Overhead	Y	10/5/2020	14:40	Contact from object	N.A.	Vehicle	Conductor - Pr	N.A.	
PG&E	10/4/2020	16:23	38.7308483	-121.1934033	Vegetation	Urban	3 meters - 0.25 Acres	Fire Agency	Granite Bay FD	Circuit ID: 152571105, SAP ID: 100066291	Y	12,000	Conductor - Primary	Overhead	Y	10/4/2020	16:18	Contact from object	N.A.	Vegetation	Conductor - Pr	N.A.	
PG&E	10/4/2020	16:23	35.629891	-120.360282	Vegetation	Agriculture	3 meters - 0.25 Acres	Self Extinguished	N.A.	Circuit ID: 182562102	Y	21,000	Conductor - Primary	Overhead	Y	10/4/2020	16:04	Equipment - PG&E	Conductor failure-all	N.A.	N.A.	N.A.	
PG&E	10/3/2020	16:47	38.50541449	-122.8391961	Vegetation	Agriculture	3 meters - 0.25 Acres	Fire Agency	Sonoma County FD	Circuit ID: 042561102, SAP ID: 103593452	Y	12,000	Conductor - Secondary	Overhead	Y	10/3/2020	17:46	Contact from object	N.A.	Vegetation	Conductor - Se	N.A.	
PG&E	10/3/2020	15:29	37.48888	-122.206464	Vegetation	Urban	3 meters - 0.25 Acres	Fire Agency	Redwood City FD	Circuit ID: 024161102	Y	12,000	Conductor - Primary	Overhead	Y	10/3/2020	14:33	Contact from object	N.A.	Animal	Conductor - Pr	N.A.	
PG&E	10/2/2020	20:10	37.2524683	-120.3159017	Vegetation	Agriculture	3 meters - 0.25 Acres	Cal Fire	N.A.	Circuit ID: 255361112, SAP ID: 101082275	Y	12,000	Service Drop	Overhead	Y	10/2/2020	21:06	Contact from object	N.A.	Vegetation	Service Drop	N.A.	
PG&E	10/2/2020	15:45	39.13299	-121.079172	Vegetation	Hardwood Woodla	0.25 - 10 Acres	Cal Fire	N.A.	Circuit ID: 152691103	Y	12,000	Conductor - Primary	Overhead	Y	10/2/2020	15:21	Contact from object	N.A.	Vegetation	Conductor - Pr	N.A.	
PG&E	10/2/2020	15:12	38.46804	-121.93695	Vegetation	Urban	1 meter - < 3 meters	Customer	N.A.	Circuit ID: 063591103	Y	12,000	Conductor - Primary	Overhead	Y	10/2/2020	15:02	Contact from object	N.A.	Vegetation	Conductor - Pr	N.A.	
PG&E	10/1/2020	12:05	37.004527	-120.083501	Vegetation	Urban	0.25 - 10 Acres	Cal Fire	N.A.	Circuit ID: 254611111	Y	12,000	Conductor - Primary	Overhead	Y	10/1/2020	12:05	Contact from object	N.A.	Vegetation	Conductor - Pr	N.A.	
PG&E	9/29/2020	16:22	38.245509	-121.76179	Vegetation	Herbaceous	1 meter - < 3 meters	Customer	N.A.	Pole ID: 101582151	Y	12,000	Pole	Overhead	Y	9/29/2020	16:36	Contact from object	N.A.	Vehicle	Pole	N.A.	
PG&E	9/29/2020	01:40	38.83678	-122.029068	Vegetation	Herbaceous	3 meters - 0.25 Acres	Utility - PG&E	N.A.	Circuit ID: 102841102	N	12,000	Conductor - Primary	Overhead	Y	9/29/2020	1:22	Contact from object	N.A.	Vegetation	Conductor - Pr	N.A.	
PG&E	9/28/2020	18:21	37.965176	-122.138831	Vegetation	Hardwood Woodla	3 meters - 0.25 Acres	Customer	N.A.	1006560423	Y	12,000	Service Drop	Overhead	Y	9/28/2020	18:19	Unknown	Conductor failure-all	N.A.	N.A.	Unknown	Unknown as to what caused the initial failure, but initial investigation found the ignition to be attributable to PG&E facilities
PG&E	9/28/2020	15:51	39.65306	-121.449352	Vegetation	Conifer Forest	3 meters - 0.25 Acres	Cal Fire	N.A.	Circuit ID: 103751102	Y	12,000	Conductor - Primary	Overhead	Y	9/28/2020	15:45	Contact from object	N.A.	Vegetation	Conductor - Pr	N.A.	
PG&E	9/28/2020	13:35	37.957961	-122.273589	Other	Urban	3 meters - 0.25 Acres	Fire Agency	Richmond FD	14341106	Y	12,000	Conductor - Insulated Secondary	Overhead	N	N.A.	N.A.	Equipment - PG&E	Conductor failure-all	N.A.	N.A.	N.A.	
PG&E	9/28/2020	8:57	37.52923	-121.99005	Vegetation	Urban	3 meters - 0.25 Acres	Fire Agency	Fremont FD	Pole ID: 100946344	Y	12,000	Pole	Overhead	Y	9/28/2020	8:40	Contact from object	N.A.	Vehicle	Pole	N.A.	
PG&E	9/27/2020	14:48	40.539222	-122.56662	Vegetation	Hardwood Forest	100 + Acres	Cal Fire	N.A.	N.A.	N.A.	12,000	N.A.	Overhead	Y	9/27/2020	14:48	Under Investigation	N.A.	N.A.	N.A.	N.A.	PG&E has included the Zogg Fire in this ignition report because CAL FIRE has announced that the cause of the Zogg Fire was a pine tree contacting PG&E overhead electric lines. PG&E's investigation into the cause of the Zogg Fire is ongoing
PG&E	9/27/2020	19:32	38.27363	-122.57607	Vegetation	Herbaceous	3 meters - 0.25 Acres	Fire Agency	Petaluma FD	Circuit ID: 043371102 between Pole ID: 101990098 and 10200500	Y	12,000	Automatic Wire Splice	Overhead	Y	9/27/2020	19:24	Equipment - PG&E	Splice/Clamp/Connector	N.A.	N.A.	N.A.	
PG&E	9/27/2020	16:56	37.7884817	-121.7699533	Vegetation	Urban	0.25 - 10 Acres	Fire Agency	San Ramon FD	Circuit ID: 014422109, Fuse: 71415	Y	21,000	Fuse	Overhead	Y	9/27/2020	16:24	Equipment - PG&E	Fuse failure - all	N.A.	N.A.	N.A.	
PG&E	9/27/2020	15:30	40.4491500	-122.3089300	Vegetation	Urban	3 meters - 0.25 Acres	Fire Agency	Anderson FD	Circuit ID: 103261101, SAP ID: 101496897	Y	12,000	Service Drop	Overhead	Y	9/27/2020	15:27	Contact from object	N.A.	Vegetation	Service Drop	N.A.	
PG&E	9/27/2020	08:11	37.9970867	-123.0156333	Vegetation	Shrub	0.25 - 10 Acres	Cal Fire	N.A.	Circuit 042291101 Pole ID:102246615	Y	12,000	Conductor - Primary	Overhead	Y	9/27/2020	9:13	Equipment - PG&E	Conductor failure-all	N.A.	N.A.	N.A.	
PG&E	9/26/2020	20:16	39.12809	-121.639179	Vegetation	Urban	Unknown	Fire Agency	Yuba City Fire dept	101300049	Y	12,000	Insulator	Overhead	N	N.A.	N.A.	Equipment - PG&E	Insulator failure	N.A.	N.A.	N.A.	Unknown whether meets reportability threshold, but confirmed to be attributable to PG&E.
PG&E	9/24/2020	15:44	39.2652567	-121.5293633	Vegetation	Agriculture	3 meters - 0.25 Acres	Cal Fire	N.A.	Circuit ID: 103211102	Y	12,000	Conductor - Primary	Overhead	Y	9/24/2020	16:01	Contact from object	N.A.	Vehicle	Conductor - Pr	N.A.	
PG&E	9/23/2020	15:31	38.2262883	-122.5311867	Vegetation	Herbaceous	10 - 100 Acres	Cal Fire	N.A.	Pole ID: 103999142	Y	12,000	Pole	Overhead	Y	9/23/2020	15:23	Contact from object	N.A.	Vehicle	Pole	N.A.	
PG&E	9/23/2020	12:17	37.6869067	-122.1469900	Vegetation	Urban	3 meters - 0.25 Acres	Fire Agency	Alco FD	Circuit ID: 013111110	Y	12,000	Conductor - Primary	Overhead	Y	9/23/2020	12:02	Contact from object	N.A.	Balloon	Conductor - Pr	N.A.	
PG&E	9/23/2020	10:26	36.81848	-121.45068	Vegetation	Herbaceous	10 - 100 Acres	Cal Fire	N.A.	Pole ID: 182742101	N	21,000	Conductor - Primary	Overhead	Y	9/23/2020	23:31	Contact from object	N.A.	Animal	Conductor - Pr	N.A.	
PG&E	9/22/2020	10:32	38.096469	-121.521445	Vegetation	Agriculture	3 meters - 0.25 Acres	Customer	N.A.	Circuit ID: 062462224	Y	21,000	Conductor - Primary	Overhead	Y	9/22/2020	7:44	Equipment - PG&E	Conductor failure-all	N.A.	N.A.	N.A.	
PG&E	9/21/2020	19:51	38.60626	-121.02263	Vegetation	Herbaceous	0.25 - 10 Acres	Cal Fire	N.A.	Circuit ID: 153612103	Y	12,000	Conductor - Primary	Overhead	Y	9/21/2020	19:40	Equipment - PG&E	Conductor failure-all	N.A.	N.A.	N.A.	
PG&E	9/21/2020	12:05	39.4684733	-121.5774917	Building	Urban	Unknown	Self Extinguished	N.A.	100359938	Y	12,000	Pole	Overhead	Y	9/21/2020	11:56	Equipment - PG&E	Pole failure	N.A.	N.A.	N.A.	Unknown whether meets reportability threshold, but confirmed to be attributable to PG&E.
PG&E	9/20/2020	11:50	36.5333883	-121.4238217	Vegetation	Barren/Other	3 meters - 0.25 Acres	Fire Agency	Gonzales FD	Circuit ID: 182131101	Y	12,000	Conductor - Primary	Overhead	Y	9/20/2020	11:46	Equipment - PG&E	Conductor failure-all	N.A.	N.A.	N.A.	
PG&E	9/18/2020	21:52	34.413213	-119.081145	Vegetation	Shrub	3 meters - 0.25 Acres	Fire Agency	Kern County FD	Circuit ID: 253391106	Y	12,000	Conductor - Primary	Overhead	Y	9/18/2020	21:50	Contact from object	N.A.	Vegetation	Conductor - Pr	N.A.	
PG&E	9/18/2020	17:49	38.718824	-121.784135	Vegetation	Agriculture	1 meter - < 3 meters	Fire Agency	Willow Creek FD	Circuit ID: 063191105	Y	12,000	Conductor - Primary	Overhead	Y	9/18/2020	16:38	Contact from object	N.A.	Vegetation	Conductor - Pr	N.A.	
PG&E	9/18/2020	15:20	38.4263450	-122.6845133	Vegetation	Hardwood Forest	1 meter - < 3 meters	Fire Agency	Santa Rosa FD	Circuit ID: 042151111	Y	750	Conductor - Secondary	Overhead	Y	9/18/2020	15:52	Contact from object	N.A.	Vegetation	Conductor - Se	N.A.	
PG&E	9/17/2020	14:19	36.555105	-119.242165	Vegetation	Agriculture	3 meters - 0.25 Acres	Fire Agency	Tulare County FD	Pole ID: 100725983	N	12,000	Guy/Span Wire	Overhead	Y	9/17/2020	13:58	Contact from object	N.A.	Vehicle	Guy/Span Wir	N.A.	
PG&E	9/17/2020	08:54	38.833792	-121.189394	Other	Urban	1 meter - < 3 meters	Unknown	N.A.	3423	N	12,000	Pothead	Overhead	Y	9/17/2020	8:47	Contact from object	N.A.	Animal	Pothead	N.A.	
PG&E	9/16/2020	16:47	37.691001	-122.412634	Vegetation	Urban	0.25 - 10 Acres	Cal Fire	Cal Fire/Brisbane FD	Switch: 2849	Y	12,000	Splice/Clamp/Connector	Overhead	Y	9/16/2020	16:35	Equipment - PG&E	Fuse failure - all	N.A.	N.A.	N.A.	
PG&E	9/14/2020	06:11	36.01766	-119.47365	Vegetation	Herbaceous	3 meters - 0.25 Acres	Cal Fire	N.A.	046/346	N	115,000	Conductor - Transmission	Overhead	Y	9/14/2020	6:02	Contact from object	N.A.	Animal	Conductor - Tr	N.A.	
PG&E	9/12/2020	14:29	37.8796667	-120.4571033	Vegetation	Urban	0.25 - 10 Acres	Cal Fire	N.A.	Circuit ID: 163781701	N	17,000	Conductor - Secondary	Overhead	N	N.A.	N.A.	Contact from object	N.A.	Vehicle	Conductor - Se	N.A.	
PG&E	9/11/2020	10:34	38.95639912	-121.1061578	Other	Hardwood Woodla	1 meter - < 3 meters	Fire Agency	Auburn FD	Fuse: 9953	Y	12,000	Fuse	Overhead	Y	9/11/2020	10:24	Contact from object	N.A.	Animal	Fuse	N.A.	
PG&E	9/9/2020	10:48	38.168543	-120.39128	Vegetation	Shrub	0.25 - 10 Acres	Cal Fire	N.A.	Eqp ID: 79826	N	17,000	Recloser	Padmounted	Y	9/9/2020	10:53	Equipment - PG&E	Recloser failure	N.A.	N.A.	N.A.	
PG&E	9/8/2020	22:02	40.018248	-122.087647	Vegetation	Agriculture	3 meters - 0.25 Acres	Cal Fire	N.A.	Circuit ID: 103481102	Y	12,000	Conductor - Primary	Overhead	Y	9/8/2020	20:55	Contact from object	N.A.	Vegetation	Conductor - Pr	N.A.	
PG&E	9/8/2020	18:18	38.4478783	-121.8583117	Vegetation	Agriculture	3 meters - 0.25 Acres	Fire Agency	Dixon FD	Circuit ID: 062061106	Y	12,000	Conductor - Primary	Overhead	Y	9/8/2020	18:12	Contact from object	N.A.	Animal	Conductor - Pr	N.A.	
PG&E	9/8/2020	14:41	37.653499	-121.673915	Other	Agriculture	0.25 - 10 Acres	Cal Fire	N.A.	Circuit ID: 013751102	Y	12,000	Conductor - Primary	Overhead	Y	9/8/2020	14:30	Equipment - PG&E	Conductor failure-all	N.A.	N.A.	N.A.	
PG&E	9/8/2020	11:21	40.437373	-122.299072	Other	Urban	1 meter - < 3 meters	Fire Agency	Anderson FD	Circuit ID: 103261101	Y	12,000	Conductor - Secondary	Overhead	Y	9/8/2020	11:20	Contact from object	N.A.	Vegetation	Conductor - Se	N.A.	
PG&E	9/8/2020	03:06	40.1864933	-122.21408	Vegetation	Urban	0.25 - 10 Acres	Cal Fire	N.A.	Circuit ID: 103531103, SAP Eqp ID: 101544948	Y	12,000	Pole	Overhead	Y	9/8/2020	3:39	Equipment - PG&E	#N/A	N.A.	N.A.	N.A.	
PG&E	9/8/2020	02:33	40.4683953	-122.3113687	Vegetation	Urban	3 meters - 0.25 Acres	Cal Fire	N.A.	Circuit ID: 103441102, SAP ID: 101496111, 101496112	Y	12,000	Conductor - Primary	Overhead	Y	9/8/2020	1:45	Contact from object	N.A.	Vegetation	Conductor - Pr	N.A.	
PG&E	9/7/2020	04:26	37.948679	-122.520107	Vegetation	Urban	3 meters - 0.25 Acres	Fire Agency	Central Marin FD	Meter: 1007683605	Y	750	Service Drop	Overhead	Y	9/7/2020	04:26	Contact from object	N.A.	Vegetation	Service Drop	N.A.	
PG&E	9/7/2020	18:04	37.000816	-121.885086	Vegetation	Conifer Forest	1 meter - < 3 meters	Fire Agency	Rio Del Mar FD	Circuit ID: 083692105	Y	21,000	Conductor - Primary	Overhead	Y	9/7/2020	18:30	Contact from object	N.A.	Vegetation	Conductor - Pr	N.A.	
PG&E	9/7/2020	16:18	38.83104154	-123.0471393	Vegetation	Hardwood Forest	3 meters - 0.25 Acres	Cal Fire	N.A.	Circuit ID: 042821101, SAP ID: 101964553	Y	12,000	Conductor - Primary	Overhead	Y	9/7/2020	16:14	Contact from object	N.A.	Other	Conductor - Pr	Weather	Communication line making contact with Primary
PG&E	9/7/2020	11:27	36.5459317	-121.3914033	Other	Herbaceous	0.25 - 10 Acres	Fire Agency	Gonzales FD	Structure: 018/093; SAP Eqp: 40650909	N	115,000	Conductor - Transmission	Overhead	Y	9/7/2020	10:58	Contact from object	N.A.	Animal	Conductor - Tr	N.A.	
PG&E	9/6/2020	20:58	37.01735	-122.12241	Vegetation	Conifer Forest	0.25 - 10 Acres	Cal Fire	Cal Fire & Scotts Valley FD	Circuit ID: 083252107	Y	21,000	Conductor - Primary	Overhead	Y	9/6/2020	17:07	Contact from object	N.A.	Vehicle	Conductor - Pr	N.A.	
PG&E	9/6/2020	16:47	36.87369593	-121.5854286	Vegetation	Hardwood Forest	0.25 - 10 Acres	Cal Fire	N.A.	CGC: 412443857077	Y	12,000	Transformer	Overhead	Y	9/6/2020	16:39	Equipment - PG&E	Transformer failure	N.A.	N.A.	N.A.	
PG&E	9/6/2020	14:29	41.249253	-123.766946	Vegetation	Conifer Forest	0.25 - 10 Acres	Cal Fire	N.A.	Circuit ID: 192401101	Y	12,000	Conductor - Primary	Overhead	Y	9/6/2020	14:27	Contact from object	N.A.	Vegetation	Conductor - Pr	N.A.	
PG&E	9/6/2020	13:09	37.7976833	-121.4547817	Other	Agriculture	3 meters - 0.25 Acres	Fire Agency	Tracy FD	Circuit ID: 162881106	Y	12,000	Conductor - Primary	Overhead	N	N.A.	N.A.	Contact from object	N.A.	Balloon	Conductor - Pr	N.A.	
PG&E	9/6/2020	13:04	38.9551	-123.591078	Other	Conifer Forest	1 meter - < 3 meters	Cal Fire	N.A.	Circuit ID: 043381101	Y	12,000	Service Drop	Overhead	N	N.A.	N.A.	Equipment - PG&E	Transformer failure	N.A.	N.A.	N.A.	
PG&E	9/6/2020	12:49	34.602574	-120.146235	Vegetation	Urban	3 meters - 0.25 Acres	Fire Agency	Santa Barbara County FD	Circuit ID: 183041102	Y	12,000	Conductor - Open Wire Secondary	Overhead	Y	9/6/2020	12:46	Equipment - PG&E	Conductor failure-all	N.A.	N.A.	N.A.	
PG&E	9/6/2020	09:00	35.5055033	-119.6895333	Vegetation	Urban	3 meters - 0.25 Acres	Fire Agency	Kern County FD	Pole ID: 100238348	Y	12,000	Pole	Overhead	Y	9/6/2020	8:41	Contact from object	N.A.	Vehicle	Pole	N.A.	
PG&E	9/5/2020	20:57	40.112855	-123.749815	Other	Herbaceous	3 meters - 0.25 Acres	Cal Fire	N.A.	44913382	N	60,000	Conductor - Transmission	Overhead	N	N.A.	N.A.	Contact from object	N.A.	Animal	Conductor - Tr	N.A.	
PG&E	9/5/2020	15:37	39.2002717	-120.8382733	Other	Conifer Forest	3 meters - 0.25 Acres	Cal Fire	N.A.	1327	N	12,000	Switch	Overhead	N	N.A.	N.A.	Equipment - PG&E	Switch failure	N.A.	N.A.	N.A.	
PG&E	9/5/2020	7:50	37.23621	-121.93641	Vegetation	Hardwood Woodla	3 meters - 0.25 Acres	Fire Agency	Santa Clara County FD	Circuit ID: 083431116, SAP ID: 100516737	Y	12,000	Conductor - Primary	Overhead	Y	9/5/2020	7:44	Contact from object	N.A.	Animal	Conductor - Pr	N.A.	
PG&E	9/5/2020	07:59	36.5865717	-121.6016483	Other	Urban	3 meters - 0.25 Acres	Cal Fire	N.A.	Circuit ID: 182731102	Y	12,000	Splice/Clamp/Connector	Overhead	Y	9/5/2020	7:38	Equipment - PG&E	Splice/Clamp/Connector	N.A.	N.A.	N.A.	
PG&E	9/4/2020	15:21	37.487902	-122.211859	Other	Urban	1 meter - < 3 meters	Fire Agency	Redwood City FD	Circuit ID: 024161102	Y	12,000	Conductor - Primary	Overhead	Y	9/4/2020	15:20	Equipment - PG&E	Conductor failure-all	N.A.	N.A.	N.A.	
PG&E	9/3/2020	13:01	34.666474	-120.132763	Other	Herbaceous	0.25 - 10 Acres	Fire Agency	Santa Barbara County FD	Circuit ID: 182721104	Y	12,000	Conductor - Primary	Overhead	Y	9/3/2020	12:45	Equipment - PG&E	Pole failure	N.A.	N.A.	N.A.	
PG&E	9/1/2020	12:04	34.8975917	-120.2976117	Vegetation	Agriculture	1 meter - < 3 meters	Customer	N.A.	CGC: 513113551650	N	12,000	Splice/Clamp/Connector	Overhead	Y	9/1/2020	13:16	Equipment - PG&E	Splice/Clamp/Connector	N.A.	N.A.	N.A.	
PG&E	9/1/2020	11:15	39.40851031	-121.2899763	Vegetation	Conifer Forest	0.25 - 10 Acres	Cal Fire	N.A.	Circuit ID: 103201102	N	12,000	Conductor - Primary	Overhead	Y	9/1/2020	10:15	Contact from object	N.A.	Vegetation	Conductor - Pr	N.A.	
PG&E	8/31/2020	10:28	38.641423	-121.589527	Other	Agriculture	3 meters - 0.25 Acres	Fire Agency	West Sacramento FD	Capacitor Bank: C497	Y	12,000	Capacitor Bank	Overhead	N	N.A.	N.A.	Equipment - PG&E	Capacitor bank failure	N.A.	N.A.	N.A.	
PG&E	8/30/2020	23:50	37.6877867	-121.4161867	Vegetation	Urban	3 meters - 0.25 Acres	Fire Agency	Tracy FD	Circuit ID: 163091101; SAP ID: 102054685	Y	12,000	Conductor - Primary	Overhead	Y	8/30/2020	22:40	Equipment - PG&E	Conductor failure-all	N.A.	N.A.	N.A.	
PG&E	8/30/2020	13:30	36.78185	-119.81126	Vegetation	Urban	1 meter - < 3 meters	Unknown	N.A.	Meter: 1004234040	Y	750	Service Drop	Overhead	Y	8/30/2020	14:29	Equipment - PG&E	Conductor failure-all	N.A.	N.A.	N.A.	
PG&E	8/30/2020	13:24	39.486	-121.5062	Vegetation	Urban	1 meter - < 3 meters	Cal Fire	N.A.	Circuit ID: 102911107, SAP ID: 100395767	Y	12,000	Conductor - Primary	Overhead	Y	8/30/2020	13:17	Contact from object	N.A.	Vegetation	Conductor - Pr	N.A.	
PG&E	8/26/2020	13:23	39.563799	-123.402385	Vegetation	Conifer Forest	0.25 - 10 Acres	Cal Fire	Cal Fire Mendocino Unit	Circuit ID: 042681102	Y	12,000	Conductor - Primary	Overhead	Y	8/26/2020	13:19	Contact from object	N.A.	Vegetation	Conductor - Pr	N.A.	
PG&E	8/26/2020	16:05	38.113086	-121.402998	Other	Herbaceous	3 meters - 0.25 Acres	Fire Agency	Woodbridge FD	Fuse: 3783	Y	21,000	Fuse	Overhead	Y	8/26/2020	15:11	Equipment - PG&E	Fuse failure - all	N.A.	N.A.	N.A.	
PG&E	8/25/2020	07:50	37.91855	-122.55477	Vegetation	Hardwood Forest	1 meter - < 3 meters	Self Extinguished	N.A.	Fuse: 2443	Y	12,000	Fuse	Overhead	Y	8/25/2020	6:15	Equipment - PG&E	Fuse failure - all	N.A.	N.A.	N.A.	
PG&E	8/25/2020	20:47	38.8460667	-121.3958167	Other	Agriculture	3 meters - 0.25 Acres	Cal Fire	N.A.	Circuit ID: 152442110	Y	21,000	Jumper	Overhead	Y	8/25/2020	20:46	Equipment - PG&E	#N/A	N.A.	N.A.	N.A.	
PG&E	8/25/2020	18:00	38.846093	-121.37759	Other	Agriculture	3 meters - 0.25 Acres	Cal Fire	N.A.	Circuit ID: 152442110	Y	21,000	Conductor - Primary	Overhead	Y	8/25/2020	15:30	Contact from object	N.A.	Balloon	Conductor - Pr	N.A.	
PG&E	8/25/2020	17:32	38.8374883	-121.3957267	Other	Herbaceous	0.25 - 10 Acres	Cal Fire	N.A.	Circuit ID: 152442110	N	12,000	Jumper	Overhead	Y	8/25/2020	22:17	Equipment - PG&E	#N/A	N.A.	N.A.	N.A.	
PG&E	8/25/2020	16:25	38.7389383	-121.1935583	Vegetation	Urban	3 meters - 0.25 Acres	Fire Agency	South Placer FD	Circuit ID: 152571102	Y	12,000	Conductor - Primary	Overhead	Y	8/25/2020	16:18	Contact from object	N.A.	Vegetation	Conductor - Pr	N.A.	
PG&E	8/25/2020	08:47	40.27761573	-122.3077984	Vegetation	Hardwood Woodla	3 meters - 0.25 Acres	Unknown	N.A.	CGC: 119145034420	N	12,000	Transformer	Overhead	Y	8/25/2020	8:43	Equipment - PG&E	Transformer failure	N.A.	N.A.	N.A.	
PG&E	8/24/2020	17:38	38.565739	-122.57517	Vegetation	Hardwood Forest	3 meters - 0.25 Acres	Cal Fire	N.A.	Circuit ID: 042711102	Y	12,000	Conductor - Primary	Overhead	Y	8/24/2020	17:34	Contact from object	N.A.	Vegetation	Conductor - Pr	N.A.	
PG&E	8/23/2020	06:46	36.894553	-121.815206	Vegetation	Agriculture	1 meter - < 3 meters	Fire Agency	Pajaro Dunes FD	Circuit ID: 083192103	Y	21,000	Conductor - Primary	Overhead	Y	8/23/2020	6:45	Contact from object	N.A.	Vegetation	Conductor - Pr	N.A.	
PG&E	8/23/2020	02:02	36.684414	-120.260325	Other	Herbaceous	3 meters - 0.25 Acres	Fire Agency	Fresno County Fire Prevention	Circuit ID: 252361112	Y	12,000	Conductor - Primary	Overhead	Y	8/22/2020	23:49	Equipment - PG&E	Conductor failure-all	N.A.	N.A.	N.A.	
PG&E	8/21/2020	16:35	40.60203	-122.24938	Other	Urban	0.25 - 10 Acres	Cal Fire	N.A.	Circuit ID: 103351104	Y	12,000	Conductor - Primary	Overhead	Y	8/21/2020	11:31	Contact from object	N.A.	Vehicle	Conductor - Pr	N.A.	
PG&E	8/21/2020	15:45	38.72218	-120.8100567	Other	Hardwood Woodla	0.25 - 10 Acres	Cal Fire	N.A.	Circuit: El Dorado-Missouri Flats #1, Structure: 13/115	N	12,000	Insulator	Overhead	Y	8/21/2020	15:21	Equipment - PG&E	Insulator failure	N.A.	N.A.	N.A.	
PG&E	8/21/2020	15:24	37.707014	-121.644004	Other	Herbaceous	3 meters - 0.25 Acres	Fire Agency	Alco FD	Circuit ID: 013751103	Y	12,000	Conductor - Primary	Overhead	Y	8/21/2020	15:10	Contact from object	N.A.	Vehicle	Conductor - Pr	N.A.	
PG&E	8/20/2020	19:23	40.153578	-122.238021	Vegetation	Urban	0.25 - 10 Acres	Fire Agency	Red Bluff FD	Pole ID: 101536445/A022/175	Y	12,000	Pole	Overhead	Y	8/20/2020	19:16	Contact from object	N.A.	Vehicle	Pole	N.A.	
PG&E	8/20/2020	11:47	38.932369	-122.751456	Vegetation	Herbaceous	3 meters - 0.25 Acres	Unknown	Third-Party	Circuit ID: 043311102	N	12,000	Conductor - Primary	Overhead	Y	8/20/2020	11:40	Contact from object	N.A.	Other	Conductor - Pr	Human Error	Third party excavator boom making contact with transmission line
PG&E	8/20/2020	01:49	36.2388383	-120.30149	Other	Herbaceous	0.25 - 10 Acres	Cal Fire	N.A.	Circuit ID: 252381107 Pole ID: 100743822	Y	12,000	Insulator	Overhead	Y	8/20/2020	0:51	Contact from object	N.A.	Animal	Insulator	N.A.	
PG&E	8/20/2020	00:42	39.00463	-122.89411	Other	Agriculture	1 meter - < 3 meters	Unknown	N.A.	Circuit ID: 042141101, SAP ID: 102159653	Y	12,000	Transformer	Overhead	Y	8/20/2020	0:19	Weather	Transformer failure	N.A.	N.A.	Weather	Lightning
PG&E	8/19/2020	04:41	39.0892	-121.1163	Vegetation	Herbaceous	3 meters - 0.25 Acres	Cal Fire	N.A.	Circuit ID: 152691109	Y	12,000	Conductor - Primary	Overhead	Y	8/19/2020	4:01	Contact from object	N.A.	Vegetation	Conductor - Pr	N.A.	
PG&E	8/19/2020	09:19	39.136956	-121.01754	Other	Hardwood Woodla	1 meter - < 3 meters	Unknown	N.A.	Circuit: Drum-Rio Oso #2; Structure: 16/135	N	115,000	Conductor - Transmission	Overhead	Y	8/19/2020	09:19	Contact from object	N.A.	Animal	Conductor - Tr	N.A.	
PG&E	8/19/2020	14:31	38.795	-121.2336383	Other	Urban	3 meters - 0.25 Acres	Cal Fire	N.A.	Circuit ID: 152061104	Y	12,000	Service Drop	Overhead	Y	8/19/2020	14:21	Equipment - PG&E	Conductor failure-all	N.A.	N.A.	N.A.	
PG&E	8/19/2020	6:45	39.4145	-123.781508	Other	Conifer Forest	3 meters - 0.25 Acres	Customer	N.A.	Circuit ID: 042761102	Y	12,000	Conductor - Secondary	Overhead	N	N.A.	N.A.	Contact from object	N.A.	Vegetation	Conductor - Se	N.A.	
PG&E	8/19/2020	06:41	38.836172	-120.951452	Vegetation	Herbaceous	0.25 - 10 Acres	Cal Fire	N.A.	Circuit ID: 153652109	N	21,000	Conductor - Primary	Overhead	Y	8/19/2020	6:22	Contact from object	N.A.	Vegetation	Conductor - Pr	N.A.	
PG&E	8/18/2020	18:24	37.9752138	-121.3247664	Other	Urban	3 meters - 0.25 Acres	Fire Agency	Stockton FD	Circuit: 163121106	Y	12,000	Splice/Clamp/Connector	Overhead	Y	8/18/2020	18:23	Equipment - PG&E	Splice/Clamp/Connector	N.A.	N.A.	N.A.	
PG&E	8/18/2020	14:58	37.596295	-121.636355	Vegetation	Herbaceous	0.25 - 10 Acres	Cal Fire	PG&E SIPT / Cal Fire	Circuit ID: 013751102	Y	750	Conductor - Secondary	Overhead	Y	8/18/2020	14:56	Equipment - PG&E	Pole failure	N.A.	N.A.	N.A.	
PG&E	8/18/2020	11:00	39.2125	-121.47876	Other	Herbaceous	3 meters - 0.25 Acres	Fire Agency	Browns Valley FD	Circuit ID: 152331108, SAP ID: 41154781	Y	12,000	Capacitor Bank	Overhead	Y	8/18/2020	10:59	Weather	Capacitor bank failure	N.A.	N.A.	Weather	Lightning
PG&E	8/17/2020	05:49	39.33048	-121.19592	Other	Herbaceous	3 meters - 0.25 Acres	Cal Fire	Cal Fire NEU West	Circuit: Colgate-Palermo; Structure: 000/008	N	60,000	Insulator	Overhead	Y	8/17/2020	5:49	Weather	Insulator	N.A.	N.A.	Weather	Lightning
PG&E	8/17/2020	18:11	38.81507	-120.873448	Vegetation	Hardwood Forest	10 - 100 Acres	Cal Fire	N.A.	Circuit ID: 153082106	Y	21,000	Conductor - Primary	Overhead	Y	8/17/2020	17:55	Contact from object	N.A.	Vegetation	Conductor - Pr	N.A.	
PG&E	8/17/2020	20:11	37.856589	-122.072928	Other	Urban	3 meters - 0.25 Acres	Cal Fire	N.A.	CGC: 315462149780	N	12,000	Transformer	Underground	Y	8/17/2020	21:07	Equipment - PG&E	Transformer failure	N.A.	N.A.	N.A.	
PG&E	8/17/2020	18:18	38.887734	-122.5851877	Other	Urban	0.25 - 10 Acres	Cal Fire	N.A.	Circuit ID: 043361103, SAP ID: 103941864	Y	12,000	Splice/Clamp/Connector	Overhead	Y	8/17/2020	18:18	Equipment - PG&E	Splice/Clamp/Connector	N.A.	N.A.	N.A.	
PG&E	8/17/2020	02:12	38.927765	-121.357837	Vegetation	Herbaceous	3 meters - 0.25 Acres	Fire Agency	Lincoln FD	Fuse: 7315	Y	12,000	Fuse	Overhead	Y	8/17/2020	1:40	Weather	Fuse	N.A.	N.A.	Weather	Lightning
PG&E	8/16/2020	16:49	37.173375	-122.06282	Vegetation	Conifer Forest	3 meters - 0.25 Acres	Fire Agency	Cupertino FD	Circuit ID: 082021106	Y	12,000	Conductor - Primary	Overhead	Y	8/16/2020	3:00	Contact from object	N.A.	Vegetation	Conductor - Pr	N.A.	
PG&E	8/16/2020	15:27	37.523893	-122.353384	Vegetation	Urban	0.25 - 10 Acres	Fire Agency	San Mateo County FD	Pole ID: 100257344	N	12,000	Insulator	Overhead	Y	8/16/2020	15:10	Equipment - PG&E	Insulator failure	N.A.	N.A.	N.A.	
PG&E	8/16/2020	15:25	37.249291	-122.031624	Vegetation	Urban	0.25 - 10 Acres	Fire Agency	Santa Clara County FD	Circuit ID: 083371107	Y	12,000	Conductor - Primary	Overhead	Y	8/16/2020	14:57	Contact from object	N.A.	Vegetation	Conductor - Pr	N.A.	
PG&E	8/16/2020	12:32	37.254204	-121.914403	Other	Urban	3 meters - 0.25 Acres	Fire Agency	San Jose FD	Circuit ID: 083431109	Y	12,000	Splice/Clamp/Connector	Overhead	Y	8/16/2020	12:22	Equipment - PG&E	Splice/Clamp/Connector	N.A.	N.A.	N.A.	
PG&E	8/16/2020	07:46	37.166344	-121.991756	Vegetation	Agriculture	0.25 - 10 Acres	Cal Fire	N.A.	Circuit ID: 082021106	Y	12,000	Conductor - Primary	Overhead	Y	8/16/2020	2:51	Weather	Conductor - Primary	N.A.	N.A.	Weather	Lightning
PG&E	8/16/2020	07:33	38.423337	-121.953252	Vegetation	Urban	3 meters - 0.25 Acres	Fire Agency	Vacaville FD	Circuit ID: 063591105	Y	12,000	Conductor - Primary	Overhead	Y	8/16/2020	7:28	Contact from object	N.A.	Vegetation	Conductor - Pr	N.A.	
PG&E	8/15/2020	15:55	37.322001	-121.995959	Vegetation	Urban	0.25 - 10 Acres	Fire Agency	San Jose FD	Pole ID:100535290	N	12,000	Guy/Span Wire	Overhead	Y	8/15/2020	15:47	Contact from object	N.A.	Vegetation	Guy/Span Wir	N.A.	
PG&E	8/15/2020	20:48	40.1121	-122.1602	Vegetation	Herbaceous	0.25 - 10 Acres	Cal Fire	N.A.	Circuit ID: 103391102, SAP ID: 101543506	Y	12,000	Conductor - Primary	Overhead	Y	8/15/2020	20:43	Contact from object	N.A.	Vegetation	Conductor - Pr	N.A.	
PG&E	8/15/2020	18:31	38.259581	-122.075286	Other	Urban	1 meter - < 3 meters	Fire Agency	Fairfield FD	CGC: 219786921602	N	12,000	Transformer	Underground	Y	8/15/2020	17:56	Equipment - PG&E	Transformer failure	N.A.	N.A.	N.A.	
PG&E	8/15/2020	18:22	37.69593869	-121.4326567	Other	Urban	0.25 - 10 Acres	Fire Agency	South County FD	Circuit ID: 163091102, SAP ID: 102053187	Y	12,000	Conductor - Primary	Overhead	Y	8/15/2020	18:14	Equipment - PG&E	Splice/Clamp/Connector	N.A.	N.A.	N.A.	
PG&E	8/15/2020	17:50	37.41892	-121.911285	Vegetation	Urban	0.25 - 10 Acres	Fire Agency	Milpitas FD	Circuit ID: 083892108, SAP ID: 100558631	Y	21,000	Conductor - Primary	Overhead	Y	8/15/2020	17:42	Contact from object	N.A.	Animal	Conductor - Pr	N.A.	
PG&E	8/15/2020	17:26	39.3720967	-121.7114367	Vegetation	Urban	1 meter - < 3 meters	Cal Fire	N.A.	Circuit ID: 103241101, SAP ID: 100377121	Y	12,000	Conductor - Secondary	Overhead	Y	8/15/2020	17:25	Contact from object	N.A.	Vegetation	Conductor - Se	N.A.	
PG&E	8/15/2020	05:26	39.121084	-122.8611994	Vegetation	Urban	1 meter - < 3 meters	Fire Agency	Northshore FD	Circuit ID: 043351103, SAP ID: 102164049	Y	12,000	Conductor - Secondary	Overhead	Y	8/15/2020	5:10	Contact from object	N.A.	Vegetation	Conductor - Se	N.A.	
PG&E	8/14/2020	16:45	37.984209	-122.07614	Other	Urban	1 meter - < 3 meters	Fire Agency	Contra Costa County FD	CGC: 315460554426	N	21,000	Transformer	Padmounted	Y	8/14/2020	16:45	Equipment - PG&E	Transformer failure	N.A.	N.A.	N.A.	
PG&E	8/14/2020	20:20	37.117485	-121.603815	Building	Urban	1 meter - < 3 meters	Fire Agency	San Martin FD	Circuit ID: 083242106	N	21,000	Conductor - Underground Service	Underground	Y	8/14/2020	20:18	Vandalism	N.A.	N.A.	N.A.	Vandalism	
PG&E	8/14/2020	15:02	36.966705	-121.5387533	Other	Urban	3 meters - 0.25 Acres	Cal Fire	N.A.	CGC: 316964717187; Circuit ID: 083182104	Y	21,000	Transformer	Overhead	Y	8/14/2020	14:29	Equipment - PG&E	Transformer failure	N.A.	N.A.	N.A.	
PG&E	8/14/2020	12:31	38.3360133	-122.7292533	Other	Herbaceous	3 meters - 0.25 Acres	Fire Agency	Sonoma County FD	Meter: 1010240104	Y	750	Service Drop	Overhead	Y	8/14/2020	12:30	Equipment - PG&E	Conductor failure-all	N.A.	N.A.	N.A.	
PG&E	8/13/2020	14:14	38.1648367	-121.6139667	Other	Urban	3 meters - 0.25 Acres	Fire Agency	Sacramento FD	Circuit ID: 062462224	Y	21,000	Conductor - Open Wire Secondary	Overhead	Y	8/13/2020	14:13	Equipment - PG&E	Conductor failure-all	N.A.	N.A.	N.A.	
PG&E	8/13/2020	10:50	38.8157883	-122.0431383	Vegetation	Agriculture	1 meter - < 3 meters	Customer	N.A.	Circuit ID: 063172101, SAP Pole ID: 101661149	Y	21,000	Jumper	Overhead	Y	8/13/2020	10:45	Contact from object	N.A.	Animal	Jumper	N.A.	
PG&E	8/12/2020	21:01	38.85131	-121.37713	Vegetation	Agriculture	3 meters - 0.25 Acres	Cal Fire	N.A.	Circuit ID: 153701105	Y	12,000	Conductor - Primary	Overhead	N	N.A.	N.A.	Contact from object	N.A.	Animal	Conductor - Pr	N.A.	
PG&E	8/12/2020	09:52	34.96869786	-119.4723263	Other	Herbaceous	100+ Acres	Fire Agency	Kern County FD	Pole ID: 100190744	N	21,000	Jumper	Overhead	Y	8/12/2020	9:49	Contact from object	N.A.	Animal	Jumper	N.A.	
PG&E	8/12/2020	3:15	36.183569	-119.717277	Other	Agriculture	1 meter - < 3 meters	Fire Agency	Kings County FD	Capacitor Bank:161C	Y	12,000	Capacitor Bank	Overhead	Y	8/12/2020	2:56	Contact from object	N.A.	Animal	Capacitor Ban	N.A.	
PG&E	8/11/2020	23:48	36.72556	-121.26768	Vegetation	Barren/Other	0.25 - 10 Acres	Cal Fire	N.A.	Circuit ID: 182492105, Fuse: 4693	Y	12,000	Conductor - Primary	Overhead	Y	8/11/2020	23:39	Contact from object	N.A.	Animal	Conductor - Pr	N.A.	
PG&E	8/11/2020	06:34	39.510425	-121.219978	Vegetation	Conifer Forest	3 meters - 0.25 Acres	Cal Fire	Cal Fire Butte	Circuit: 103201101, Pole: 100396459	Y	12,000	Conductor - Primary	Overhead	Y	8/11/2020	6:15	Contact from object	N.A.	Vegetation	Conductor - Pr	N.A.	
PG&E	8/10/2020	10:20	40.399981	-121.939049	Other	Herbaceous	10 - 100 Acres	Cal Fire	N.A.	40863458	N	500,000	Other	Overhead	N	N.A.	N.A.	Equipment - PG&E	Other	N.A.	N.A.	Other	Induction caused ignition
PG&E	8/9/2020	08:53	39.119088	-121.062784	Other	Herbaceous	3 meters - 0.25 Acres	Cal Fire	N.A.	019/150, 019/154	N	115,000	Conductor - Transmission	Overhead	Y	8/9/2020	08:53	Contact from object	N.A.	Animal	Conductor - Tr	N.A.	
PG&E	8/9/2020	17:35	37.723351	-122.037068	Other	Urban	1 meter - < 3 meters	Fire Agency	Alco FD	Pole ID: 100901019 Circuit ID: 014091110	Y	12,000	Pole	Overhead	Y	8/9/2020	17:29	Contact from object	N.A.	Vehicle	Pole	N.A.	
PG&E	8/9/2020	00:03	40.79832	-124.177676	Other	Urban	1 meter - < 3 meters	Utility - PG&E	PG&E Employee	Pole ID: 100968858 Circuit ID: 192121107	Y	12,000	Riser	Overhead	Y	8/9/2020	0:37	Equipment - PG&E	Riser Failure	N.A.	N.A.	N.A.	
PG&E	8/8/2020	20:38	39.1082133	-121.6222817	Vegetation	Urban	1 meter - < 3 meters	Self Extinguished	N.A.	Circuit ID: 153781102	Y	12,000	Splice/Clamp/Connector	Overhead	Y	8/8/2020	20:21	Equipment - PG&E	Splice/Clamp/Connector	N.A.	N.A.	N.A.	
PG&E	8/7/2020	15:45	36.706717	-120.440847	Building	Urban	3 meters - 0.25 Acres	Cal Fire	N.A.	252311104	Y	750	Service Drop	Overhead	Y	8/7/2020	15:40	Equipment - PG&E	Conductor failure-all	N.A.	N.A.	N.A.	
PG&E	8/7/2020	15:45	34.74964077	-120.274641	Vegetation	Urban	10 - 100 Acres	Fire Agency	Santa Barbara County FD	Pole ID: 101858779	Y	12,000	Splice/Clamp/Connector	Overhead	Y	8/7/2020	14:54	Equipment - PG&E	Splice/Clamp/Connector	N.A.	N.A.	N.A.	
PG&E	8/7/2020	14:03	36.838545	-121.371861	Other	Herbaceous	1 meter - < 3 meters	Fire Agency	Hollister FD	Circuit ID: 182492103	Y	21,000	Conductor - Primary	Overhead	Y	8/7/2020	13:56	Contact from object	N.A.	Animal	Conductor - Pr	N.A.	
PG&E	8/6/2020	13:01	36.663563	-119.761515	Vegetation	Urban	1 meter - < 3 meters	Cal Fire	N.A.	Circuit ID: 254251108	Y	12,000	Conductor - Racked Secondary	Overhead	Y	8/6/2020	12:52	Contact from object	N.A.	Vegetation	Conductor - Ra	N.A.	
PG&E	8/5/2020	12:39	39.44983	-121.19761	Vegetation	Conifer Forest	0.25 - 10 Acres	Cal Fire	N.A.	Circuit ID: 103201102, Fuse: 1939	Y	12,000	Conductor - Primary	Overhead	Y	8/5/2020	12:41	Contact from object	N.A.	Vegetation	Conductor - Pr	N.A.	
PG&E	8/5/2020	19:40	39.825775	-122.0618183	Vegetation	Agriculture	0.25 - 10 Acres	Fire Agency	Capay FD	Circuit ID: 102111101	Y	750	Conductor - Secondary	Overhead	Y	8/5/2020	19:34	Contact from object	N.A.	Vegetation	Conductor - Se	N.A.	
PG&E	8/5/2020	19:05	38.33232108	-120.6712191	Other	Hardwood Woodla	0.25 - 10 Acres	Cal Fire	N.A.	Switch: L5803	Y	12,000	Switch	Overhead	Y	8/5/2020	18:49	Vandalism	N.A.	N.A.	N.A.	Vandalism	
PG&E	8/5/2020	11:31	40.893937	-123.571581	Vegetation	Urban	3 meters - 0.25 Acres	Fire Agency	US Forest Service	Circuit ID: 192171103 Pole ID: 100963292	Y	12,000	Conductor - Primary	Overhead	Y	8/5/2020	11:24	Contact from object	N.A.	Vegetation	Conductor - Pr	N.A.	
PG&E	8/5/2020	7:25	38.265415	-122.79165	Other	Urban	3 meters - 0.25 Acres	Fire Agency	Sonoma County FD	Pole ID: 101987195 Circuit ID: 042631108	Y	12,000	Pole	Overhead	Y	8/5/2020	7:19	Contact from object	N.A.	Vehicle	Pole	N.A.	
PG&E	8/5/2020	02:28	40.563185	-122.3687417	Vegetation	Hardwood Woodla	1 meter - < 3 meters	Fire Agency	Redding FD	Circuit ID: 103401102, SAP ID: 101473643	Y	12,000	Conductor - Primary	Overhead	Y	8/5/2020	2:11	Contact from object	N.A.	Vegetation	Conductor - Pr	N.A.	
PG&E	8/4/2020	12:11	39.92083	-122.4535	Other	Herbaceous	3 meters - 0.25 Acres	Cal Fire	N.A.	Circuit: 103331102, Pole: 101522530	Y	12,000	Conductor - Primary	Overhead	Y	8/4/2020	11:58	Contact from object	N.A.	Animal	Conductor - Pr	N.A.	
PG&E	8/3/2020	16:38	37.39450362	-122.0064957	Other	Urban	1 meter - < 3 meters	Self Extinguished	N.A.	83421109	N	12,000	Riser	Overhead	N	N.A.	N.A.	Contact from object	N.A.	Balloon	Riser	N.A.	
PG&E	8/3/2020	23:15	38.8972967	-121.361055	Other	Agriculture	3 meters - 0.25 Acres	Fire Agency	Lincoln FD	Circuit ID: 153701105	Y	12,000	Conductor - Primary	Overhead	Y	8/3/2020	23:03	Contact from object	N.A.	Balloon	Conductor - Pr	N.A.	
PG&E	8/3/2020	18:43	38.676826	-121.652299	Other	Herbaceous	3 meters - 0.25 Acres	Fire Agency	West Sacramento FD	Voltage Regulator: R464	Y	12,000	Voltage Regulator	Overhead	Y	8/3/2020	18:15	Equipment - PG&E	Voltage Regulator failure	N.A.	N.A.	N.A.	
PG&E	8/2/2020	18:37	35.824904	-120.545199	Vegetation	Hardwood Woodla	0.25 - 10 Acres	Cal Fire	N.A.	Circuit ID: 182661104	N	12,000	Conductor - Primary	Overhead	Y	8/2/2020	23:38	Contact from object	N.A.	Vegetation	Conductor - Pr	N.A.	
PG&E	8/2/2020	4:19	36.85933	-120.34139	Vegetation	Agriculture	3 meters - 0.25 Acres	Cal Fire	N.A.	Transmission pole: 44883391 - 014/174	N	115,000	Guy/Span Wire	Overhead	Y	8/2/2020	4:19	Contact from object	N.A.	Vehicle	Guy/Span Wir	N.A.	
PG&E	8/2/2020	16:01	34.838068	-120.221247	Other	Hardwood Woodla	0.25 - 10 Acres	Fire Agency	Santa Barbara County FD	Fuse: 6829, 7359, Circuit: 182811102, Pole: 101862714, 10191804	Y	12,000	Fuse	Overhead	Y	8/2/2020	15:55	Equipment - PG&E	Fuse failure - all	N.A.	N.A.	N.A.	
PG&E	8/2/2020	23:19	37.414152	-122.173711	Other	Herbaceous	0.25 - 10 Acres	Fire Agency	Palo Alto FD	CGC: 315142933707	Y	12,000	Splice/Clamp/Connector	Overhead	Y	8/2/2020	23:18	Equipment - PG&E	Transformer failure	N.A.	N.A.	N.A.	
PG&E	8/2/2020	10:13	35.3942867	-119.0456083	Other	Urban	3 meters - 0.25 Acres	Fire Agency	Bakerfield FD	Transformer CGC: 516886369101	Y	12,000	Transformer	Overhead	Y	8/2/2020	10:10	Equipment - PG&E	Transformer failure	N.A.	N.A.	N.A.	
PG&E	8/2/2020	09:52	34.6219	-120.2369	Vegetation	Agriculture	3 meters - 0.25 Acres	Fire Agency	Santa Barbara County FD	Circuit ID:183041101	N	12,000	Automatic Wire Splice	Overhead	Y	8/2/2020	9:37	Equipment - PG&E	Splice/Clamp/Connector	N.A.	N.A.	N.A.	
PG&E	8/1/2020	15:42	38.867864	-121.355888	Vegetation	Hardwood Woodla	3 meters - 0.25 Acres	Cal Fire	Cal Fire Nevada County FD	Circuit ID: 153701105, SAP ID: 100051057, 100050640	Y	12,000	Conductor - Primary	Overhead	Y	8/1/2020	15:35	Contact from object	N.A.	Vegetation	Conductor - Pr	N.A.	
PG&E	8/1/2020	06:14	37.698554	-122.193529	Other	Urban	1 meter - < 3 meters	Fire Agency	Alco FD	Circuit ID: 013111106	N	12,000	Conductor - Primary	Overhead	Y	8/1/2020	6:04	Contact from object	N.A.	Animal	Conductor - Pr	N.A.	

PG&E	5/22/2020	18:21	39.66293	-121.7758633	Vegetation	Agriculture	1 meter - < 3 meters	Fire Agency	Butte County FD	Cal	20634572798	Y	12,000	Bushing Mounted Cutout	Overhead	Y	5/22/2020	18:12	Contact from object	N.A.	Animal	Bushing Mount	N.A.						
PG&E	5/31/2020	13:59	36.65563	-121.61272	Vegetation	Urban	0.25 - 10 Acres	Fire Agency	Salinas FD		18726S104	N	12,000	Fuse	Overhead	N	N.A.	N.A.	Equipment - PG&E	Fuse Failure - all	N.A.	N.A.	N.A.						
PG&E	5/30/2020	16:35	38.886089	-121.2103206	Vegetation	Hardwood Woodla	3 meters - 0.25 Acres	Unknown	N.A.		Circuit ID: 312701101 SAP ID: 100041460	Y	12,000	Fuse	Overhead	Y	5/30/2020	16:23	Contact from object	N.A.	Vegetation	Fuse	N.A.						
PG&E	5/20/2020	18:37	35.15588	-120.4841617	Vegetation	Urban	3 meters - 0.25 Acres	Fire Agency	Taft FD		Circuit ID: 252081103	N	12,000	Conductor - Primary	Overhead	Y	5/20/2020	18:32	Contact from object	N.A.	Animal	Conductor - Pr	N.A.						
PG&E	5/17/2020	15:14	36.1317517	-121.0230267	Vegetation	Urban	10 - 100 Acres	Cal Fire	N.A.		182191103	Y	12,000	Conductor - Primary	Overhead	Y	5/17/2020	15:03	Weather	Conductor failure-all	N.A.	N.A.	Weather	Hark Winds					
PG&E	5/17/2020	14:31	35.302652	-118.863405	Vegetation	Agriculture	3 meters - 0.25 Acres	Fire Agency	Kern County FD		Pole ID: 100157814	N	12,000	Pole	Overhead	Y	5/17/2020	14:05	Contact from object	N.A.	Vehicle	Pole	N.A.						
PG&E	5/16/2020	05:58	38.314618	-121.9413281	Vegetation	Urban	3 meters - 0.25 Acres	Fire Agency	Davis FD		63541307	Y	21,000	Conductor - Primary	Overhead	Y	5/16/2020	5:05	Equipment - PG&E	Conductor failure-all	N.A.	N.A.	N.A.						
PG&E	5/14/2020	08:51	36.13745	-120.269195	Other	Herbaceous	10 - 100 Acres	Cal Fire	N.A.		4600	N	12,000	Recloser	Overhead	Y	5/14/2020	8:40	Contact from object	N.A.	Animal	Recloser	N.A.						
PG&E	5/14/2020	04:32	38.110383	-122.218279	Vegetation	Urban	3 meters - 0.25 Acres	Fire Agency	Vallejo FD		242451101	Y	12,000	Conductor - Primary	Overhead	Y	5/14/2020	4:21	Contact from object	N.A.	Animal	Conductor - Pr	N.A.						
PG&E	5/14/2020	03:39	38.224764	-120.834697	Vegetation	Herbaceous	3 meters - 0.25 Acres	Cal Fire	N.A.		163731101	Y	12,000	Conductor - Primary	Overhead	Y	5/14/2020	3:13	Contact from object	N.A.	Balloon	Conductor - Pr	N.A.						
PG&E	5/12/2020	17:30	37.27163	-121.9911	Vegetation	Hardwood Woodla	3 meters - 0.25 Acres	Cal Fire	N.A.		Circuit ID: 354111103	Y	12,000	Conductor - Primary	Overhead	Y	5/12/2020	17:17	Contact from object	N.A.	Vegetation	Conductor - Pr	N.A.						
PG&E	5/12/2020	12:57	36.38925	-120.69349	Vegetation	Agriculture	3 meters - 0.25 Acres	Fire Agency	Kings County FD		352661104	Y	12,000	Conductor - Primary	Overhead	Y	5/12/2020	12:49	Contact from object	N.A.	Vehicle	Conductor - Pr	N.A.						
PG&E	5/11/2020	9:23	37.59161	-122.22398	Other	Urban	3 meters - 0.25 Acres	Fire Agency	Redwood City FD		Circuit ID: 354261103	Y	12,000	Conductor - Primary	Overhead	Y	5/11/2020	9:11	Equipment - PG&E	Conductor failure-all	N.A.	N.A.	N.A.						
PG&E	5/11/2020	8:42	35.7831867	-120.4274267	Vegetation	Rural	3 meters - 0.25 Acres	Cal Fire	N.A.		Circuit ID: 182561103	Y	12,000	Conductor - Primary	Overhead	Y	5/11/2020	8:42	Contact from object	N.A.	Vehicle	Conductor - Pr	N.A.						
PG&E	5/10/2020	16:59	38.6860981	-122.7872267	Other	Urban	1 meter - < 3 meters	Fire Agency	Auburn FD		Circuit ID: 212161103	Y	12,000	Sleeve/Clamp/Connector	Overhead	Y	5/10/2020	16:59	Equipment - PG&E	Sleeve/Clamp/Connector	N.A.	N.A.	N.A.						
PG&E	5/9/2020	18:49	39.007013	-122.781647	Vegetation	Hardwood Forest	3 meters - 0.25 Acres	Fire Agency	Kelseyville FD		Pole ID: 193149758	Y	12,000	Pole	Overhead	Y	5/9/2020	18:46	Contact from object	N.A.	Vehicle	Pole	N.A.						
PG&E	5/9/2020	15:15	37.8683923	-120.4113738	Other	Rural	0.25 - 10 Acres	Cal Fire	N.A.		Pole ID: 100329027 Circuit ID: 163781701	Y	17,000	Pole	Overhead	Y	5/9/2020	15:46	Contact from object	N.A.	Vehicle	Pole	N.A.						
PG&E	5/8/2020	14:29	38.645384	-121.0295454	Vegetation	Herbaceous	3 meters - 0.25 Acres	Fire Agency	El Dorado Hills FD		Pole ID: 1014292	Y	21,000	Pole	Overhead	Y	5/8/2020	14:29	Contact from object	N.A.	Vehicle	Pole	N.A.						
PG&E	5/8/2020	12:54	35.9423883	-120.0914167	Other	Rural	3 meters - 0.25 Acres	Self Extinguished	N.A.		Capacitor: 156K Circuit ID: 253102101	N	21,000	Capacitor Bank	Overhead	N	N.A.	N.A.	Contact from object	N.A.	Animal	Capacitor Bank	N.A.						
PG&E	5/7/2020	17:52	37.30412	-120.68749	Other	Agriculture	0.25 - 10 Acres	Cal Fire	Merced County Cal Fire		Circuit ID: 253611102 Pole ID: 103581165	Y	12,000	Pole	Overhead	Y	5/7/2020	17:38	Contact from object	N.A.	Vehicle	Pole	N.A.						
PG&E	5/7/2020	13:25	38.1072183	-121.9888	Other	Rural	3 meters - 0.25 Acres	Fire Agency	Suisun FD		Circuit ID: 352701104	N	12,000	Splice/Clamp/Connector	Overhead	Y	5/7/2020	14:11	Equipment - PG&E	Splice/Clamp/Connector	N.A.	N.A.	N.A.						
PG&E	5/6/2020	12:30	35.45534099	-120.57693	Vegetation	Hardwood Woodla	3 meters - 0.25 Acres	Unknown	N.A.		103389816	N	750	Service Connector	Overhead	N	N.A.	N.A.	Equipment - PG&E	Service Neutral failure	N.A.	N.A.	N.A.						
PG&E	5/6/2020	22:51	39.52888449	-120.8364549	Other	Rural	3 meters - 0.25 Acres	Cal Fire	N.A.		Circuit ID: 163541102	N	12,000	Conductor - Primary	Overhead	Y	5/6/2020	22:24	Equipment - PG&E	Conductor failure-all	N.A.	N.A.	N.A.						
PG&E	5/6/2020	14:11	37.008346	-120.141729	Other	Urban	0.25 - 10 Acres	Cal Fire	N.A.		Circuit ID: 252411133	Y	12,000	Conductor - Secondary	Overhead	Y	5/6/2020	14:10	Equipment - PG&E	Conductor failure-all	N.A.	N.A.	N.A.						
PG&E	5/5/2020	16:30	38.690463	-122.938251	Vegetation	Hardwood Forest	0.25 - 10 Acres	Cal Fire	N.A.		362751113	Y	12,000	Conductor - Primary	Overhead	Y	5/5/2020	16:27	Contact from object	N.A.	Vegetation	Conductor - Pr	N.A.						
PG&E	5/5/2020	08:55	34.68579399	-120.306669	Vegetation	Herbaceous	3 meters - 0.25 Acres	Fire Agency	Santa Barbara County FD		Circuit ID: 182721102	N	12,000	Splice/Clamp/Connector	Overhead	Y	5/5/2020	5:35	Equipment - PG&E	Splice/Clamp/Connector	N.A.	N.A.	N.A.						
PG&E	5/4/2020	18:25	38.48572935	-122.7605635	Other	Urban	3 meters - 0.25 Acres	Fire Agency	Santa Rosa FD		Circuit ID: 352561107	N	12,000	Conductor - Primary	Overhead	Y	5/4/2020	18:16	Equipment - PG&E	Conductor failure-all	N.A.	N.A.	N.A.						
PG&E	5/2/2020	14:04	36.6401388	-119.3865007	Other	Agriculture	0.25 - 10 Acres	Cal Fire	N.A.		Circuit ID: 253941106	N	12,000	Conductor - Primary	Overhead	Y	5/2/2020	14:03	Contact from object	N.A.	Other	Conductor - Pr	Outside Force	Third party canopy made contact with primary circuit.				
PG&E	5/1/2020	15:40	35.88687932	-120.4110834	Other	Urban	3 meters - 0.25 Acres	Fire Agency	Santa Maria FD		Circuit ID: 182061108	Y	12,000	Conductor - Primary	Overhead	Y	5/1/2020	15:41	Equipment - PG&E	Conductor failure-all	N.A.	N.A.	N.A.						
PG&E	5/1/2020	09:56	38.647425	-122.634975	Vegetation	Herbaceous	3 meters - 0.25 Acres	Cal Fire	N.A.		Guy attached to 10312762	Y	12,000	Guy/Span Wire	Overhead	Y	5/1/2020	9:42	Contact from object	N.A.	Vehicle	Guy/Span Wire	N.A.						
PG&E	4/30/2020	20:36	38.9898545	-122.8835565	Vegetation	Rural	0.25 - 10 Acres	Cal Fire	N.A.		Circuit ID: 364291101	Y	12,000	Conductor - Primary	Overhead	Y	5/1/2020	0:00	Contact from object	N.A.	Vegetation	Conductor - Pr	N.A.						
PG&E	4/29/2020	13:26	36.549213	-120.585661	Vegetation	Hardwood Forest	3 meters - 0.25 Acres	Cal Fire	N.A.		Circuit ID: 354711101	Y	12,000	Conductor - Primary	Overhead	Y	4/29/2020	16:24	Contact from object	N.A.	Vegetation	Conductor - Pr	N.A.						
PG&E	4/29/2020	15:45	38.557765	-121.599573	Vegetation	Hardwood Woodla	0.25 - 10 Acres	Cal Fire	N.A.		Circuit ID: 353091102	Y	12,000	Conductor - Primary	Overhead	Y	4/29/2020	15:33	Contact from object	N.A.	Vegetation	Conductor - Pr	N.A.						
PG&E	4/28/2020	12:45	38.1072183	-121.9888	Other	Wetland	3 meters - 0.25 Acres	Utility - PG&E	N.A.		Pole ID: 100150043 Circuit ID: 062701104	N	12,000	Conductor - Primary	Overhead	N	N.A.	N.A.	Contact from object	N.A.	Balloon	Conductor - Pr	N.A.						
PG&E	4/27/2020	14:27	36.73498	-120.102881	Vegetation	Agriculture	0.25 - 10 Acres	Fire Agency	North Central FD		Pole ID: 100361675	N	12,000	Lightning Arrester	Overhead	Y	4/27/2020	14:10	Equipment - PG&E	Lightning arrester failure	N.A.	N.A.	N.A.						
PG&E	4/24/2020	16:30	38.2640617	-121.6074135	Other	Agriculture	1 meter - < 3 meters	Fire Agency	Suisun FD		Circuit ID: 353801105	Y	12,000	Service Drop	Overhead	N	N.A.	N.A.	Equipment - PG&E	Conductor failure-all	N.A.	N.A.	N.A.						
PG&E	4/25/2020	04:20	38.12290367	-121.6949758	Other	Herbaceous	3 meters - 0.25 Acres	Fire Agency	Rio Vista FD		Fuse: 17587	N	21,000	Fuse	Overhead	Y	4/25/2020	3:40	Contact from object	N.A.	Vegetation	Fuse	N.A.						
PG&E	4/23/2020	18:05	35.123396	-120.629124	Building	Urban	Structure Only	Cal Fire	San Luis Obispo		182601106	N.A.	12,000	N.A.	Overhead	N	N.A.	N.A.	Under Investigation	N.A.	N.A.	N.A.	N.A.	PG&E has included the following ignition that meets Electric Incident Report criteria, defined by Appendix B to CPUC D.06-04-055. PG&E has not formed a conclusion about the origin or cause of this particular ignition.				
PG&E	4/23/2020	15:33	37.893316	-121.034339	Vegetation	Herbaceous	0.25 - 10 Acres	Fire Agency	Farmington FD		Circuit ID: 163572702	N	17,000	Conductor - Primary	Overhead	Y	4/23/2020	15:25	Contact from object	N.A.	Balloon	Conductor - Pr	N.A.						
PG&E	4/23/2020	11:08	39.2823317	-121.6820728	Other	Rural	3 meters - 0.25 Acres	Unknown	N.A.		Pole ID: 100792347 Circuit ID: 353771104	Y	12,000	Pole	Overhead	Y	4/23/2020	11:05	Equipment - PG&E	Pole failure	N.A.	N.A.	N.A.						
PG&E	4/22/2020	14:40	37.032386	-120.120519	Vegetation	Herbaceous	0.25 - 10 Acres	Cal Fire	N.A.		254611104	N	12,000	Conductor - Primary	Overhead	Y	4/22/2020	14:30	Unknown	Conductor failure-all	N.A.	N.A.	Unknown	Unknown as to what caused the initial failure, but initial investigation found the ignition to be attributable to PG&E facilities.				
PG&E	4/17/2020	20:21	37.6834533	-121.25295	Other	Agriculture	3 meters - 0.25 Acres	Fire Agency	Lathrop Manteca FD		Circuit ID: 163801704	Y	17,000	Conductor - Primary	Overhead	Y	4/17/2020	20:00	Equipment - PG&E	Conductor failure-all	N.A.	N.A.	N.A.						
PG&E	4/15/2020	16:05	39.0565842	-121.736054	Vegetation	Agriculture	3 meters - 0.25 Acres	Fire Agency	Sutter County FD		352711103	Y	12,000	Conductor - Primary	Overhead	Y	4/15/2020	16:03	Contact from object	N.A.	Vehicle	Conductor - Pr	N.A.						
PG&E	4/14/2020	17:56	38.159686	-121.807305	Vegetation	Agriculture	1 meter - < 3 meters	Fire Agency	Suisun FD		Circuit ID: 353631107	N	21,000	Service Drop	Overhead	Y	4/14/2020	17:55	Contact from object	N.A.	Vehicle	Service Drop	N.A.						
PG&E	4/7/2020	15:42	36.660469	-121.6489651	Other	Herbaceous	1 meter - < 3 meters	Cal Fire	N.A.		182201102	Y	12,000	Conductor - Primary	Overhead	Y	4/7/2020	15:38	Equipment - PG&E	Conductor failure-all	N.A.	N.A.	N.A.						
PG&E	4/3/2020	12:39	35.5060683	-119.62216	Other	Agriculture	0.25 - 10 Acres	Utility - PG&E	PG&E SPT		5 191796 113	Y	12,000	Transformer	Overhead	Y	4/3/2020	12:17	Contact from object	N.A.	Animal	Transformer	N.A.						
PG&E	4/2/2020	16:27	38.802347	-123.13207	Vegetation	Urban	3 meters - 0.25 Acres	Fire Agency	South Coast FPD		Transmission: ELK-GUALALA-69kV Conductor: Distribution Circuit	Y	60,000	Conductor - Transmission	Overhead	Y	4/2/2020	16:23	Contact from object	N.A.	Vegetation	Conductor - Tr	N.A.						
PG&E	4/17/2020	21:47	40.6858833	-121.924365	Building	Shrub	3 meters - 0.25 Acres	Cal Fire	N.A.		Circuit ID: 353601101	N	12,000	Service Drop	Overhead	Y	3/18/2020	22:42	Contact from object	N.A.	Vegetation	Service Drop	N.A.						
PG&E	4/13/2020	16:09	38.2239367	-121.9737767	Other	Urban	3 meters - 0.25 Acres	Fire Agency	Vacaville FD		Circuit ID: 353601110	N	750	Conductor - Secondary	Overhead	N	N.A.	N.A.	Contact from object	N.A.	Vegetation	Conductor - Se	N.A.						
PG&E	5/12/2020	13:08	40.06794	-122.390862	Other	Agriculture	Unknown	Unknown	N.A.		103391102	N	12,000	Conductor - Primary	Overhead	N	N.A.	N.A.	Contact from object	N.A.	Vehicle	Conductor - Pr	N.A.	Unknown whether meets reportability threshold, but confirmed to be attributable to PG&E.				
PG&E	5/8/2020	16:33	35.87644	-119.644863	Vegetation	Barren/Other	Unknown	Unknown	N.A.		252151103	N	12,000	Conductor - All	Overhead	N	N.A.	N.A.	Contact from object	N.A.	Vegetation	Conductor - All	N.A.	Unknown whether meets reportability threshold, but confirmed to be attributable to PG&E.				
PG&E	5/7/2020	7:58	35.84408	-120.049167	Vegetation	Agriculture	0.25 - 10 Acres	Fire Agency	Kings County FD		Circuit ID: 253451101	N	12,000	Conductor - Primary	Overhead	Y	5/7/2020	11:00	Contact from object	N.A.	Animal	Conductor - Pr	N.A.						
PG&E	5/6/2020	16:21	37.1752319	-119.789618	Other	Hardwood Woodla	0.25 - 10 Acres	Cal Fire	N.A.		Transformer #191088881	N	21,000	Jumper	Overhead	Y	5/6/2020	14:15	Contact from object	N.A.	Animal	Jumper	N.A.						
PG&E	5/4/2020	1:55	36.8631217	-120.0715827	Vegetation	Urban	3 meters - 0.25 Acres	Fire Agency	Madera County FD		252761104	N	12,000	Conductor - Secondary	Overhead	Y	5/4/2020	1:21	Equipment - PG&E	Conductor failure-all	N.A.	N.A.	N.A.						
PG&E	5/1/2020	21:43	38.28955	-121.853028	Vegetation	Urban	Utility - PG&E	N.A.	N.A.		12-009 Insulator	N	12,000	Insulator	Overhead	Y	5/1/2020	21:40	Contact from object	N.A.	Vehicle	Insulator	N.A.						
PG&E	5/1/2020	7:39	39.3405094	-121.5621128	Other	Urban	3 meters - 0.25 Acres	Cal Fire	Oroville FD		Circuit ID: 353011107	Y	12,000	Conductor - Backed Secondary	Overhead	Y	5/1/2020	7:30	Weather	Conductor failure-all	N.A.	N.A.	Weather	Hark Winds					
PG&E	5/2/2020	10:56	36.729863	-120.264872	Vegetation	Agriculture	0.25 - 10 Acres	Cal Fire	N.A.		Circuit ID: 252311102	N	12,000	Conductor - Primary	Overhead	Y	5/2/2020	10:25	Contact from object	N.A.	Other	Conductor - Pr	Human Error	Gun Shot				
PG&E	5/2/2020	15:51	37.77886489	-121.9652032	Vegetation	Urban	1 meter - < 3 meters	Fire Agency	Campbell FD		Circuit ID: 353711109	N	12,000	Conductor - Secondary	Overhead	Y	5/2/2020	15:35	Contact from object	N.A.	Vegetation	Conductor - Se	N.A.						
PG&E	5/29/2020	14:37	38.7581617	-121.2853881	Other	Agriculture	0.25 - 10 Acres	Fire Agency	Salinas FD		Circuit ID: 183731101 SAP ID: 60171418	Y	30,000	Conductor - Primary	Overhead	Y	5/29/2020	14:18	Contact from object	N.A.	Vehicle	Conductor - Pr	N.A.						
PG&E	5/21/2020	6:58	35.28161233	-118.9409612	Vegetation	Agriculture	3 meters - 0.25 Acres	Self Extinguished	N.A.		14951	N	12,000	Fuse	Overhead	Y	5/21/2020	7:36	Equipment - PG&E	Fuse Failure - all	N.A.	N.A.	N.A.						
PG&E	5/14/2020	9:45	36.63103	-119.6959667	Other	Agriculture	1 meter - < 3 meters	Cal Fire	N.A.		Circuit ID: 254121101	N	12,000	Conductor - Primary	Overhead	Y	5/14/2020	10:13	Contact from object	N.A.	Vehicle	Conductor - Pr	N.A.						
PG&E	5/13/2020	10:09	37.741382	-121.423936	Building	Urban	3 meters - 0.25 Acres	Fire Agency	City of Tracy FD		Meter: 1006234555	Y	12,000	Service Drop	Overhead	Y	5/13/2020	10:35	Contact from object	N.A.	Vegetation	Service Drop	N.A.						
PG&E	5/11/2020	16:42	36.765313	-119.75186	Vegetation	Urban	1 meter - < 3 meters	Fire Agency	Fresno FD		Circuit ID: 253711106 pole id 185293183	Y	750	Service Drop	Overhead	N	N.A.	N.A.	Contact from object	N.A.	Vegetation	Service Drop	N.A.						
PG&E	5/10/2020	13:05	40.45800592	-122.3828177	Other	Herbaceous	3 meters - 0.25 Acres	Fire Agency	Anderson FD		Circuit ID: 103661101	Y	12,000	Pole	Overhead	Y	5/10/2020	12:59	Equipment - PG&E	Guy/Span Wire failure	N.A.	N.A.	N.A.						
PG&E	5/10/2020	14:51	37.0476722	-121.9881115	Vegetation	Hardwood Woodla	1 meter - < 3 meters	Fire Agency	Soquel FD		Circuit ID: 353571306	Y	21,000	Conductor - Primary	Overhead	Y	5/9/2020	14:44	Contact from object	N.A.	Vegetation	Conductor - Pr	N.A.						
PG&E	5/9/2020	11:58	38.054484	-122.212936	Other	Hardwood Woodla	Structure Only	Fire Agency	Crockett-Carquinez FD		13432207	Y	21,000	Service Drop	Overhead	N	N.A.	N.A.	Under Investigation	N.A.	N.A.	N.A.	N.A.	PG&E has included the following ignition that meets Electric Incident Report criteria, defined by Appendix B to CPUC D.06-04-055. PG&E has not formed a conclusion about the origin or cause of this particular ignition.				
PG&E	5/9/2020	16:34	35.88014921	-121.6298107	Vegetation	Hardwood Woodla	0.25 - 10 Acres	Fire Agency	Arroyas Tri County Fire Protection District		Circuit ID: 182742104	Y	21,000	Conductor - Primary	Overhead	Y	5/9/2020	16:09	Contact from object	N.A.	Vegetation	Conductor - Pr	N.A.						
PG&E	5/9/2020	15:19	38.5408499	-121.74199	Other	Urban	Unknown	Fire Agency	Davis FD		1 20Y4E+11	Y	12,000	Jumper	Overhead	Y	5/9/2020	14:58	Equipment - PG&E	Transformer failure	N.A.	N.A.	N.A.	Unknown whether meets reportability threshold, but confirmed to be attributable to PG&E.				
PG&E	5/9/2020	10:08	39.092964	-120.363398	Vegetation	Conifer Forest	3 meters - 0.25 Acres	Utility - PG&E	N.A.		Circuit ID: 100013965	N	12,000	Conductor - Primary	Overhead	Y	5/9/2020	10:07	Contact from object	N.A.	Vegetation	Conductor - Pr	N.A.						
PG&E	5/9/2020	14:56	37.3671	-120.141	Vegetation	Barren/Other	1 meter - < 3 meters	Cal Fire	Cal Fire - Ranchería		Circuit ID: 253111103	Y	12,000	Conductor - Primary	Overhead	Y	5/9/2020	6:08	Contact from object	N.A.	Vegetation	Conductor - Pr	N.A.						
PG&E	5/9/2020	16:41	37.352816	-122.091714	Vegetation	Hardwood Woodla	1 meter - < 3 meters	Fire Agency	Santa Clara County FD		83771107	N	12,000	Conductor - Primary	Overhead	Y	5/9/2020	13:27	Contact from object	N.A.	Vegetation	Conductor - Se	N.A.						
PG&E	5/9/2020	17:54	37.45448	-122.21628	Building	Urban	1 meter - < 3 meters	Unknown	N.A.		Circuit ID: 353511105	Y	12,000	Jumper	Overhead	Y	5/9/2020	17:51	Equipment - PG&E	#N/A	N.A.	N.A.	N.A.						
PG&E	5/9/2020	16:21	37.671435	-120.321017	Vegetation	Herbaceous	3 meters - 0.25 Acres	Cal Fire	N.A.		252611102	N	12,000	Conductor - Primary	Overhead	N	N.A.	N.A.	Equipment - PG&E	Conductor failure-all	N.A.	N.A.	N.A.						
PG&E	5/9/2020	15:46	39.19163	-121.166585	Vegetation	Urban	0.25 - 10 Acres	Cal Fire	N.A.		252681103	N	12,000	Conductor - Primary	Overhead	Y	5/9/2020	15:06	Contact from object	N.A.	Animal	Conductor - Pr	N.A.						
PG&E	5/10/2020	8:47	39.376381	-122.163148	Other	Urban	0.25 - 10 Acres	Fire Agency	Maxwell FD		92981105	N	12,000	Conductor - Primary	Overhead	Y	5/10/2020	8:42	Contact from object	N.A.	Vehicle	Conductor - Pr	N.A.						