



Diana S. Gallegos
Regulatory Relations
diana.s.genasci@sce.com

January 11, 2021

Leslie Palmer, Director
Safety Enforcement Division
California Public Utilities Commission
505 Van Ness Avenue
San Francisco, CA 94102


SUBJECT: SCE PSPS Post Event Report – December 16 to December 24, 2020

Dear Director Palmer:

Southern California Edison (SCE) respectfully submits the attached report in compliance with the Public Safety Power Shutoff (PSPS) Post Event Reporting requirements regarding its PSPS event that began December 16 and ended December 24, 2020.

This report has been verified by an Officer of SCE in accordance with Rule 1.11 of the Commission's Rules of Practice and Procedure.

Sincerely,

DocuSigned by:

29E9CB7BDB43475...
Diana S. Gallegos
Principal Manager, Regulatory Relations

cc: ESRB_CompplianceFilings@cpuc.ca.gov

**Southern California Edison
Public Safety Power Shutoff Protocol (PSPS)
Post-Event Reporting in Compliance with Resolution ESRB-
8 and PSPS OIR Phase 1 & 2 Requirements
December 16 to December 24, 2020**

**Submitted to:
California Public Utilities Commission
Director of the Safety and Enforcement Division
January 11, 2020**

Executive Summary

This report provides information related to the Public Safety Power Shutoff (PSPS) events that occurred in SCE's service area from December 16 through December 24, 2020. On December 16, 2020, Southern California Edison (SCE) remotely activated¹ an Incident Management Team (IMT) to manage a weather event where a forecasted Santa Ana event with high winds and low relative humidity levels was anticipated to potentially require the use of SCE's Public Safety Power Shutoff (PSPS) protocol, which could impact as many as 193,464 customers. SCE customers in Kern, Los Angeles, Orange, Riverside, San Bernardino, Tulare, and Ventura counties were originally in scope during a period of concern from December 16 at 9:00 am through December 24 at 6:00 pm. During this event, SCE also de-energized circuits not originally in scope when unexpected high wind conditions and elevated FPI levels were observed in the areas of concern as detailed in this report. Ultimately, SCE pro-actively de-energized 21,849 customers in areas of Inyo, Kern, Los Angeles, Riverside, San Bernardino, and Ventura counties. Power was restored to most customers impacted by PSPS on December 24th, with the exception of 4 customers whose power was restored on December 25th by 11:03 am.

SCE submits this report to demonstrate its compliance with the directives of Resolution ESRB-8 and the California Public Utilities Commission (CPUC or Commission) PSPS Order to Institute Rulemaking (OIR) Phase 1 (Decision (D.) 19-05-042) and Phase 2 (D.20-05-051) requirements associated with PSPS events. This report explains SCE's decision to call, sustain, and conclude a de-energization event and provides both a summary of the event and the responses to the post-event questions as required by the Commission. SCE submits this report to the Director of Safety and Enforcement Division (SED) and the service list for Rulemaking R. 18-12-005.

SCE appreciates that PSPS de-energizations pose significant challenges and hardships for its customers and the Public Safety Partners that provide vital services to our communities. SCE recognizes that this is particularly true when the unexpected onset of dangerous weather and fuel conditions requires that SCE take actions quickly and without all the advance notifications contemplated by the CPUC. SCE's decision to activate its PSPS protocol is based on careful consideration of multiple factors, including forecasted weather, fuel conditions, and impacts to Public Safety Partners and the communities we serve. Because SCE takes seriously its responsibilities and understands the impacts of de-energization events, SCE only uses PSPS de-energization when it believes that there are no other reasonable alternatives to mitigate identified risks to public safety that would result from catastrophic wildfire.

SCE remains committed to continuously improving its processes and welcomes input from its customers, Public Safety Partners, community representatives, and local governments on ways we can work together to enhance the existing processes, improve communication and coordination amongst impacted entities, and minimize the impact of PSPS events on all stakeholders.

¹SCE utilized remote IMT activation due to the impacts of COVID-19.

SCE took the following actions to manage its response during the PSPS event:

1. Activated a Dedicated PSPS IMT to coordinate response operations associated with the potential use of PSPS to maintain public safety. The IMT was activated and operated remotely due to the COVID-19 pandemic.
2. Reached out to the Geographical Coordination Center (GACC)² to coordinate regarding its expectation for fire potential over the course of the PSPS event.
3. Provided notifications to Public Safety Partners, critical infrastructure providers, the CPUC, the California Department of Forestry and Fire Protection (CAL FIRE), the California Governor's Office of Emergency Services (Cal OES), and affected SCE customers. Additionally, SCE provided notices to Community-Based Organizations (CBOs), such as Independent Living Centers (ILCs), the American Red Cross, 2-1-1, and Fire Safety Councils.
4. Initiated operating restrictions on impacted circuits, as applicable.
5. Performed field patrols of impacted circuits where possible in preparation for the potential use of the PSPS protocol for de-energization.
6. Deployed Community Resource Centers and Community Crew Vehicles (CCVs) to impacted communities.
7. Performed live field observations of monitored circuits as required during the period of concern to validate actual weather conditions and the need for the use of PSPS for de-energization.
8. Utilized the Public Safety Power Shutoff protocol to de-energize circuits within High Fire Risk Areas (HFRA) as determined necessary by the Incident Commander based on observed conditions utilizing weather stations and/or live field observations
9. Performed post patrols to verify no damage to de-energized circuits in support of restoration activities.

Event Summary December 16 to December 24, 2020³

December 16th – SCE meteorologists notified SCE's Business Resiliency Duty Manager (BRDM) of a Santa Ana weather system that was forecast to bring elevated fire weather for portions of the SCE territory initially beginning December 18 at 9:00 am and continuing through December 19 at 3:00 pm. On December 16, SCE contacted the Southern California GACC and sent the CPUC an email at 12:59 pm to communicate the activation of the dedicated Public Safety Power Shutoff Incident Management Team (PSPS IMT). SCE notified public safety partners and critical infrastructure providers at 2:18 pm and 7:43 pm of the PSPS event forecasted. At that point, weather forecasts indicated circuits in Los Angeles, Orange, Riverside, San Bernardino, and Ventura counties and approximately 45,045 customers potentially in scope for de-energization during the period of concern set to begin on December 18th.

December 17th -- SCE held its daily State Executive call at 2:30 pm, an OEM County Coordination call at 3:00 pm and a Critical Infrastructure call at 3:30 pm to communicate the weather forecast, customers in scope and answer any questions regarding the event. SCE emailed participants after the daily calls

² The GACC is the physical location of an interagency, regional operation center for the effective coordination, mobilization, and demobilization of emergency management resources. A coordination center serves federal, state and local wildland fire agencies through logistical coordination of resources throughout the geographic area, and with other geographic areas, as well.

³ The following event summary serves to provide an overview of the event. Additional details regarding specific PSPS requirements are addressed in further detail after this narrative.

to provide the briefing materials shared. SCE sent notifications to public safety partners at 1:20 pm and 8:48 pm and critical infrastructure providers and customers at 2:32 pm and 7:48 pm with respect to circuits projected to be in scope for the event. At that point, updated weather forecasts indicated circuits in Los Angeles, San Bernardino, Ventura, Orange, and Riverside, and approximately 60,853 customers potentially in scope for de-energization during the period of concern, which was revised to December 18 at 9:00 am through December 20 at 3:00 pm.

December 18th -- SCE held its daily State Executive call at 2:30 pm, an OEM County Coordination call at 3:00 pm and a Critical Infrastructure call at 3:30 pm to communicate the weather forecast, customers in scope and answer any questions regarding the event. SCE emailed participants after the daily calls to provide the briefing materials shared. SCE sent notifications to public safety partners at 12:55 am and 8:22 pm and critical infrastructure providers and customers at 1:34 pm and 8:45 pm with respect to circuits projected to be in scope for the event. At that point, updated weather forecasts indicated circuits in Los Angeles, San Bernardino, Ventura, Orange, Riverside, and Ventura counties, and approximately 61,960 customers potentially in scope for de-energization during the period of concern, which was revised to last from December 18 at 9:00 am through December 20 at 6:00 pm.

On December 18th at approximately 8:30 am, the PSPS IMT began observing dangerous fire weather conditions, including rapidly escalating wind speeds as detected on SCE's weather stations and elevated Fire Potential Index values, as detailed in the table on page 7, on circuits in San Bernardino and Los Angeles counties. As such, at approximately 9:47 am SCE began de-energizing the circuits as detailed in the table on page 7. Customers on these impacted circuits had received advance notification of de-energization; however, not all customers received imminent notification of de-energization. Although SCE attempted to provide imminent notification of de-energization to all the impacted customers, due to internal issues coordinating imminent notifications between grid operations, responsible for managing de-energizations, and customer service, responsible for providing notices, SCE was unable to provide imminent notifications of de-energization to all customers before de-energization occurred.⁴

December 19th -- SCE held its daily State Executive call at 2:30 pm, an OEM County Coordination call at 3:00 pm and a Critical Infrastructure call at 3:30 pm to communicate the weather forecast, customers in scope and answer any questions regarding the event. SCE emailed participants after the daily calls to provide the briefing materials shared. SCE sent notifications to public safety partners at 12:27 pm and critical infrastructure providers and customers at 11:45 am and 10:11 pm with respect to circuits projected to be in scope for the event. At that point, updated weather forecasts indicated circuits in Los Angeles, Ventura, Orange, Riverside, and San Bernardino counties, and approximately 128,177 customers potentially in scope for de-energization during the period of concern, which was revised to last through December 20 at 12:00 pm.

On December 19th at approximately 5:00 am, the PSPS IMT again began observing dangerous fire weather conditions on circuits in Ventura and Los Angeles counties and at approximately 5:12 am began de-energizing circuits as detailed in the table on page 7. Customers on these impacted circuits had received advance notification of de-energization; however, not all customers received imminent notification of de-energization. Although SCE attempted to provide imminent notification of de-

⁴Notification details for all de-energized circuits can be found in Attachment B-Critical Infrastructure and Customer Notifications. SCE details notification challenges in the lessons learned section of this report.

energization to all the impacted customers, due to internal issues coordinating imminent notifications between grid operations, responsible for managing de-energizations, and customer service, responsible for providing notices, SCE was unable to provide imminent notifications of de-energization to all customers before de-energization occurred.⁵ The IMT patrolled de-energized circuits for restoration where possible based on subsiding weather conditions, send imminent notice of re-energization, and restore circuits as conditions in the field improved.

December 20th – As the period of concern was set to expire at 12:00 pm on Sunday, December 20, SCE meteorologists notified the PSPS IMT of the potential for an additional Santa Ana weather system bringing dangerous fire weather conditions for portions of Kern, Los Angeles, Tulare, Riverside, Orange, San Bernardino, and Ventura counties from December 22 at 9:00 am through December 24 at 6:00 pm with approximately 151,794 customers potentially in scope for de-energization. The IMT continued to patrol de-energized circuits for restoration where possible based on subsiding weather conditions, send imminent notice of re-energization, and restore circuits as conditions in the field improved.

SCE held its daily State Executive call at 2:30 pm, an OEM County Coordination call at 3:00 pm and a Critical Infrastructure call at 3:30 pm to communicate the current and incoming weather forecast, customers in scope and answer any questions regarding the event. SCE emailed participants after the daily calls to provide the briefing materials shared. SCE sent notifications to public safety partners at 11:55 am and 8:29 pm and critical infrastructure providers and customers at 12:23 pm and 8:06 pm with respect to circuits projected to be in scope now through December 24. The IMT continued to patrol de-energized circuits for restoration where possible based on subsiding weather conditions, send imminent notice of re-energization, and restore circuits as conditions in the field improved.

December 21st -- SCE held its daily State Executive call at 2:30 pm, an OEM County Coordination call at 3:00 pm and a Critical Infrastructure call at 3:30 pm to communicate the weather forecast, customers in scope and answer any questions regarding the event. SCE emailed participants after the daily calls to provide the briefing materials shared. SCE sent notifications to public safety partners at 1:25 pm and 9:40 pm and critical infrastructure providers and customers at 1:11 pm and 8:51 pm with respect to circuits projected to be in scope for the event. At that point, updated weather forecasts indicated circuits in Kern, Tulare, Ventura, Los Angeles, Orange, Riverside, and San Bernardino counties, and approximately 147,706 customers potentially in scope for de-energization during the period of concern, which was revised to last from December 23 at 6:00 am to December 24 at 12:00 pm. The IMT continued to patrol de-energized circuits for restoration where possible based on subsiding weather conditions, send imminent notice of re-energization, and restore circuits as conditions in the field improved.

December 22nd – SCE held its daily State Executive call at 2:30 pm, an OEM County Coordination call at 3:00 pm and a Critical Infrastructure call at 3:30 pm to communicate the weather forecast, customers in scope and answer any questions regarding the event. SCE emailed participants after the daily calls to provide the briefing materials shared. SCE sent notifications to public safety partners at 2:27 pm and 10:24 pm and critical infrastructure providers and customers at 2:37 pm with respect to circuits projected to be in scope for the event. At that point, updated weather forecasts indicated circuits in Kern, Los Angeles, Ventura, Tulare, San Bernardino, Orange, and Riverside counties, and approximately

⁵Notification details for all de-energized circuits can be found in Attachment B-Critical Infrastructure and Customer Notifications. SCE details notification challenges in the lessons learned section of this report.

193,464 customers potentially in scope for de-energization during the period of concern now revised to last from December 23 at 3:00 am to December 24 at 3:00 pm.

On December 22nd at approximately 6:00 am, the PSPS IMT observed dangerous fire weather conditions on one circuit in Inyo county not originally in scope for this event and at approximately 6:21 am SCE de-energized this circuit due to rapidly escalating wind speeds as detected on SCE's weather stations in the area and elevated Fire Potential Index values as detailed in the table on page 7. Customers on this circuit did not receive any prior notification of potential de-energization given the sudden onset of fire weather conditions and the need to de-energize quickly. The IMT continued to patrol de-energized circuits for restoration where possible based on subsiding weather conditions, send imminent notice of re-energization, and restore circuits as conditions in the field improved.

December 23rd -- At approximately 2:00 am, the PSPS IMT again began observing dangerous fire weather conditions on circuits in Kern, Los Angeles, Riverside, San Bernardino, and Ventura counties and at approximately 3:02 am began de-energizing customers circuits as detailed in the table on page 7. Customers on these impacted circuits had received advance notification of potential de-energization. SCE also de-energized 3 circuits not originally forecast to be in scope for this event in Kern and Ventura counties at 10:24 am on December 23 due to rapidly escalating wind speeds as detected on SCE's weather stations in the area and elevated Fire Potential Index values as detailed in the table on Page 7. Customers on these three circuits did not receive any prior notification of potential de-energization given the sudden onset of fire weather conditions and the need to de-energize quickly.

SCE held its daily State Executive call at 2:30 pm, an OEM County Coordination call at 3:00 pm and a Critical Infrastructure call at 3:30 pm to communicate the weather forecast, customers in scope and answer any questions regarding the event. SCE emailed participants after the daily calls to provide the briefing materials shared. SCE sent notifications to public safety partners at 12:52 pm and 9:03 pm and critical infrastructure providers and customers at 11:33 pm and 9:16 pm with respect to circuits projected to be in scope through December 24. The IMT continued to patrol de-energized circuits for restoration where possible based on subsiding weather conditions, send imminent notice of re-energization, and restore circuits as conditions in the field improved.

December 24th -- SCE meteorologists contacted the Business Resiliency Duty Manager and indicated it was unlikely that the incoming forecasted Santa Ana wind event would bring elevated fire weather conditions that could necessitate the use of PSPS. Given this updated assessment, SCE communicated its intention to demobilize the PSPS IMT to the CPUC, CalOES and the potentially impacted counties of Kern, Los Angeles, Orange, Riverside, San Bernardino, and Ventura. SCE emailed participants to provide the briefing materials for the last update for this event. The IMT continued to patrol de-energized circuits for restoration where possible based on subsiding weather conditions, send imminent notice of re-energization, and restore circuits as conditions in the field improved. SCE sent all-clear notifications to public safety partners at 2:42 pm and 5:40 pm and critical infrastructure providers and customers by 4:34 pm and at approximately 3:30 pm on December 24th began demobilizing the PSPS IMT. One circuit shared by SCE and PG&E was transferred back to field operations until it could be fully restored on December 25th at 11:03 am.

The following responses address how SCE complied with all applicable PSPS regulatory requirements, including ESRB-8 and the Phase 1 (D. 19-05-042) and Phase 2 (D. 20-05-051) decisions, during this event.

1. The time, place and duration of the power shutoff event

During this event, de-energization on various circuits started at 9:47 am on December 18 and continued through December 25 at 11:03 am. The event impacted portions Kern, Los Angeles, Riverside, San Bernardino, and Ventura counties. The table below provides the timeline for de-energization and restoration for all impacted circuits.

De-Energization/Re-Energization Circuit Timeline

Circuit	Isolation Device ⁶	De-Energized Date/Military Time	Customers Affected	Re-Energized ⁷ (1st load) Date/Military Time	Re-Energized ⁸ (All load) Date/Military Time
SAND CANYON	RAR0191	12/18/2020 09:47	9		12/19/2020 12:39
NORTHPARK	CB	12/18/2020 09:57	1101	12/18/2020 17:01	12/18/2020 17:16
ECHO	RAR0826	12/18/2020 10:21	117		12/18/2020 15:12
SUTT	RAR0825	12/18/2020 10:20	81		12/18/2020 15:55
CLUB OAKS	RAR0686	12/18/2020 11:18	0		12/21/2020 13:08
ENERGY	GS1321-4, GS7920-1	12/19/2020 05:12	16	12/19/2020 11:29	12/19/2020 14:34
ANTON	RAR0217 & RAR1992	12/19/2020 08:20	139		12/19/2020 14:04
ENERGY	GS1321-4, GS7920-1	12/19/2020 21:51	46	12/20/2020 14:54	12/20/2020 16:18
SAND CANYON	RAR0191	12/23/2020 03:02	9		12/24/2020 10:31
LOUCKS	CB	12/23/2020 04:51	55	12/23/2020 18:54	12/24/2020 11:04
SHOVEL	RAR3431	12/23/2020 04:51	54	12/23/2020 18:54	12/23/2020 18:57
CALSTATE	RAR0868	12/23/2020 05:57	10		12/24/2020 11:13
ENERGY	RAR0012	12/23/2020 07:16	37		12/24/2020 14:37
DYSART	RAR0278	12/23/2020 07:37	75	12/24/2020 12:05	12/24/2020 13:15
SADDLEBACK	PS0356	12/23/2020 07:40	4	12/24/2020 11:54	12/24/2020 13:13
TAPO	PS0046	12/23/2020 07:41	0		12/24/2020 15:12
ENERGY	GS1321-4, GS7920-1	12/23/2020 07:59	9		12/24/2020 12:21
ANTON	RAR1993	12/23/2020 08:26	49	12/24/2020 11:57	12/24/2020 14:36
BALCOM	RCS1127	12/23/2020 08:59	359	12/24/2020 9:15	12/24/2020 11:15
RAINBOW	RAR1941	12/23/2020 08:58	18		12/24/2020 11:42

⁶ Remote Automatic Recloser (RAR), Remote Controlled Switch (RCS), Pole Switch (PS), Gas Switch (GS), Padmount Enclosure (PME), and Circuit Breaker (CB) denote different types of sectionalizing devices used by SCE

⁷1st load identifies if the circuit was re-energized in sections based on pre-patrols and weather conditions impacting the ability to re-energize the entire line simultaneously.

⁸ All Load identifies when the entire circuit was fully re-energized.

Circuit	Isolation Device ⁶	De-Energized Date/Military Time	Customers Affected	Re-Energized ⁷ (1st load) Date/Military Time	Re-Energized ⁸ (All load) Date/Military Time
GNATCATCHER	CB	12/23/2020 09:10	1451	12/24/2020 14:41	12/24/2020 15:51
CONDOR	CB	12/23/2020 09:10	1463	12/24/2020 13:59	12/24/2020 15:09
ESTABAN	RAR9580	12/23/2020 09:48	156	12/23/2020 17:20	12/23/2020 18:10
TWIN LAKES	RCS5233-2 TO GS1347-3	12/23/2020 10:12	467	12/23/2020 11:23	12/24/2020 11:32
COBRA	GS4245-1	12/23/2020 10:14	676	12/24/2020 11:41	12/24/2020 11:43
JULIUS	PME5271-1	12/23/2020 10:14	2002	12/24/2020 13:07	12/24/2020 13:09
MARCUS	GS0030-3	12/23/2020 10:19	1391	12/24/2020 12:24	12/24/2020 12:31
ARLENE	CB	12/23/2020 10:19	597		12/24/2020 12:39
HILLFIELD	CB	12/23/2020 10:19	1624	12/24/2020 13:49	12/24/2020 14:19
RACER	CB	12/23/2020 10:20	384	12/24/2020 12:01	12/24/2020 12:25
BOOTLEGGER	PS0850	12/23/2020 10:43	62		12/23/2020 16:54
BIG ROCK	PS0473	12/23/2020 10:38	119		12/24/2020 10:18
SAND CANYON	RAR0290	12/23/2020 10:34	52		12/24/2020 11:49
CABANA	GS5097-3	12/23/2020 10:51	2363	12/23/2020 13:14	12/23/2020 13:17
GUITAR	RAR0402	12/23/2020 11:08	42		12/24/2020 10:24
STEEL	RAR7845	12/23/2020 11:29	2		12/24/2020 15:25
NORTHPARK	RAR0822	12/23/2020 14:31	552	12/24/2020 9:58	12/24/2020 10:00
VARGAS	RAR0828	12/23/2020 14:33	393		12/24/2020 8:04
DUKE	RAR0534	12/23/2020 14:27	23		12/24/2020 14:11
NAPOLEON	RAR0932	12/23/2020 14:35	45		12/24/2020 14:01
SWEETWATER	CB	12/23/2020 14:52	2739	12/24/2020 9:08	12/24/2020 9:10
VERA CRUZ	RAR0870	12/23/2020 15:16	5		12/24/2020 9:02
PHEASANT	RAR0272	12/23/2020 15:18	178		12/24/2020 11:07
RAINBOW	RAR2137	12/23/2020 17:50	161		12/24/2020 11:46
NORTHPARK	RAR0824	12/23/2020 18:03	71		12/24/2020 9:53
ATENTO	RAR7034	12/23/2020 20:10	801	12/24/2020 8:38	12/24/2020 8:40
PETIT	RCS1197	12/23/2020 20:39	92		12/24/2020 11:37
FINGAL	RAR0352	12/23/2020 21:26	232	12/24/2020 11:22	12/24/2020 14:12
ESTABAN	RAR9580	12/23/2020 22:18	156		12/24/2020 10:20
CASTRO	RAR1228	12/24/2020 02:20	20		12/24/2020 10:29
HONEYCRISP	GS1423-2	12/24/2020 03:04	802	12/24/2020 6:10	12/24/2020 14:28
Additional De-Energizations Not Originally in the Period of Concern					
Circuit	Isolation Device	De-Energized Date/Military Time	Customers Affected	Re-Energized (1st load) Date/Military Time	Re-Energized (All load) Date/Military Time
BIRCHIM	RAR0323	12/22/2020 06:21	3		12/22/2020 12:52
FROZEN	PS0269	12/23/2020 10:24	1		12/24/2020 16:03
RICARDO	RAR0141	12/23/2020 11:05	532		12/24/2020 12:05
GRAPEVINE PEAK	PG&E FUSE#2447	12/23/2020 14:45	4		12/25/2020 11:03

2. The local communities’ representatives contacted prior to de-energization, the date on which they were contacted, and whether the areas affected by the de-energization are classified as Zone 1, Tier 2, or Tier 3 as per the definition in General Order 95, Rule 21.2⁹

County	Public Safety Partner	Date	Tier
Kern	County and State public safety and first responder agencies and local governments	12/16	Tier 2 Tier 3
Los Angeles	County and State public safety and first responder agencies and local governments	12/16	Tier 2 Tier 3
Orange	County and State public safety and first responder agencies and local governments	12/16	Tier 2 Tier 3
Riverside	County and State public safety and first responder agencies and local governments	12/16	Tier 2 Tier 3
San Bernardino	County and State public safety and first responder agencies and local governments	12/16	Tier 2 Tier 3
Tulare	County and State public safety and first responder agencies and local governments	12/20	Tier 2 Tier 3
Ventura	County and State public safety and first responder agencies and local governments	12/16	Tier 2 Tier 3

3. If unable to provide customers with notice at least 2 hours prior to the de-energization event, provide an explanation in its report.

On December 19th SCE de-energized circuits that were in scope for this event without two-hour notice of imminent de-energization. These circuits received earlier notices of potential de-energization for the reasons noted in the narrative above. Additionally, on December 22nd and 23rd, SCE de-energized circuits not originally forecast to be in scope for this event due to rapidly

⁹ See Attachment A Public Safety Partner Notifications for specifics of notifications. SCE maintains communication with local communities for the duration of the PSPS event and all dates listed denote initial notification to impacted stakeholders.

escalating wind speeds and high Fire Potential Index ratings. These circuits did not receive any prior notification of potential de-energization.¹⁰

4. Summarize the number and nature of complaints received as the result of the de-energization event and include claims that are filed due to de-energization.

As of the submission of this report, SCE is not aware of any formal complaints that were submitted to the Commission. SCE Consumer Affairs did receive 51 complaints from representatives of affected cities through the CPUC’s Consumer Affairs Branch related to SCE’s PSPS events¹¹ as detailed in the following table. As of the filing of this report, SCE was aware of 45 claims related to this PSPS event: 44 claimed food loss, 1 claimed property damage.

PSPS Event Date	Number of Complaints	Nature of Complaints
11/24	1	<ul style="list-style-type: none"> • General dispute on PSPS
11/29	1	<ul style="list-style-type: none"> • Protesting PSPS and impacts to people on medical equipment
12/4	12	<ul style="list-style-type: none"> • Length of PSPS outage • Well water and medical needs • General dispute on PSPS • Upset about multiple events • Food loss
12/16	37	<ul style="list-style-type: none"> • Protesting PSPS events • Disagrees with need for PSPS • PSPS event duration is too long • Food loss due to PSPS • Concerned about loss of cell service • Disruption of Work/School • PSPS unfairly impacts elderly • PSPS notification frequency too often

Local jurisdictions expressed concern or sent inquiries related to the use of PSPS during this event and SCE is including the following examples of those interactions here for context. The following is not an exhaustive list of all SCE’s interactions with local agencies during this PSPS event.

- Supervisor Barger's office requested that SCE check on the immediate needs of a customer concerned about the PSPS events affecting the Acton and Agua Dulce areas. Summary of Complaint: Resident did not believe the PSPS was justified by the wind speeds at the resident's location. The resident has been experiencing planned outages for two years to harden the system but does not see a reduction in PSPS episodes. The \$300/\$500 rebate to purchase a generator is inadequate since they would need to rewire their electrical panel due to the load from their well pump and pressure pump for sanitary water. Resident also mentioned that for the 12/17 PSPS event that affected them, they only received 24-hour notice, which is

¹⁰Notification details for all de-energized circuits can be found in Attachment B-Critical Infrastructure and Customer Notifications.

¹¹ SCE in including complaints from previous PSPS events received after the 10-day filing period in this report

inconsistent with SCE's stated guidelines for notifications. Representatives from SCE held a meeting with Barger County to discuss open items related to PSPS.

- Kern County contacted SCE about the Tenneco circuit in Kern County. The circuit received an all clear on 12/22 then received a notice on 12/23 stating the area covered by the Tenneco circuit (Pine Mountain Club; Pinon Pines Estate; Lake of the Woods; Frazier Park) was still in scope. Representatives from SCE responded and explained SCE's process for determining areas with the potential for use of PSPS.
- Riverside County duty chief asked to connect with our GIS teams in regard to circuit notifications. The County said there was a long lag time between the actual de-energization and when notifications were sent out by the SCE LNO. They wanted to be able to update their GIS page in real time. They received complaints from stakeholders. Representatives from SCE responded with an FAQ on accessing the SCE REST page.
- District Director for Congressman Mike Garcia asked SCE if hotel lodging assistance for customers with medical needs is something SCE provides during PSPS events. Representatives from SCE responded no and explained the services provided by SCE along with the link to where information can be referenced.

5. The timeline for power restoration (re-energization), in addition to the steps taken to restore power as required in Resolution ESRB-8.

A PSPS event will continue while dangerous fire weather conditions exist, and the threat of a catastrophic wildfire event remains due to these conditions. If circuits are de-energized, those circuits and impacted lines will be inspected to ensure there is no damage before power can be safely restored. Any visual inspection of the power lines typically takes place during daylight hours for safety and accuracy. Therefore, patrol and restoration operations may be limited or prolonged during overnight hours. SCE strives to restore all power within 24 hours of de-energization when possible. The timeline for power restoration is detailed in the table below.

Circuit	Isolation Device	IC Approved Restoration Operations	Circuit Fully Re-energized
SAND CANYON	RAR0191	12/19/2020 9:48	12/19/2020 12:39
NORTHPARK	CB	12/18/2020 14:15	12/18/2020 17:16
ECHO	RAR0826	12/18/2020 13:52	12/18/2020 15:12
SUTT	RAR0825	12/18/2020 13:51	12/18/2020 15:55
CLUB OAKS	RAR0686	12/20/2020 16:28	12/21/2020 13:08
ENERGY	GS1321-4, GS7920-1	12/19/2020 9:41	12/19/2020 14:34
ANTON	RAR0217 & RAR1992	12/19/2020 10:54	12/19/2020 14:04
ENERGY	GS1321-4, GS7920-1	12/20/2020 14:07	12/20/2020 16:18
SAND CANYON	RAR0191	12/24/2020 8:38	12/24/2020 10:31
LOUCKS	CB	12/23/2020 17:50	12/24/2020 11:04
SHOVEL	RAR3431	12/23/2020 17:50	12/23/2020 18:57
CALSTATE	RAR0868	12/24/2020 7:35	12/24/2020 11:13
ENERGY	RAR0012	12/24/2020 11:28	12/24/2020 14:37
DYSART	RAR0278	12/24/2020 9:24	12/24/2020 13:15

Circuit	Isolation Device	IC Approved Restoration Operations	Circuit Fully Re-energized
SADDLEBACK	PS0356	12/24/2020 9:25	12/24/2020 13:13
TAPO	PS0046	12/24/2020 8:38	12/24/2020 15:12
ENERGY	GS1321-4, GS7920-1	12/24/2020 11:28	12/24/2020 12:21
ANTON	RAR1993	12/24/2020 11:05	12/24/2020 14:36
BALCOM	RCS1127	12/24/2020 8:38	12/24/2020 11:15
RAINBOW	RAR1941	12/24/2020 10:08	12/24/2020 11:42
GNATCATCHER	CB	12/24/2020 14:09	12/24/2020 15:51
CONDOR	CB	12/24/2020 13:15	12/24/2020 15:09
ESTABAN	RAR9580	12/23/2020 16:45	12/23/2020 18:10
TWIN LAKES	RCS5233-2 TO GS1347-3	12/24/2020 10:00	12/24/2020 11:32
COBRA	GS4245-1	12/24/2020 10:42	12/24/2020 11:43
JULIUS	PME5271-1	12/24/2020 10:42	12/24/2020 13:09
MARCUS	GS0030-3	12/24/2020 10:42	12/24/2020 12:31
ARLENE	CB	12/24/2020 11:15	12/24/2020 12:39
HILLFIELD	CB	12/24/2020 11:15	12/24/2020 14:19
RACER	CB	12/24/2020 10:42	12/24/2020 12:25
BOOTLEGGER	PS0850	12/23/2020 16:44	12/23/2020 16:54
BIG ROCK	PS0473	12/24/2020 9:58	12/24/2020 10:18
SAND CANYON	RAR0290	12/24/2020 8:38	12/24/2020 11:49
CABANA	GS5097-3	12/23/2020 12:33	12/23/2020 13:17
GITAR	RAR0402	12/24/2020 8:38	12/24/2020 10:24
STEEL	RAR7845	12/24/2020 12:05	12/24/2020 15:25
NORTHPARK	RAR0822	12/24/2020 7:43	12/24/2020 10:00
VARGAS	RAR0828	12/24/2020 6:53	12/24/2020 8:04
DUKE	RAR0534	12/24/2020 12:12	12/24/2020 14:11
NAPOLEON	RAR0932	12/24/2020 12:11	12/24/2020 14:01
SWEETWATER	CB	12/24/2020 6:54	12/24/2020 9:10
VERA CRUZ	RAR0870	12/24/2020 7:55	12/24/2020 9:02
PHEASANT	RAR0272	12/24/2020 9:44	12/24/2020 11:07
RAINBOW	RAR2137	12/24/2020 10:08	12/24/2020 11:46
NORTHPARK	RAR0824	12/24/2020 7:43	12/24/2020 9:53
ATENTO	RAR7034	12/24/2020 7:13	12/24/2020 8:40
PETIT	RCS1197	12/24/2020 9:26	12/24/2020 11:37
FINGAL	RAR0352	12/24/2020 9:29	12/24/2020 14:12
ESTABAN	RAR9580	12/24/2020 8:38	12/24/2020 10:20
CASTRO	RAR1228	12/24/2020 8:38	12/24/2020 10:29
HONEYCRISP	GS1423-2	12/24/2020 4:43	12/24/2020 14:28
BIRCHIM	RAR0323	12/22/2020 8:24	12/22/2020 12:52
FROZEN	PS0269	12/24/2020 14:21	12/24/2020 16:03
RICARDO	RAR0141	12/24/2020 10:57	12/24/2020 12:05

Circuit	Isolation Device	IC Approved Restoration Operations	Circuit Fully Re-energized
GRAPEVINE PEAK	PG&E FUSE#2447	12/24/2020 14:21	12/25/2020 11:03

6. For any circuits that require more than 24 hours to restore, the utility shall explain why it was unable to restore each circuit within this timeframe in its post event report.

SCE’s restoration process begins after dangerous fire weather conditions in the field have subsided, the period of concern has expired and the Incident Commander has approved restoration operations. SCE was able to restore power to all de-energized circuits within 24 hours after the Incident Commander approved restoration operations on de-energized circuits.

7. Identify the address of each community assistance location during the de-energization event, describe the location (in a building, a trailer, etc.), and describe the assistance available at each location, and give the days and hours that it was open.

Each of the CRC/CCV locations were equipped with ice vouchers or ice, water, firewood, blankets, and customer resiliency kits (containing PSPS program information, mask, gloves, hand sanitizer, solar power battery charger or an LED light with built-in battery). Both CRCs and CCVs were used in this event given the scope and size of the event and SCE’s ability to adhere to COVID-19 protocols through their use. Each location was reviewed with local community site management and county EMS input and agreement. Based on the Governor’s Stay-at-Home Order, SCE with external input chose locations and types of resources carefully with both SCE and customer safety as our highest priority.

CCV Locations and Details

Type	County	City/Community	Day and Time	Address
CCV	Los Angeles	Acton	12/18-12/20, 8am-10pm	3748 Nickels St., Acton, CA 93510
CRC	Los Angeles	Agua Dulce	12/18-12/20, 8am-10pm	33201 Agua Dulce Canyon Rd., Agua Dulce, CA 91390
CCV	Orange	Lake Forest	12/18-12/20, 8am-10pm	1004 Portola Oaks Dr., Lake Forest, CA 92610
CCV	San Bernardino	San Bernardino	12/18-12/20, 8am-10pm	5500 University Parkway, San Bernardino, CA 92407
CRC	Ventura	Moorpark	12/18-12/20, 8am-10pm	799 Moorpark Ave, Moorpark, CA 93021
CRC	Ventura	Simi Valley	12/18-12/19, 8am-10pm	3900 Avenida Simi, Simi Valley, CA 93063
CCV	Ventura	Simi Valley	12/20, 8am-10pm	3900 Avenida Simi, Simi Valley, CA 93063
CRC	Riverside	Cabazon	12/19, 8am-10pm	50390 Carmen Ave., Cabazon 92230
CCV	Kern	Tehachapi	12/23-12/24, 8am-10pm	21415 Reeves St., Tehachapi, CA 93561
CCV	Los Angeles	Acton	12/23-12/24, 8am-10pm	3748 Nickels St., Acton, CA

				93510
CRC	Los Angeles	Agua Dulce	12/23-12/24, 8am-10pm	33201 Agua Dulce Canyon Rd., Agua Dulce, CA 91390
CCV	Orange	Lake Forest	12/23-12/24, 8am-10pm	1004 Portola Oaks Dr., Lake Forest, CA 92610
CCV	Riverside	Beaumont	12/23-12/24, 8am-10pm	647 Orange Ave., Beaumont, CA 92223
CCV	San Bernardino	Fontana	12/23-12/24, 8am-10pm	15556 Summit Ave., Fontana, CA 92336
CCV	Ventura	Fillmore	12/23-12/24, 8am-10pm	533 Santa Clara St., Fillmore, CA 93015
CCV	Ventura	Simi Valley	12/23-12/24, 8am-10pm	3900 Avenida Simi, Simi Valley, CA 93063

-

8. Any wind-related damage(s) to SCE’s overhead equipment in the areas where power is shutoff.

Crews performed post-patrols on de-energized circuits to ensure they can be safely re-energized, completing repairs before safely restoring power. A summary of all wind-related damage from this PSPS event found during the post-patrol process is below:

Circuit	County	Structure	Damage
CALSTATE	San Bernardino	1770544E	Damaged post type insulators
STEEL	Riverside	2204662E	Damaged primary wire

9. All factors considered by SCE in its decision to shut off power, including wind speed, temperature, humidity, and vegetation moisture in the vicinity of the de-energized circuits

SCE’s decision to shut off power is dynamic and was made by considering the following factors during this PSPS event:

- National Weather Service-issued watches and warnings for high fire risk areas in our territory,
- Ongoing assessments from our in-house meteorologists using high-resolution weather models, data from SCE weather stations and publicly available weather stations.
- The SCE Fire Potential Index (FPI), a tool that utilizes weather data, fuel conditions, and vegetation moisture content to rate the daily fire potential across our region. SCE uses the following metrics to rate ignition potential -- Low - 11.99, Elevated - 12-14.99 and Extreme - 15 and above
- Wind trends¹² and speeds, particularly when they exceed or are expected to exceed National Weather Service Wind Advisory levels (defined as 31 mph sustained wind speed and 46 mph gust wind speed) or exceed the top 1% of historical wind speeds in the area. Wind speeds are particularly important when we consider them in combination with other local conditions, such as dry vegetation, that could present a true hazard for the community. Wind speed thresholds may also be adjusted based on other factors or circuit design.

¹² SCE defines wind trends as increasing wind speeds that are projected to exceed threshold

SCE considered the following specific factors to inform de-energization decisions:

Circuit Name	Isolation Device	Weather Station	Wind Sustained	Gust Sustained	Threshold Sustained	FPI Value	Reasons for De-Energization
SAND CANYON	RAR0191	SCE Magic Mountain Truck Trail	33.36	49.98	31/46	13	<ul style="list-style-type: none"> Exceeded Threshold Exceeded FPI
NORTHPARK	CB	SCE W Little League Dr	30.7	42.8	31/46	13	<ul style="list-style-type: none"> High Wind Trend Exceeded FPI
ECHO	RAR0826	SCE Arrowhead Springs Rd	29.7	44.4	31/46	13	<ul style="list-style-type: none"> High Wind Trend Exceeded FPI
SUTT	RAR0825	SCE Arrowhead Springs Rd	29.7	44.4	31/46	13	<ul style="list-style-type: none"> High Wind Trend Exceeded FPI
CLUB OAKS	RAR0686	SCE Arrowhead Springs Rd	29.7	44.4	31/46	13	<ul style="list-style-type: none"> High Wind Trend Exceeded FPI
ENERGY	GS1321-4, GS7920-1	SCE Browns Canyon	32	46.3	31/46	13	<ul style="list-style-type: none"> Exceeded Threshold Exceeded FPI
ANTON	RAR0217 & RAR1992	SCE Happy Camp Rd	30.3	47.4	31/46	12.9	<ul style="list-style-type: none"> Exceeded Threshold Exceeded FPI
ENERGY	GS1321-4, GS7920-1	SCE Browns Canyon	32	46.3	31/46	13	<ul style="list-style-type: none"> Exceeded Threshold Exceeded FPI
BIRCHIM	RAR0323	SCE Round Valley	31.5	51.7	31/46	12	<ul style="list-style-type: none"> Exceeded Threshold Exceeded FPI
SAND CANYON	RAR0191	SCE Magic Mtn Truck Trail	30.3	39	31/46	13.9	<ul style="list-style-type: none"> High Wind Trend Exceeded FPI
LOUCKS	CB	SCE Letteau Mtwy	30	46.3	31/46	13.9	<ul style="list-style-type: none"> Downstream circuit fed by Shovel (source de-energized)
SHOVEL	RAR3431	SCE Letteau Mtwy	30	46.3	31/46	13.8	<ul style="list-style-type: none"> Exceeded Threshold Exceeded FPI
CALSTATE	RAR0868	SCE Devil Canyon	42.5	50.9	31/46	13.8	<ul style="list-style-type: none"> Exceeded Threshold Exceeded FPI
ENERGY	RAR0012	SCE Oat Mountain	32.5	49.6	31/46	13.9	<ul style="list-style-type: none"> Exceeded Threshold Exceeded FPI
DYSART	RAR0278	SCE Old Banning Idyllwind Rd	22.8	45.3	31/46	13.9	<ul style="list-style-type: none"> Downstream circuit fed by Saddleback (source de-energized)
SADDLEBACK	PS0356	SCE Old Banning Idyllwind Rd	22.8	45.3	31/46	13.9	<ul style="list-style-type: none"> High Wind Trend Exceeded FPI

Circuit Name	Isolation Device	Weather Station	Wind Sustained	Gust Sustained	Threshold Sustained	FPI Value	Reasons for De-Energization
TAPO	PS0046	SCE Tapo Canyon	27.4	38.9	31/46	13.9	<ul style="list-style-type: none"> • High Wind Trend • Exceeded FPI
ENERGY	GS1321-4, GS7920-1	SCE Browns Canyon	30.9	51.2	31/46	13.9	<ul style="list-style-type: none"> • Exceeded Threshold • Exceeded FPI
ANTON	RAR1993	SCE Happy Camp Rd	21.4	42.5	31/46	13.9	<ul style="list-style-type: none"> • High Wind Trend • Exceeded FPI
BALCOM	RCS1127	SCE South Mountain	32.2	46.4	31/46	13.8	<ul style="list-style-type: none"> • Exceeded Threshold • Exceeded FPI
RAINBOW	RAR1941	SCE South Mountain	32.2	46.4	31/46	13.8	<ul style="list-style-type: none"> • Exceeded Threshold • Exceeded FPI
GNATCATCHER	CB	SCE Cummings Valley	31.9	44.7	31/46	13.6	<ul style="list-style-type: none"> • Exceeded Threshold • Exceeded FPI
CONDOR	CB	SCE Cummings Valley	31.9	44.7	31/46	13.6	<ul style="list-style-type: none"> • Exceeded Threshold • Exceeded FPI
ESTABAN	RAR9580	SCE Hondo Barranca Rd	20.3	49.9	31/45	13.8	<ul style="list-style-type: none"> • Exceeded Threshold • Exceeded FPI
FROZEN	PS0269	Grapevine Peak (RAWS) GVPC1	32	42	31/46	12	<ul style="list-style-type: none"> • Exceeded Threshold • Exceeded FPI
TWIN LAKES	RCS5233-2 TO GS1347-3	SCE Cochran St	42.6	58.7	31/45	13.9	<ul style="list-style-type: none"> • Exceeded Threshold • Exceeded FPI
COBRA	GS4245-1	SCE Solemint Mtwy	36	50.5	31/42	13.9	<ul style="list-style-type: none"> • Exceeded Threshold • Exceeded FPI
JULIUS	PME5271-1	SCE Solemint Mtwy	36	50.5	31/46	13.9	<ul style="list-style-type: none"> • Exceeded Threshold • Exceeded FPI
MARCUS	GS0030-3	SCE Solemint Mtwy	36	50.5	31/46	13.9	<ul style="list-style-type: none"> • Exceeded Threshold • Exceeded FPI
ARLENE	CB	SCE Solemint Mtwy	36	50.5	31/46	13.9	<ul style="list-style-type: none"> • Exceeded Threshold • Exceeded FPI
HILLFIELD	CB	SCE Solemint Mtwy	36	50.5	31/46	13.9	<ul style="list-style-type: none"> • Exceeded Threshold • Exceeded FPI
RACER	CB	SCE Solemint Mtwy	36	50.5	31/46	13.9	<ul style="list-style-type: none"> • Exceeded Threshold • Exceeded FPI
BOOTLEGGER	PS0850	SCE Acton Canyon	22.2	47.1	31/46	13.9	<ul style="list-style-type: none"> • Exceeded Threshold • Exceeded FPI
BIG ROCK	PS0473	SCE Cochran St	39.7	59.3	31/46	13.9	<ul style="list-style-type: none"> • Exceeded Threshold • Exceeded FPI

Circuit Name	Isolation Device	Weather Station	Wind Sustained	Gust Sustained	Threshold Sustained	FPI Value	Reasons for De-Energization
SAND CANYON	RAR0290	SCE Mesa Grande Rd	25.5	48.1	31/46	13.9	<ul style="list-style-type: none"> • Exceeded Threshold • Exceeded FPI
CABANA	GS5097-3	SCE Jurupa Hills	34.4	49.5	31/46	12.8	<ul style="list-style-type: none"> • Exceeded Threshold • Exceeded FPI
RICARDO	RAR0141	SCE Crimea Street Fire Rd	37.1	61.2	31/46	12	<ul style="list-style-type: none"> • Exceeded Threshold • Exceeded FPI
GUITAR	RAR0402	SCE Tapo Canyon	27.3	48.7	31/46	13.7	<ul style="list-style-type: none"> • Exceeded Threshold • Exceeded FPI
STEEL	RAR7845	SCE Badlands	24.3	46.9	30/43	12.9	<ul style="list-style-type: none"> • Exceeded Threshold • Exceeded FPI
GRAPEVINE PEAK	PG&E FUSE#2447	Grapevine CHP (AT714)	42	55	31/46	12	<ul style="list-style-type: none"> • High Wind Trend • Exceeded FPI
NORTHPARK	RAR0822	SCE Meyers Canyon	26.1	46	31/46	13.9	<ul style="list-style-type: none"> • Exceeded Threshold • Exceeded FPI
VARGAS	RAR0828	SCE Sycamore Canyon Rd	25.1	46.9	31/46	13.8	<ul style="list-style-type: none"> • Exceeded Threshold • Exceeded FPI
DUKE	RAR0534	SCE Mount Davis	29.4	47.6	30/46	13.8	<ul style="list-style-type: none"> • Exceeded Threshold • Exceeded FPI
NAPOLEON	RAR0932	SCE Lamb Canyon Landfall	29.4	41	31/45	13.8	<ul style="list-style-type: none"> • High Wind Trend • Exceeded FPI
SWEETWATER	CB	SCE Badger Canyon Rd	34.9	54.4	31/46	13.7	<ul style="list-style-type: none"> • Exceeded Threshold • Exceeded FPI
VERA CRUZ	RAR0870	SCE Carbon Canyon	27.8	36.5	28/42	13.9	<ul style="list-style-type: none"> • High Wind Trend • Exceeded FPI
PHEASANT	RAR0272	SCE Walling Dr	32.8	45.3	31/45	13.9	<ul style="list-style-type: none"> • Exceeded Threshold • Exceeded FPI
RAINBOW	RAR2137	SCE Bixby Rd	21.2	45.7	31/46	13.9	<ul style="list-style-type: none"> • High Wind Trend • Exceeded FPI
NORTHPARK	RAR0824	SCE W Little League Dr	27	48.2	31/46	13.9	<ul style="list-style-type: none"> • Exceeded Threshold • Exceeded FPI
ATENTO	RAR7034	SCE Baker Canyon	30.5	46.3	31/46	13.9	<ul style="list-style-type: none"> • Exceeded Threshold • Exceeded FPI
PETIT	RCS1197	SCE South Mountain	33.6	47.1	31/46	12	<ul style="list-style-type: none"> • Exceeded Threshold • Exceeded FPI
FINGAL	RAR0352	SCE Twin Pines	28	46	31/46	12	<ul style="list-style-type: none"> • Exceeded Threshold • Exceeded FPI
ESTABAN	RAR9580	SCE Hondo Barranca Rd	26	51.1	26/38	13.8	<ul style="list-style-type: none"> • Exceeded Threshold • Exceeded FPI
CASTRO	RAR1228	SCE Anlauf Canyon	31.1	46	30/46	13.9	<ul style="list-style-type: none"> • Exceeded Threshold • Exceeded FPI

Circuit Name	Isolation Device	Weather Station	Wind Sustained	Gust Sustained	Threshold Sustained	FPI Value	Reasons for De-Energization
HONEYCRISP	GS1423-2	SCE San Timoteo Canyon	29.6	46.2	29/42	12.8	<ul style="list-style-type: none"> Exceeded Threshold Exceeded FPI

10. Evaluation of alternatives to de-energization that were considered, and mitigation measures used to decrease the risk of utility-caused wildfire in the de-energized area and an explanation of how the utility determined that the benefit of de-energization outweighed the potential public safety risks:

SCE sets thresholds based on SCE’s risk-informed assessment of the potential for a catastrophic wildfire should an ignition occur under the conditions presented. Under such conditions, the harm to life and property resulting from a catastrophic wildfire vastly outweighs the impacts of the de-energization necessary to eliminate the potential of ignition. Additionally, SCE only uses de-energization when no other alternatives will mitigate this fire risk and to the extent possible, minimizes the impact by limiting the de-energization to the smallest number of customers possible through segmentation of impacted circuits, where possible.

In all PSPS events, SCE uses sectionalizing through RAR devices or switches when available within a reasonable period to isolate and de-energize only the necessary portions of circuits. While avoiding de-energization entirely is not always possible, SCE takes these steps to reduce the impacts of de-energization on the community, considering the impacts of the de-energization on its stakeholders within the overall risk posed by the prevailing weather conditions, its de-energizations thresholds, and the unacceptable public safety risk of catastrophic wildfire ignition.

11. A copy of all notifications, the timing of notifications, the methods of notifications and who made the notifications (the utility or local public safety partners).

A copy of all notifications and the timing of notifications can be found in Attachment A - Public Safety Partner Notifications, Attachment B - Critical Infrastructure and Customer Notifications, and Attachment C - PSPS Activation Customer Notification Messaging. All PSPS event notifications to key stakeholders, including Public Safety Partners and customers, are delivered via voice, email, and TTY (telecommunication device for the hearing impaired) formats as per the preference of the recipient. Notifications are offered in multiple languages. All notifications were made by SCE.

12. Number of affected customers broken down by all classifications including residential, medical baseline, commercial/industrial, etc.

A detailed description of the number of affected customers broken down by all classifications including residential, medical baseline, commercial/industrial, etc. is provided in Attachment B- Customer and Critical Infrastructure Notifications.

13. An explanation of the circumstances that resulted in failure to communicate a potential pro-active de-energization event, if any.

On December 19th SCE de-energized circuits that were in scope for this event without two-hour notice of imminent de-energization. These circuits received earlier notices of potential de-energization for the reasons noted in the narrative above. Additionally, on December 22nd and 23rd, SCE de-energized circuits not originally forecast to be in scope for this event due to rapidly escalating wind speeds and high Fire Potential Index ratings. These circuits did not receive any prior notification of potential de-energization.¹³

14. Each electric investor-owned utility shall enumerate and explain the cause of any false communications in its post event reports by citing the sources of changing data.

SCE notes that its PSPS notices before potential de-energization only provide a warning to customers of a possible de-energization event. SCE notices are designed to give customers notice that a de-energization could take place and a time frame within which the event is most likely to occur so that customers can act and prepare. Given the unpredictability of weather on the ground, however, SCE's advance notices do not affirmatively confirm that a circuit *will be* de-energized. In fact, for clarity, SCE does not provide any affirmative confirmation of de-energization in its notifications until an actual de-energization has taken place.

SCE believes this event could be viewed as an example of a false-negative communication since we were unable to provide all of the required advance notice of de-energization to Public Safety Partners, critical infrastructure providers, or customers on some circuits during this event given the rapid onset of hazardous weather conditions. Additionally, as discussed below, any advance notifications to customers who were not de-energized, although not viewed by SCE as false positives, are being reported here for transparency purposes. SCE provided notice to 193,464 customers of potential de-energization but not all of these customers were de-energized.

15. A description and evaluation of engagement with local and state public safety partners in providing advanced education and outreach during the de-energization event.

Advanced education and outreach of this Public Safety Power Shutoff event was communicated to all impacted counties projected to be in scope, emergency management officials, CalOES, and the Commission before any forecasted weather was anticipated to impact the SCE service territory. Updates were provided throughout the event using the CalOES PSPS Notification Form, daily situational awareness and coordination calls and individual contact with Public Safety Partners in the affected counties.

16. For those customers where positive or affirmative notification was attempted, an accounting of the customers (which tariff and/or access and functional needs population designation), the number of notification attempts made, the timing of attempts, who made the notification attempt (utility or public safety partner) and the number of customers for whom positive notification was achieved.

¹³Notification details for all de-energized circuits can be found in Attachment B-Critical Infrastructure and Customer Notifications.

SCE only tracks critical care customers for positive or affirmative receipt of notification attempts. Notifications are made daily as these customers remain on potentially impacted circuits. There were 919 critical care customers in scope for potential de-energization during this PSPS event and SCE was able to make positive contact with all of them. SCE regularly requests updated contact information from all critical care customers to maintain accurate contact lists.

17. A description of how sectionalizing, i.e., separating loads within a circuit, was considered and implemented and the extent to which it impacted the size and scope of the de-energization event.

There were 193,464 total customers in scope for potential de-energization during the period of concern for this event across all known circuits. There were an additional 540 customers not in scope for the period of concern that SCE had to ultimately de-energize. SCE reduced the number of customers de-energized to 21,847 customers total using weather stations and switching playbooks that identified sectionalizing devices to limit the scope of the event. These sectionalizing devices¹⁴ separate and isolate the de-energization areas, limiting the de-energization impacts as detailed in the table on page 7 of this report. During the process of sectionalizing, 2,191 customers temporarily lost power (approximately 58 minutes for the longest duration) but SCE does not consider these customers as pro-actively de-energized in the context of PSPS due to the fact that this was a loss of power during switching operations and the customers at issue were only minimally impacted by the PSPS event.

18. Lessons learned from the de-energization events.

As previously stated in recent 2020 post-event reports, SCE is in the process of completing a comprehensive review of the late 2020 PSPS events and intends to provide a holistic lesson-learned assessment to the Commission.

19. Any recommended updates to the guidelines adopted in Resolution ESRB-8 and this decision.

SCE notes that its PSPS notices before potential de-energization only provide a warning to customers of a possible de-energization event. SCE notices are designed to give customers notice that a de-energization could take place and a time frame within which the event is most likely to occur so that customers can act and prepare. Given the unpredictability of weather on the ground, however, SCE's advance notices do not affirmatively confirm that a circuit *will be* de-energized. In fact, for clarity, SCE does not provide any affirmative notifications until an actual de-energization has taken place.

SCE believes that its notices are correct and factual. The definition of false positive is subject to interpretation about which notifications should be included. Impending de-energizations could reasonably be interpreted as notifications of imminent de-energization 1-4 hours before outages. SCE believes, however, that the Commission may be interested in all the advance notices of a

¹⁴ Remote Automatic Recloser (RAR), Remote Controlled Switch (RCS), Pole Switch (PS), Gas Switch (GS), Padmount Enclosure (PME), and Circuit Breaker (CB) denote different types of sectionalizing devices used by SCE.

possible de-energization to such customers. Consequently, in an effort to assure transparency and full compliance, SCE will treat them here as potential “false positives” within the meaning of the PSPS guidance. SCE would appreciate any additional Commission clarification or guidance on this issue to assure it is fully compliant.

SCE notes that “false positives” typically refer to decisions made, or actions taken, based on erroneous information. Differences between notifications and actual de-energizations, however, do not stem from incorrect data, but rather from actual ground conditions varying from forecast conditions. This variance is inherent because of the constantly changing nature of emergent weather. SCE hopes that the Commission will take this into consideration when clarifying the definition of false positives going forward.

Officer Verification

I am an officer of the applicant corporation herein and am authorized to make this verification on its behalf. I am informed and believe that the matters stated in the foregoing document are true.

I declare under penalty of perjury that the foregoing is true and correct. Executed this 11th day of January 2021 in Cerritos, California

DocuSigned by:

Erik Takayesu

42007563804B477...

Erik Takayesu

Vice President,

Transmission, Substations & Operations

Attachment A

Public Safety Partner Notifications

PSPS Notification Audit Report for 2020-12-16 through 2020-12-24

Notification ID	Message Title	Sent On
704104053607015	Important: SCE Initial Notice for PSPS Event in LOS ANGELES COUNTY on Friday 12/18/2020.	Dec 16, 2020 14:02:23 PST
704104053607023	Important: SCE Initial Notice for PSPS Event in ORANGE COUNTY on Friday 12/18/2020.	Dec 16, 2020 14:06:27 PST
704104053607029	Important: SCE Initial Notice for PSPS Event in RIVERSIDE COUNTY on Friday 12/18/2020.	Dec 16, 2020 14:09:30 PST
704104053607046	Important: SCE Initial Notice for PSPS Event in SAN BERNARDINO on Friday 12/18/2020.	Dec 16, 2020 14:18:12 PST
704104053607053	Important: SCE Initial Notice for PSPS Event in VENTURA COUNTY on Friday 12/18/2020.	Dec 16, 2020 14:21:52 PST
708502100115543	Important: SCE Update Notice for PSPS Event in LOS ANGELES COUNTY.	Dec 16, 2020 19:30:57 PST
708502100115544	Important: SCE Update Notice for PSPS Event in ORANGE COUNTY.	Dec 16, 2020 19:32:59 PST
708502100115546	Important: SCE Update Notice for PSPS Event in RIVERSIDE COUNTY.	Dec 16, 2020 19:34:49 PST
708502100115556	Important: SCE Update Notice for PSPS Event in SAN BERNARDINO COUNTY.	Dec 16, 2020 19:40:09 PST
708502100115558	Important: SCE Update Notice for PSPS Event in VENTURA COUNTY.	Dec 16, 2020 19:43:32 PST
708502100116693	Important: SCE Update Notice for PSPS Event in VENTURA COUNTY.	Dec 17, 2020 12:55:56 PST
708502100116714	Important: SCE Update Notice for PSPS Event in SAN BERNARDINO COUNTY.	Dec 17, 2020 13:05:01 PST
708502100116727	Important: SCE Update Notice for PSPS Event in RIVERSIDE COUNTY.	Dec 17, 2020 13:12:36 PST
708502100116731	Important: SCE Update Notice for PSPS Event in ORANGE COUNTY.	Dec 17, 2020 13:15:31 PST
708502100116741	Important: SCE Update Notice for PSPS Event in LOS ANGELES COUNTY.	Dec 17, 2020 13:20:12 PST
708502100117175	Important: SCE Update Notice for PSPS Event in SAN BERNARDINO COUNTY.	Dec 17, 2020 20:29:36 PST
708502100117177	Important: SCE Update Notice for PSPS Event in VENTURA COUNTY.	Dec 17, 2020 20:34:14 PST
708502100117180	Important: SCE Update Notice for PSPS Event in RIVERSIDE COUNTY.	Dec 17, 2020 20:39:44 PST
708502100117182	Important: SCE Update Notice for PSPS Event in ORANGE COUNTY.	Dec 17, 2020 20:42:58 PST
708502100117186	Important: SCE Update Notice for PSPS Event in LOS ANGELES COUNTY.	Dec 17, 2020 20:48:13 PST
709464172792794	Important: SCE Imminent De-Energize Notice for PSPS Event in LOS ANGELES COUNTY (SAND CANYON, SEGMENT 3).	Dec 18, 2020 08:44:26 PST
710013928606670	Important: SCE Imminent De-Energize Notice for PSPS Event in SAN BERNARDINO (ACOSTA, SEGMENTS 2 & 4).	Dec 18, 2020 09:35:36 PST
710013928606700	Important: SCE Imminent De-Energize Notice for PSPS Event in SAN BERNARDINO COUNTY (NORTHPARK CIRCUIT, SEGMENTS - ALL).	Dec 18, 2020 09:51:32 PST
709464172792941	Important: SCE De-Energize Notice for PSPS Event in LOS ANGELES COUNTY at 09:48 (SAND CANYON, SEGMENT 3).	Dec 18, 2020 10:08:15 PST
710013928606734	Important: SCE Imminent De-Energize Notice for PSPS Event in SAN BERNARDINO COUNTY (ECHO CIRCUIT, SEGMENTS - ALL).	Dec 18, 2020 10:11:14 PST
709464172792948	Important: SCE De-Energize Notice for PSPS Event in SAN BERNARDINO COUNTY at 09:57 (NORTHPARK, SEGMENT ALL).	Dec 18, 2020 10:12:03 PST
710013928606742	Important: SCE Imminent De-Energize Notice for PSPS Event in SAN BERNARDINO COUNTY (IMPALA CIRCUIT, SEGMENTS - ALL).	Dec 18, 2020 10:13:51 PST
710013928606751	Important: SCE Imminent De-Energize Notice for PSPS Event in SAN BERNARDINO COUNTY (SUTT CIRCUIT, SEGMENT 5).	Dec 18, 2020 10:17:08 PST
710013928606764	Important: SCE Imminent De-Energize Notice for PSPS Event in LOS ANGELES COUNTY (RED BOX CIRCUIT, SEGMENT 2).	Dec 18, 2020 10:23:06 PST
710013928606800	Important: SCE De-Energize Notice for PSPS Event in SAN BERNARDINO COUNTY at 10:21 (SUTT CIRCUIT, SEGMENT 5).	Dec 18, 2020 10:47:24 PST
710013928606817	Important: SCE De-Energize Notice for PSPS Event in SAN BERNARDINO COUNTY at 10:20 (ECHO CIRCUIT SEGMENT - NON TRADITIONAL).	Dec 18, 2020 10:57:27 PST
708639539071567	Important: SCE De-Energize Notice for PSPS Event in San Bernardino County at 1110 (CLUB OAKS ,Segment 2).	Dec 18, 2020 11:34:46 PST
708639539071605	Important: SCE Imminent De-Energize Notice for PSPS Event in LOS ANGELES COUNTY (SAND CANYON, SEGMENT 4 and 5).	Dec 18, 2020 11:56:53 PST
709464172793212	Important: SCE Update Notice for PSPS Event in LOS ANGELES COUNTY.	Dec 18, 2020 12:44:15 PST
709464172793216	Important: SCE Update Notice for PSPS Event in ORANGE COUNTY.	Dec 18, 2020 12:45:38 PST
709464172793223	Important: SCE Update Notice for PSPS Event in RIVERSIDE COUNTY.	Dec 18, 2020 12:48:09 PST
709464172793236	Important: SCE Update Notice for PSPS Event in SAN BERNARDINO COUNTY.	Dec 18, 2020 12:53:49 PST
709464172793242	Important: SCE Update Notice for PSPS Event in VENTURA COUNTY.	Dec 18, 2020 12:55:59 PST
709464172793318	Important: SCE Imminent Re-Energize Notice for PSPS Event in SAN BERNARDINO County.	Dec 18, 2020 14:08:21 PST
709464172793322	Important: SCE Imminent Re-Energize Notice for PSPS Event in SAN BERNARDINO COUNTY. (ECHO, SEGMENT Non-Traditional)	Dec 18, 2020 14:11:00 PST
709464172793340	Important: SCE Imminent Re-Energize Notice for PSPS Event in SAN BERNARDINO. (NORTHPARK, SEGMENT ALL)	Dec 18, 2020 14:21:47 PST
710013928607332	Important: SCE Re-Energize Notice for PSPS Event in SAN BERNARDINO COUNTY at 15:13 (ECHO CIRCUIT, SEGMENT - NON TRADITIONAL).	Dec 18, 2020 16:22:13 PST
710013928607339	Important: SCE Re-Energize Notice for PSPS Event in SAN BERNARDINO County at 15:55 (SUTT CIRCUIT, SEGMENT 5).	Dec 18, 2020 16:27:19 PST

PSPS Notification Audit Report for 2020-12-16 through 2020-12-24

Notification ID	Message Title	Sent On
707952344304830	Important: SCE Re-Energize Notice for PSPS Event in SAN BERNARDINO COUNTY at 17:16 (NORTH PARK, ALL SEGMENTS).	Dec 18, 2020 18:07:04 PST
707952344304920	Important: SCE Update Notice for PSPS Event in LOS ANGELES COUNTY.	Dec 18, 2020 20:15:32 PST
707952344304922	Important: SCE Update Notice for PSPS Event in ORANGE COUNTY.	Dec 18, 2020 20:16:52 PST
707952344304923	Important: SCE Update Notice for PSPS Event in RIVERSIDE COUNTY.	Dec 18, 2020 20:18:18 PST
707952344304924	Important: SCE Update Notice for PSPS Event in SAN BERNARDINO COUNTY.	Dec 18, 2020 20:19:54 PST
707952344304925	Important: SCE Update Notice for PSPS Event in VENTURA COUNTY.	Dec 18, 2020 20:22:21 PST
707952344305030	Important: SCE Imminent De-Energize Notice for PSPS Event in LOS ANGELES COUNTY (BIG ROCK CIRCUIT, SEGMENTS 2, 3).	Dec 18, 2020 23:11:21 PST
707952344305032	Important: SCE Imminent De-Energize Notice for PSPS Event in VENTURA COUNTY (BIG ROCK CIRCUIT, SEGMENTS 2, 3).	Dec 18, 2020 23:13:28 PST
707952344305147	Important: SCE Imminent De-Energize Notice for PSPS Event in LOS ANGELES COUNTY (BIG ROCK CIRCUIT, SEGMENTS 2, 3).	Dec 19, 2020 04:08:11 PST
707952344305148	Important: SCE Imminent De-Energize Notice for PSPS Event in VENTURA COUNTY (BIG ROCK CIRCUIT, SEGMENTS 2, 3).	Dec 19, 2020 04:08:42 PST
709464172794242	Important: SCE De-Energize Notice for PSPS Event in VENTURA COUNTY at 05:12 (ENERGY, SEGMENT 4 & 6).	Dec 19, 2020 05:21:05 PST
707952344305205	Important: SCE De-Energize Notice for PSPS Event in LOS ANGELES COUNTY at 05:12 (ENERGY CIRCUIT, SEGMENT 4, 6).	Dec 19, 2020 05:21:17 PST
709464172794384	Important: SCE Imminent De-Energize Notice for PSPS Event in VENTURA COUNTY (ANTON, SEGMENT 2).	Dec 19, 2020 07:59:24 PST
709464172794412	Important: SCE De-Energize Notice for PSPS Event in VENTURA COUNTY at 08:20 (ANTON, SEGMENT 2).	Dec 19, 2020 08:27:10 PST
709464172794509	Important: SCE Imminent Re-Energize Notice for PSPS Event in LOS ANGELES County. (ENERGY, SEGMENT ALL)	Dec 19, 2020 09:52:06 PST
709464172794512	Important: SCE Imminent Re-Energize Notice for PSPS Event in VENTURA County. (ENERGY, SEGMENT ALL)	Dec 19, 2020 09:53:12 PST
709464172794514	Important: SCE Imminent Re-Energize Notice for PSPS Event in LOS ANGELES. (SAND CANYON, SEGMENT 3)	Dec 19, 2020 09:55:12 PST
709464172794579	Important: SCE Imminent Re-Energize Notice for PSPS Event in VENTURA County. (ANTON, SEGMENT 2)	Dec 19, 2020 10:58:00 PST
710013928608311	Important: SCE Update Notice for PSPS Event in VENTURA COUNTY.	Dec 19, 2020 11:02:58 PST
710013928608319	Important: SCE Update Notice for PSPS Event in LOS ANGELES COUNTY.	Dec 19, 2020 11:06:56 PST
710013928608321	Important: SCE Update Notice for PSPS Event in ORANGE COUNTY.	Dec 19, 2020 11:09:05 PST
710013928608322	Important: SCE Update Notice for PSPS Event in RIVERSIDE COUNTY.	Dec 19, 2020 11:11:42 PST
710013928608327	Important: SCE Update Notice for PSPS Event in SAN BERNARDINO COUNTY.	Dec 19, 2020 11:17:09 PST
709464172794712	Important: SCE Re-Energize Notice for PSPS Event in LOS ANGELES County at 12:39 (SAND CANYON, SEGMENT 3).	Dec 19, 2020 12:52:13 PST
709464172794798	Important: SCE Re-Energize Notice for PSPS Event in VENTURA County at 14:04 (ANTON, SEGMENT 2).	Dec 19, 2020 14:16:54 PST
710013928608626	Important: SCE Re-Energize Notice for PSPS Event in VENTURA County at 14:34 (ENERGY CIRCUIT, SEGMENT 4, 5 AND PARTIAL 6).	Dec 19, 2020 15:24:17 PST
710013928608635	Important: SCE Re-Energize Notice for PSPS Event in LOS ANGELES COUNTY at 14:34 (ENERGY CIRCUIT, SEGMENTS 4, 5 AND PARTIAL 6).	Dec 19, 2020 15:28:38 PST
707952344305895	Important: SCE Update Notice for PSPS Event in VENTURA COUNTY.	Dec 19, 2020 21:06:34 PST
707952344305897	Important: SCE Update Notice for PSPS Event in LOS ANGELES COUNTY.	Dec 19, 2020 21:08:07 PST
707952344305899	Important: SCE Update Notice for PSPS Event in ORANGE COUNTY.	Dec 19, 2020 21:10:06 PST
707952344305902	Important: SCE Update Notice for PSPS Event in LOS ANGELES COUNTY.	Dec 19, 2020 21:13:24 PST
707952344305908	Important: SCE Update Notice for PSPS Event in RIVERSIDE COUNTY.	Dec 19, 2020 21:16:11 PST
707952344305910	Important: SCE Update Notice for PSPS Event in SAN BERNARDINO COUNTY.	Dec 19, 2020 21:18:22 PST
707952344305917	Important: SCE Imminent De-Energize Notice for PSPS Event in VENTURA COUNTY (ENERGY CIRCUIT, SEGMENTS 4, 5, 6).	Dec 19, 2020 21:25:20 PST
707952344305919	Important: SCE Imminent De-Energize Notice for PSPS Event in LOS ANGELES COUNTY (ENERGY CIRCUIT, SEGMENTS 4, 5, 6).	Dec 19, 2020 21:27:58 PST
707952344305949	Important: SCE De-Energize Notice for PSPS Event in VENTURA COUNTY at 21:59 (ENERGY CIRCUIT, SEGMENT Partial 4 & 6).	Dec 19, 2020 22:06:31 PST
707952344305950	Important: SCE De-Energize Notice for PSPS Event in LOS ANGELES COUNTY at 21:59 (ENERGY CIRCUIT, SEGMENT Partial 4, 6).	Dec 19, 2020 22:08:19 PST
709739050701258	Important: SCE Imminent De-Energize Notice for PSPS Event in SAN BERNARDINO COUNTY (NORTH PARK CIRCUIT, ALL SEGMENTS).	Dec 20, 2020 09:54:36 PST
709739050701268	Important: SCE Imminent De-Energize Notice for PSPS Event in LOS ANGELES COUNTY (SAND CANYON CIRCUIT, SEGMENT 3).	Dec 20, 2020 10:00:04 PST
709739050701275	Important: SCE Imminent De-Energize Notice for PSPS Event in VENTURA COUNTY (ANTON CIRCUIT, SEGMENT 2).	Dec 20, 2020 10:05:33 PST
709739050701310	Important: SCE Imminent De-Energize Notice for PSPS Event in VENTURA COUNTY (BIG ROCK CIRCUIT, SEGMENTS 2, 3).	Dec 20, 2020 10:58:42 PST
709739050701312	Important: SCE Imminent De-Energize Notice for PSPS Event in LOS ANGELES COUNTY (BIG ROCK CIRCUIT, SEGMENTS 2, 3).	Dec 20, 2020 11:00:49 PST
709739050701315	Important: SCE Imminent De-Energize Notice for PSPS Event in VENTURA COUNTY (TWIN LAKES CIRCUIT, SEGMENT 2).	Dec 20, 2020 11:04:31 PST
709739050701340	Important: SCE Update Notice for PSPS Event in KERN COUNTY.	Dec 20, 2020 11:41:25 PST

PSPS Notification Audit Report for 2020-12-16 through 2020-12-24

Notification ID	Message Title	Sent On
709739050701341	Important: SCE Update Notice for PSPS Event in LOS ANGELES COUNTY.	Dec 20, 2020 11:44:00 PST
709739050701343	Important: SCE Update Notice for PSPS Event in ORANGE COUNTY.	Dec 20, 2020 11:45:36 PST
709739050701347	Important: SCE Update Notice for PSPS Event in RIVERSIDE COUNTY.	Dec 20, 2020 11:48:10 PST
709739050701349	Important: SCE Update Notice for PSPS Event in SAN BERNARDINO COUNTY.	Dec 20, 2020 11:50:46 PST
709739050701350	Important: SCE Update Notice for PSPS Event in TULARE COUNTY.	Dec 20, 2020 11:52:49 PST
709739050701353	Important: SCE Update Notice for PSPS Event in VENTURA COUNTY.	Dec 20, 2020 11:55:18 PST
710013928610033	Important: SCE Re-Energize Notice for PSPS Event in VENTURA COUNTY at 14:07 (ENERGY CIRCUIT, SEGMENTS PARTIAL 4, and ALL SEGMENT 6).	Dec 20, 2020 14:30:31 PST
710013928610039	Important: SCE Re-Energize Notice for PSPS Event in LOS ANGELES COUNTY at 14:07 (ENERGY CIRCUIT, SEGMENTS PARTIAL 4, and ALL SEGMENT 6)	Dec 20, 2020 14:34:18 PST
710013928610050	CORRECTION: Important: SCE Imminent Re-Energize Notice for PSPS Event in LOS ANGELES COUNTY. (ENERGY CIRCUIT, SEGMENT PARTIAL 4 and SE	Dec 20, 2020 14:43:37 PST
709464172795943	*CORRECTION* Important: SCE Imminent Re-Energize Notice for PSPS Event in VENTURA County. (ENERGY, SEGMENT Partial 4, All 6)	Dec 20, 2020 14:44:50 PST
710013928610093	Important: SCE Re-Energize Notice for PSPS Event in LOS ANGELES COUNTY at 14:54 (ENERGY CIRCUIT, SEGMENT PARTIAL 4).	Dec 20, 2020 15:20:36 PST
710013928610096	Important: SCE Re-Energize Notice for PSPS Event in VENTURA County at 14:54 (ENERGY CIRCUIT, SEGMENT PARTIAL 4).	Dec 20, 2020 15:24:12 PST
710013928610190	Important: SCE Re-Energize Notice for PSPS Event in LOS ANGELES County at 16:18 (ENERGY CIRCUIT, SEGMENT 6).	Dec 20, 2020 16:39:33 PST
709464172796035	Important: SCE Imminent Re-Energize Notice for PSPS Event in SAN BERNARDINO. (CLUB OAKS, SEGMENT 2)	Dec 20, 2020 16:43:46 PST
710013928610198	Important: SCE Re-Energize Notice for PSPS Event in VENTURA County at 16:18 (ENERGY CIRCUIT, SEGMENT 6).	Dec 20, 2020 16:44:06 PST
708639539074147	Important: SCE Update Notice for PSPS Event in TULARE COUNTY.	Dec 20, 2020 19:55:50 PST
708639539074151	Important: SCE Update Notice for PSPS Event in KERN COUNTY.	Dec 20, 2020 20:01:17 PST
708639539074154	Important: SCE Update Notice for PSPS Event in LOS ANGELES COUNTY.	Dec 20, 2020 20:07:19 PST
708639539074155	Important: SCE Update Notice for PSPS Event in ORANGE COUNTY.	Dec 20, 2020 20:11:44 PST
708639539074160	Important: SCE Update Notice for PSPS Event in RIVERSIDE COUNTY.	Dec 20, 2020 20:17:46 PST
708639539074162	Important: SCE Update Notice for PSPS Event in SAN BERNARDINO COUNTY.	Dec 20, 2020 20:23:20 PST
708639539074166	Important: SCE Update Notice for PSPS Event in VENTURA COUNTY.	Dec 20, 2020 20:29:54 PST
709739050702786	Important: SCE Update Notice for PSPS Event in KERN COUNTY.	Dec 21, 2020 13:13:26 PST
709739050702790	Important: SCE Update Notice for PSPS Event in LOS ANGELES COUNTY.	Dec 21, 2020 13:15:18 PST
709739050702793	Important: SCE Update Notice for PSPS Event in ORANGE COUNTY.	Dec 21, 2020 13:16:30 PST
709739050702800	Important: SCE Update Notice for PSPS Event in RIVERSIDE COUNTY.	Dec 21, 2020 13:20:10 PST
709739050702804	Important: SCE Update Notice for PSPS Event in SAN BERNARDINO COUNTY.	Dec 21, 2020 13:21:59 PST
709739050702805	Important: SCE Update Notice for PSPS Event in TULARE COUNTY.	Dec 21, 2020 13:23:21 PST
709739050702810	Important: SCE Update Notice for PSPS Event in VENTURA COUNTY.	Dec 21, 2020 13:25:19 PST
709739050703312	Important: SCE Re-Energize Notice for PSPS Event in SAN BERNARDINO COUNTY at 13:03 (CLUB OAKS CIRCUIT, SEGMENT 2-No customers were imp	Dec 21, 2020 18:55:16 PST
709739050703414	Important: SCE Update Notice for PSPS Event in KERN COUNTY.	Dec 21, 2020 20:31:19 PST
709739050703420	Important: SCE Update Notice for PSPS Event in LOS ANGELES COUNTY.	Dec 21, 2020 20:34:05 PST
709739050703423	Important: SCE Update Notice for PSPS Event in ORANGE COUNTY.	Dec 21, 2020 20:35:42 PST
709739050703430	Important: SCE Update Notice for PSPS Event in RIVERSIDE COUNTY.	Dec 21, 2020 20:41:40 PST
709739050703434	Important: SCE Update Notice for PSPS Event in SAN BERNARDINO COUNTY.	Dec 21, 2020 20:44:23 PST
709739050703435	Important: SCE Update Notice for PSPS Event in TULARE COUNTY.	Dec 21, 2020 20:45:27 PST
709739050703439	Important: SCE Update Notice for PSPS Event in VENTURA COUNTY.	Dec 21, 2020 20:47:31 PST
709739050703464	CORRECTION-Important: SCE Update Notice for PSPS Event in KERN COUNTY.	Dec 21, 2020 21:33:19 PST
709739050703465	CORRECTION-Important: SCE Update Notice for PSPS Event in LOS ANGELES COUNTY.	Dec 21, 2020 21:35:22 PST
709739050703466	CORRECTION-Important: SCE Update Notice for PSPS Event in ORANGE COUNTY.	Dec 21, 2020 21:36:22 PST
709739050703469	CORRECTION-Important: SCE Update Notice for PSPS Event in RIVERSIDE COUNTY.	Dec 21, 2020 21:37:21 PST
709739050703471	CORRECTION-Important: SCE Update Notice for PSPS Event in SAN BERNARDINO COUNTY.	Dec 21, 2020 21:38:18 PST
709739050703475	CORRECTION-Important: SCE Update Notice for PSPS Event in TULARE COUNTY.	Dec 21, 2020 21:39:19 PST
709739050703477	CORRECTION-Important: SCE Update Notice for PSPS Event in VENTURA COUNTY.	Dec 21, 2020 21:40:21 PST

PSPS Notification Audit Report for 2020-12-16 through 2020-12-24

Notification ID	Message Title	Sent On
709739050703850	Important: SCE De-Energize Notice for PSPS Event in INYO COUNTY at 0621 (BIRCHIM, Seg 4).	Dec 22, 2020 06:50:15 PST
709739050703855	Important: SCE De-Energize Notice for PSPS Event in MONO COUNTY at 0621 (BIRCHIM, Seg 4).	Dec 22, 2020 06:53:51 PST
708502100123206	Important: SCE Imminent Re-Energize Notice for PSPS Event in MONO COUNTY (BIRCHIM CIRCUIT, SEG 4)	Dec 22, 2020 08:47:29 PST
708502100123214	Important: SCE Imminent Re-Energize Notice for PSPS Event in INYO COUNTY (BIRCHIM CIRCUIT, SEG 4)	Dec 22, 2020 08:52:55 PST
708502100123555	Important: SCE Update Notice for PSPS Event in SAN BERNARDINO COUNTY	Dec 22, 2020 13:04:05 PST
708502100123588	Important: SCE Update Notice for PSPS Event in RIVERSIDE COUNTY	Dec 22, 2020 13:35:54 PST
708502100123617	Important: SCE Update Notice for PSPS Event in LOS ANGELES COUNTY	Dec 22, 2020 14:04:01 PST
708502100123633	Important: SCE Update Notice for PSPS Event in VENTURA COUNTY	Dec 22, 2020 14:18:12 PST
708502100123646	Important: SCE Update Notice for PSPS Event in KERN COUNTY	Dec 22, 2020 14:27:24 PST
709876489659084	Important: SCE Re-Energize Notice for PSPS Event in Mono County at 12:52 (BIRCHIM, SEGMENT 4).	Dec 22, 2020 14:32:08 PST
708502100123659	Important: SCE Update Notice for PSPS Event in TULARE COUNTY	Dec 22, 2020 14:36:05 PST
709876489659099	Important: SCE Re-Energize Notice for PSPS Event in Inyo County at 12:52 (BIRCHIM, SEGMENT 4).	Dec 22, 2020 14:41:19 PST
708502100123671	Important: SCE Update Notice for PSPS Event in ORANGE COUNTY	Dec 22, 2020 14:44:31 PST
709464172799132	Important: SCE Update Notice for PSPS Event in VENTURA COUNTY.	Dec 22, 2020 21:27:36 PST
709464172799136	Important: SCE Update Notice for PSPS Event in Orange County.	Dec 22, 2020 21:35:49 PST
709464172799140	Important: SCE Update Notice for PSPS Event in Tulare County.	Dec 22, 2020 21:41:42 PST
709464172799145	Important: SCE Update Notice for PSPS Event in San Bernardino County.	Dec 22, 2020 21:50:22 PST
709464172799149	Important: SCE Update Notice for PSPS Event in Riverside County.	Dec 22, 2020 22:02:37 PST
709464172799152	Important: SCE Update Notice for PSPS Event in Los Angeles County.	Dec 22, 2020 22:11:51 PST
709464172799153	Important: SCE Update Notice for PSPS Event in Kern County.	Dec 22, 2020 22:16:36 PST
709464172799155	Important: SCE Update Notice for PSPS Event in Inyo County.	Dec 22, 2020 22:21:08 PST
709464172799158	Important: SCE Update Notice for PSPS Event in Mono County.	Dec 22, 2020 22:24:31 PST
708502100124287	Important: SCE Imminent De-Energize Notice for PSPS Event in LOS ANGELES COUNTY (SAND CANYON circuit, Segment 3).	Dec 23, 2020 02:48:15 PST
708502100124296	Important: SCE De-Energize Notice for PSPS Event in LOS ANGELES COUNTY at 03:02 (SAND CANYON circuit, Segment 3).	Dec 23, 2020 03:08:31 PST
709464172799401	Important: SCE Imminent De-Energize Notice for PSPS Event in Los Angeles County. (LOUCKS).	Dec 23, 2020 04:38:52 PST
709464172799432	Important: SCE De-Energize Notice for PSPS Event in LOUCKS at 04:51. Segment CB.	Dec 23, 2020 05:03:17 PST
709464172799439	Important: SCE Imminent De-Energize Notice for PSPS Event in Los Angeles County. (RED BOX).	Dec 23, 2020 05:09:01 PST
708502100124457	Important: SCE De-Energize Notice for PSPS Event in SAN BERNARDINO COUNTY AT 5:58 (CALSTATE CIRCUIT, SEGMENT 2)	Dec 23, 2020 06:12:02 PST
709876489659806	Important: SCE Imminent De-Energize Notice for PSPS Event in VENTURA COUNTY (TAPO CIRCUIT, SEGMENTS 3, 4).	Dec 23, 2020 06:38:11 PST
708502100124492	Important: SCE Imminent De-Energize Notice for PSPS Event in LOS ANGELES COUNTY (GUITAR CIRCUIT, SEG 6; DAVENPORT CIRCUIT, SEG 3, 4; EN	Dec 23, 2020 06:41:01 PST
708502100124529	Important: SCE Imminent De-Energize Notice for PSPS Event in VENTURA COUNTY (GUITAR CIRCUIT, SEG 6 and ENERGY CIRCUIT, SEG 4, 5, 6)	Dec 23, 2020 07:09:20 PST
708502100124545	Important: SCE Imminent De-Energize Notice for PSPS Event in RIVERSIDE COUNTY (DYSART CIRCUIT, ALL SEGMENTS and SADDLEBACK CIRCUIT, AL	Dec 23, 2020 07:22:14 PST
708502100124558	Important: SCE De-Energize Notice for PSPS Event in LOS ANGELES COUNTY (ENERGY CIRCUIT, SEG 6) at 7:17	Dec 23, 2020 07:30:46 PST
708502100124561	Important: SCE De-Energize Notice for PSPS Event in VENTURA COUNTY (ENERGY CIRCUIT, SEG 6) at 7:17	Dec 23, 2020 07:35:32 PST
708502100124583	Important: SCE Imminent De-Energize Notice for PSPS Event in RIVERSIDE COUNTY (FINGAL, SEG 1, 2)	Dec 23, 2020 07:51:47 PST
709876489659932	Important: SCE De-Energize Notice for PSPS Event in RIVERSIDE COUNTY at 07:40 (SADDLEBACK CIRCUIT, ALL SEGMENTS).	Dec 23, 2020 08:07:45 PST
708502100124614	Important: SCE Imminent De-Energize Notice for PSPS Event in VENTURA COUNTY (ANTON, Segment 2)	Dec 23, 2020 08:13:23 PST
709876489659960	Important: SCE De-Energize Notice for PSPS Event in RIVERSIDE COUNTY at 07:40 (DYSART CIRCUIT, ALL SEGMENTS).	Dec 23, 2020 08:18:39 PST
708502100124644	Important: SCE Imminent De-Energize Notice for PSPS Event in RIVERSIDE COUNTY (TAHQUITZ CIRCUIT, SEG 2)	Dec 23, 2020 08:32:52 PST
708502100124661	Important: SCE Imminent De-Energize Notice for PSPS Event in RIVERSIDE COUNTY (DUKE circuit, Seg 3).	Dec 23, 2020 08:41:35 PST
709876489660000	Important: SCE Imminent De-Energize Notice for PSPS Event in KERN COUNTY (CONDOR CIRCUIT, ALL SEGMENTS).	Dec 23, 2020 08:44:26 PST
708502100124679	Important: SCE Imminent De-Energize Notice for PSPS Event in VENTURA COUNTY (RAINBOW CIRCUIT, SEG 3; BALCOM CIRCUIT, SEG 1 and BIG RO	Dec 23, 2020 08:49:56 PST
709876489660029	Important: SCE Imminent De-Energize Notice for PSPS Event in LOS ANGELES COUNTY (BIG ROCK CIRCUIT, SEGMENTS 2, 3).	Dec 23, 2020 09:02:12 PST
708502100124710	Important: SCE De-Energize Notice for PSPS Event in VENTURA COUNTY at 8:18 (ENERGY CIRCUIT, SEG 4, 6 PARTIAL)	Dec 23, 2020 09:05:28 PST

PSPS Notification Audit Report for 2020-12-16 through 2020-12-24

Notification ID	Message Title	Sent On
709876489660048	Important: SCE Imminent De-Energize Notice for PSPS Event in KERN COUNTY (GNATCATCHER CIRCUIT, ALL SEGMENTS).	Dec 23, 2020 09:12:09 PST
709876489660071	Important: SCE De-Energize Notice for PSPS Event in LOS ANGELES COUNTY at 08:18 (ENERGY CIRCUIT, SEGMENT 4, 6 PARTIAL).	Dec 23, 2020 09:19:43 PST
708502100124730	Important: SCE De-Energize Notice for PSPS Event in VENTURA COUNTY (ENERGY CIRCUIT, SEG 4, 6 PARTIAL) *CORRECTION*	Dec 23, 2020 09:20:56 PST
709876489660110	Important: SCE De-Energize Notice for PSPS Event in VENTURA COUNTY (RAINBOW CIRCUIT, SEGMENT 3 at 08:58) (BALCOM CIRCUIT, SEGMENT 1 a	Dec 23, 2020 09:40:08 PST
708639539077969	Important: SCE Imminent De-Energize Notice for PSPS Event in LOS ANGELES County (BOOTLEGGERS, SEGMENTS ALL, Partial 1).	Dec 23, 2020 09:41:08 PST
708639539077976	Important: SCE Imminent De-Energize Notice for PSPS Event in LOS ANGELES County (DAVENPORT, SEGMENTS 5, 6).	Dec 23, 2020 09:43:49 PST
708502100124768	Important: SCE De-Energize Notice for PSPS Event in KERN COUNTY (CONDOR CIRCUIT, SEG ALL at 9:10 and GNATCATCHER CIRCUIT, SEG ALL at 9:1	Dec 23, 2020 09:44:15 PST
708639539077981	Important: SCE Imminent De-Energize Notice for PSPS Event in VENTURA COUNTY (ESTABAN, SEGMENT 3).	Dec 23, 2020 09:48:04 PST
708639539078004	Important: SCE Imminent De-Energize Notice for PSPS Event in LOS ANGELES COUNTY (SAND CANYON, SEGMENTS 3, 4, 5) (COBRA, SEGMENTS ALL)	Dec 23, 2020 09:58:10 PST
708639539078011	Important: SCE Imminent De-Energize Notice for PSPS Event in SAN BERNARDINO COUNTY (BLUE CUT, SEGMENTS 5).	Dec 23, 2020 09:59:48 PST
708502100124791	Important: SCE Imminent De-Energize Notice for PSPS Event in VENTURA COUNTY (RAINBOW CIRCUIT, SEG 4, 5)	Dec 23, 2020 10:02:36 PST
708639539078032	Important: SCE Imminent De-Energize Notice for PSPS Event in KERN COUNTY (FROZEN, SEGMENTS ALL).	Dec 23, 2020 10:11:04 PST
708502100124816	Important: SCE De-Energize Notice for PSPS Event in VENTURA COUNTY (ESTABAN CIRCUIT, SEG 3 at 9:47)	Dec 23, 2020 10:12:48 PST
708639539078044	Important: SCE Imminent De-Energize Notice for PSPS Event in VENTURA COUNTY (CASSIDY, SEGMENTS ALL).	Dec 23, 2020 10:15:51 PST
708639539078050	Important: SCE Imminent De-Energize Notice for PSPS Event in LOS ANGELES COUNTY (JULIUS, SEGMENTS ALL).	Dec 23, 2020 10:19:43 PST
708639539078052	Important: SCE Imminent De-Energize Notice for PSPS Event in LOS ANGELES COUNTY (ARLENE, SEGMENTS ALL) (HILLFIELD, SEGMENTS ALL)..	Dec 23, 2020 10:24:06 PST
708502100124851	Important: SCE Imminent De-Energize Notice for PSPS Event in RIVERSIDE COUNTY (BLACK HILLS CIRCUIT, SEG 2)	Dec 23, 2020 10:30:37 PST
708639539078074	Important: SCE Imminent De-Energize Notice for PSPS Event in SAN BERNARDINO COUNTY (ACOSTA, Partial SEGMENTS 2 & 4).	Dec 23, 2020 10:36:03 PST
708502100124864	Important: SCE De-Energize Notice for PSPS Event in VENTURA COUNTY (TWIN LAKES CIRCUIT, SEG 2 at 10:13)	Dec 23, 2020 10:39:52 PST
708639539078087	Important: SCE Imminent De-Energize Notice for PSPS Event in RIVERSIDE COUNTY (STEEL, SEGMENT 2).	Dec 23, 2020 10:44:54 PST
708639539078089	Important: SCE Imminent De-Energize Notice for PSPS Event in KERN COUNTY (FROZEN, SEGMENTS 2, 3, 4).	Dec 23, 2020 10:45:50 PST
708502100124881	Important: SCE Imminent De-Energize Notice for PSPS Event in KERN COUNTY (VIENTO CIRCUIT, SEG 3)	Dec 23, 2020 10:48:50 PST
708639539078104	Important: SCE Imminent De-Energize Notice for PSPS Event in SAN BERNARDINO COUNTY (SWEETWATER, SEGMENTS ALL) (CALSTATE, SEGMENTS	Dec 23, 2020 10:52:16 PST
708639539078107	Important: SCE Imminent De-Energize Notice for PSPS Event in SAN BERNARDINO COUNTY (CABANA, SEGMENTS ALL).	Dec 23, 2020 10:55:07 PST
708502100124906	Important: SCE Imminent De-Energize Notice for PSPS Event in RIVERSIDE (CABANA CIRCUIT, SEGMENT ALL)	Dec 23, 2020 10:58:55 PST
708639539078115	Important: SCE De-Energize Notice for PSPS Event in LOS ANGELES COUNTY at 10:38 (BIG ROCK, SEGMENTS 2, 3).	Dec 23, 2020 10:59:38 PST
708639539078120	Important: SCE De-Energize Notice for PSPS Event in VENTURA COUNTY at 10:38 (BIG ROCK, SEGMENT 2, 3).	Dec 23, 2020 11:01:23 PST
708639539078134	Important: SCE Imminent De-Energize Notice for PSPS Event in SAN BERNARDINO COUNTY (ACOSTA, SEGMENT 4).	Dec 23, 2020 11:08:18 PST
708502100124936	Important: SCE De-Energize Notice for PSPS Event in SAN BERNARDINO COUNTY (CABANA CIRCUIT, SEGMENTS ALL at 10:51)	Dec 23, 2020 11:18:37 PST
708502100124945	Important: SCE De-Energize Notice for PSPS Event in RIVERSIDE COUNTY (CABANA CIRCUIT, SEGMENT ALL at 10:51)	Dec 23, 2020 11:22:50 PST
708639539078159	Important: SCE De-Energize Notice for PSPS Event in LOS ANGELES COUNTY at various times (ALL SEGMENTS: HILLFIELD, ARLENE, COBRA, JULIUS, M	Dec 23, 2020 11:27:31 PST
708502100124968	Important: SCE De-Energize Notice for PSPS Event in VENTURA COUNTY (RICARDO CIRCUIT, SEG 2 at 11:06)	Dec 23, 2020 11:40:00 PST
708639539078197	Important: SCE Re-Energize Notice for PSPS Event in LOS ANGELES County (COBRA, SEGMENT 1, 11:01; JULIUS, SEGMENT Partial 1, 11:12).	Dec 23, 2020 11:54:12 PST
708502100125020	Important: SCE De-Energize Notice for PSPS Event in LOS ANGELES COUNTY (BOOTLEGGERS CIRCUIT, SEGMENT 1 PARTIAL at 10:47)	Dec 23, 2020 12:03:01 PST
708639539078218	Important: SCE Re-Energize Notice for PSPS Event in VENTURA County at 11:24 (TWIN LAKES, SEGMENT 2).	Dec 23, 2020 12:07:25 PST
708639539078233	Important: SCE De-Energize Notice for PSPS Event in KERN COUNTY at 10:24 (FROZEN, SEGMENT ALL).	Dec 23, 2020 12:12:47 PST
708502100125032	Important: SCE Re-Energize Notice for PSPS Event in RIVERSIDE COUNTY at 8:35 (SADDLEBACK CIRCUIT, SEGMENT 1 (PARTIAL)	Dec 23, 2020 12:17:47 PST
708639539078244	Important: SCE De-Energize Notice for PSPS Event in RIVERSIDE COUNTY at 11:29 (STEEL, SEGMENT 2).	Dec 23, 2020 12:17:51 PST
709876489660362	Important: SCE Update Notice for PSPS Event in LOS ANGELES COUNTY.	Dec 23, 2020 12:22:05 PST
708639539078263	Important: SCE De-Energize Notice for PSPS Event in LOS ANGELES COUNTY at 11:08 (GUITAR, SEGMENT 6).	Dec 23, 2020 12:28:09 PST
708639539078265	Important: SCE De-Energize Notice for PSPS Event in VENTURA COUNTY at 11:08 (GUITAR, SEGMENT 6).	Dec 23, 2020 12:29:47 PST
709876489660376	Important: SCE Update Notice for PSPS Event in KERN COUNTY.	Dec 23, 2020 12:30:01 PST
709876489660383	Important: SCE Update Notice for PSPS Event in ORANGE COUNTY.	Dec 23, 2020 12:33:43 PST
709876489660397	Important: SCE Update Notice for PSPS Event in RIVERSIDE COUNTY.	Dec 23, 2020 12:39:59 PST

PSPS Notification Audit Report for 2020-12-16 through 2020-12-24

Notification ID	Message Title	Sent On
708502100125066	Important: SCE Imminent Re-Energize Notice for PSPS Event in SAN BERNARDINO COUNTY (CABANA CIRCUIT, SEGMENT ALL)	Dec 23, 2020 12:44:57 PST
709876489660402	Important: SCE Update Notice for PSPS Event in SAN BERNARDINO COUNTY.	Dec 23, 2020 12:45:02 PST
709876489660405	Important: SCE Update Notice for PSPS Event in TULARE COUNTY.	Dec 23, 2020 12:47:23 PST
708502100125069	Important: SCE Imminent Re-Energize Notice for PSPS Event in RIVERSIDE COUNTY (CABANA CIRCUIT, SEGMENT ALL)	Dec 23, 2020 12:48:29 PST
709876489660415	Important: SCE Update Notice for PSPS Event in VENTURA COUNTY.	Dec 23, 2020 12:52:39 PST
708639539078307	Important: SCE Imminent De-Energize Notice for PSPS Event in RIVERSIDE COUNTY (DUKE circuit, Seg 3).	Dec 23, 2020 12:56:16 PST
708639539078351	Important: SCE Imminent De-Energize Notice for PSPS Event in SAN BERNARDINO COUNTY (VARGAS, SEGMENT 2).	Dec 23, 2020 13:12:35 PST
708639539078361	Important: SCE Imminent De-Energize Notice for PSPS Event in SAN BERNARDINO COUNTY (IMPALA, SEGMENTS ALL).	Dec 23, 2020 13:15:50 PST
708639539078378	Important: SCE Re-Energize Notice for PSPS Event in RIVERSIDE County at 13:17 (CABANA, SEGMENTS ALL).	Dec 23, 2020 13:25:56 PST
708639539078379	Important: SCE Re-Energize Notice for PSPS Event in SAN BERANRDINO County at 13:17 (CABANA, SEGMENTS ALL).	Dec 23, 2020 13:27:08 PST
716748437323783	Important: SCE Imminent De-Energize Notice for PSPS Event in RIVERSIDE COUNTY (NAPOLEON CIRCUIT, SEG 4 AND PHEASANT CIRCUIT, SEG ALL)	Dec 23, 2020 13:52:04 PST
716748437323805	Important: SCE Re-Energize Notice for PSPS Event in LOS ANGELES COUNTY at 13:40 (RACER CIRCUIT, SEGMENT 1 PARTIAL)	Dec 23, 2020 14:05:16 PST
713999658256635	Important: SCE Imminent De-Energize Notice for PSPS Event in SAN BERNARDINO COUNTY (NORTH PARK, SEGMENTS 3, 4, 5).	Dec 23, 2020 14:29:51 PST
716748437323873	Important: SCE De-Energize Notice for PSPS Event in RIVERSIDE COUNTY at 14:27 (DUKE CIRCUIT, SEGMENT 3)	Dec 23, 2020 14:38:24 PST
713999658256683	Important: SCE De-Energize Notice for PSPS Event in RIVERSIDE COUNTY at 14:35 (NAPOLEON, SEGMENT 2).	Dec 23, 2020 14:42:49 PST
713999658256697	Important: SCE Imminent De-Energize Notice for PSPS Event in SAN BERNARDINO COUNTY (CARMELITA, SEGMENT 2).	Dec 23, 2020 14:46:36 PST
716748437323898	Important: SCE De-Energize Notice for PSPS Event in SAN BERNARDINO COUNTY (VARGAS CIRCUIT, SEG 2 at 14:33 and NORTH PARK CIRCUIT, SEG 3)	Dec 23, 2020 14:52:09 PST
716748437323909	Important: SCE Imminent De-Energize Notice for PSPS Event in SAN BERNARDINO COUNTY (ECHO CIRCUIT, SEG ALL and SUTT CIRCUIT, SEG 5)	Dec 23, 2020 15:00:31 PST
713999658256738	Important: SCE Imminent De-Energize Notice for PSPS Event in ORANGE COUNTY (VERA CRUZ, SEGMENT 3).	Dec 23, 2020 15:02:12 PST
713999658256745	Important: SCE De-Energize Notice for PSPS Event in SAN BERNARDINO COUNTY at 14:53 (SWEETWATER, SEGMENT ALL).	Dec 23, 2020 15:04:33 PST
713999658256756	Important: SCE De-Energize Notice for PSPS Event in KERN COUNTY at 14:45 (GRAPEVINE PEAK, SEGMENT ALL).	Dec 23, 2020 15:06:54 PST
716748437323939	Important: SCE Imminent De-Energize Notice for PSPS Event in SAN BERNARDINO COUNTY (CARMELITA, SEGMENT ALL).	Dec 23, 2020 15:14:21 PST
713999658256780	Important: SCE Imminent De-Energize Notice for PSPS Event in SAN BERNARDINO COUNTY (BADGER, SEGMENTS ALL).	Dec 23, 2020 15:18:00 PST
713999658256786	Important: SCE Imminent De-Energize Notice for PSPS Event in RIVERSIDE COUNTY (DUKE circuit, Seg ALL).	Dec 23, 2020 15:22:58 PST
713999658256796	Important: SCE Imminent De-Energize Notice for PSPS Event in VENTURA COUNTY (RAINBOW CIRCUIT, SEG 4, 5)	Dec 23, 2020 15:26:09 PST
716748437323956	Important: SCE Imminent De-Energize Notice for PSPS Event in RIVERSIDE COUNTY (FINGAL CIRCUIT, SEG 1; ROUNDEL CIRCUIT, SEG ALL; MORELLO)	Dec 23, 2020 15:27:45 PST
713999658256808	Important: SCE Imminent De-Energize Notice for PSPS Event in KERN COUNTY (ZENDA, SEGMENT 3).	Dec 23, 2020 15:29:59 PST
713999658256820	Important: SCE Imminent De-Energize Notice for PSPS Event in KERN COUNTY (RANKIN, SEGMENT 2).	Dec 23, 2020 15:33:45 PST
716748437323973	Important: SCE De-Energize Notice for PSPS Event in RIVERSIDE COUNTY at 15:18 (PHEASANT CIRCUIT, SEGMENT ALL)	Dec 23, 2020 15:34:47 PST
713999658256828	Important: SCE Imminent De-Energize Notice for PSPS Event in SAN BERNARDINO COUNTY (NORTH PARK, SEGMENTS 1 (Partial), 2, 3, 4).	Dec 23, 2020 15:39:45 PST
713999658256836	Important: SCE Imminent De-Energize Notice for PSPS Event in VENTURA COUNTY (ZONE, SEGMENTS ALL; TOWNSHIP, SEGMENTS ALL).	Dec 23, 2020 15:43:48 PST
713999658256840	Important: SCE De-Energize Notice for PSPS Event in ORANGE COUNTY at 15:16 (VERA CRUZ, SEGMENT 3).	Dec 23, 2020 15:46:05 PST
716748437323994	Important: SCE Imminent De-Energize Notice for PSPS Event in RIVERSIDE COUNTY (SAVORY CIRCUIT, SEG 3, 4 and RANIER CIRCUIT, SEG ALL)	Dec 23, 2020 15:48:15 PST
713999658256892	Important: SCE Imminent De-Energize Notice for PSPS Event in LOS ANGELES COUNTY (ENERGY, SEGMENTS 4, 5, 6).	Dec 23, 2020 16:14:08 PST
716748437324027	Important: SCE Imminent De-Energize Notice for PSPS Event in RIVERSIDE COUNTY (SCHMIDT CIRCUIT, SEGMENTS ALL)	Dec 23, 2020 16:14:52 PST
713999658256894	Important: SCE Imminent De-Energize Notice for PSPS Event in VENTURA COUNTY (ENERGY, SEGMENTS 4, 5, 6).	Dec 23, 2020 16:15:32 PST
713999658256898	Important: SCE Imminent De-Energize Notice for PSPS Event in VENTURA COUNTY (BIG ROCK, SEGMENTS 1, 2, Partial 3).	Dec 23, 2020 16:18:49 PST
713999658256900	Important: SCE Imminent De-Energize Notice for PSPS Event in LOS ANGELES COUNTY (BIG ROCK CIRCUIT, SEGMENTS 1, 2, Partial 3).	Dec 23, 2020 16:19:20 PST
716748437324085	Important: SCE Imminent Re-Energize Notice for PSPS Event in VENTURA COUNTY (ESTABAN CIRCUIT, SEGMENT 3)	Dec 23, 2020 16:55:53 PST
713999658256969	Important: SCE Imminent Re-Energize Notice for PSPS Event in LOS ANGELES County (BOOTLEGGGER, SEGMENT 1)	Dec 23, 2020 16:56:24 PST
713999658256991	Important: SCE Re-Energize Notice for PSPS Event in LOS ANGELES County at 16:55 (BOOTLEGGGER, SEGMENT 1).	Dec 23, 2020 17:12:56 PST
713999658256997	Important: SCE Imminent Re-Energize Notice for PSPS Event in RIVERSIDE County. (STEEL, SEGMENT 2)	Dec 23, 2020 17:15:04 PST
716748437324112	Important: SCE Imminent Re-Energize Notice for PSPS Event in VENTURA COUNTY (RICARDO CIRCUIT, SEGMENT 2)	Dec 23, 2020 17:19:41 PST
713999658257013	Important: SCE Imminent De-Energize Notice for PSPS Event in ORANGE COUNTY (ATENTO CIRCUIT, SEGMENTS 3, 4, 5, 6).	Dec 23, 2020 17:27:48 PST

PSPS Notification Audit Report for 2020-12-16 through 2020-12-24

Notification ID	Message Title	Sent On
716748437324118	Important: SCE Imminent De-Energize Notice for PSPS Event in LOS ANGELES COUNTY (VETERANS CIRCUIT, SEGMENT 2)	Dec 23, 2020 17:29:18 PST
713999658257020	Important: SCE Imminent De-Energize Notice for PSPS Event in SAN BERNARDINO COUNTY (VERDEMONT, SEGMENTS 4, 5, 6).	Dec 23, 2020 17:29:33 PST
713999658257024	Important: SCE Imminent De-Energize Notice for PSPS Event in RIVERSIDE COUNTY (BONNEVILLE, SEGMENT 3).	Dec 23, 2020 17:33:15 PST
713999658257031	Important: SCE Re-Energize Notice for PSPS Event in SAN BERNARDINO County at 17:00 (SWEETWATER, SEGMENT Partial 2).	Dec 23, 2020 17:39:01 PST
718122826858714	Important: SCE Imminent Re-Energize Notice for PSPS Event in LOS ANGELES COUNTY. (Loucks, Segment CB)	Dec 23, 2020 18:05:47 PST
718122826858718	Important: SCE De-Energize Notice for PSPS Event in VENTURA COUNTY at 17:50 (RAINBOW CIRCUIT, SEGMENT 4, 5).	Dec 23, 2020 18:10:24 PST
718122826858726	Important: SCE De-Energize Notice for PSPS Event in SAN BERNARDINO COUNTY at 18:08 (NORTH PARK CIRCUIT, SEGMENT 2, 3, 4).	Dec 23, 2020 18:24:14 PST
717023315231048	Important: SCE Re-Energize Notice for PSPS Event in VENTURA County at 18:10 (ESTABAN, SEGMENT 3).	Dec 23, 2020 18:28:35 PST
718122826858758	Important: SCE Imminent De-Energize Notice for PSPS Event in Los Angeles County (DAVENPORT).	Dec 23, 2020 19:24:17 PST
718122826858763	Important: SCE Imminent De-Energize Notice for PSPS Event in Kern County (VIENTO).	Dec 23, 2020 19:30:04 PST
718122826858788	Important: SCE Re-Energize Notice for PSPS Event in Los Angeles County at 18:54 (LOUCKS, partial Segment 1).	Dec 23, 2020 19:50:26 PST
717023315231109	Important: SCE Imminent De-Energize Notice for PSPS Event in ORANGE COUNTY (ATENTO CIRCUIT).	Dec 23, 2020 20:13:02 PST
718122826858803	Important: SCE Imminent De-Energize Notice for PSPS Event in Ventura County (Petit).	Dec 23, 2020 20:28:34 PST
718122826858806	Important: SCE Imminent De-Energize Notice for PSPS Event in Ventura County (ESTABAN).	Dec 23, 2020 20:33:42 PST
718122826858808	Important: SCE De-Energize Notice for PSPS Event in ORANGE COUNTY at 20:10 (ATENTO CIRCUIT, SEGMENT 3, 4, 5, 6).	Dec 23, 2020 20:36:34 PST
717023315231128	Important: SCE De-Energize Notice for PSPS Event in VENTURA COUNTY at 20:40 (PETIT CIRCUIT, SEGMENT PARTIAL 1, 2, 3).	Dec 23, 2020 20:46:17 PST
717023315231134	Important: SCE Update Notice for PSPS Event in LOS ANGELES COUNTY.	Dec 23, 2020 20:51:58 PST
717023315231135	Important: SCE Update Notice for PSPS Event in KERN COUNTY.	Dec 23, 2020 20:53:48 PST
717023315231137	Important: SCE Update Notice for PSPS Event in ORANGE COUNTY.	Dec 23, 2020 20:55:44 PST
718122826858830	Important: SCE Imminent De-Energize Notice for PSPS Event in Ventura County (Angus Circuit).	Dec 23, 2020 20:56:14 PST
717023315231140	Important: SCE Update Notice for PSPS Event in RIVERSIDE COUNTY.	Dec 23, 2020 20:57:46 PST
717023315231141	Important: SCE Update Notice for PSPS Event in SAN BERNARDINO COUNTY.	Dec 23, 2020 20:59:09 PST
717023315231142	Important: SCE Update Notice for PSPS Event in TULARE COUNTY.	Dec 23, 2020 21:00:51 PST
717023315231143	Important: SCE Update Notice for PSPS Event in VENTURA COUNTY.	Dec 23, 2020 21:03:05 PST
718122826858847	Important: SCE Re-Energize Notice for PSPS Event in Ventura County at 20:53 (Petit Circuit, Segment partial 1, 2, 3).	Dec 23, 2020 21:20:11 PST
718122826858850	Important: SCE De-Energize Notice for PSPS Event in Riverside County at 21:26 (FINGAL CIRCUIT, SEGMENT 2).	Dec 23, 2020 21:31:48 PST
718122826858873	Important: SCE De-Energize Notice for PSPS Event in VENTURA COUNTY at 22:18 (ESTABAN CIRCUIT, SEGMENT 3).	Dec 23, 2020 22:32:30 PST
718122826858891	Important: SCE Imminent De-Energize Notice for PSPS Event in Ventura County (Castro Circuit).	Dec 23, 2020 23:27:34 PST
718122826858914	Important: SCE Imminent De-Energize Notice for PSPS Event in Los Angeles County (Veterans Circuit).	Dec 24, 2020 00:17:07 PST
717023315231209	Important: SCE Imminent De-Energize Notice for PSPS Event in LOS ANGELES County (ANACONDA CIRCUIT).	Dec 24, 2020 00:17:28 PST
718122826858925	Important: SCE Imminent De-Energize Notice for PSPS Event in Ventura County (Township Circuit).	Dec 24, 2020 01:04:38 PST
717023315231233	Important: SCE Imminent De-Energize Notice for PSPS Event in VENTURA County (TAPO CIRCUIT).	Dec 24, 2020 01:13:29 PST
718122826858963	Important: SCE Imminent De-Energize Notice for PSPS Event in Ventura County (Zone Circuit).	Dec 24, 2020 02:24:58 PST
718122826858964	Important: SCE De-Energize Notice for PSPS Event in VENTURA COUNTY at 02:21 (CASTRO CIRCUIT, SEGMENT 5).	Dec 24, 2020 02:25:51 PST
718122826858980	Important: SCE Imminent De-Energize Notice for PSPS Event in Ventura County (Anton Circuit).	Dec 24, 2020 02:54:03 PST
717023315231275	Important: SCE Imminent De-Energize Notice for PSPS Event in RIVERSIDE County (HONEYCRISP CIRCUIT).	Dec 24, 2020 02:55:35 PST
718122826858992	Important: SCE Imminent De-Energize Notice for PSPS Event in Riverside County (Deluz Circuit).	Dec 24, 2020 03:07:14 PST
718122826858993	Important: SCE De-Energize Notice for PSPS Event in RIVERSIDE COUNTY at 03:04 (HONEYCRISP CIRCUIT, SEGMENT ALL).	Dec 24, 2020 03:10:37 PST
718122826859071	Important: SCE Re-Energize Notice for PSPS Event in Riverside County at 04:29 (Honeycrisp Circuit, SEGMENT 2).	Dec 24, 2020 04:49:14 PST
717573071045738	Important: SCE Partial Re-Energize Notice for PSPS Event in RIVERSIDE COUNTY at 06:11 (HONEYCRISP, SEGMENT ALL).	Dec 24, 2020 06:43:52 PST
716748437324793	Important: SCE Imminent Re-Energize Notice for PSPS Event in SAN BERNARDINO COUNTY (VARGAS CIRCUIT, SEG 2 and SWEETWATER CIRCUIT, SEG 2)	Dec 24, 2020 07:07:07 PST
717573071045814	Important: SCE Imminent Re-Energize Notice for PSPS Event in ORANGE COUNTY. (ATENTO, SEGMENTS 3, 4, 5 & 6)	Dec 24, 2020 07:21:54 PST
717573071045844	Important: SCE Imminent Re-Energize Notice for PSPS Event in SAN BERNARDINO COUNTY. (CALSTATE, SEGMENT 2)	Dec 24, 2020 07:42:22 PST
716748437324838	Important: SCE Imminent Re-Energize Notice for PSPS Event in SAN BERNARDINO COUNTY (NORTH PARK CIRCUIT, SEG 2, 3, 4, 5)	Dec 24, 2020 07:50:49 PST

PSPS Notification Audit Report for 2020-12-16 through 2020-12-24

Notification ID	Message Title	Sent On
717573071045872	Important: SCE Imminent Re-Energize Notice for PSPS Event in ORANGE COUNTY. (VERA CRUZ, SEGMENT 3)	Dec 24, 2020 08:01:15 PST
716748437324875	Important: SCE Re-Energize Notice for PSPS Event in SAN BERNARDINO COUNTY at 8:04 (VARGAS CIRCUIT, SEGMENT 2)	Dec 24, 2020 08:19:20 PST
716748437324913	Important: SCE Imminent Re-Energize Notice for PSPS Event in LOS ANGELES COUNTY (GUITAR CIRCUIT, SEG 6 and SAND CANYON CIRCUIT, SEG 3, 5)	Dec 24, 2020 09:02:33 PST
717573071045980	Important: SCE Imminent Re-Energize Notice for PSPS Event in VENTURA COUNTY. (BALCOM, SEGMENTS 1&2; CASTRO, SEGMENT 5; ESTABAN, SEG 3)	Dec 24, 2020 09:13:57 PST
716748437324927	Important: SCE Re-Energize Notice for PSPS Event in ORANGE COUNTY at 9:03 (VERA CRUZ CIRCUIT, SEGMENT 3)	Dec 24, 2020 09:17:10 PST
717573071045997	Important: SCE Imminent Re-Energize Notice for PSPS Event in VENTURA COUNTY. (TAPO, SEGMENTS 3 & 4)	Dec 24, 2020 09:21:12 PST
717573071046010	Important: SCE Imminent Re-Energize Notice for PSPS Event in RIVERSIDE COUNTY. (DYSART, SEGMENTS ALL)	Dec 24, 2020 09:29:47 PST
716748437324950	Important: SCE Re-Energize Notice for PSPS Event in SAN BERNARDINO COUNTY at 09:10 (SWEETWATER CIRCUIT, SEGMENT ALL)	Dec 24, 2020 09:30:31 PST
717573071046017	Important: SCE Imminent Re-Energize Notice for PSPS Event in VENTURA COUNTY. (PETIT, SEGMENT 1)	Dec 24, 2020 09:34:16 PST
716748437324962	Important: SCE Imminent Re-Energize Notice for PSPS Event in RIVERSIDE COUNTY (SADDLEBACK CIRCUIT, SEG ALL and FINGAL CIRCUIT, SEG 2, 3, 4)	Dec 24, 2020 09:40:13 PST
716748437324990	Important: SCE Imminent Re-Energize Notice for PSPS Event in VENTURA COUNTY (BIG ROCK CIRCUIT, SEG 2, 3)	Dec 24, 2020 10:08:11 PST
717573071046096	Important: SCE Re-Energize Notice for PSPS Event in SAN BERNARDINO at 10:01 (NORTH PARK, SEGMENTS 2, 3, 4 & 5).	Dec 24, 2020 10:15:27 PST
716748437325001	Important: SCE Imminent Re-Energize Notice for PSPS Event in VENTURA COUNTY (RAINBOW CIRCUIT, SEGMENTS 3, 4, 5)	Dec 24, 2020 10:19:31 PST
717573071046118	Important: SCE Imminent Re-Energize Notice for PSPS Event in RIVERSIDE COUNTY. (PHEASANT, ALL SEGMENTS)	Dec 24, 2020 10:26:35 PST
717573071046126	Important: SCE Re-Energize Notice for PSPS Event in VENTURA COUNTY at 10:24 (ESTABAN, SEGMENT 3).	Dec 24, 2020 10:33:39 PST
717573071046132	Important: SCE Re-Energize Notice for PSPS Event in VENTURA COUNTY at 10:24 (GUITAR, SEGMENT 6).	Dec 24, 2020 10:38:27 PST
716748437325020	Important: SCE Re-Energize Notice for PSPS Event in LOS ANGELES COUNTY at 10:24 (GUITAR CIRCUIT, SEGMENT 6)	Dec 24, 2020 10:39:37 PST
717573071046141	Important: SCE Re-Energize Notice for PSPS Event in VENTURA COUNTY at 10:29 (CASTRO, SEGMENT 5).	Dec 24, 2020 10:43:20 PST
716748437325026	Important: SCE Imminent Re-Energize Notice for PSPS Event in LOS ANGELES COUNTY (LOUCKS CIRCUIT, SEGMENT ALL)	Dec 24, 2020 10:45:38 PST
717573071046164	Important: SCE Imminent Re-Energize Notice for PSPS Event in LOS ANGELES COUNTY. (COBRA, SEGMENT 1)	Dec 24, 2020 10:56:33 PST
716748437325039	Important: SCE Imminent Re-Energize Notice for PSPS Event in LOS ANGELES (JULIS CIRCUIT, SEG 4; MARCUS CIRCUIT, SEG ALL; RACER CIRCUIT, SEG 2)	Dec 24, 2020 11:05:12 PST
716748437325045	Important: SCE Imminent Re-Energize Notice for PSPS Event in VENTURA COUNTY (RICARDO CIRCUIT, SEGMENT 2)	Dec 24, 2020 11:10:31 PST
717573071046181	Important: SCE Imminent Re-Energize Notice for PSPS Event in VENTURA COUNTY. (ANTON, SEGMENT 2-partial)	Dec 24, 2020 11:14:33 PST
717573071046187	Important: SCE Re-Energize Notice for PSPS Event in RIVERSIDE COUNTY at 11:07 (PHEASANT, ALL SEGMENTS).	Dec 24, 2020 11:19:25 PST
716748437325059	Important: SCE Re-Energize Notice for PSPS Event in LOS ANGELES COUNTY at 11:04 (LOUCKS CIRCUIT, SEGMENT ALL)	Dec 24, 2020 11:20:26 PST
717573071046202	Important: SCE Imminent Re-Energize Notice for PSPS Event in LOS ANGELES COUNTY. (ARLENE, ALL SEGMENTS)	Dec 24, 2020 11:25:34 PST
716748437325062	Important: SCE Re-Energize Notice for PSPS Event in VENTURA COUNTY at 11:15 (BALCOM CIRCUIT, SEGMENT 1, 2)	Dec 24, 2020 11:26:22 PST
717573071046212	Important: SCE Imminent Re-Energize Notice for PSPS Event in LOS ANGELES COUNTY. (HILLFIELD, ALL SEGMENTS)	Dec 24, 2020 11:29:47 PST
716748437325067	Important: SCE Re-Energize Notice for PSPS Event in SAN BERNARDINO COUNTY at 11:13 (CAL STATE CIRCUIT, SEGMENT 2)	Dec 24, 2020 11:32:43 PST
717573071046224	Important: SCE Imminent Re-Energize Notice for PSPS Event in VENTURA COUNTY. (ENERGY, SEGMENTS 4-partial & 6-partial)	Dec 24, 2020 11:40:23 PST
717573071046225	Important: SCE Imminent Re-Energize Notice for PSPS Event in LOS ANGELES COUNTY. (ENERGY, SEGMENTS 4-partial & 6-partial)	Dec 24, 2020 11:42:26 PST
717573071046228	Important: SCE Re-Energize Notice for PSPS Event in VENTURA COUNTY at 11:38 (PETIT, SEGMENT 1).	Dec 24, 2020 11:48:23 PST
716748437325082	Important: SCE Re-Energize Notice for PSPS Event in LOS ANGELES at 11:44 (COBRA CIRCUIT, SEGMENT 1)	Dec 24, 2020 11:55:50 PST
717573071046243	Important: SCE Imminent Re-Energize Notice for PSPS Event in RIVERSIDE COUNTY. (HONEYCRISP, ALL SEGMENTS)	Dec 24, 2020 11:57:40 PST
716748437325085	Important: SCE Re-Energize Notice for PSPS Event in VENTURA COUNTY at 11:46 (RAINBOW CIRCUIT, SEGMENT 3, 4, 5)	Dec 24, 2020 12:01:19 PST
717573071046257	Important: SCE Re-Energize Notice for PSPS Event in LOS ANGELES COUNTY at 11:49 (SAND CANYON, SEGMENTS 3 and 5).	Dec 24, 2020 12:06:44 PST
717573071046274	Important: SCE Re-Energize Notice for PSPS Event in VENTURA COUNTY at 12:05 (RICARDO , SEGMENT 2).	Dec 24, 2020 12:16:02 PST
717573071046282	Important: SCE Imminent Re-Energize Notice for PSPS Event in RIVERSIDE COUNTY. (NAPOLEON, SEGMENT 2)	Dec 24, 2020 12:21:19 PST
716748437325101	Important: SCE Imminent Re-Energize Notice for PSPS Event in RIVERSIDE COUNTY (STEEL CIRCUIT, SEG 2 and DUKE CIRCUIT, SEG 3)	Dec 24, 2020 12:28:17 PST
717573071046312	Important: SCE Re-Energize Notice for PSPS Event in LOS ANGELES COUNTY at 12:25 (RACER, ALL SEGMENTS) AND 12:25 (MARCUS, ALL SEGMENTS)	Dec 24, 2020 12:38:54 PST
717573071046329	Important: SCE Re-Energize Notice for PSPS Event in LOS ANGELES COUNTY at 12:39 (ARLENE, ALL SEGMENTS).	Dec 24, 2020 12:50:21 PST
717573071046367	Important: SCE Re-Energize Notice for PSPS Event in LOS ANGELES COUNTY at 13:09 (JULIUS, SEGMENT 4).	Dec 24, 2020 13:19:10 PST
716748437325172	Important: SCE Re-Energize Notice for PSPS Event in RIVERSIDE COUNTY (DYSART CIRCUIT, SEG ALL at 13:17 and SADDLEBACK CIRCUIT, SEG ALL at 13:18)	Dec 24, 2020 13:28:51 PST
718535143719921	Important: SCE Update Notice for PSPS Event in TULARE COUNTY.	Dec 24, 2020 14:08:29 PST

PSPS Notification Audit Report for 2020-12-16 through 2020-12-24

Notification ID	Message Title	Sent On
718535143719923	Important: SCE Update Notice for PSPS Event in KERN COUNTY.	Dec 24, 2020 14:12:09 PST
718535143719931	Important: SCE Update Notice for PSPS Event in VENTURA COUNTY.	Dec 24, 2020 14:20:43 PST
716748437325218	Important: SCE Re-Energize Notice for PSPS Event in RIVERSIDE COUNTY at 14:12 (FINGAL CIRCUIT, SEGMENTS 2, 3, 4)	Dec 24, 2020 14:21:30 PST
718535143719934	Important: SCE Update Notice for PSPS Event in SAN BERNARDINO COUNTY.	Dec 24, 2020 14:23:13 PST
718535143719935	Important: SCE Update Notice for PSPS Event in RIVERSIDE COUNTY.	Dec 24, 2020 14:26:15 PST
717573071046469	Important: SCE Re-Energize Notice for PSPS Event in RIVERSIDE COUNTY at 14:01 (NAPOLEON, SEGMENT 2).	Dec 24, 2020 14:30:59 PST
716748437325229	Important: SCE Re-Energize Notice for PSPS Event in LOS ANGELES COUNTY at 14:20 (HILLFIELD CIRCUIT, SEGMENT ALL)	Dec 24, 2020 14:31:18 PST
717573071046475	Important: SCE Imminent Re-Energize Notice for PSPS Event in KERN COUNTY. (GNATCATCHER, ALL SEGMENT; CONDOR, SEGMENT 1-partial; FROZEN	Dec 24, 2020 14:33:49 PST
718535143719940	Important: SCE Update Notice for PSPS Event in ORANGE COUNTY.	Dec 24, 2020 14:34:36 PST
716748437325242	Important: SCE Re-Energize Notice for PSPS Event in RIVERSIDE COUNTY (DUKE CIRCUIT, SEG ALL at 14:12 and HONEYCRISP CIRCUIT, SEG ALL at 14:	Dec 24, 2020 14:41:54 PST
718535143719947	Important: SCE Update Notice for PSPS Event in LOS ANGELES COUNTY.	Dec 24, 2020 14:42:14 PST
717573071046492	Important: SCE Re-Energize Notice for PSPS Event in VENTURA COUNTY at 14:36 (ANTON, SEGMENT 2-partial).	Dec 24, 2020 14:46:44 PST
717573071046502	Important: SCE Re-Energize Notice for PSPS Event in VENTURA at 14:37 (ENERGY, SEGMENT 4-partial & SEGMENT 6-partial).	Dec 24, 2020 14:51:57 PST
716748437325252	Important: SCE Re-Energize Notice for PSPS Event in LOS ANGELES COUNTY at 14:37 (ENERGY CIRCUIT, SEGMENT 4 PARTIAL and SEGMENT 6 PARTIAL)	Dec 24, 2020 14:54:10 PST
717573071046518	Important: SCE Re-Energize Notice for PSPS Event in VENTURA COUNTY at 11:32 (TWIN LAKES, SEGMENT 2) and 14:35 (TAPO, SEGMENT 3 & 4)	Dec 24, 2020 15:04:06 PST
716748437325281	Important: SCE Re-Energize Notice for PSPS Event in KERN COUNTY at 15:09 (CONDOR CIRCUIT, SEGMENT ALL)	Dec 24, 2020 15:26:01 PST
716748437325296	Important: SCE Re-Energize Notice for PSPS Event in RIVERSIDE COUNTY at 15:21 (STEEL CIRCUIT, SEGMENT 2)	Dec 24, 2020 15:37:32 PST
719772094301271	Important: SCE Re-Energize Notice for PSPS Event in KERN COUNTY at 15:51 (GNATCATCHER, ALL SEGMENTS).	Dec 24, 2020 16:10:30 PST
716748437325312	Important: SCE Re-Energize Notice for PSPS Event in KERN COUNTY at 16:03 (FROZEN CIRCUIT, SEGMENT ALL)	Dec 24, 2020 16:10:39 PST
719772094301284	Important: SCE Re-Energize Notice for PSPS Event in LOS ANGELES COUNTY at 14:37 (ENERGY, SEGMENTS 4,5,6).	Dec 24, 2020 16:22:22 PST
719772094301287	Important: SCE Re-Energize Notice for PSPS Event in VENTURA COUNTY at 14:37 (ENERGY, SEGMENTS 4,5,6).	Dec 24, 2020 16:25:30 PST
719772094301299	Important: SCE Re-Energize Notice for PSPS Event in LOS ANGELES COUNTY at 10:18 (BIG ROCK, SEGMENTS 2,3).	Dec 24, 2020 16:40:44 PST
719772094301303	Important: SCE Re-Energize Notice for PSPS Event in VENTURA COUNTY at 10:18 (BIG ROCK, SEGMENTS 2,3).	Dec 24, 2020 16:47:58 PST
718535143720068	Important: SCE Event Concluded Notice for PSPS Event in INYO County.	Dec 24, 2020 17:12:41 PST
718535143720071	Important: SCE Event Concluded Notice for PSPS Event in KERN County.	Dec 24, 2020 17:16:50 PST
718535143720072	Important: SCE Event Concluded Notice for PSPS Event in LOS ANGELES Co.	Dec 24, 2020 17:21:15 PST
718535143720074	Important: SCE Event Concluded Notice for PSPS Event in ORANGE County.	Dec 24, 2020 17:23:53 PST
718535143720077	Important: SCE Event Concluded Notice for PSPS Event in RIVERSIDE County.	Dec 24, 2020 17:28:28 PST
718535143720078	Important: SCE Event Concluded Notice for PSPS Event in SAN BERNARDINO county.	Dec 24, 2020 17:33:36 PST
718535143720080	Important: SCE Event Concluded Notice for PSPS Event in TULARE.	Dec 24, 2020 17:36:05 PST
718535143720084	Important: SCE Event Concluded Notice for PSPS Event in VENTURA County.	Dec 24, 2020 17:40:44 PST

SCE LNO Notification Template Text: 2020-12-16 PSPS Activation

Liaison Officer (LNO) notifications are sent by circuit and/or county and based on circuits listed on SCE's Monitored Circuit List (MCL). LNO notifications begin 72 hours before the period of concern, when possible. LNO notifications differ from SCE customer notifications in terms of timing, message content, frequency, and audience.

There are seven unique LNO notification templates:

- An **Initial** notification is sent at the start of the incident for each impacted county and includes the activation's first LNO spreadsheet.
- **Update** notifications are sent twice daily with an attached LNO spreadsheet after each weather report/POC generated by Operations.
- **Imminent De-Energization, De-Energization, Imminent Re-Energization, and Re-Energization** notifications are sent, as needed, during PSPS events. No attachments.
- An **Event Concluded** notification is sent at the end of the incident for each county that had a circuit on the MCL letting officials know SCE's IMT is over. Attachment optional.

LNO notifications are sent to the following stakeholder groups. Contacts are either mapped to specific circuits or are included based on their County-level affiliation.

- Local City/County/Tribal Officials
- Public Safety Partners including CalFire and CalOES
- CCA Administrators
- State and Federal Legislative District Offices
- 211 Operators
- Independent Living Centers
- Other stakeholders with longer range emergency planning responsibilities

Initial Notification

Description:

Sent one time per county, starting 72 hours in advance of a possible PSPS event, alerting contacts that our weather specialists forecast potential extreme weather ahead. Includes the LNO POC spreadsheet with information about circuits and locations that could be impacted. Sent to all impacted jurisdictions and other LNO contacts, grouped by County.

Notification Subject Line and Message

Important: SCE Initial Notice for PSPS Event in [COUNTY NAME] on [start POC DATE].

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to projected weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some

cities and/or unincorporated areas in [COUNTY NAME]. SCE is also notifying customers on the affected circuits about the potential shutoff, giving them time to prepare.

SCE has opened its Emergency Operations Center and activated an Incident Management Team to monitor the weather and other conditions in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

Please refer to the attached file for status and periods of concern for specific circuits in your county.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at sce.com/outage.

Recommended Language to Share with the Public: SCE may shut off power on one or more circuits in your area. For more information, visit sce.com/PSPS.

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at sce.com/maps.
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at sce.com/PSPS.
- Access SCE's non-PSPS outage information page at sce.com/outages.
- Access information on weather conditions at sce.com/fireweather.
- SCE's post-PSPS reports are available at sce.com/pmps.

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.

- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - sce.com/PSPS is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at sce.com/pspсалerts.

Updated Conditions Notification

Description:

Sent once or twice daily after the Initial Notification to provide updates as the period of concern approaches. Includes the LNO POC spreadsheet with information about circuits and locations that could be/are impacted. Sent to all impacted jurisdictions, grouped by County.

Notification Subject Line and Message:

Important: SCE Update Notice for PSPS Event in [County Name].

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in [COUNTY NAME]. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at sce.com/outage.

Recommended Language to Share with the Public: Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit sce.com/PSPS.

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at sce.com/maps.
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at sce.com/PSPS.
- Access SCE's non-PSPS outage information page at sce.com/outages.
- Access information on weather conditions at sce.com/fireweather.
- SCE's post-PSPS reports are available at sce.com/pspss.

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - sce.com/PSPS is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at sce.com/pspsalerts.

Imminent De-Energize Notification

Description:

Sent 1-4 hours in advance of expected power shut off, when possible, for specific circuit(s). No spreadsheet attachment, all content is on the body of the notification. Sent to all impacted jurisdictions, grouped by County.

Notification Subject Line and Message:

Important: SCE Imminent De-Energize Notice for PSPS Event in [County Name].

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition through the PSPS

may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit:** [CIRCUIT name]
- **County:**
- **Segment:**
- **Incorporated City of:**
- **Unincorporated County Area:** [cut and paste from LNO spreadsheet]

Circuit segments may be viewed at [sce.com/psps](https://www.sce.com/psps) and maps downloaded at [sce.com/maps](https://www.sce.com/maps).

This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, **if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

Recommended Language to Share with the Public: Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit www.sce.com/PSPS.

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.

- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.

- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - sce.com/PSPS is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at sce.com/pspsalerts.

De-Energize Notification

Description:

Sent after a PSPS power shut off has occurred for specific circuit(s). No spreadsheet attachment, all content is on the body of the notification. Includes official date/time of de-energization for circuit(s). Sent to all impacted jurisdictions, grouped by County.

Notification Subject Line and Message:

Important: SCE De-Energize Notice for PSPS Event in [COUNTY NAME] at [TIME].

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to weather conditions, SCE conducted a Public Safety Power Shutoff (PSPS) to circuits in your county. Impacted circuits and locations are:

- **Circuit: [CIRCUIT name]**
- **County:**
- **Segment:**
- **Incorporated City of:**
- **Unincorporated County Area: [cut and paste from LNO spreadsheet]**
- **De-Energized Date:**
- **De-Energized Time:**

Circuit segments may be viewed at sce.com/psps and maps downloaded at sce.com/maps.

SCE is also notifying customers on the affected circuits to inform them about the shutoff. SCE understands the inconvenience of shutting off electric service. Safety is SCE's first priority. This Public Safety Power Shutoff (PSPS) action was taken with the safety of our customers and the public in mind, and to maintain the integrity of the electric system for all of our customers.

SCE has an Incident Management Team (IMT) in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe.

Power will be restored as weather conditions improve, crews conduct inspections, any necessary repairs have been made, and we determine it is safe to re-energize lines. In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

Recommended Language to Share with the Public: Due to current weather conditions, SCE has shut off power in your area. Check your email for details and visit www.sce.com/PSPS.

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at sce.com/maps.
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at sce.com/PSPS.
- Access SCE's non-PSPS outage information page at sce.com/outages.
- Access information on weather conditions at sce.com/fireweather.
- SCE's post-PSPS reports are available at sce.com/psps.

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - sce.com/PSPS is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at sce.com/pspsalerts.

Imminent Re-Energize Notification

Description:

Sent once inspections are underway and with 1-hour advance notice of expected power restoration, when possible, for specific circuit(s). No spreadsheet attachment, all content is on the body of the notification. Sent to all impacted jurisdictions, grouped by County.

Notification Subject Line and Message:

Important: SCE Imminent Re-Energize Notice for PSPS Event in [COUNTY NAME].

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have completed inspections, made any necessary repairs, and determined it is safe to begin **RE-ENERGIZING** the following circuit(s) or segments of circuit(s):

- **Circuit: [CIRCUIT name]**
- **Segment(s):**
- **County:**
- **Incorporated City of:**
- **Unincorporated County Area: [cut and paste from LNO spreadsheet or circuit tool]**

Circuit segments may be viewed at sce.com/psps and maps downloaded at sce.com/maps.

SCE will also begin notifying customers that power will be turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working safely and as quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

Recommended Language to Share with the Public: SCE will begin turning power back on in your area. SCE has inspected its electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit sce.com/PSPS.

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at sce.com/maps.
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at sce.com/PSPS.

- Access SCE’s non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE’s post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it’s monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Re-Energize Notification

Description:

Sent after a PSPS re-energization has occurred for specific circuit(s). No spreadsheet attachment, all content is on the body of the notification. Includes official date/time of power restoration for circuit(s). Sent to all impacted jurisdictions, grouped by County.

Notification Subject Line and Message:

Important: SCE Re-Energize Notice for PSPS Event in [COUNTY NAME].

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- **Circuit:**
- **County:**
- **Incorporated City of:**
- **Unincorporated County Area: (cut and paste from LNO Spreadsheet]**
- **Re-Energized Date:**
- **Re-Energized Time:**

SCE is also notifying customers that power has been turned back on. SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

Recommended Language to Share with the Public: SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.

- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - sce.com/PSPS is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at sce.com/pspsalerts.

Event Concluded Notification

Notification Subject Line and Message:

Sent, by county, once all circuits are re-energized* and the event is over for that county. Depending on circumstances, this may be sent with or without an LNO POC attachment. Eventually each county will receive an Event Concluded “all clear” so they know the weather event has passed and all power is up.

*Sometimes (rarely), a circuit may take longer to re-energize such as when we are working in a fire area and crews don't have access. In those cases that circuit may be transitioned to Operations and closed out from a PSPS standpoint. That information is included in the Event Concluded notification, indicating power is not fully restored for that circuit(s).

Notification Subject Line and Message:

Important: SCE Event Concluded Notice for PSPS Event in [COUNTY NAME].

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE's Incident Management Team is standing down and both SCE systems and staff have returned to normal status.

For customers in areas experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

Recommended Language to Share with the Public: The power shutoff in your area has concluded. Customers in this area, however, may experience other weather-related or unplanned repair outages not related to the Public Safety Power Shutoff (PSPS). Check your email for details and visit sce.com/PSPS.

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at sce.com/maps.
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at sce.com/PSPS.
- Access SCE's non-PSPS outage information page at sce.com/outages.
- Access information on weather conditions at sce.com/fireweather.

- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Attachment B

Critical Infrastructure and Customer Notifications

ZONE	D			Ventura	12/20/2020 08:40, 12/18/2020 18:00, 12/17/2020 10:00	12/24/2020 13:30, 12/19/2020 14:44, 12/17/2020 18:15	12/20/2020 12:23	12/17/2020 13:37, 12/21/2020 13:11	12/18/2020 20:45, 12/22/2020 13:43	12/19/2020 11:45	12/23/2020 21:40	12/17/2020 20:39, 12/19/2020 21:18, 12/24/2020 14:50	12/23/2020 15:45				
------	---	--	--	---------	--	--	---------------------	---	---	------------------	------------------	--	------------------	--	--	--	--

Circuits de-energized CB or Segmented

Attachment C

PPSP Activation Customer Notification Messaging

Customer Automated Notifications - Messaging

Preparing to Re-Energize (Imminent Restoration)

Voice/ Voice Mail/TTY:

This is an important safety message from Southern California Edison. SCE will soon begin the process of inspecting electrical lines in the ^city variable^ area. Provided we find no safety concerns, we will begin the power restoration process. To ensure you are ready for service, turn off or unplug any appliances or equipment that may automatically start when your power is restored. For more information on SCE's restoration process, please visit sce.com/psps. Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

Text/SMS:

SCE Safety Alert: SCE will soon begin the process of inspecting electrical lines in the ^city variable^ area. Provided we find no safety concerns, we will begin the power restoration process. To ensure you are ready for service, turn off or unplug any appliances or equipment that may automatically start when your power is restored. For more information on SCE's restoration process, please visit sce.com/psps. Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

E-Mail:

Subject: SCE Safety Alert: Public Safety Power Shutoff (PSPS) Preparing to Re Energize Notification

From: do_not_reply@scewebservices.com

Southern California Edison

This is an important safety message from Southern California Edison.

SCE will soon begin the process of inspecting electrical lines in the ^city variable^ area. Provided we find no safety concerns, we will begin the power restoration process. To ensure you are ready for service, turn off or unplug any appliances or equipment that may automatically start when your power is restored.

The following address(es) are within areas SCE is preparing to re-energize:

13240 Riverview Dr.
Victorville, CA 92395-1234
Service Account: 3-XXX-XX45-67
Meter: 123456-654321
Rate: GS-2

For more information on SCE's restoration process, please visit sce.com/psps. Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

Thank You,

Southern California Edison

Shutoff

Voice/ Voice Mail/TTY:

This is an important safety message from Southern California Edison. Southern California Edison has proactively turned off power to the ^city_variable^ area due to fire weather conditions. Your power may be restored at any time. To ensure you are ready for service turn off or unplug any appliances or equipment that may automatically start when your power is restored. We will update you as conditions change. For more information, please visit sce.com/psps. If you see a downed power line, stay away, call 9 1 1, and report this to S C E at 1-800-611-1911.

Text/SMS:

SCE Safety Alert: Southern California Edison has proactively turned off power to the ^city_variable^ area due to fire weather conditions. Your power may be restored at any time. To ensure you are ready for service turn off or unplug any appliances or equipment that may automatically start when your power is restored. We will update you as conditions change. For more information, please visit sce.com/psps. If you see a downed power line, stay away, call 9 1 1, and report this to S C E at 1-800-611-1911.

E-Mail:

Subject: SCE Safety Alert: Public Safety Power Shutoff (PSPS) Notification

From: [do not reply@scewebservices.com](mailto:do_not_reply@scewebservices.com)

Southern California Edison

This is an important safety message from Southern California Edison. Southern California Edison has proactively turned off power to your area due to fire weather conditions. Your power may be restored at any time. To ensure you are ready for service turn off or unplug any appliances or equipment that may automatically start when your power is restored. We will update you as conditions change.

The following address(es) may be affected:

13240 Riverview Dr.
Victorville, CA 92395-1234
Service Account: 3-XXX-XX45-67
Meter: 123456-654321
Rate: GS-2

For more information, please visit sce.com/psps. If you see a downed power line, stay away, call 9 1 1, and report this to S C E at 1-800-611-1911.

Thank You,

Southern California Edison

Restored

Voice /Voice Mail/TTY:

This is an important safety message from Southern California Edison. Southern California Edison proactively turned off power to the ^city_variable^ area on ^date variable^ date, due to fire weather conditions. Power has now been restored. If your power is still off, please call 1-800-611-1911 or visit sce.com/outage.

Text/SMS:

SCE Safety Alert: Southern California Edison proactively turned off power to the ^city_variable^ area on ^date variable^ date, due to fire weather conditions. Power has now been restored. If your power is still off, please call 1-800-611-1911 or visit sce.com/outage.

E-Mail:

Subject: SCE Safety Alert: Public Safety Power Shutoff (PSPS) Restoration Notification

From: do_not_reply@scewebservices.com

Southern California Edison

Southern California Edison proactively turned off power to the ^city_variable^ area on ^date variable^ date, due to fire weather conditions. Power has now been restored.

The following address(es) have been restored:

13240 Riverview Dr.
Victorville, CA 92395-1234
Service Account: 3-XXX-XX45-67
Meter: 123456-654321
Rate: GS-2

If your power is still off, please call 1-800-611-1911 or visit sce.com/outage.

Thank You,

Southern California Edison

Avoided/All Clear Notification - Messaging

Voice/ Voice Mail/TTY:

This is an important safety message from Southern California Edison. Due to forecast fire weather conditions, Southern California Edison continues to explore a potential Public Safety Power Shutoff of electrical lines in the ^city_variable^ area. These conditions may result in SCE turning off your power. SCE anticipates that this may occur on ^Day of week^ ^morning/afternoon/evening^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send daily updates until conditions improve. For more information, please visit sce.com/psps. Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

Text/SMS:

SCE Safety Alert: Due to forecast fire weather conditions, Southern California Edison continues to explore a potential Public Safety Power Shutoff of electrical lines in the ^city_variable^ area. These conditions may result in SCE turning off your power. SCE anticipates that this may occur on ^Day of week^ ^morning/afternoon/evening^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send daily updates until conditions improve. For more information, please visit sce.com/psps. Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

E-Mail:

Subject: SCE Safety Alert: Public Safety Power Shutoff (PSPS) Update Notification

From: do_not_reply@scewebservices.com

Southern California Edison

Due to forecast fire weather conditions, Southern California Edison continues to explore a potential Public Safety Power Shutoff of electrical lines in your area. These conditions may result in SCE turning off your power. SCE anticipates that this may occur on ^Day of week^ ^morning/afternoon/evening^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send daily updates until conditions improve.

The following address(es) are within areas being monitored:

13240 Riverview Dr.
Victorville, CA 92395-1234
Service Account: 3-XXX-XX45-67
Meter: 123456-654321
Rate: GS-2

For more info such as expected duration: please visit www.sce.com/psps. Downed power line? Stay away, Call 911, and SCE at 1-800-611-1911.

Thank You,

Southern California Edison