Water System Name: Meyers Water Company, In	er Confidence Report nc. Report Date: 6/27/16								
We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2015 and may include earlier monitoring data.									
Este informe contiene información muy importante se entienda bien.	obre su agua potable. Tradúzcalo ó hable con alguien que lo								
Type of water source(s) in use: Well (Water System Number #2800530)									
Name & general location of source(s): Well on M.W.C. property located at 1830 Milton Rd. Napa, CA 94559									
Drinking Water Source Assessment information:									
Time and place of regularly scheduled board meetings for	r public participation:none								
For more information, contact: Matt Fullner or Jay Gard	ner Phone: (707) 254-9547								
TERMS USED	IN THIS REPORT								
Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically	Primary Drinking Water Standards (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.								
feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.	Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the								
Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which	drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.								
there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).	Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.								
Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the	Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.								
California Environmental Protection Agency. Maximum Residual Disinfectant Level (MRDL):	Variances and Exemptions: State Board permission to exceed an MCL or not comply with a treatment technique								

ND: not detectable at testing limit water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial ppm: parts per million or milligrams per liter (mg/L) contaminants. ppb: parts per billion or micrograms per liter (µg/L) Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant ppt: parts per trillion or nanograms per liter (ng/L) below which there is no known or expected risk to

The highest level of a disinfectant allowed in drinking

health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

under certain conditions.

ppq: parts per quadrillion or picogram per liter (pg/L)

pCi/L: picocuries per liter (a measure of radiation)

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Revised Jan 2016 2015 SWS CCR Form

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are by-products of industrial
 processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural
 application, and septic systems.
- Radioactive contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resources Control Board (State Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, 7, and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

TABLE 1 –	SAMPLING	RESULT	S SHOWI	NG THE DE	TECTION	OF COLIF	ORM BACTERIA
Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of months in violation		MCL		MCLG	Typical Source of Bacteria
Total Coliform Bacteria	(In a mo.) Q	0		More than 1 sample in a month with a detection		0	Naturally present in the environment
Fecal Collform or E. coll	(In the year)	0		A routine sample and a repeat sample detect total coliform and either sample also detects fecal coliform or <i>E. coli</i>		0	Human and animal fecal waste
TABLE 2	-SAMPLIN	ig resul	TS SHOV	VING THE	DETECTIO	N OF LEA	D AND COPPER
Lead and Copper (complete if lead or copper detected in the last sample set)	Sample Date	No. of samples collected	90 th percentile level detected	No. sites exceeding AL	AL	PHG	Typical Source of Contaminan
Lead (ppb)	10/2013	5	3.4 ppb	0	15ppb	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	10/2013	5	.24 ppm	0	1.3ppm	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
	TABLE 3	-SAMPL	ING RESI	ULTS FOR	SODIUM A	ND HARDI	NESS
Chemical or Constituent (and reporting units)	Sample Date			Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminan
Sedium (ppm)	10/2013	140рр:	m	140ppm		none	Salt present in the water and is generally naturally occurring
Hardness (ppm)	10/2013	320pp	m	320ppm	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

^{*}Any violation of an MCL or AL is asterisked. Additional information regarding the violation is provided later in this report.

2015 SWS CCR Form Revised Jan 2016

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Arsenic	10/2013	6.5ppb	6.5ppb	10ppb		
Barium	10/2013	500ppb	500ppb	1000ppb		
TABLE 5 – DETE	CTION OF	CONTAMINA	NTS WITH A S	ECONDAR	Y DRINKIN	G WATER STANDARD
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Chloride	10/2013	280ppm	280ppm	500ppm		Runoff/Leaching from natural deposits: seawater influence
Color See Addendum A	10/2013	33units	33units	15units		Naturally occurring organic materials
	TABLE	6 - DETECTION	OF UNREGU	LATED CO	NTAMINA	NTS
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level		Health Effects Language
N.D. for any U.C.			· · · · · · · · · · · · · · · · · · ·			

^{*}Any violation of an MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Meyer Water Company, Inc. is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. [Optional: If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants.] If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at https://www.epa.gov/lead.

2015 SWS CCR Form Revised Jan 2016

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL, MRDL, AL, TT, OR MONITORING AND REPORTING REQUIREMENT							
Violation	Explanation	Duration	Actions Taken to Correct the Violation	Health Effects Language			
							
	}						

For Water Systems Providing Ground Water as a Source of Drinking Water

TABLE 7 – SAMPLING RESULTS SHOWING FECAL INDICATOR-POSITIVE GROUND WATER SOURCE SAMPLES								
Microbiological Contaminants (complete if fecal-indicator detected) Total No. of Detections Sample MCL (MCLG) [MRDL] Typical Source of Contaminant								
(In the year)		0	(0)	Human and animal fecal waste				
(In the year)		TT	n/a	Human and animal fecal waste				
(In the year)		TT	n/a	Human and animal fecal waste				
	Total No. of Detections (In the year)	Total No. of Detections Dates (In the year)	Total No. of Detections Sample Dates MCL [MRDL] (In the year) 0 (In the year) TT	Total No. of Detections Sample Dates MCL [MRDL] PHG (MCLG) [MRDLG] (In the year) 0 (0) (In the year) TT n/a				

Summary Information for Fecal Indicator-Positive Ground Water Source Samples, Uncorrected Significant Deficiencies, or Ground Water TT

SPECIAL	NOTICE OF FECAL IND	ICATOR-POSITIVE	GROUND WATER SOURCE S	SAMPLE
	"			
	SPECIAL NOTICE FOR	UNCORRECTED SIG	INIFICANT DEFICIENCIES	
	•			
	VIOLA	TION OF GROUND \	WATER TT	
TT Violation	Explanation	Duration	Actions Taken to Correct the Violation	Health Effects Language
			İ	

2015 SWS CCR Form Revised Jan 2016

ATTACHMENT 7

Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Board's website at http://www.waterboards.ca.gov/drinking water/certlic/drinkingwater/CCR.shtml)

Water System Name:			Meyers Water Company, Inc						
Water	Syster	n Number:	2800530						
given) with the	1/16 Furthe con	her, the syste	(date em certifies nitoring date	e) to customers (s that the information	its Consumer Cons and appropriate ration contained in the mitted to the State	notices of availa	bility have been ect and consistent		
		ure: Number:	Juell Fullner Secretary/Treas (707) 254-954		Date: 7/1/16				
				e appropriate:	•	•			
		was distribu ds used:	ted by ma	il or other direct	delivery method	s. Specify other	r direct delivery		
		wing method	s:		oill paying consur	mers. Those eff	orts included the		
		Posting the CCR on the Internet at www							
		Advertising	the availal	bility of the CCR	in news media (atta	ach copy of press	release)		
	Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)								
	Posted the CCR in public places (attach a list of locations)								
	POSTED AT OUTDOOR BULLETIN BOARD LOCATED AT 1501 MILTON ROAD NAPA, CA 94559								
	Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools								
		Delivery to	community	y organizations (a	ttach a list of organ	nizations)			
		Other (attac	h a list of	other methods use	d)				
		vstems serving llowing addr			Posted CCR on a	publicly-accessil	ole internet site at		
\boxtimes	For privately-owned utilities: Delivered the CCR to the California Public Utilities Commission This form is provided as a convenience and may be used to meet the certification requirement of section 64483(c), California Code of Regulations.								