

New CPUC Order on Pole Attachments

Wireless West Conference Anaheim, California April 21, 2016

Charlotte F. TerKeurst

Program Manager
Electric Safety and Reliability Branch
Safety and Enforcement Division
California Public Utilities Commission





Decision (D.) 16-01-046 Issued in Rulemaking 14-05-001

In 1998, D.98-10-058 provided competitive local exchange carriers and cable television providers with nondiscriminatory access to public utility infrastructure.

D.16-01-046 now provides commercial mobile radio service (CMRS) carriers with nondiscriminatory access.


- Amends most right-of-way rules in D.98-10-058 to apply to CMRS.
- But adopts CMRS-specific pole-attachment fees (not addressed in this presentation).
- Amends General Order (GO) 95 to ensure that CMRS pole installations are safe.
- Provides that certain other issues may be considered later.





Typical CMRS Attachments

(source: AT&T)






ANTENNAS FROM 2' - 3' IN DIAMETER AND 2' - 4' TALL



GO 95 Safety Amendments (page 1 of 3)

 Prohibit antenna installations that obstruct pole climbing space or interfere with fall-protection gear.










GO 95 Safety Amendments (page 2 of 3)

 Require poleoverturning calculations for new pole-top antenna attachments.







GO 95 Safety Amendments

(page 3 of 3)

- Generally prohibit antennas on guard arms.
- Clarify requirements for signs regarding radio-frequency radiation of antennas.
- Clarify protocols for de-energizing antennas.
- Only qualified workers may work on wireless facilities installed above supply lines.





Pending Issues (page 1 of 2)

D.16-01-046 directs that SED shall:

 Evaluate whether the definition of "material increase" in existing Rule 44.2 should be revised.

Rule 44.2: Any entity planning the addition of facilities that materially increases loads on a structure shall perform a loading calculation...

Note: ... a material increase in load is an addition which increases the load on a structure by more than five percent per installation, or ten percent over a 12-month span, of the electric utility's or Communication Infrastructure Provider's current load.





Pending Issues (page 2 of 2)

SED shall:

- Develop a proposed rule regarding interference with fall-protection gear, to apply to all pole attachments.
- Develop a proposed rule regarding pole overturning calculations, to apply to all pole-top (and perhaps other) installations.

SED may:

 Resubmit its proposed Rule 94.3-D regarding safety factor calculations, and address whether it should apply to all pole attachments, or just CMRS.





Upcoming CPUC en banc on Pole Safety

April 28, 2016

9:30 am - 5 pm

Ronald Reagan State Building—Auditorium

300 S. Spring St

Los Angeles, CA 90013

Agenda and media advisory available at: http://www.cpuc.ca.gov/General.aspx?id=10150

