

Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Board's website at http://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml)

Water System Name: **Rio Plaza Water Co Inc**
Water System Number: **5610010**

The water system above hereby certifies that its Consumer Confidence Report was distributed on 3-23-2019 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By: Name Frank Brommenschenkel
Signature Frank Brommenschenkel
Title Consultant
Phone Number (805) 525-4200 Date 3-25-2019

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:

US Mail to each customer

"Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

- Posted the CCR on the internet at http://
- Mailed the CCR to postal patrons within the service area (attach zip codes used)
- Advertised the availability of the CCR in news media (attach a copy of press release)
- Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)
- Posted the CCR in public places (attach a list of locations)
- Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools
- Delivery to community organizations (attach a list of organizations)
- Other (attach a list of other methods used)

For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: http://

For privately-owned utilities: Delivered the CCR to the California Public Utilities Commission

2018 Consumer Confidence Report

Water System Name: Rio Plaza Water Co Inc

Report Date: February 2019

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2018.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: According to SWRCB records, this Source is Groundwater. This Assessment was done using the Default Groundwater System Method.

Your water comes from 2 source(s): Well 02 and Well 03 (1B)

Opportunities for public participation in decisions that affect drinking water quality: Regularly-scheduled water board or city/county council meetings currently are not required for this private water system.

For more information about this report, or any questions relating to your drinking water, please call (805)525-4200 and ask for Frank Brommenschenkel.

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

mg/L: milligrams per liter or parts per million (ppm)

ug/L: micrograms per liter or parts per billion (ppb)

pCi/L: picocuries per liter (a measure of radiation)

NTU: Nephelometric Turbidity Units

umhos/cm: micro mhos per centimeter

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, 6, 7 and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Sources of Contaminant
Total Coliform Bacteria	1/mo. (2018)	0	no more than 1 positive monthly sample	0	Naturally present in the environment.

Lead and Copper (complete if lead or copper detected in last sample set)	Sample Date	90th percentile level detected	No. Sites Exceeding AL	AL	PHG	Typical Sources of Contaminant
Copper (mg/L)	11 (2016)	0.20	0	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (mg/L)	(2013 - 2016)	86	83 - 88	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2013 - 2016)	507	485 - 528	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 4 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Fluoride (mg/L)	(2013 - 2016)	0.7	n/a	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.
Nitrate as N (mg/L)	(2018)	2.2	2.1 - 2.2	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite as N (mg/L)	(2013 - 2016)	2	1.7 - 2.3	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Selenium (ug/L)	(2013 - 2016)	5	n/a	50	30	Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots(feed additive)
Gross Alpha (pCi/L)	(2013 - 2014)	3.99	2.44 - 5.54	15	(0)	Erosion of natural deposits.
Uranium (pCi/L)	(2008 - 2013)	3.27	2.85 - 3.68	20	0.43	Erosion of natural deposits

Table 5 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (mg/L)	(2013 - 2016)	63	55 - 71	500	n/a	Runoff/leaching from natural deposits; seawater influence
Specific Conductance (umhos/cm)	(2013 - 2016)	1330	n/a	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2013 - 2016)	490	430 - 550	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2013 - 2016)	945	920 - 970	1000	n/a	Runoff/leaching from natural deposits
Turbidity (NTU)	(2013 - 2016)	1.1	0.7 - 1.4	5	n/a	Soil runoff

Table 6 - DETECTION OF UNREGULATED CONTAMINANTS					
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Boron (mg/L)	(2013 - 2016)	0.6	n/a	1	Boron exposures resulted in decreased fetal weight (developmental effects) in newborn rats.

Table 7 - ADDITIONAL DETECTIONS					
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Calcium (mg/L)	(2013 - 2016)	127	122 - 131	n/a	n/a
Magnesium (mg/L)	(2013 - 2016)	47	44 - 49	n/a	n/a
pH (units)	(2013 - 2016)	7.5	7.1 - 7.9	n/a	n/a
Alkalinity (mg/L)	(2013 - 2016)	195	190 - 200	n/a	n/a
Aggressiveness Index	(2013 - 2016)	12.3	11.9 - 12.7	n/a	n/a
Langelier Index	(2013 - 2016)	0.38	-0.04 - 0.8	n/a	n/a

Table 8 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Total Trihalomethanes (TTHMs) (ug/L)	(2018)	9	n/a	80	n/a	No	By-product of drinking water disinfection
Haloacetic Acids (five) (ug/L)	(2018)	2	n/a	60	n/a	No	By-product of drinking water disinfection

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Rio Plaza Water Co.* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

About our Total Coliform Bacteria: Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.

About our Sulfate: Sulfate was found at levels that exceed the secondary MCL. The Sulfate MCL was set to protect you against unpleasant aesthetic effects such as color, taste or odor. Violating this MCL does not pose a risk to public health.

2018 Consumer Confidence Report Drinking Water Assessment Information

Assessment Information

A source water assessment was conducted for the WELL 02 and the WELL 03 of the RIO PLAZA WATER CO INC water system in August, 2001.

Well 02 - is considered most vulnerable to the following activities not associated with any detected contaminants:
Abandoned Septic systems - high density [>1 /acre]

Well 03 (1B) - is considered most vulnerable to the following activities not associated with any detected contaminants:
Abandoned Septic systems - high density [>1 /acre]

Acquiring Information

A copy of the complete assessment may be viewed at:

SWRCB Division of Drinking Water

1180 Eugenia Place

Suite 200

Carpinteria, CA 93013

You may request a summary of the assessment be sent to you by contacting:

Jeff Densmore

District Engineer

805 566 1326

Rio Plaza Water Co.

Analytical Results By FGL - 2018

MICROBIOLOGICAL CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Total Coliform Bacteria			0	5%	n/a			0	2 - 2
3460 George St.	SP 1816912-1					2018-12-19	Absent		
3460 George St.	SP 1815329-1					2018-11-20	Absent		
3460 George St.	SP 1814097-1					2018-10-23	Absent		
3460 George St.	SP 1812238-1					2018-09-13	Absent		
3460 George St.	SP 1810938-1					2018-08-21	Absent		
3460 George St.	SP 1809197-1					2018-07-13	Absent		
3460 George St.	SP 1808081-1					2018-06-20	Absent		
3460 George St.	SP 1806750-1					2018-05-22	Absent		
3460 George St.	SP 1805318-1					2018-04-20	Absent		
3460 George St.	SP 1803705-1					2018-03-19	Absent		
3460 George St.	SP 1802228-1					2018-02-20	Absent		
3460 George St.	SP 1800898-1					2018-01-19	Absent		
3475 Minna Dr.	SP 1816912-2					2018-12-19	Absent		
3475 Minna Dr.	SP 1815329-2					2018-11-20	Absent		
3475 Minna Dr.	SP 1814097-2					2018-10-23	Absent		
3475 Minna Dr.	SP 1812238-2					2018-09-13	Absent		
3475 Minna Dr.	SP 1810938-2					2018-08-21	Absent		
3475 Minna Dr.	SP 1809197-2					2018-07-13	Absent		
3475 Minna Dr.	SP 1808081-2					2018-06-20	Absent		
3475 Minna Dr.	SP 1806750-2					2018-05-22	Absent		
3475 Minna Dr.	SP 1805318-2					2018-04-20	Absent		
3475 Minna Dr.	SP 1803705-2					2018-03-19	Absent		
3475 Minna Dr.	SP 1802228-2					2018-02-20	Absent		
3475 Minna Dr.	SP 1800898-2					2018-01-19	Absent		
Bacti-Well 02	SP 1814365-1					2018-10-29	<1.0		
Bacti-Well 02	SP 1814323-1					2018-10-26	2		
Bacti-Well 02	SP 1809198-1					2018-07-13	<1.0		
Bacti-Well 02	SP 1805375-1					2018-04-23	<1.0		
Bacti-Well 02	SP 1800899-1					2018-01-19	<1.0		
Bacti-Well 03 (1B)	SP 1814098-1					2018-10-23	<1.0		
Bacti-Well 03 (1B)	SP 1809252-1					2018-07-16	<1.0		
Bacti-Well 03 (1B)	SP 1805319-1					2018-04-20	<1.0		
Bacti-Well 03 (1B)	SP 1800958-1					2018-01-22	<1.0		

LEAD AND COPPER RULE									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
Copper		mg/L		1.3	.3			0.20	11
CuPb- 1017 Lemar	SP 1606999-6	mg/L				2016-06-16	0.27		
CuPb- 1025 Will Ave.	SP 1606999-4	mg/L				2016-06-16	0.11		
CuPb- 1035 Salem Ave.	SP 1606999-8	mg/L				2016-06-16	ND		
CuPb- 3321 Citrus	SP 1606999-7	mg/L				2016-06-17	0.24		
CuPb- 334 Lemar	SP 1606999-1	mg/L				2016-06-18	0.13		
CuPb- 3411 Balboa St.	SP 1606999-3	mg/L				2016-06-19	0.15		
CuPb- 344 Helsam Ave.	SP 1606999-2	mg/L				2016-06-19	0.11		
CuPb- 3486 Cortez	SP 1606999-9	mg/L				2016-06-18	ND		
CuPb- 401 Will Ave.	SP 1606999-5	mg/L				2016-06-16	0.20		
CuPb- 808 Simon Way	SP 1606999-10	mg/L				2016-06-19	0.07		
CuPb- 971 Helsam Ave.	SP 1606999-11	mg/L				2016-06-16	ND		

SAMPLING RESULTS FOR SODIUM AND HARDNESS

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Sodium		mg/L		none	none			86	83 - 88
Well 02	SP 1308458-1	mg/L				2013-08-16	88		
Well 03 (1B)	SP 1609553-1	mg/L				2016-08-17	83		
Hardness		mg/L		none	none			507	485 - 528
Well 02	SP 1308458-1	mg/L				2013-08-16	528		
Well 03 (1B)	SP 1609553-1	mg/L				2016-08-17	485		

PRIMARY DRINKING WATER STANDARDS (PDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Fluoride		mg/L		2	1			0.7	0.7 - 0.7
Well 02	SP 1308458-1	mg/L				2013-08-16	0.7		
Well 03 (1B)	SP 1609553-1	mg/L				2016-08-17	0.7		
Nitrate as N		mg/L		10	10			2.2	2.1 - 2.2
Well 02	SP 1810940-1	mg/L				2018-08-21	2.1		
Well 03 (1B)	SP 1810942-1	mg/L				2018-08-21	2.2		
Nitrate + Nitrite as N		mg/L		10	10			2.0	1.7 - 2.3
Well 02	SP 1308458-1	mg/L				2013-08-16	1.7		
Well 03 (1B)	SP 1609553-1	mg/L				2016-08-17	2.3		
Selenium		ug/L	50	50	30			5	5 - 5
Well 02	SP 1308458-1	ug/L				2013-08-16	5		
Well 03 (1B)	SP 1609553-1	ug/L				2016-08-17	5		
Gross Alpha		pCi/L		15	(0)			3.99	2.44 - 5.54
Well 02	SP 1409255-1	pCi/L				2014-08-15	2.44		
Well 03 (1B)	SP 1308835-1	pCi/L				2013-08-26	5.54		
Uranium		pCi/L		20	0.43			3.27	2.85 - 3.68
Well 02	SP 0809167-3	pCi/L				2008-08-22	3.68		
Well 03 (1B)	SP 1308835-1	pCi/L				2013-08-26	2.85		

SECONDARY DRINKING WATER STANDARDS (SDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chloride		mg/L		500	n/a			63	55 - 71
Well 02	SP 1308458-1	mg/L				2013-08-16	71		
Well 03 (1B)	SP 1609553-1	mg/L				2016-08-17	55		
Specific Conductance		umhos/cm		1600	n/a			1330	1330 - 1330
Well 02	SP 1308458-1	umhos/cm				2013-08-16	1330		
Well 03 (1B)	SP 1609553-1	umhos/cm				2016-08-17	1330		
Sulfate		mg/L		500	n/a			490	430 - 550
Well 02	SP 1308458-1	mg/L				2013-08-16	550		
Well 03 (1B)	SP 1609553-1	mg/L				2016-08-17	430		
Total Dissolved Solids		mg/L		1000	n/a			945	920 - 970
Well 02	SP 1308458-1	mg/L				2013-08-16	970		
Well 03 (1B)	SP 1609553-1	mg/L				2016-08-17	920		
Turbidity		NTU		5	n/a			1.1	0.7 - 1.4
Well 02	SP 1308838-1	NTU				2013-08-26	1.4		
Well 03 (1B)	SP 1609553-1	NTU				2016-08-17	0.7		

UNREGULATED CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Boron		mg/L		NS	n/a			0.6	0.6 - 0.6
Well 02	SP 1308458-1	mg/L				2013-08-16	0.6		
Well 03 (1B)	SP 1609553-1	mg/L				2016-08-17	0.6		

ADDITIONAL DETECTIONS									
------------------------------	--	--	--	--	--	--	--	--	--

Rio Plaza Water Co. CCR Login Linkage - 2018

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
Bacti-Rout-01	SP 1800898-1	2018-01-19	Coliform	3460 George St.	Routine Bacteriological Monitoring
	SP 1802228-1	2018-02-20	Coliform	3460 George St.	Routine Bacteriological Monitoring
	SP 1803705-1	2018-03-19	Coliform	3460 George St.	Routine Bacteriological Monitoring
	SP 1805318-1	2018-04-20	Coliform	3460 George St.	Routine Bacteriological Monitoring
	SP 1806750-1	2018-05-22	Coliform	3460 George St.	Routine Bacteriological Monitoring
	SP 1808081-1	2018-06-20	Coliform	3460 George St.	Routine Bacteriological Monitoring
	SP 1809197-1	2018-07-13	Coliform	3460 George St.	Routine Bacteriological Monitoring
	SP 1810938-1	2018-08-21	Coliform	3460 George St.	Routine Bacteriological Monitoring
	SP 1812238-1	2018-09-13	Coliform	3460 George St.	Routine Bacteriological Monitoring
	SP 1814097-1	2018-10-23	Coliform	3460 George St.	Routine Bacteriological Monitoring
	SP 1815329-1	2018-11-20	Coliform	3460 George St.	Routine Bacteriological Monitoring
Bacti-Rout-02	SP 1816912-1	2018-12-19	Coliform	3460 George St.	Routine Bacteriological Monitoring
	SP 1800898-2	2018-01-19	Coliform	3475 Minna Dr.	Routine Bacteriological Monitoring
	SP 1802228-2	2018-02-20	Coliform	3475 Minna Dr.	Routine Bacteriological Monitoring
	SP 1803705-2	2018-03-19	Coliform	3475 Minna Dr.	Routine Bacteriological Monitoring
	SP 1805318-2	2018-04-20	Coliform	3475 Minna Dr.	Routine Bacteriological Monitoring
	SP 1806750-2	2018-05-22	Coliform	3475 Minna Dr.	Routine Bacteriological Monitoring
	SP 1808081-2	2018-06-20	Coliform	3475 Minna Dr.	Routine Bacteriological Monitoring
	SP 1809197-2	2018-07-13	Coliform	3475 Minna Dr.	Routine Bacteriological Monitoring
	SP 1810938-2	2018-08-21	Coliform	3475 Minna Dr.	Routine Bacteriological Monitoring
	SP 1812238-2	2018-09-13	Coliform	3475 Minna Dr.	Routine Bacteriological Monitoring
	SP 1814097-2	2018-10-23	Coliform	3475 Minna Dr.	Routine Bacteriological Monitoring
Bacti-Source-01	SP 1815329-2	2018-11-20	Coliform	3475 Minna Dr.	Routine Bacteriological Monitoring
	SP 1816912-2	2018-12-19	Coliform	3475 Minna Dr.	Routine Bacteriological Monitoring
	SP 1800899-1	2018-01-19	Coliform	Bacti-Well 02	Source Bacteriological Monitoring-Well 02
	SP 1805375-1	2018-04-23	Coliform	Bacti-Well 02	Source Bacteriological Monitoring-Well 02
	SP 1809198-1	2018-07-13	Coliform	Bacti-Well 02	Source Bacteriological Monitoring-Well 02
Bacti-Source-02	SP 1814323-1	2018-10-26	Coliform	Bacti-Well 02	Source Bacteriological Monitoring-Well 02
	SP 1814365-1	2018-10-29	Coliform	Bacti-Well 02	Source Bacteriological Monitoring
	SP 1800958-1	2018-01-22	Coliform	Bacti-Well 03 (1B)	Source Bacteriological Monitoring-Well 03 (1B)
	SP 1805319-1	2018-04-20	Coliform	Bacti-Well 03 (1B)	Source Bacteriological Monitoring-Well 03 (1B)
CuPb-ss06	SP 1809252-1	2018-07-16	Coliform	Bacti-Well 03 (1B)	Source Bacteriological Monitoring-Well 03 (1B)
	SP 1814098-1	2018-10-23	Coliform	Bacti-Well 03 (1B)	Source Bacteriological Monitoring-Well 03 (1B)
	SP 1606999-6	2016-06-16	Metals, Total	CuPb- 1017 Lemar	Copper & Lead Monitoring
	SP 1606999-4	2016-06-16	Metals, Total	CuPb- 1025 Will Ave.	Copper & Lead Monitoring
	SP 1606999-8	2016-06-16	Metals, Total	CuPb- 1035 Salem Ave.	Copper & Lead Monitoring
	SP 1606999-7	2016-06-17	Metals, Total	CuPb- 3321 Citrus	Copper & Lead Monitoring
	SP 1608662-1	2016-07-28	Metals, Total	CuPb- 3321 Citrus	Drinking Water Monitoring
	SP 1606999-1	2016-06-18	Metals, Total	CuPb- 334 Lemar	Copper & Lead Monitoring
	SP 1606999-3	2016-06-19	Metals, Total	CuPb- 3411 Balboa St.	Copper & Lead Monitoring
	SP 1606999-2	2016-06-19	Metals, Total	CuPb- 344 Helsam Ave.	Copper & Lead Monitoring
	SP 1606999-9	2016-06-18	Metals, Total	CuPb- 3486 Cortez	Copper & Lead Monitoring
DBP-STG2-ss01	SP 1606999-5	2016-06-16	Metals, Total	CuPb- 401 Will Ave.	Copper & Lead Monitoring
	SP 1606999-10	2016-06-19	Metals, Total	CuPb- 808 Simon Way	Copper & Lead Monitoring
	SP 1606999-11	2016-06-16	Metals, Total	CuPb- 971 Helsam Ave.	Copper & Lead Monitoring
	SP 1810934-1	2018-08-21	EPA 551.1	STG 2 - 3460 George St.	Stage 2 DBP Monitoring
STW-2	SP 1810934-1	2018-08-21	EPA 552.2	STG 2 - 3460 George St.	Stage 2 DBP Monitoring
	SP 0809167-3	2008-08-22	Radio Chemistry	Well 02	Drinking Water Monitoring
	SP 1308458-1	2013-08-16	Metals, Total	Well 02	Well 2 - Water Quality

	SP 1308458-1	2013-08-16	General Mineral	Well 02	Well 2 - Water Quality
	SP 1308838-1	2013-08-26	Wet Chemistry	Well 02	Well 2 - Water Quality
	SP 1409255-1	2014-08-15	Radio Chemistry	Well 02	Well 2 - Radio
WELL02	SP 1810940-1	2018-08-21	Wet Chemistry	Well 02	Well 2 - Water Quality
STW-3	SP 1308835-1	2013-08-26	Radio Chemistry	Well 03 (1B)	Well 3 - Radio
WELL03	SP 1609553-1	2016-08-17	Metals, Total	Well 03 (1B)	Well 3 - Water Quality
	SP 1609553-1	2016-08-17	Wet Chemistry	Well 03 (1B)	Well 3 - Water Quality
	SP 1609553-1	2016-08-17	General Mineral	Well 03 (1B)	Well 3 - Water Quality
Bacti-Source-02	SP 1810942-1	2018-08-21	Wet Chemistry	Well 03 (1B)	Well 3 - Water Quality