



Diana S. Gallegos
State Regulatory Affairs
diana.s.genasci@sce.com

November 23, 2020

Leslie Palmer, Director
Safety Enforcement Division
California Public Utilities Commission
505 Van Ness Avenue
San Francisco, CA 94102


SUBJECT: SCE PSPS Post Event Report – November 3 to November 7, 2020

Dear Director Palmer:

Southern California Edison (SCE) respectfully submits the attached report in compliance with the Public Safety Power Shutoff (PSPS) Post Event Reporting requirements regarding its PSPS event that began November 3 to November 7, 2020.

This report has been verified by an Officer of SCE in accordance with Rule 1.11 of the Commission's Rules of Practice and Procedure.

Sincerely,

DocuSigned by:

29E9CB7BDB43475...

Diana S. Gallegos
Sr. Advisor, State Regulatory Affairs

cc: ESRB_ComplianceFilings@cpuc.ca.gov

**Southern California Edison
Public Safety Power Shutoff Protocol (PSPS)
Post-Event Reporting in Compliance with Resolution ESRB-8
and PSPS OIR Phase 1 & 2 Requirements
November 3 to November 7, 2020**

**Submitted to:
California Public Utilities Commission
Director of the Safety and Enforcement Division
November 23, 2020**

Executive Summary

On November 3, 2020, Southern California Edison (SCE) remotely activated¹ an Incident Management Team (IMT) to manage a weather event where forecasted high winds and low relative humidity levels were anticipated to potentially require the use of SCE's Public Safety Power Shutoff (PSPS) protocol, which could impact as many as 4,100 customers. Customers within Inyo, Mono, San Bernardino, and Santa Barbara counties were originally in scope with a period of concern initially identified from November 5 at 9 pm to November 6 at 9 pm. During this event, SCE also de-energized three circuits in Mono County when unexpected high wind conditions were observed by meteorologists and weather stations in Mono County that were not previously forecasted. Ultimately, SCE pro-actively de-energized 1,335 customers in areas of Inyo, Mono, and San Bernardino counties. Power was restored to all customers on November 7 by 09:37 am.

SCE submits this report to demonstrate its compliance with the directives of Resolution ESRB-8 and the California Public Utilities Commission (CPUC or Commission) PSPS Order to Institute Rulemaking (OIR) Phase 1 (D. 19-05-042) and Phase 2 (D.20-05-051) requirements associated with PSPS events. This report explains SCE's decision to call, sustain, and conclude a de-energization event and provides both a summary of the event and the responses to the post-event questions as required by the Commission.

SCE appreciates that PSPS de-energizations pose significant challenges and hardships for its customers and the Public Safety Partners that provide vital services to our communities. SCE recognizes that this is particularly true when the unexpected onset of dangerous weather and fuel conditions requires that SCE take actions quickly and without all of the advance notifications contemplated by the CPUC. SCE's decision to activate its PSPS protocol is based on careful consideration of multiple factors, including forecasted weather, fuel conditions, and impacts to Public Safety Partners and the communities we serve. Because SCE takes seriously its responsibilities and understands the impacts of de-energization events, SCE only uses PSPS de-energization when it believes that there are no other reasonable alternatives to mitigate identified risks to public safety that would result from catastrophic wildfire.

SCE remains committed to continuously improving its processes and welcomes input from its customers, Public Safety Partners, community representatives, and local governments on ways we can work together to enhance the existing processes, improve communication and coordination amongst impacted entities, and minimize the impact of PSPS events on all stakeholders.

¹ SCE utilized remote IMT activation due to the impacts of COVID-19.

SCE took the following actions to manage its response during this PSPS event:

1. Activated a Dedicated PSPS IMT to coordinate response operations associated with the potential use of PSPS to maintain public safety. The IMT was activated and operated remotely due to the COVID-19 pandemic.
2. Reached out to the Geographical Coordination Center (GACC) to coordinate expectations for fire potential over the course of the PSPS event.
3. Notified Public Safety Partners, critical infrastructure providers, the CPUC, the California Department of Forestry and Fire Protection (CAL FIRE), the California Governor's Office of Emergency Services (Cal OES), and affected SCE customers. Additionally, SCE notified Community-Based Organizations (CBOs) such as Independent Living Centers (ILCs), the American Red Cross, 2-1-1, and Fire Safety Councils.
4. Initiated operating restrictions on impacted circuits as applicable.
5. Performed field patrols of impacted circuits in preparation for the potential use of PSPS.
6. Opened Community Resource Centers (CRCs) and deployed Community Crew Vehicles (CCVs) to impacted communities.
7. Performed live field observations of monitored circuits as required during the period of concern to validate actual weather conditions and the need for the use of PSPS for de-energization.
8. Performed post patrols to verify no damage to de-energized circuits in support of restoration activities.

Event Summary November 3²

November 2nd - SCE meteorologists notified SCE's Business Resiliency Duty Manager (BRDM) of a weather system that was forecasted to bring elevated fire weather for portions of the SCE territory beginning November 5 and continuing through November 6. On November 2, SCE contacted the Southern California Geographical Coordination Center (GACC) and sent the CPUC an email at 6:59 pm to communicate the intent to activate a Public Safety Power Shutoff Incident Management Team (PSPS IMT) on November 3. Initially, SCE identified circuits in Inyo, Mono, San Bernardino, and Santa Barbara counties with approximately 3,300 customers potentially in scope for a PSPS event.

November 3rd - SCE held a State Executive call at 2:00 pm and an OEM County Coordination call at 3:00 pm to communicate the weather forecast, potential customers in scope, and to answer any questions. SCE sent notifications to public safety partners and critical infrastructure providers at 2:01 pm and 8:07 pm and customers at 8:08 pm with respect to circuits projected to be in scope for the event. SCE also dispatched pre-patrol resources to begin inspecting circuits in scope for the event. At that point, weather forecasts indicated only portions of Inyo, Mono, and San Bernardino counties in scope with approximately 3,323 customers during the period of concern from November 5th to November 7th³.

² The following event summary serves to provide an overview of the event. Additional details regarding specific PSPS requirements are addressed in further detail after this narrative.

³ On November 6, the period of concern changed to encompass November 7 due to updated weather forecasting.

November 4th - SCE held its daily State Executive call at 2:00 pm and an OEM County Coordination call at 3:00 pm to communicate the weather forecast, customers in scope, and to answer any questions. SCE also began a daily coordination call for critical infrastructure providers (water/telecom) at 3:30 pm during this event. SCE emailed the CPUC after the daily calls to provide the briefing material shared during the 2:00 pm call. SCE sent notifications to public safety partners and customers at 11:18 am and critical infrastructure providers at 6:44 pm with respect to circuits projected to be in scope for the event. At that point, weather forecasts indicated portions of Inyo, Mono, and San Bernardino counties and approximately 3,353 customers potentially in scope for de-energization from November 5th through November 7th.

November 5th - SCE held its daily State Executive call at 2:00 pm an OEM County Coordination call at 3:00 pm and a Critical Infrastructure call at 3:30 pm to communicate the weather forecast, customers in scope and to answer any questions regarding the PSPS event. SCE emailed the CPUC after the daily calls to provide the briefing material shared during the 2:00 pm call. SCE sent notifications to public safety partners, and customers at 2:30 pm and critical infrastructure at 2:31 pm with respect to circuits projected to be in scope for the event. At that point, weather forecasts indicated portions of Inyo, Mono and San Bernardino counties and approximately 4,026 customers were potentially in scope for de-energization during the period of concern from November 5th through November 7th.

November 6th –At approximately 8:30 am on November 6, the PSPS IMT began observing dangerous fire weather conditions in the Bridgeport and Yucca Valley areas impacting two circuits originally forecast in scope for de-energization, as well as an additional three circuits in Mono and San Bernardino counties not originally forecast to exceed wind thresholds and FPI criteria. SCE provided imminent notification of de-energization to all five circuits and at approximately 10:54 am began de-energizing a total of 1,335 customers in Mono and San Bernardino Counties as detailed in the tables on Page 6 and page 9. SCE held its daily State Executive call at 2:00 pm, an OEM County Coordination call at 3:00 pm and a Critical Infrastructure call at 3:30 pm to communicate the weather forecast, customers in scope for de-energization and answer any questions regarding the PSPS event. SCE emailed the CPUC after the daily call to provide the briefing material shared during the 2:00 pm call.

November 7th – As hazardous weather conditions subsided, SCE began sending imminent re-energization notifications to public safety partners, critical infrastructure, and customers. SCE performed patrols for circuit restoration on de-energized circuits, ultimately restoring power to all circuits by 09:37 am as detailed in the table on page 6.

The following responses address how SCE complied with all applicable PSPS regulatory requirements, including ESRB-8 and the Phase 1 (D. 19-05-042) and Phase 2 (D. 20-05-051) decisions, during this event.

1. The time, place and duration of the power shutoff event

This event started at 10:54 am on Friday, November 6 and continued through Saturday, November 7 at 9:37 am. The event impacted portions of Inyo, Mono, and San Bernardino counties. The table below provides the timeline for de-energization and restoration for all impacted circuits.

Circuit	Isolation Device ⁴	De-Energized Date/Military Time	Customers Affected	Re-Energized ⁵ (1 st load) Date/Military Time	Re-Energized (All load) Date/Military Time
Tufa	RAR0289	11/06/2020 1054	1	N/A	11/06/2020 1803
Sky Hi	RCS0469	11/06/2020 1224	166	11/06/2020 1706	11/07/2020 0937
Sky Hi	RAR0081	11/06/2020 1230	3	N/A	11/06/2020 1737
Additional De-Energizations Not Originally in the Period of Concern ⁶					
Strosnider	CB	11/06/2020 1309	413	11/06/2020 1608	11/06/2020 1621
Robinson Creek	CB	11/06/2020 1252	242	11/06/2020 1824	11/06/2020 1842
Campanula	RAR0640	11/06/2020 1505	287	11/06/2020 2005	11/06/2020 2212
Campanula	RAR0625	11/06/2020 1507	221	N/A	11/06/2020 1956

2. The local communities' representatives contacted prior to de-energization, the date on which they were contacted, and whether the areas affected by the de-energization are classified as Zone 1, Tier 2, or Tier 3 as per the definition in General Order 95, Rule 21.2⁷

County	Public Safety Partner	Date	Tier
Inyo	County and State public safety and first responder agencies and local governments	11/3	Tier 2, Tier 3
Mono	County and State public safety and first responder agencies and local governments	11/3	Tier 2, Tier 3
San Bernardino	County and State public safety and first responder agencies and local governments	11/3	Tier 2, Tier 3

⁴ Remote Automatic Recloser (RAR) and Circuit Breaker (CB) denote different types of sectionalizing devices used by SCE

⁵ 1st load identifies if the circuit was re-energized in sections based on pre-patrols and weather conditions impacting the ability to re-energize the entire line simultaneously. All Load identifies when the entire circuit was re-energized.

⁶ Given rapid onset of hazardous weather conditions, these circuits did not receive any notification prior to de-energization.

⁷ See Attachment A Public Safety Partner Notifications for specifics of notifications.

County	Public Safety Partner	Date	Tier
Santa Barbara	County and State public safety and first responder agencies and local governments	11/3	Tier 2, Tier 3

3. If unable to provide customers with notice at least 2 hours prior to the de-energization event, provide an explanation in its report.

On November 6 SCE de-energized the Strosnider, Robinson Creek and Campanula circuits in Mono and San Bernardino counties unexpectedly, as these circuits were not originally forecasted to be in scope for this event. Although these three circuits received imminent notification of de-energization, SCE was not able to provide the imminent notices at least two hours prior to the de-energization on the Campanula and Strosnider circuits as detailed in Attachment B-Customer and Critical Infrastructure Notifications.

4. Summarize the number and nature of complaints received as the result of the de-energization event and include claims that are filed due to de-energization.

As of the submission of this report, SCE is not aware of any formal complaints that were submitted to the Commission. SCE Consumer Affairs did not receive any complaints and no claims have been submitted for this event. Any complaints/claims received after submission of this report will be added to subsequent reports, as they are received and processed.

SCE did receive communication from the Bridgeport Indian Colony, expressing concern on the timing of imminent notification for de-energization on the Strosnider circuit during this event. SCE has reached out to them to enhance future communications in PSPS events.

5. The timeline for power restoration (re-energization), in addition to the steps taken to restore power as required in Resolution ESRB-8.

A PSPS event will continue while dangerous fire weather conditions exist and the threat of a catastrophic wildfire event remains due to these conditions. If circuits are de-energized, those circuits and lines will be inspected to ensure there is no damage before power can be safely restored. Any visual inspection of the power lines typically take place during daylight hours for safety and accuracy. Therefore, patrol and restoration operations may be limited or prolonged during overnight hours. SCE strives to restore all power within 24 hours of de-energization when possible. The timeline for power restoration is detailed in the table below.

Circuit	Isolation Device	IC Authorized Imminent Restoration Notification	Post Patrol Initiated	Circuit Fully Re-energized
TUFA	RAR0289	11/6/2020 16:54	11/6/2020 16:54	11/6/2020 18:03
SKY HI	RCS0469	11/6/2020 16:39	11/6/2020	11/7/2020 09:37

Circuit	Isolation Device	IC Authorized Imminent Restoration Notification	Post Patrol Initiated	Circuit Fully Re-energized
			16:39	
SKY HI	RAR0081	11/6/2020 16:54	11/6/2020 16:54	11/6/2020 17:37
STROSNIDER	CB	11/6/2020 14:25	11/6/2020 15:07	11/6/2020 16:21
ROBINSON CREEK	CB	11/6/2020 14:25	11/6/2020 15:07	11/6/2020 18:42
CAMPANULA	RAR0640	11/6/2020 17:25	11/6/2020 17:25	11/6/2020 22:12
CAMPANULA	RAR0625	11/6/2020 17:25	11/6/2020 17:25	11/6/2020 19:56

- 6. For any circuits that require more than 24 hours to restore, the utility shall explain why it was unable to restore each circuit within this timeframe in its post event report.**

SCE was able to restore all circuits within the 24-hour timeframe as detailed in the table on page 7.

- 7. Identify the address of each community assistance location during the de-energization and describe the assistance available at each location and give the days and hours that it was open.**

Type	County	City/Community	Day and Time	Address
CRC	Inyo	Bishop	Friday, November 6, 2020 8am to 10pm	Sears Hometown, 1361 Rocking W Dr., Bishop, 93514
CCV	San Bernardino	Lucerne Valley	Friday, November 6, 2020 8am to 10pm	Pioneer Park, 33269 Old Woman Springs Rd., Lucerne Valley, 92356
CCV	Mono	June Lake	Friday, November 6, 2020 8am to 10pm	June Lake Community Building & Library, 90 Granite Ave., June Lake, 93529
CCV	Mono	Bridgeport	Friday, November 6, 2020 5pm to 10pm	Superior Court House, School St. & Hwy. 395 (Main St.), Bridgeport, 93517

- 8. Any wind-related damage(s) to SCE's overhead equipment in the areas where power is shutoff.**

Crews performed post-patrols on de-energized circuits before re-energization to ensure safe operating conditions. No wind-related damage was found on SCE's overhead equipment during patrol in the areas where power was shutoff.

9. All factors considered by SCE in its decision to shut off power, including wind speed, temperature, humidity, and vegetation moisture in the vicinity of the de-energized circuits

SCE's decision to shut off power is dynamic and made by considering the following factors as applicable during each event:

- National Weather Service-issued watches and warnings for high fire risk areas in our territory.
- Ongoing assessments from our in-house meteorologists using high-resolution weather models, data from SCE weather stations and publicly available weather stations.
- The SCE Fire Potential Index (FPI), a tool that utilizes weather data, fuel conditions, and vegetation moisture content to rate the daily fire potential across our region. SCE uses the following metrics to rate ignition potential -- Low - 11.99, Elevated - 12-14.99 and Extreme - 15 and above
- Wind trends⁸ and speeds, particularly when they exceed or are expected to exceed National Weather Service Wind Advisory levels (defined as 31 mph sustained wind speed and 46 mph gust wind speed) or exceed the top 1% of historical wind speeds in the area. Wind speeds are particularly important when we consider them in combination with other local conditions, such as dry vegetation, that could present a true hazard for the community. Wind speed thresholds may also be adjusted based on other factors or circuit design.
- Specific concerns received from state and local fire authorities, emergency management personnel and/or law enforcement regarding public safety issues.
- The expected impact of turning off power to essential services such as public safety agencies, water pumps and/or traffic controls.
- Other operational considerations, such as the state of the potentially impacted circuits, flying debris and/or downed wires.
- When possible and safe during extreme fire weather conditions, we can deploy on-the-ground observers in high fire risk areas to monitor live conditions in real time.

SCE considered the following factors listed in the table below to inform de-energization decisions:

Circuit Name	Isolation Device ⁹	Weather Station	Wind Sustained	Gust Sustained	Threshold Sustained	FPI Value	Reasons for De-Energization
TUFA	RAR0289	SCE Bodie State Park	27.51	37.7	31 / 46	12.27	<ul style="list-style-type: none"> • High Wind Trend • Exceeded FPI
SKI HI	RCS0469	SCE Sundance Rd.	26.7	41.1	31 / 46	12.53	<ul style="list-style-type: none"> • High Wind Trend • Exceeded FPI
SKI HI	RAR0081	SCE Castle Rock Rd	21.5	40.4	31 / 46	12.53	<ul style="list-style-type: none"> • High Wind Trend • Exceeded FPI

⁸ SCE defines wind trends as increasing wind speeds that are projected to exceed threshold

⁹ Remote Automatic Recloser (RAR) and Circuit Breaker (CB) denote different types of sectionalizing devices used by SCE

Circuit Name	Isolation Device ⁹	Weather Station	Wind Sustained	Gust Sustained	Threshold Sustained	FPI Value	Reasons for De-Energization
STROSNIDER	CB	SCE Bridgeport Valley	33.9	51.5	31 / 46	12.53	<ul style="list-style-type: none"> Exceeded Threshold Exceeded FPI
ROBINSON CREEK	CB	SCE Twin Lakes Rd	39.3	57.0	31 / 46	11.25	<ul style="list-style-type: none"> Exceeded Threshold 1% Historical
CAMPANULA	RAR0640	SCE Mesa Dr	30.7	40.3	31 / 46	12.52	<ul style="list-style-type: none"> Met Threshold Exceeded FPI
CAMPANULA	RAR0640	SCE Mesa Dr	30.7	40.3	31 / 46	12.52	<ul style="list-style-type: none"> High Wind Trend Exceeded FPI

10. Evaluation of alternatives to de-energization that were considered, and mitigation measures used to decrease the risk of utility-caused wildfire in the de-energized area and an explanation of how the utility determined that the benefit of de-energization outweighed the potential public safety risks:

SCE sets thresholds based on SCE’s risk-informed assessment of the potential for a catastrophic wildfire should an ignition occur under the conditions presented. Under such conditions, the harm to life and property resulting from a catastrophic wildfire vastly outweighs the impacts of the de-energization necessary to eliminate the potential of ignition. Additionally, SCE only uses de-energization when no other alternatives will mitigate this fire risk and to the extent possible, minimizes the impact by limiting the de-energization to the smallest number of customers possible through segmentation of impacted circuits, where possible.

In all PSPS events, SCE uses sectionalizing through RAR devices or switches when available within a reasonable period to isolate and de-energize only the necessary portions of circuits. While avoiding de-energization entirely is not always possible, SCE takes these steps to reduce the impacts of de-energization on the community, considering the impacts of the de-energization on its stakeholders within the overall risk posed by the prevailing weather conditions, its de-energizations thresholds, and the unacceptable public safety risk of catastrophic wildfire ignition.

11. A copy of all notifications, the timing of notifications, the methods of notifications and who made the notifications (the utility or local public safety partners).

A copy of all notifications and the timing of notifications can be found in Attachment A -Public Safety Partner Notifications, Attachment B - Critical Infrastructure and Customer Notifications and Attachment C - PSPS Activation Customer Notification Messaging. All PSPS event notifications to key stakeholders, including Public Safety Partners and customers, are delivered via voice, email, and TTY (telecommunication

device for the hearing impaired) formats as per the preference of the recipient. Notifications are offered in multiple languages. All notifications were made by SCE.

12. Number of affected customers broken down by all classifications including residential, medical baseline, commercial/industrial, etc.

A detailed description of the number of affected customers broken down by all classifications including residential, medical baseline, commercial/industrial, etc. is provided in Attachment B-Customer and Critical Infrastructure Notifications.

13. An explanation of the circumstances that resulted in failure to communicate a potential pro-active de-energization event, if any.

During this event, SCE provided at least imminent notice of de-energization to all impacted customers. On November 6, however, SCE de-energized the Strosnider, Robinson Creek and Campanula circuits in Mono and San Bernardino counties unexpectedly, as these circuits were not originally forecasted to be in scope for this event. Although these three circuits received imminent notification of de-energization, SCE was not able to provide notices at least two hours prior to the de-energization on the Campanula and Strosnider circuits as detailed in Attachment B-Customer and Critical Infrastructure Notifications.

14. Each electric investor-owned utility shall enumerate and explain the cause of any false communications in its post event reports by citing the sources of changing data.

SCE notes that its PSPS notices before potential de-energization only provide a warning to customers of a possible de-energization event. SCE notices are designed to give customers notice that a de-energization could take place and a time frame within which the event is most likely to occur so that customers can act and prepare. Given the unpredictability of weather on the ground, however, SCE's advance notices do not affirmatively confirm that a circuit *will be* de-energized. In fact, for clarity, SCE does not provide any affirmative confirmation of de-energization in its notifications until an actual de-energization has taken place.

SCE believes this event could be viewed as an example of a false-negative communication for certain circuits and customers since we were unable to provide all of the required advance notices of de-energization to Public Safety Partners, critical infrastructure providers, or customers given the rapid onset of hazardous weather conditions. Additionally, as discussed below any advance notifications to customers who were not de-energized, although not viewed by SCE as false positives, are being reported here for transparency purposes. SCE provided notice to 5,189 customers of potential de-energization but not all of these customers were de-energized.

15. A description and evaluation of engagement with local and state public safety partners in providing advanced education and outreach during the de-energization event.

Advanced education and outreach of this Public Safety Power Shutoff event was communicated to all impacted counties projected to be in scope, emergency management officials, CalOES, and the Commission before any forecasted weather was scheduled to impact the SCE service territory. Updates were provided throughout the event using the CalOES PSPS Notification Form, daily situational awareness and coordination calls and individual contact with Public Safety Partners in the affected counties.

16. For those customers where positive or affirmative notification was attempted, an accounting of the customers (which tariff and/or access and functional needs population designation), the number of notification attempts made, the timing of attempts, who made the notification attempt (utility or public safety partner) and the number of customers for whom positive notification was achieved.

SCE only tracks critical care customers for positive or affirmative receipt of notification attempts. Notifications are made daily as these customers remain on potentially impacted circuits. There was a total of 35 critical care customers impacted and SCE made positive contact with all of them during this event. A summary of all customer notifications to include medical baseline and critical care customers can be found in Attachment B- Customer and Critical Infrastructure Notifications.

17. A description of how sectionalizing, i.e., separating loads within a circuit, was considered and implemented and the extent to which it impacted the size and scope of the de-energization event.

There were approximately 5,189 customers predicted to be scope for de-energization during this event, out of which 1,135 customers were actually de-energized. SCE reduced the total number of customers impacted by de-energization on all circuits to 1,335 customers using switching playbooks that identified sectionalizing devices to limit the scope of the event. SCE used an RAR device to separate and isolate the de-energization areas, limiting the de-energization impacts as detailed in the table on page 6 of this report. During the process of sectionalizing, 82 customers temporarily lost power (for approximately 1 minute) on the Pickle Meadows circuit but SCE is not including this in the count of de-energized customers due to the fact that this was an extremely short loss of power during switching operations and the customers at issue were not actually impacted by the PSPS events.

18. Lessons learned from the de-energization events.

SCE continues to evaluate lessons learned from all 2020 PSPS events and is considering potential improvements within that context.

19. Any recommended updates to the guidelines adopted in Resolution ESRB-8 and this decision.

SCE notes that its PSPS notices before potential de-energization) only provide a warning to customers of a possible de-energization event. SCE notices are designed to give customers notice that a de-energization could take place and a time frame within which the event is most likely to occur so that customers can take action and prepare. Given the unpredictability of weather on the ground, however, SCE's advance notices do not affirmatively confirm that a circuit *will be* de-energized. In fact, for clarity, SCE does not provide any affirmative notifications until an actual de-energization has taken place.

SCE believes that its notices are correct and factual. The definition of false positive is subject to interpretation about which notifications should be included. Impending de-energizations could reasonably be interpreted as notifications of imminent de-energization 1-4 hours before outages. SCE believes, however, that the Commission may be interested in all the advance notices of a possible de-energization to such customers. Consequently, in an effort to assure transparency and full compliance, SCE will treat them here as potential "false positives", see above, within the meaning of the PSPS guidance. SCE would appreciate any additional Commission clarification or guidance on this issue to assure it is fully compliant.

SCE notes that "false positives" typically refer to decisions made, or actions taken based on erroneous information. Differences between notifications and actual de-energizations, however, do not stem from incorrect data, but rather from actual ground conditions varying from forecast conditions. This variance is inherent because of the constantly changing nature of emergent weather. SCE hopes that the Commission will take this into consideration when clarifying the definition of false positives going forward.

Officer Verification

I am an officer of the applicant corporation herein and am authorized to make this verification on its behalf. I am informed and believe that the matters stated in the foregoing document are true.

I declare under penalty of perjury that the foregoing is true and correct. Executed this 23rd day of November 2020 in Cerritos, California

DocuSigned by:

Erik Takayesu

420B7563894B477...

Erik Takayesu

Vice President,

Transmission, Substations & Operations

Attachment A

Public Safety Partner Notifications

Everbridge PSPS Notification Audit Report 2020-11-03-1244 All Counties Rpt1

Notification ID	Message Title	Sent On
595802158276248	Important: SCE Initial Notice for PSPS Event in Inyo County on 11/5/2020.	Nov 03, 2020 12:24:23 PST
595802158276262	Important: SCE Initial Notice for PSPS Event in Mono County on 11/5/2020.	Nov 03, 2020 12:32:01 PST
595802158276283	Important: SCE Initial Notice for PSPS Event in San Bernardino County on 11/6/2020.	Nov 03, 2020 12:40:33 PST
595802158276291	Important: SCE Initial Notice for PSPS Event in Santa Barbara County on 11/6/2020.	Nov 03, 2020 12:44:42 PST

Rocio M Contreras-Regalado

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Tuesday, November 3, 2020 12:25 PM
To: Rocio M Contreras-Regalado
Subject: Important: SCE Initial Notice for PSPS Event in Inyo County on 11/5/2020.
Attachments: SCE+LNO+POC+INYO+2020-11-03+Rpt+1.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to projected weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Inyo County**. SCE is also notifying customers on the affected circuits about the potential shutoff, giving them time to prepare.

SCE has opened its Emergency Operations Center and activated an Incident Management Team to monitor the weather and other conditions in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

Please refer to the attached file for status and periods of concern for specific circuits in your county.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: SCE may shut off power on one or more circuits in your area. For more information, visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Southern California Edison LNO Circuit List with Periods of Concern
As of 11/03/2020 Circuit List All Counties Report #1

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspections.
Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.
Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.
Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See sca.com/safety/wildfire/paps for total customer counts by county.
Note 5: Please refer to Definitions tab for additional information.
Note 6: Any circuits on the list that do not display period of concern times means those circuits have periods of concern that start beyond the time periods shown. Watch for more on subsequent reports.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MBL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)	
BIRCHM	INYO		Round Valley ; Scheelite ; Mesa ; West Bishop ; east of Grouse Mountain	Initial					11/03/2020		11/04/2020		11/05/2020	2100-0000	11/06/2020	0000-2100		528	4	10	9	2	553

Rocio M Contreras-Regalado

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Tuesday, November 3, 2020 12:32 PM
To: Rocio M Contreras-Regalado
Subject: Important: SCE Initial Notice for PSPS Event in Mono County on 11/5/2020.
Attachments: SCE+LNO+POC+MONO+2020-11-03+Rpt+1.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to projected weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Mono County**. SCE is also notifying customers on the affected circuits about the potential shutoff, giving them time to prepare.

SCE has opened its Emergency Operations Center and activated an Incident Management Team to monitor the weather and other conditions in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

Please refer to the attached file for status and periods of concern for specific circuits in your county.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: SCE may shut off power on one or more circuits in your area. For more information, visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Southern California Edison LNO Circuit List with Periods of Concern
As of 11/03/2020 Circuit List All Counties Report #1

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspections.
Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.
Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.
Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See sce.com/safety/wildfire/paps for total customer counts by county.
Note 5: Please refer to Definitions tab for additional information.
Note 6: Any circuits on the list that do not display period of concern times means those circuits have periods of concern that start beyond the time periods shown. Watch for more on subsequent reports.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MBL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)
BIRCHM	MONO		Paradise ; Portion of Swall Meadows	Initial					11/03/2020		11/04/2020		11/05/2020	2100-0000	11/06/2020	0000-2100	6	0	0	0	0	6
DYNAMO	MONO		Dunderberg Mill ; Bridgeport Feeder	Initial					11/03/2020		11/04/2020		11/05/2020	2100-0000	11/06/2020	0000-1800	1	0	0	0	0	1
GULL LAKE	MONO		June Lake Down Canyon	Initial					11/03/2020		11/04/2020		11/05/2020	2100-0000	11/06/2020	0000-1800	361	1	8	3	0	373
REVERSE PEAK	MONO		June Lake Village and Loop ; Crestview	Initial					11/03/2020		11/04/2020		11/05/2020	2100-0000	11/06/2020	0000-1800	487	0	46	5	0	538

Rocio M Contreras-Regalado

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Tuesday, November 3, 2020 12:41 PM
To: Rocio M Contreras-Regalado
Subject: Important: SCE Initial Notice for PSPS Event in San Bernardino County on 11/6/2020.
Attachments: SCE+LNO+POC+SAN+BERNARDINO+2020-11-03+Rpt+1.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to projected weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **San Bernardino County**. SCE is also notifying customers on the affected circuits about the potential shutoff, giving them time to prepare.

SCE has opened its Emergency Operations Center and activated an Incident Management Team to monitor the weather and other conditions in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

Please refer to the attached file for status and periods of concern for specific circuits in your county.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: SCE may shut off power on one or more circuits in your area. For more information, visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Southern California Edison LNO Circuit List with Periods of Concern
As of 11/03/2020 Circuit List All Counties Report #1

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspections.
Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.
Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.
Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See sced.com/safety/wildfire/paps for total customer counts by county.
Note 5: Please refer to Definitions tab for additional information.
Note 6: Any circuits on the list that do not display period of concern times means those circuits have periods of concern that start beyond the time periods shown. Watch for more on subsequent reports.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MBL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)	
CUSHENBURY	SAN BERNARDINO		HWY CA 18 between North of Doble and Cushenbury	Initial					11/03/2020		11/04/2020		11/05/2020		11/06/2020	0900-1800		1	0	2	0	0	3
DOBLE	SAN BERNARDINO		Doble ; Upper Holcomb Valley ; Arrastre Flats ; Furnace Canyon	Initial					11/03/2020		11/04/2020		11/05/2020		11/06/2020	0900-1800		1	0	1	0	0	2
SCOUT	SAN BERNARDINO		Northeast of Fawnskin	Initial					11/03/2020		11/04/2020		11/05/2020		11/06/2020	0900-1800		4	0	0	0	0	4
SKY HI	SAN BERNARDINO		Lucerne Valley ; Fifteen mile Valley east of Milpas drive ; Crystal Creek N of Gateway Rd ; Cushenbury	Initial					11/03/2020		11/04/2020		11/05/2020		11/06/2020	0900-1800		1475	0	33	57	32	1597
LUTE	SAN BERNARDINO		North of Big Bear ; Apple Valley	Initial					11/03/2020		11/04/2020		11/05/2020		11/06/2020	0900-1800	UNAVBL	UNAVBL	UNAVBL	UNAVBL	UNAVBL	UNAVBL	

Rocio M Contreras-Regalado

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Tuesday, November 3, 2020 12:45 PM
To: Rocio M Contreras-Regalado
Subject: Important: SCE Initial Notice for PSPS Event in Santa Barbara County on 11/6/2020.
Attachments: SCE+LNO+POC+SANTA+BARBARA+2020-11-03+Rpt+1.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to projected weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Santa Barbara County**. SCE is also notifying customers on the affected circuits about the potential shutoff, giving them time to prepare.

SCE has opened its Emergency Operations Center and activated an Incident Management Team to monitor the weather and other conditions in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

Please refer to the attached file for status and periods of concern for specific circuits in your county.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: SCE may shut off power on one or more circuits in your area. For more information, visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Southern California Edison LNO Circuit List with Periods of Concern
As of 11/03/2020 Circuit List All Counties Report #1

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspections.
Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.
Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.
Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See sce.com/safety/wildfire/paps for total customer counts by county.
Note 5: Please refer to Definitions tab for additional information.
Note 6: Any circuits on the list that do not display period of concern times means those circuits have periods of concern that start beyond the time periods shown. Watch for more on subsequent reports.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MIL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)
CONCEPCION	SANTA BARBARA		Gaviota ; Concepcion ; Jalema ; Drake ; Sacate	Initial					11/03/2020		11/04/2020		11/05/2020		11/06/2020	0900-1200	206	1	38	0	0	245

Everbridge PSPS Notification Audit Report 2020-11-03-1848 All Counties Report 2

Notification ID	Message Title	Sent On
595802158276836	Important: SCE Update Notice for PSPS Event in Santa Barbara County.	Nov 03, 2020 18:42:32 PST
595802158276838	Important: SCE Update Notice for PSPS Event in San Bernardino County.	Nov 03, 2020 18:44:49 PST
595802158276839	Important: SCE Update Notice for PSPS Event in Mono County.	Nov 03, 2020 18:47:11 PST
595802158276840	Important: SCE Update Notice for PSPS Event in Inyo County.	Nov 03, 2020 18:48:58 PST

Rocio M Contreras-Regalado

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Tuesday, November 3, 2020 6:43 PM
To: SCE Liaison Officer
Subject: Important: SCE Update Notice for PSPS Event in Santa Barbara County.
Attachments: SCE+LNO+POC+SANTA+BARBARA+2020-11-03+Rpt+2.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Santa Barbara County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Southern California Edison LNO Circuit List with Periods of Concern
As of 11/03/2020 Circuit List All Counties Report #2

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspections.
Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.
Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.
Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See sce.com/safety/wildfire/paps for total customer counts by county.
Note 5: Please refer to Definitions tab for additional information.
Note 6: Any circuits on the list that do not display period of concern times means those circuits have periods of concern that start beyond the time periods shown. Watch for more on subsequent reports.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MIL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)
CONCEPCION	SANTA BARBARA		Gaviota ; Concepcion ; Jalema ; Drake ; Sacate	All Clear					11/03/2020		11/04/2020		11/05/2020		11/06/2020		206	1	38	0	0	245

Rocio M Contreras-Regalado

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Tuesday, November 3, 2020 6:45 PM
To: SCE Liaison Officer
Subject: Important: SCE Update Notice for PSPS Event in San Bernardino County.
Attachments: SCE+LNO+POC+SAN+BERNARDINO+2020-11-03+Rpt+2.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **San Bernardino County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspсалerts).

Southern California Edison LNO Circuit List with Periods of Concern
As of 11/03/2020 Circuit List All Counties Report #2

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspections.
Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.
Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.
Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See sce.com/safety/wildfire/paps for total customer counts by county.
Note 5: Please refer to Definitions tab for additional information.
Note 6: Any circuits on the list that do not display period of concern times means those circuits have periods of concern that start beyond the time periods shown. Watch for more on subsequent reports.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MBL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)	
CUSHENBURY	SAN BERNARDINO		HWY CA 18 between North of Doble and Cushenbury	No Change					11/03/2020		11/04/2020		11/05/2020		11/06/2020	0900-1800		1	0	2	0	0	3
DOBLE	SAN BERNARDINO		Doble ; Upper Holcomb Valley ; Arrastre Flats ; Furnace Canyon	Update					11/03/2020		11/04/2020		11/05/2020		11/06/2020	0900-1800		1	0	1	0	0	2
SCOUT	SAN BERNARDINO		Northeast of Fawnskin	Update					11/03/2020		11/04/2020		11/05/2020		11/06/2020	0900-1800		4	0	0	0	0	4
SKY HI	SAN BERNARDINO		Lucerne Valley ; Fifteen mile Valley east of Milpas drive ; Crystal Creek N of Gateway Rd ; Cushenbury	No Change					11/03/2020		11/04/2020		11/05/2020		11/06/2020	0900-1800		1475	0	33	57	32	1597
LUTE	SAN BERNARDINO		North of Big Bear ; Apple Valley	Update					11/03/2020		11/04/2020		11/05/2020		11/06/2020	0900-1800	UNAVBL	UNAVBL	UNAVBL	UNAVBL	UNAVBL	UNAVBL	

Rocio M Contreras-Regalado

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Tuesday, November 3, 2020 6:47 PM
To: Rocio M Contreras-Regalado
Subject: Important: SCE Update Notice for PSPS Event in Mono County.
Attachments: SCE+LNO+POC+MONO+2020-11-03+Rpt+2.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Mono County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Southern California Edison LNO Circuit List with Periods of Concern
As of 11/03/2020 Circuit List All Counties Report #2

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspections.
Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.
Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.
Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See sce.com/safety/wildfire/paps for total customer counts by county.
Note 5: Please refer to Definitions tab for additional information.
Note 6: Any circuits on the list that do not display period of concern times means those circuits have periods of concern that start beyond the time periods shown. Watch for more on subsequent reports.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MBL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)
BIRCHM	MONO		Paradise ; Portion of Swall Meadows	Update					11/03/2020		11/04/2020		11/05/2020	2100-0000	11/06/2020	0000-0000	6	0	0	0	0	6
DYNAMO	MONO		Dunderberg Mill ; Bridgeport Feeder	Update					11/03/2020		11/04/2020		11/05/2020	2100-0000	11/06/2020	0000-0000	1	0	0	0	0	1
GULL LAKE	MONO		June Lake Down Canyon	Update					11/03/2020		11/04/2020		11/05/2020	2100-0000	11/06/2020	0000-0000	361	1	8	3	0	373
REVERSE PEAK	MONO		June Lake Village and Loop ; Crestview	Update					11/03/2020		11/04/2020		11/05/2020	2100-0000	11/06/2020	0000-0000	487	0	46	5	0	538
TUFA	MONO		Christown ; Mono City ; and Mono Lake	Initial					11/03/2020		11/04/2020		11/05/2020		11/06/2020	0900-1200	103	0	3	0	0	106

Rocio M Contreras-Regalado

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Tuesday, November 3, 2020 6:49 PM
To: Rocio M Contreras-Regalado
Subject: Important: SCE Update Notice for PSPS Event in Inyo County.
Attachments: SCE+LNO+POC+INYO+2020-11-03+Rpt+2.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Inyo County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Southern California Edison LNO Circuit List with Periods of Concern
As of 11/03/2020 Circuit List All Counties Report #2

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspections.
Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.
Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.
Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See sce.com/safety/wildfire/paps for total customer counts by county.
Note 5: Please refer to Definitions tab for additional information.
Note 6: Any circuits on the list that do not display period of concern times means those circuits have periods of concern that start beyond the time periods shown. Watch for more on subsequent reports.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MIL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)
BIRCHM	INYO		Round Valley ; Scheelite ; Mesa ; West Bishop ; east of Grouse Mountain	Update					11/03/2020		11/04/2020		11/05/2020	2100-0000	11/06/2020	0000-0000	528	4	10	9	2	553

Everbridge PPS Notification Audit Report 2020-11-04-1003 All Counties Report 1

Notification ID	Message Title	Sent On
595802158277827	Important: SCE Update Notice for PPS Event in San Bernardino County.	Nov 04, 2020 09:55:39 PST
595802158277836	Important: SCE Update Notice for PPS Event in Inyo County.	Nov 04, 2020 09:59:57 PST
595802158277841	Important: SCE Update Notice for PPS Event in Mono County.	Nov 04, 2020 10:03:50 PST

Rocio M Contreras-Regalado

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Wednesday, November 4, 2020 9:56 AM
To: SCE Liaison Officer
Subject: Important: SCE Update Notice for PSPS Event in San Bernardino County.
Attachments: SCE+LNO+POC+SAN+BERNARDINO+2020-11-04-Rpt+1.xlsx

Follow Up Flag: Follow up
Flag Status: Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **San Bernardino County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Southern California Edison LNO Circuit List with Periods of Concern
As of 11/04/2020 Circuit List All Counties Report #1

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspections.
Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.
Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.
Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See sce.com/safety/wildfire/paps for total customer counts by county.
Note 5: Please refer to Definitions tab for additional information.
Note 6: Any circuits on the list that do not display period of concern times means those circuits have periods of concern that start beyond the time periods shown. Watch for more on subsequent reports.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MBL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)
CUSHENBURY	SAN BERNARDINO		HWY CA 18 between North of Doble and Cushenbury	Update					11/04/2020		11/05/2020		11/06/2020	0600-1800	11/07/2020		1	0	2	0	0	3
DOBLE	SAN BERNARDINO		Doble ; Upper Holcomb Valley ; Arrastre Flats ; Furnace Canyon	Update					11/04/2020		11/05/2020		11/06/2020	0300-1800	11/07/2020		1	0	1	0	0	2
SCOUT	SAN BERNARDINO		Northeast of Fawnskin	Update					11/04/2020		11/05/2020		11/06/2020	0300-1800	11/07/2020		4	0	0	0	0	4
SKY HI	SAN BERNARDINO		Lucerne Valley ; Fifteen mile Valley east of Milpas drive ; Crystal Creek N of Gateway Rd ; Cushenbury	Update					11/04/2020		11/05/2020		11/06/2020	0600-1800	11/07/2020		1476	0	33	57	32	1598
LUTE	SAN BERNARDINO		North of Big Bear ; Apple Valley	Update					11/04/2020		11/05/2020		11/06/2020	0300-1800	11/07/2020		UNAVBL	UNAVBL	UNAVBL	UNAVBL	UNAVBL	UNAVBL

Rocio M Contreras-Regalado

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Wednesday, November 4, 2020 10:00 AM
To: SCE Liaison Officer
Subject: Important: SCE Update Notice for PSPS Event in Inyo County.
Attachments: SCE+LNO+POC+INYO+2020-11-04-Rpt+1.xlsx

Follow Up Flag: Follow up
Flag Status: Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Inyo County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Southern California Edison LNO Circuit List with Periods of Concern
As of 11/04/2020 Circuit List All Counties Report #1

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspections.
Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.
Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.
Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See sce.com/safety/wildfire/paps for total customer counts by county.
Note 5: Please refer to Definitions tab for additional information.
Note 6: Any circuits on the list that do not display period of concern times means those circuits have periods of concern that start beyond the time periods shown. Watch for more on subsequent reports.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MIL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)
BIRCHM	INYO		Round Valley ; Scheelite ; Mesa ; West Bishop ; east of Grouse Mountain	Update					11/04/2020		11/05/2020	2100-0000	11/06/2020	0000-0000	11/07/2020	0000-0300	528	4	10	9	2	553

Rocio M Contreras-Regalado

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Wednesday, November 4, 2020 10:04 AM
To: SCE Liaison Officer
Subject: Important: SCE Update Notice for PSPS Event in Mono County.
Attachments: SCE+LNO+POC+MONO+2020-11-04-Rpt+1.xlsx

Follow Up Flag: Follow up
Flag Status: Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Mono County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Southern California Edison LNO Circuit List with Periods of Concern
As of 11/04/2020 Circuit List All Counties Report #1

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspections.
Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.
Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.
Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See sce.com/safety/wildfire/paps for total customer counts by county.
Note 5: Please refer to Definitions tab for additional information.
Note 6: Any circuits on the list that do not display period of concern times means those circuits have periods of concern that start beyond the time periods shown. Watch for more on subsequent reports.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MIL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)
BANTA	MONO		Lee Vining ; Lee Vining Canyon	Initial					11/04/2020		11/05/2020		11/06/2020	0600-1800	11/07/2020		131	2	13	1	1	148
BIRCHM	MONO		Paradise ; Portion of Sawall Meadows	Update					11/04/2020		11/05/2020	2100-0000	11/06/2020	0000-0000	11/07/2020	0000-0000	6	0	0	0	0	6
CAIN RANCH	MONO		Tioga Gas Mart ; Pumice Valley	Initial					11/04/2020		11/05/2020		11/06/2020	0900-1200	11/07/2020		18	0	4	0	0	22
DYNAMO	MONO		Dunderberg Mill ; Bridgeport Feeder	Update					11/04/2020		11/05/2020	2100-0000	11/06/2020	0000-1800	11/07/2020		1	0	0	0	0	1
GULL LAKE	MONO		June Lake Down Canyon	Update					11/04/2020		11/05/2020	2100-0000	11/06/2020	0000-1800	11/07/2020		361	1	8	3	0	373
REVERSE PEAK	MONO		June Lake Village and Loop ; Crestview	Update					11/04/2020		11/05/2020	2100-0000	11/06/2020	0000-1800	11/07/2020		487	0	46	5	0	538
TUFA	MONO		Chinatown ; Mono City ; and Mono Lake	Update					11/04/2020		11/05/2020		11/06/2020	0000-1800	11/07/2020		103	0	3	0	0	106

Everbridge PPS Notification Audit Report 2020-11-04 All Counties Report 2

Notification ID	Message Title	Sent On
595802158278801	Important: SCE Update Notice for PPS Event in Inyo County.	Nov 04, 2020 18:36:18 PST
595802158278807	Important: SCE Update Notice for PPS Event in Mono County.	Nov 04, 2020 18:39:37 PST
595802158278812	Important: SCE Update Notice for PPS Event in San Bernardino County.	Nov 04, 2020 18:42:03 PST

Rocio M Contreras-Regalado

From: SCEliaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Wednesday, November 4, 2020 6:37 PM
To: SCE Liaison Officer
Subject: Important: SCE Update Notice for PSPS Event in Inyo County.
Attachments: SCE+LNO+POC+INYO+2020-11-04+Rpt+2.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Inyo County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Southern California Edison LNO Circuit List with Periods of Concern
As of 11/04/2020 Circuit List All Counties Report #2

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspections.
Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.
Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.
Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See sce.com/safety/wildfire/paps for total customer counts by county.
Note 5: Please refer to Definitions tab for additional information.
Note 6: Any circuits on the list that do not display period of concern times means those circuits have periods of concern that start beyond the time periods shown. Watch for more on subsequent reports.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MBL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)	
BIRCHM	INYO		Round Valley ; Scheelite ; Mesa ; West Bishop ; east of Grouse Mountain	Update					11/04/2020		11/05/2020		11/06/2020	0300-0000	11/07/2020	0000-0300		528	4	10	9	2	553
SINKER	INYO		Bishop Creek Road	Initial					11/04/2020		11/05/2020		11/06/2020	1200-0000	11/07/2020		14	0	0	0	0	14	

Rocio M Contreras-Regalado

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Wednesday, November 4, 2020 6:40 PM
To: Rocio M Contreras-Regalado
Subject: Important: SCE Update Notice for PSPS Event in Mono County.
Attachments: SCE+LNO+POC+MONO+2020-11-04+Rpt+2.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Mono County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Southern California Edison LNO Circuit List with Periods of Concern
As of 11/04/2020 Circuit List All Counties Report #2

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspections.
Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.
Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.
Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See sca.com/safety/wildfire/paps for total customer counts by county.
Note 5: Please refer to Deflections tab for additional information.
Note 6: Any circuits on the list that do not display period of concern times means those circuits have periods of concern that start beyond the time periods shown. Watch for more on subsequent reports.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MedL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)
BANTA	MONO		Lee Vining ; Lee Vining Canyon	Update					11/04/2020		11/05/2020		11/06/2020	0900-1500	11/07/2020		131	2	13	1	1	148
BROCKM	MONO		Paradise ; Portion of Swall Meadows	Update					11/04/2020		11/05/2020		11/06/2020	0300-0000	11/07/2020	0000-0300	6	0	0	0	0	6
CAIN BANCH	MONO		Tioga Gas Mart ; Pumice Valley	Update					11/04/2020		11/05/2020		11/06/2020	0600-1500	11/07/2020		38	0	4	0	0	22
DYNAMO	MONO		Dunderberg Mill ; Bridgeport Feeder	Update					11/04/2020		11/05/2020		11/06/2020	0300-1200	11/07/2020		1	0	0	0	0	1
GULL LAKE	MONO		June Lake Down Canyon	Update					11/04/2020		11/05/2020		11/06/2020	0300-1200	11/07/2020		363	1	8	3	0	373
REVERSE PEAK	MONO		June Lake Village and Loop ; Crestview	Update					11/04/2020		11/05/2020		11/06/2020	0300-1200	11/07/2020		487	0	46	5	0	538
ROCKCREEK	MONO		Swall Meadows	Initial					11/04/2020		11/05/2020		11/06/2020	1800-0000	11/07/2020		127	1	6	0	0	134
TLUFA	MONO		Chinatown ; Mono City ; and Mono Lake	Update					11/04/2020		11/05/2020		11/06/2020	0600-1500	11/07/2020		103	0	3	0	0	106

Rocio M Contreras-Regalado

From: SCEliaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Wednesday, November 4, 2020 6:42 PM
To: Rocio M Contreras-Regalado
Subject: Important: SCE Update Notice for PSPS Event in San Bernardino County.
Attachments: SCE+LNO+POC+SAN+BERNARDINO+2020-11-04+Rpt+2.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **San Bernardino County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Southern California Edison LNO Circuit List with Periods of Concern
As of 11/04/2020 Circuit List All Counties Report #2

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspections.
Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.
Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.
Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See sce.com/safety/wildfire/paps for total customer counts by county.
Note 5: Please refer to Definitions tab for additional information.
Note 6: Any circuits on the list that do not display period of concern times means those circuits have periods of concern that start beyond the time periods shown. Watch for more on subsequent reports.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MBL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)	
CUSHENBURY	SAN BERNARDINO		HWY CA 18 between North of Doble and Cushenbury	Update					11/04/2020		11/05/2020		11/06/2020	0600-1500	11/07/2020			1	0	2	0	0	3
DOBLE	SAN BERNARDINO		Doble ; Upper Holcomb Valley ; Arrastre Flats ; Furnace Canyon	Update					11/04/2020		11/05/2020		11/06/2020	0600-1500	11/07/2020			1	0	1	0	0	2
SCOUT	SAN BERNARDINO		Northeast of Fawnskin	Update					11/04/2020		11/05/2020		11/06/2020	0600-1500	11/07/2020			4	0	0	0	0	4
SKY HI	SAN BERNARDINO		Lucerne Valley ; Fifteen mile Valley east of Milpas drive ; Crystal Creek N of Gateway Rd ; Cushenbury	Update					11/04/2020		11/05/2020		11/06/2020	0900-1500	11/07/2020			1476	0	33	57	32	1598
LITE	SAN BERNARDINO		North of Big Bear ; Apple Valley	Update					11/04/2020		11/05/2020		11/06/2020	0600-1500	11/07/2020		UNAVBL	UNAVBL	UNAVBL	UNAVBL	UNAVBL	UNAVBL	

Everbridge PSPS Notification Audit Report 2020-11-05-1326 All Counties Report 1

Notification ID	Message Title	Sent On
625214094311436	Important: SCE Update Notice for PSPS Event in San Bernardino County.	Nov 05, 2020 13:21:00 PST
625214094311441	Important: SCE Update Notice for PSPS Event in Mono County.	Nov 05, 2020 13:24:07 PST
625214094311445	Important: SCE Update Notice for PSPS Event in Inyo County.	Nov 05, 2020 13:26:44 PST

Rocio M Contreras-Regalado

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Thursday, November 5, 2020 1:21 PM
To: SCE Liaison Officer
Subject: Important: SCE Update Notice for PSPS Event in San Bernardino County.
Attachments: SCE+LNO+POC+SAN+BERNARDINO+2020-11-05-Rpt+1.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **San Bernardino County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Southern California Edison LNO Circuit List with Periods of Concern
As of 11/05/2020 Circuit List All Counties Report #1

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspections.
Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.
Note 3: 12-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.
Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See ce.com/safety/alerts/pages for total customer counts by county.
Note 5: Please refer to Definitions tab for additional information.
Note 6: Any circuits on the list that do not display period of concern times means those circuits have periods of concern that start beyond the time periods shown. Watch for more on subsequent reports.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MBL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)	
BEAR VALLEY	SAN BERNARDINO		Mill Creek Canyon ; Angelus Oaks ; Piesanita ; Converse Flats ; Seven Oaks ; Forest Falls	Initial					11/05/2020		11/06/2020	0900-1500	11/07/2020		11/08/2020		31	0	0	0	1	0	32
BEAR VALLEY	SAN BERNARDINO	BIG BEAR LAKE		Initial					11/05/2020		11/06/2020	0900-1500	11/07/2020		11/08/2020		31	0	0	0	1	0	32
CAMP ANGELLUS	SAN BERNARDINO		Angelus Oaks ; Glen Martin	Initial					11/05/2020		11/06/2020	0900-1500	11/07/2020		11/08/2020		292	0	8	9	0	309	
CUSHENBURY	SAN BERNARDINO		HWY CA 18 between North of Doble and Cushenbury	Update					11/05/2020		11/06/2020	0600-1800	11/07/2020		11/08/2020		1	0	2	0	0	3	
DOBLE	SAN BERNARDINO		Doble ; Upper Holcomb Valley ; Arcastro Flats ; Furnace Canyon	Update					11/05/2020		11/06/2020	0600-1800	11/07/2020		11/08/2020		1	0	1	0	0	2	
JENKS LAKE	SAN BERNARDINO		Seven Oaks ; Jenks Meadow ; Jenks Lake ; Barton Hills	Initial					11/05/2020		11/06/2020	0900-1500	11/07/2020		11/08/2020		132	0	10	0	0	142	
SCOUT	SAN BERNARDINO		Northeast of Fawnskin	Update					11/05/2020		11/06/2020	0600-1800	11/07/2020		11/08/2020		4	0	0	0	0	4	
SKY HI	SAN BERNARDINO		Lucerne Valley ; Fifteen mile Valley east of Milpas drive ; Crystal Creek N of Gateway Rd ; Cushenbury	Update					11/05/2020		11/06/2020	0600-1800	11/07/2020		11/08/2020		1476	0	33	57	32	1598	
UTE	SAN BERNARDINO		North of Big Bear ; Apple Valley	Update					11/05/2020		11/06/2020	0600-1800	11/07/2020		11/08/2020	UNAVBL	UNAVBL	UNAVBL	UNAVBL	UNAVBL	UNAVBL		
WEESHA	SAN BERNARDINO		Piesanita	Initial					11/05/2020		11/06/2020	0900-1500	11/07/2020		11/08/2020		53	0	0	0	0	53	

Rocio M Contreras-Regalado

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Thursday, November 5, 2020 1:24 PM
To: SCE Liaison Officer
Subject: Important: SCE Update Notice for PSPS Event in Mono County.
Attachments: SCE+LNO+POC+MONO+2020-11-05-Rpt+1.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Mono County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Southern California Edison LNO Circuit List with Periods of Concern
As of 11/05/2020 Circuit List All Counties Report #1

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspections.
Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.
Note 3: 12-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.
Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See ce.com/safety/alerts/pegs for total customer counts by county.
Note 5: Please refer to Definitions tab for additional information.
Note 6: Any circuits on the list that do not display period of concern times means those circuits have periods of concern that start beyond the time periods shown. Watch for more on subsequent reports.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MBL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)
BANTA	MONO		Lee Vining ; Lee Vining Canyon	Update					11/05/2020		11/06/2020	0300-1500	11/07/2020		11/08/2020		131	2	13	1	0	148
BIRCHM	MONO		Paradise ; Portion of Swall Meadows	Update					11/05/2020	2100-0000	11/06/2020	0000-2100	11/07/2020		11/08/2020		6	0	0	0	0	6
CANN BANCH	MONO		Tioga Gas Mart ; Pumice Valley	Update					11/05/2020		11/06/2020	0300-1500	11/07/2020		11/08/2020		18	0	4	0	0	22
DYNAMO	MONO		Bundenberg Mill ; Bridgeport Feeder	Update					11/05/2020		11/06/2020	0000-1500	11/07/2020		11/08/2020		1	0	0	0	0	1
GULL LAKE	MONO		June Lake Down Canyon	Update					11/05/2020	2100-0000	11/06/2020	0000-1800	11/07/2020		11/08/2020		361	1	8	3	0	373
REVERSE PEAK	MONO		June Lake Village and Loop ; Cratersview	Update					11/05/2020	2100-0000	11/06/2020	0000-1800	11/07/2020		11/08/2020		487	0	46	1	0	538
ROCKCREEK	MONO		Heard Meadows	Update					11/05/2020		11/06/2020	0300-2100	11/07/2020		11/08/2020		127	1	0	0	0	134
TUFA	MONO		Chinatown ; Mono City ; and Mono Lake	Update					11/05/2020		11/06/2020	0600-0900	11/07/2020		11/08/2020		102	0	3	0	0	105

Rocio M Contreras-Regalado

From: SCEliaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Thursday, November 5, 2020 1:27 PM
To: SCE Liaison Officer
Subject: Important: SCE Update Notice for PSPS Event in Inyo County.
Attachments: SCE+LNO+POC+INYO+2020-11-05-Rpt+1.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Inyo County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Southern California Edison LNO Circuit List with Periods of Concern
As of 11/05/2020 Circuit List All Counties Report #1

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspections.
Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.
Note 3: 12-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.
Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See ce.com/safety/alerts/pags for total customer counts by county.
Note 5: Please refer to Definitions tab for additional information.
Note 6: Any circuits on the list that do not display period of concern times means those circuits have periods of concern that start beyond the time periods shown. Watch for more on subsequent reports.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Reston. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MBL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)
BIRCHIM	INYO		Round Valley ; Scheelite ; Mesa ; West Bishop ; east of Grouse Mountain	Update					11/05/2020	2100-0000	11/06/2020	0000-2100	11/07/2020		11/08/2020		528	4	10	9	2	553
SINKER	INYO		Bishop Creek Road	All Clear					11/05/2020		11/06/2020		11/07/2020		11/08/2020		14	0	0	0	0	14

Everbridge PPS Notification Audit Report 2020-11-05 All Counties Report 2

Notification ID	Message Title	Sent On
626313605939339	Important: SCE Update Notice for PPS Event in Inyo County.	Nov 05, 2020 19:44:38 PST
626313605939347	Important: SCE Update Notice for PPS Event in Mono County.	Nov 05, 2020 19:49:27 PST
626313605939355	Important: SCE Update Notice for PPS Event in San Bernardino County.	Nov 05, 2020 19:55:02 PST
626313605939365	Important: SCE Initial Notice for PPS Event in Tuolumne County on 11-6-20	Nov 05, 2020 20:01:03 PST

Estela Aguilar

From: SCEliaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Thursday, November 5, 2020 7:45 PM
To: Estela Aguilar
Subject: Important: SCE Update Notice for PSPS Event in Inyo County.
Attachments: SCE+LNO+Period+of+Concern+2020-11-03+No+2+Inyo+County.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Inyo County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Southern California Edison LNO Circuit List with Periods of Concern
As of 11/05/2020 Circuit List All Counties Report #1

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspections.
Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.
Note 3: 12-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.
Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See ce.com/safety/alerts/pages for total customer counts by county.
Note 5: Please refer to Definitions tab for additional information.
Note 6: Any circuits on the list that do not display period of concern times means those circuits have periods of concern that start beyond the time periods shown. Watch for more on subsequent reports.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Reston. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MBL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)
BIRCHIM	INYO		Round Valley ; Scheelite ; Mesa ; West Bishop ; east of Grouse Mountain	Update					11/05/2020	2100-0000	11/06/2020	0000-2100	11/07/2020		11/08/2020		528	4	10	9	2	553
SINKER	INYO		Bishop Creek Road	All Clear					11/05/2020		11/06/2020		11/07/2020		11/08/2020		14	0	0	0	0	14

Estela Aguilar

From: SCEliaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Thursday, November 5, 2020 7:50 PM
To: Estela Aguilar
Subject: Important: SCE Update Notice for PSPS Event in Mono County.
Attachments: SCE+LNO+Period+of+Concern+2020-11-03+No+2+Mono+County.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Mono County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Southern California Edison LNO Circuit List with Periods of Concern
As of 11/05/2020 Circuit List All Counties Report #2

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspections.
Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.
Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.
Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See [sce.com/safety/wildfire/paps](https://www.sce.com/safety/wildfire/paps) for total customer counts by county.
Note 5: Please refer to Definitions tab for additional information.
Note 6: Any circuits on the list that do not display period of concern times means those circuits have periods of concern that start beyond the time periods shown. Watch for more on subsequent reports.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Reston. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MBL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)
BAMTA	MONO		Lee Vining ; Lee Vining Canyon	Update					11/05/2020		11/06/2020	0900-1500	11/07/2020		11/08/2020		131	2	13	1	1	148
BROHAM	MONO		Paradise ; Portion of Swall Meadows	Update					11/05/2020		11/06/2020	0000-2100	11/07/2020		11/08/2020		534	4	10	9	2	559
CAJIN RANCH	MONO		Toga Gas Mart ; Pumice Valley	Update					11/05/2020		11/06/2020	0900-1500	11/07/2020		11/08/2020		18	0	4	0	0	22
DYNAMO	MONO		Dunderberg Mill ; Bridgeport Feeder	Update					11/05/2020		11/06/2020	0900-1500	11/07/2020		11/08/2020		1	0	0	0	0	1
GULL LAKE	MONO		June Lake Down Canyon	Update					11/05/2020		11/06/2020	0600-1200	11/07/2020		11/08/2020		361	1	8	3	0	373
REVERSE PEAK	MONO		June Lake Village and Loop ; Crestview	Update					11/05/2020		11/06/2020	0600-1200	11/07/2020		11/08/2020		487	0	46	5	0	538
RHINEDOLLAR	MONO		Upper Lee Vining Canyon ; Tuolumne	Initial					11/05/2020		11/06/2020	0600-1200	11/07/2020		11/08/2020		3	0	26	0	0	29
ROCKCREEK	MONO		Swall Meadows	All Clear					11/05/2020		11/06/2020		11/07/2020		11/08/2020		127	1	6	0	0	134
TUFA	MONO		Chinatown ; Mono City ; and Mono Lake	All Clear					11/05/2020		11/06/2020		11/07/2020		11/08/2020		102	0	3	0	0	105

Rocio M Contreras-Regalado

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Thursday, November 5, 2020 7:55 PM
To: SCE Liaison Officer
Subject: Important: SCE Update Notice for PSPS Event in San Bernardino County.
Attachments: SCE+LNO+Period+of+Concern+2020-11-03+No+2+San+Bernardino+County.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **San Bernardino County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Southern California Edison LNO Circuit List with Periods of Concern
As of 11/05/2020 Circuit List All Counties Report #2

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspections.
Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.
Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.
Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See sce.com/safety/wildfire/paps for total customer counts by county.
Note 5: Please refer to Definitions tab for additional information.
Note 6: Any circuits on the list that do not display period of concern means those circuits have periods of concern that start beyond the time periods shown. Watch for more on subsequent reports.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Reston. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MBL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)
BEAR VALLEY	SAN BERNARDINO		Mill Creek Canyon ; Angelus Oaks ; Pinezanita ; Converse Flats ; Seven Oaks ; Forest Falls	No Change				-	11/05/2020		11/06/2020	0900-1500	11/07/2020		11/08/2020		31	0	0	1	0	32
BEAR VALLEY	SAN BERNARDINO	BIG BEAR LAKE		No Change				-	11/05/2020		11/06/2020	0900-1500	11/07/2020		11/08/2020		31	0	0	1	0	32
CAMP ANGELLUS	SAN BERNARDINO		Angelus Oaks ; Glen Martin	No Change				-	11/05/2020		11/06/2020	0900-1500	11/07/2020		11/08/2020		292	0	8	9	0	309
CUSHENBURY	SAN BERNARDINO		HWY CA 18 between North of Doble and Cushenbury	Update				-	11/05/2020		11/06/2020	0900-1800	11/07/2020		11/08/2020		1	0	2	0	0	3
DOBLE	SAN BERNARDINO		Doble ; Upper Holcomb Valley ; Arroyo Flats ; Furnace Canyon	Update				-	11/05/2020		11/06/2020	0900-1800	11/07/2020		11/08/2020		1	0	1	0	0	2
JENKS LAKE	SAN BERNARDINO		Seven Oaks ; Jenks Meadow ; Jenks Lake ; Barton Hills	No Change				-	11/05/2020		11/06/2020	0900-1500	11/07/2020		11/08/2020		132	0	30	0	0	162
SCOUT	SAN BERNARDINO		Northeast of Fawnskin	Update				-	11/05/2020		11/06/2020	0900-1800	11/07/2020		11/08/2020		4	0	0	0	0	4
SKY HI	SAN BERNARDINO		Lucerne Valley ; Fifteen mile Valley east of Milpas drive ; Crystal Creek N of Gateway Rd ; Cushenbury	Update				-	11/05/2020		11/06/2020	0600-1500	11/07/2020		11/08/2020		1476	0	33	57	32	1598
UTE	SAN BERNARDINO		North of Big Bear ; Apple Valley	Update				-	11/05/2020		11/06/2020	0900-1800	11/07/2020		11/08/2020		UNAVBL	UNAVBL	UNAVBL	UNAVBL	UNAVBL	UNAVBL
WEESHA	SAN BERNARDINO		Pinezanita	No Change				-	11/05/2020		11/06/2020	0900-1500	11/07/2020		11/08/2020		52	0	0	0	0	52

Rocio M Contreras-Regalado

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Thursday, November 5, 2020 8:01 PM
To: SCE Liaison Officer
Subject: Important: SCE Initial Notice for PSPS Event in Tuolumne County on 11-6-20
Attachments: SCE+LNO+Period+of+Concern+2020-11-03+No+2+Tuolumne+County.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to projected weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Tuolumne County**. SCE is also notifying customers on the affected circuits about the potential shutoff, giving them time to prepare.

SCE has opened its Emergency Operations Center and activated an Incident Management Team to monitor the weather and other conditions in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

Please refer to the attached file for status and periods of concern for specific circuits in your county.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: SCE may shut off power on one or more circuits in your area. For more information, visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Southern California Edison LNO Circuit List with Periods of Concern
As of 11/05/2020 Circuit List All Counties Report #2

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspections.
Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.
Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.
Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See sce.com/safety/wildfire/paps for total customer counts by county.
Note 5: Please refer to Definitions tab for additional information.
Note 6: Any circuits on the list that do not display period of concern times means those circuits have periods of concern that start beyond the time periods shown. Watch for more on subsequent reports.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Reston. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MBL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)
RHINEDOLLAR	TUOLUMNE		Moraine Flat ; Tuolumne Meadows ; Dana Meadows	Initial					11/05/2020		11/06/2020	0600-1200	11/07/2020		11/08/2020		3	0	26	0	0	29

Everbridge PPS Notification Audit Report 2020-11-06-1108-All Counties-IMDE

Notification ID	Message Title	Sent On
626313605939925	Important: SCE Imminent De-Energize Notice for PPS Event in San Bernardino County.	Nov 06, 2020 06:50:22 PST
626313605940057	Important: SCE Imminent De-Energize Notice for PPS Event in Mono County.	Nov 06, 2020 08:14:58 PST
626313605940152	Important: SCE Imminent De-Energize Notice for PPS Event in Mono County.	Nov 06, 2020 08:58:31 PST
626588483847089	Important: SCE Imminent De-Energize Notice for PPS Event in Mono County.	Nov 06, 2020 08:59:37 PST
626313605940175	Important: SCE Imminent De-Energize Notice for PPS Event in Mono County.	Nov 06, 2020 09:09:38 PST
626313605940356	Important: SCE Imminent De-Energize Notice for PPS Event in Mono County.	Nov 06, 2020 11:08:56 PST

Rocio M Contreras-Regalado

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Friday, November 6, 2020 6:51 AM
To: SCE Liaison Officer
Subject: Important: SCE Imminent De-Energize Notice for PSPS Event in San Bernardino County.

Follow Up Flag: Follow up
Flag Status: Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit: SKY HI**
- **County: San Bernardino County**
- **Segments 3, 4 and 5 impacted**
- **Unincorporated County Area: Lucerne Valley; Fifteen mile Valley east of Milpas Drive; Crystal Creek N of Gateway Rd; CushnBury**

This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, **if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

Recommended Language to Share with the Public: Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit www.sce.com/PSPS.

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at sce.com/maps.
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at sce.com/PSPS.
- Access SCE's non-PSPS outage information page at sce.com/outages.

- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Rocio M Contreras-Regalado

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Friday, November 6, 2020 8:15 AM
To: SCE Liaison Officer
Subject: Important: SCE Imminent De-Energize Notice for PSPS Event in Mono County.

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit: TUFA**
- **County: Mono County**
- **Segment 2 impacted**
 - **Circuit segments may be viewed at sce.com/psps and maps downloaded at sce.com/maps.**
- **Unincorporated County Area: Chinatown ; Mono City ; and Mono Lake**

This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, **if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

Recommended Language to Share with the Public: Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit www.sce.com/PSPS.

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at sce.com/maps.
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at sce.com/PSPS.
- Access SCE's non-PSPS outage information page at sce.com/outages.
- Access information on weather conditions at sce.com/fireweather.
- SCE's post-PSPS reports are available at sce.com/psps.

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Rocio M Contreras-Regalado

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Friday, November 6, 2020 8:59 AM
To: SCE Liaison Officer
Subject: Important: SCE Imminent De-Energize Notice for PSPS Event in Mono County.

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit: DYNAMO**
- **County: Mono County**
- **Segment: Segment 1**
- **Unincorporated County Area: Dunderberg Mill ; Bridgeport Feeder**

Circuit segments may be viewed at [sce.com/pmps](https://www.sce.com/pmps) and maps downloaded at [sce.com/maps](https://www.sce.com/maps).

This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, **if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

Recommended Language to Share with the Public: Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit www.sce.com/PSPS.

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).

- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Rocio M Contreras-Regalado

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Friday, November 6, 2020 9:00 AM
To: SCE Liaison Officer
Subject: Important: SCE Imminent De-Energize Notice for PSPS Event in Mono County.

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit: CONWAY**
- **County: Mono**
- **Segment: All segments**
- **Unincorporated County Area: North Conway ; Willow Springs ; Bridgeport Feeder**

Circuit segments may be viewed at [sce.com/pmps](https://www.sce.com/pmps) and maps downloaded at [sce.com/maps](https://www.sce.com/maps).

This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, **if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

Recommended Language to Share with the Public: Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit www.sce.com/PSPS.

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).

- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Rocio M Contreras-Regalado

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Friday, November 6, 2020 9:10 AM
To: SCE Liaison Officer
Subject: Important: SCE Imminent De-Energize Notice for PSPS Event in Mono County.

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit: ROBINSON CREEK**
- **County: Mono County**
- **Segment: Segment 2**
- **Unincorporated County Area: Bridgeport Valley to Twin Lakes**

Circuit segments may be viewed at [sce.com/pmps](https://www.sce.com/pmps) and maps downloaded at [sce.com/maps](https://www.sce.com/maps).

This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, **if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

Recommended Language to Share with the Public: Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit www.sce.com/PSPS.

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).

- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Rocio M Contreras-Regalado

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Friday, November 6, 2020 11:09 AM
To: SCE Liaison Officer
Subject: Important: SCE Imminent De-Energize Notice for PSPS Event in Mono County.

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit: REVERSE PEAK**
- **County: Mono**
- **Segment: Segment 1**
- **Unincorporated County Area: June Lake Village and Loop ; Crestview**

- **Circuit: CAIN RANCH**
- **County: Mono**
- **Segment: All Segments**
- **Unincorporated County Area: Tioga Gas Mart ; Pumice Valley**

Circuit segments may be viewed at [sce.com/psps](https://www.sce.com/psps) and maps downloaded at [sce.com/maps](https://www.sce.com/maps).

This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, **if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

Recommended Language to Share with the Public: Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit www.sce.com/PSPS.

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at sce.com/maps.
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at sce.com/PSPS.
- Access SCE's non-PSPS outage information page at sce.com/outages.
- Access information on weather conditions at sce.com/fireweather.
- SCE's post-PSPS reports are available at sce.com/pmps.

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - sce.com/PSPS is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at sce.com/pmpsalerts.

Everbridge PPS Notification Audit Report 2020-11-06-1315-DE

Notification ID	Message Title	Sent On
626313605940363	Important: SCE De-Energize Notice for PPS Event in Mono County at 10:54am on 11/6/2020.	Nov 06, 2020 11:15:18 PST
626313605940555	Important: SCE De-Energize Notice for PPS Event in San Bernardino County at 12:24 & 12:30 on 11/6/2020.	Nov 06, 2020 13:09:59 PST
626313605940574	Important: SCE De-Energize Notice for PPS Event in Mono County] at 1253 on 11/06/2020.	Nov 06, 2020 13:15:10 PST

Rocio M Contreras-Regalado

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Friday, November 6, 2020 11:16 AM
To: SCE Liaison Officer
Subject: Important: SCE De-Energize Notice for PSPS Event in Mono County at 10:54am on 11/6/2020.

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to weather conditions, SCE conducted a Public Safety Power Shutoff (PSPS) to circuits in your county. Impacted circuits and locations are:

- **Circuit: TUFA**
- **County: Mono County**
- **Segment: Segment 2**
- **Unincorporated County Area: Chinatown ; Mono City ; and Mono Lake**
- **De-Energized Date: 11/06/2020**
- **De-Energized Time: 10:54am**

Circuit segments may be viewed at [sce.com/psps](https://www.sce.com/psps) and maps downloaded at [sce.com/maps](https://www.sce.com/maps).

SCE is also notifying customers on the affected circuits to inform them about the shutoff. SCE understands the inconvenience of shutting off electric service. Safety is SCE's first priority. This Public Safety Power Shutoff (PSPS) action was taken with the safety of our customers and the public in mind, and to maintain the integrity of the electric system for all of our customers.

SCE has an Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe.

Power will be restored as weather conditions improve, crews conduct inspections, any necessary repairs have been made, and we determine it is safe to re-energize lines. In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

Recommended Language to Share with the Public: Due to current weather conditions, SCE has shut off power in your area. Check your email for details and visit www.sce.com/PSPS.

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).

- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Rocio M Contreras-Regalado

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Friday, November 6, 2020 1:10 PM
To: SCE Liaison Officer
Subject: Important: SCE De-Energize Notice for PSPS Event in San Bernardino County at 12:24 & 12:30 on 11/6/2020.

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to weather conditions, SCE conducted a Public Safety Power Shutoff (PSPS) to circuits in your county. Impacted circuit(s) and location(s) are:

- **Circuit: SKY HI**
- **County: San Bernardino County**
- **Segments: 4**
- **Unincorporated County Area: Lucerne Valley ; Fifteen mile Valley east of Milpas drive ; Crystal Creek N of Gateway Rd ; CushenBury**
- **De-Energized Date: 11/6/2020**
- **De-Energized Time: 12:24 & 12:30**

Circuit segments may be viewed at [sce.com/psps](https://www.sce.com/psps) and maps downloaded at [sce.com/maps](https://www.sce.com/maps).

SCE is also notifying customers on the affected circuits to inform them about the shutoff. SCE understands the inconvenience of shutting off electric service. Safety is SCE's first priority. This Public Safety Power Shutoff (PSPS) action was taken with the safety of our customers and the public in mind, and to maintain the integrity of the electric system for all of our customers.

SCE has an Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe.

Power will be restored as weather conditions improve, crews conduct inspections, any necessary repairs have been made, and we determine it is safe to re-energize lines. In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

Recommended Language to Share with the Public: Due to current weather conditions, SCE has shut off power in your area. Check your email for details and visit www.sce.com/PSPS.

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).

- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Rocio M Contreras-Regalado

From: SCEliaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Friday, November 6, 2020 1:15 PM
To: SCE Liaison Officer
Subject: Important: SCE De-Energize Notice for PSPS Event in Mono County] at 1253 on 11/06/2020.

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to weather conditions, SCE conducted a Public Safety Power Shutoff (PSPS) to circuits in your county. Impacted circuits and locations are:

- **Circuit: ROBINSON CREEK**
- **County: Mono**
- **Segment: Segment 2**
- **Unincorporated County Area: Bridgeport Valley to Twin Lakes**
- **De-Energized Date: 11/06/2020**
- **De-Energized Time: 1253**

Circuit segments may be viewed at [sce.com/psps](https://www.sce.com/psps) and maps downloaded at [sce.com/maps](https://www.sce.com/maps).

SCE is also notifying customers on the affected circuits to inform them about the shutoff. SCE understands the inconvenience of shutting off electric service. Safety is SCE's first priority. This Public Safety Power Shutoff (PSPS) action was taken with the safety of our customers and the public in mind, and to maintain the integrity of the electric system for all of our customers.

SCE has an Incident Management Team (IMT) in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe.

Power will be restored as weather conditions improve, crews conduct inspections, any necessary repairs have been made, and we determine it is safe to re-energize lines. In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

Recommended Language to Share with the Public: Due to current weather conditions, SCE has shut off power in your area. Check your email for details and visit www.sce.com/PSPS.

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).

- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Notification ID	Message Title	Sent On
626313605940459	Important: SCE Imminent De-Energize Notice for PSPS Event in Mono County.	Nov 06, 2020 12:16:34 PST
626313605940510	Important: SCE Imminent De-Energize Notice for PSPS Event in Mono County.	Nov 06, 2020 12:51:02 PST
626313605940687	Important: SCE Imminent De-Energize Notice for PSPS Event in San Bernardino County.	Nov 06, 2020 14:51:38 PST
626313605940721	Important: SCE Imminent De-Energize Notice for PSPS Event in Inyo County.	Nov 06, 2020 15:13:33 PST
626313605940725	Important: SCE Imminent De-Energize Notice for PSPS Event in Mono County.	Nov 06, 2020 15:17:11 PST

Rocio M Contreras-Regalado

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Friday, November 6, 2020 12:17 PM
To: SCE Liaison Officer
Subject: Important: SCE Imminent De-Energize Notice for PSPS Event in Mono County.

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit: STROSNIDER**
- **County: Mono**
- **Segment: All Segments**
- **Unincorporated County Area: Bridgeport City**

Circuit segments may be viewed at [sce.com/psps](https://www.sce.com/psps) and maps downloaded at [sce.com/maps](https://www.sce.com/maps).

This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, **if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

Recommended Language to Share with the Public: Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit www.sce.com/PSPS.

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).

- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Rocio M Contreras-Regalado

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Friday, November 6, 2020 12:51 PM
To: SCE Liaison Officer
Subject: Important: SCE Imminent De-Energize Notice for PSPS Event in Mono County.

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit: PICKLE MEADOWS**
- **County: Mono County**
- **Segment: All Segments**
- **Unincorporated County Area: Bridgeport Valley to Pickle Meadows**

Circuit segments may be viewed at [sce.com/pmps](https://www.sce.com/pmps) and maps downloaded at [sce.com/maps](https://www.sce.com/maps).

This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, **if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

Recommended Language to Share with the Public: Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit www.sce.com/PSPS.

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).

- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Rocio M Contreras-Regalado

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Friday, November 6, 2020 2:52 PM
To: SCE Liaison Officer
Subject: Important: SCE Imminent De-Energize Notice for PSPS Event in San Bernardino County.

Follow Up Flag: Follow up
Flag Status: Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit: CAMPANULA**
- **County: San Bernardino County**
- **Segment: All Segments**
- **Incorporated City of: Yucca Valley**
- **Unincorporated: Rim Rock**

- **Circuit: PIONEERTOWN**
- **County: San Bernardino County**
- **Segment: Segment 6**
- **Incorporated City of: Yucca Valley**
- **Unincorporated: Pioneertown**

- **Circuit segments may be viewed at [sce.com/psps](https://www.sce.com/psps) and maps downloaded at [sce.com/maps](https://www.sce.com/maps).**

This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, **if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

Recommended Language to Share with the Public: Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit www.sce.com/PSPS.

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at sce.com/maps.
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at sce.com/PSPS.
- Access SCE's non-PSPS outage information page at sce.com/outages.
- Access information on weather conditions at sce.com/fireweather.
- SCE's post-PSPS reports are available at sce.com/pspss.

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - sce.com/PSPS is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at sce.com/pspsalerts.

Rocio M Contreras-Regalado

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Friday, November 6, 2020 3:14 PM
To: SCE Liaison Officer
Subject: Important: SCE Imminent De-Energize Notice for PSPS Event in Inyo County.

Follow Up Flag: Follow up
Flag Status: Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit: BIRCHIM**
- **County: Inyo County**
- **Segment: Segments 4**
- **Unincorporated County Area: Round Valley ; Scheelite ; Mesa ; West Bishop ; east of Grouse Mountain**

Circuit segments may be viewed at [sce.com/psps](https://www.sce.com/psps) and maps downloaded at [sce.com/maps](https://www.sce.com/maps).

This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, **if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

Recommended Language to Share with the Public: Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit www.sce.com/PSPS.

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at sce.com/maps.
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at sce.com/PSPS.
- Access SCE's non-PSPS outage information page at sce.com/outages.
- Access information on weather conditions at sce.com/fireweather.
- SCE's post-PSPS reports are available at sce.com/pspss.

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - sce.com/PSPS is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at sce.com/pspsalerts.

Rocio M Contreras-Regalado

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Friday, November 6, 2020 3:17 PM
To: SCE Liaison Officer
Subject: Important: SCE Imminent De-Energize Notice for PSPS Event in Mono County.

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit: BIRCHIM**
- **County: Mono County**
- **Segment: Segment 4**
- **Unincorporated County Area: Paradise ; Portion of Swall Meadows**

Circuit segments may be viewed at [sce.com/pmps](https://www.sce.com/pmps) and maps downloaded at [sce.com/maps](https://www.sce.com/maps).

This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, **if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

Recommended Language to Share with the Public: Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit www.sce.com/PSPS.

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).

- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Everbridge PSPS Notification Audit Report 2020-11-06-1550-Mono County-IMRE

Notification ID	Message Title	Sent On
626313605940765	Important: SCE Imminent Re-Energize Notice for PSPS Event in Mono County.	Nov 06, 2020 15:50:15 PST

Rocio M Contreras-Regalado

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Friday, November 6, 2020 3:50 PM
To: SCE Liaison Officer
Subject: Important: SCE Imminent Re-Energize Notice for PSPS Event in Mono County.

Follow Up Flag: Follow up
Flag Status: Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have completed inspections, made any necessary repairs, and determined it is safe to begin **RE-ENERGIZING** the following circuit(s) or segments of circuit(s):

- **Circuit: STROSNIDER**
- **County: Mono County**
- **Segment: All Segments**
- **Unincorporated County Area: Bridgeport City**

Circuit segments may be viewed at [sce.com/psps](https://www.sce.com/psps) and maps downloaded at [sce.com/maps](https://www.sce.com/maps).

SCE will also begin notifying customers that power will be turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working safely and as quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

Recommended Language to Share with the Public: SCE will begin turning power back on in your area. SCE has inspected its electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Everbridge PPS Notification Audit Report 2020-11-06-1604-DE

Notification ID	Message Title	Sent On
626313605940746	Important: SCE De-Energize Notice for PPS Event in STROSNIDER at 1309 on 11/06/2020.	Nov 06, 2020 15:33:31 PST
626313605940782	Important: SCE De-Energize Notice for PPS Event in San Bernardino at 1505 on 11/6/2020.	Nov 06, 2020 16:04:51 PST

Rocio M Contreras-Regalado

From: SCEliaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Friday, November 6, 2020 3:34 PM
To: SCE Liaison Officer
Subject: Important: SCE De-Energize Notice for PSPS Event in STROSNIDER at 1309 on 11/06/2020.

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to weather conditions, SCE conducted a Public Safety Power Shutoff (PSPS) to circuits in your county. Impacted circuits and locations are:

- **Circuit: STROSNIDER**
- **County: Mono County**
- **Segment: All Segments**
- **Unincorporated County Area: Bridgeport City**

Circuit segments may be viewed at [sce.com/psps](https://www.sce.com/psps) and maps downloaded at [sce.com/maps](https://www.sce.com/maps).

SCE is also notifying customers on the affected circuits to inform them about the shutoff. SCE understands the inconvenience of shutting off electric service. Safety is SCE's first priority. This Public Safety Power Shutoff (PSPS) action was taken with the safety of our customers and the public in mind, and to maintain the integrity of the electric system for all of our customers.

SCE has an Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe.

Power will be restored as weather conditions improve, crews conduct inspections, any necessary repairs have been made, and we determine it is safe to re-energize lines. In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

Recommended Language to Share with the Public: Due to current weather conditions, SCE has shut off power in your area. Check your email for details and visit www.sce.com/PSPS.

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).

- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Rocio M Contreras-Regalado

From: SCEliaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Friday, November 6, 2020 4:05 PM
To: SCE Liaison Officer
Subject: Important: SCE De-Energize Notice for PSPS Event in San Bernardino at 1505 on 11/6/2020.

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to weather conditions, SCE conducted a Public Safety Power Shutoff (PSPS) to circuits in your county. Impacted circuits and locations are:

- **Circuit: CAMPANULA**
- **County: San Bernardino**
- **Segment: Segments 2&4**
- **Incorporated City of: Yucca Valley**
- **Unincorporated County Area: Rim Rock; Campanula**
- **De-Energized Date: 11/06/2020**
- **De-Energized Time: 1505**

Circuit segments may be viewed at [sce.com/psps](https://www.sce.com/psps) and maps downloaded at [sce.com/maps](https://www.sce.com/maps).

SCE is also notifying customers on the affected circuits to inform them about the shutoff. SCE understands the inconvenience of shutting off electric service. Safety is SCE's first priority. This Public Safety Power Shutoff (PSPS) action was taken with the safety of our customers and the public in mind, and to maintain the integrity of the electric system for all of our customers.

SCE has an Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe.

Power will be restored as weather conditions improve, crews conduct inspections, any necessary repairs have been made, and we determine it is safe to re-energize lines. In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

Recommended Language to Share with the Public: Due to current weather conditions, SCE has shut off power in your area. Check your email for details and visit www.sce.com/PSPS.

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).

- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Everbridge PSPS Notification Audit Report 2020-11-06-1645-Mono County-RE

Notification ID	Message Title	Sent On
626313605940829	Important: SCE Re-Energize Notice for PSPS Event in Mono County.	Nov 06, 2020 16:45:38 PST

Rocio M Contreras-Regalado

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Friday, November 6, 2020 4:46 PM
To: SCE Liaison Officer
Subject: Important: SCE Re-Energize Notice for PSPS Event in Mono County.

Follow Up Flag: Follow up
Flag Status: Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- **Circuit: STROSNIDER**
- **County: Mono County**
- **Segment: All Segments**
- **Unincorporated County Area: Bridgeport City**
- **Re-Energized Date: 11/06/2020**
- **Re-Energized Time: 1621**

Circuit segments may be viewed at [sce.com/psps](https://www.sce.com/psps) and maps downloaded at [sce.com/maps](https://www.sce.com/maps).

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

Recommended Language to Share with the Public: SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).

- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Everbridge PSPS Notification Audit Report 2020-11-06-2004 All Counties Report 2

Notification ID	Message Title	Sent On
626313605941002	Important: SCE Update Notice for PSPS Event in Inyo County.	Nov 06, 2020 19:51:51 PST
626313605941009	Important: SCE Update Notice for PSPS Event in Mono County.	Nov 06, 2020 19:55:13 PST
626313605941014	Important: SCE Update Notice for PSPS Event in Mono County.	Nov 06, 2020 19:59:30 PST
626313605941022	Important: SCE Update Notice for PSPS Event in San Bernardino County.	Nov 06, 2020 20:04:13 PST

From: SCELiaisonOfficer@sce.com
To: [SCE Liaison Officer](#)
Subject: Important: SCE Update Notice for PSPS Event in Inyo County.
Date: Friday, November 6, 2020 7:53:40 PM
Attachments: [SCE+LNO+Period+of+Concern+2020-11-06+No+2+Inyo+County.xlsx](#)

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Inyo County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit sce.com/PSPS.

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at sce.com/maps.
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at sce.com/PSPS.
- Access SCE's non-PSPS outage information page at sce.com/outages.
- Access information on weather conditions at sce.com/fireweather.
- SCE's post-PSPS reports are available at sce.com/psps.

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.

- [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
- Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Southern California Edison LNO Circuit List with Periods of Concern
As of 11/06/2020 Circuit List All Counties Report #2

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspections.
Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.
Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.
Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See sce.com/safety/wildfire/pags for total customer counts by county.
Note 5: Please refer to Definitions tab for additional information.
Note 6: Any circuits on the list that do not display period of concern times means those circuits have periods of concern that start beyond the time periods shown. Watch for more on subsequent reports.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MBL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)
BIRCHIM	INYO		Round Valley ; Scheelite ; Mesa ; West Bishop ; east of Grouse Mountain	No Change					11/06/2020	0900-2100	11/07/2020		11/08/2020		11/09/2020		535	4	10	9	2	560

Jeffrey 1 Lee

From: SCEliaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Friday, November 6, 2020 7:55 PM
To: SCE Liaison Officer
Subject: Important: SCE Update Notice for PSPS Event in Mono County.

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Mono County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

From: SCELiaisonOfficer@sce.com
To: [SCE Liaison Officer](#)
Subject: Important: SCE Update Notice for PSPS Event in Mono County.
Date: Friday, November 6, 2020 8:01:36 PM
Attachments: [SCE+LNO+Period+of+Concern+2020-11-06+No+2+Mono+County.xlsx](#)

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Update including POC attachment

Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Mono County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas

designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your**

residents on your website or social media.

- 800-611-1911 is for outage-specific Customer Service issues.
- 800-684-8123 is for all other billing and service inquiries.
- [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
- Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Southern California Edison LNO Circuit List with Periods of Concern
As of 11/06/2020 Circuit List All Counties Report #2

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspections.
Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.
Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.
Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See sce.com/safety/wildfire/psps for total customer counts by county.
Note 5: Please refer to Definitions tab for additional information.
Note 6: Any circuits on the list that do not display period of concern times means those circuits have periods of concern that start beyond the time periods shown. Watch for more on subsequent reports.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MBL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)
BANTA	MONO		Lee Vining ; Lee Vining Canyon	All Clear					11/06/2020		11/07/2020		11/08/2020		11/09/2020		131	2	13	1	1	148
BIRCHIM	MONO		Paradise ; Portion of Swall Meadows	No Change					11/06/2020	0900-2100	11/07/2020		11/08/2020		11/09/2020		535	4	10	9	2	560
CAIN RANCH	MONO		Tioga Gas Mart ; Pumice Valley	All Clear					11/06/2020		11/07/2020		11/08/2020		11/09/2020		18	0	4	0	0	22
CONWAY	MONO		North Conway; Willow Springs; Bridgeport Feeder	All Clear					11/06/2020		11/07/2020		11/08/2020		11/09/2020							
DYNAMO	MONO		Dunderberg Mill ; Bridgeport Feeder	All Clear					11/06/2020		11/07/2020		11/08/2020		11/09/2020		1	0	0	0	0	1
GULL LAKE	MONO		June Lake Down Canyon	All Clear					11/06/2020		11/07/2020		11/08/2020		11/09/2020		361	1	8	3	0	373
PICKLE MEADOWS	MONO		Bridgeport Valley to Pickle Meadows	All Clear					11/06/2020		11/07/2020		11/08/2020		11/09/2020							
REVERSE PEAK	MONO		June Lake Village and Loop ; Crestview	All Clear					11/06/2020		11/07/2020		11/08/2020		11/09/2020		487	0	46	5	0	538
TUFA	MONO		Chinatown ; Mono City ; and Mono Lake	All Clear					11/06/2020		11/07/2020		11/08/2020		11/09/2020		103	0	3	0	0	106

From: SCELiaisonOfficer@sce.com
To: [SCE Liaison Officer](#)
Subject: Important: SCE Update Notice for PSPS Event in San Bernardino County.
Date: Friday, November 6, 2020 8:09:16 PM
Attachments: [SCE+LNO+Period+of+Concern+2020-11-06+No+2+San+Bernardino+County.xlsx](#)

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **San Bernardino County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit sce.com/PSPS.

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at sce.com/maps.
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at sce.com/PSPS.
- Access SCE's non-PSPS outage information page at sce.com/outages.
- Access information on weather conditions at sce.com/fireweather.
- SCE's post-PSPS reports are available at sce.com/psps.

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.

- [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
- Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Southern California Edison LNO Circuit List with Periods of Concern
As of 11/06/2020 Circuit List All Counties Report #2

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspections.
Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.
Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.
Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See sce.com/safety/wildfire/pags for total customer counts by county.
Note 5: Please refer to Definitions tab for additional information.
Note 6: Any circuits on the list that do not display period of concern times means those circuits have periods of concern that start beyond the time periods shown. Watch for more on subsequent reports.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MBL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)
BEAR VALLEY	SAN BERNARDINO		Mill Creek Canyon ; Angelus Oaks ; Pinezanita ; Converse Flats ; Seven Oaks ; Forest Falls	All Clear					11/06/2020		11/07/2020		11/08/2020		11/09/2020		31	0	0	1	0	32
BEAR VALLEY	SAN BERNARDINO	BIG BEAR LAKE		All Clear					11/06/2020		11/07/2020		11/08/2020		11/09/2020		31	0	0	1	0	32
CAMP ANGELUS	SAN BERNARDINO		Angelus Oaks ; Glen Martin	All Clear					11/06/2020		11/07/2020		11/08/2020		11/09/2020		292	0	8	9	0	309
DOBIE	SAN BERNARDINO		Dobie ; Upper Holcomb Valley ; Arrastre Flats ; Furnace Canyon	Update					11/06/2020	1500-1800	11/07/2020		11/08/2020		11/09/2020		1	0	1	0	0	2
JENKS LAKE	SAN BERNARDINO		Seven Oaks ; Jenks Meadow ; Jenks Lake ; Barton Hills	All Clear					11/06/2020		11/07/2020		11/08/2020		11/09/2020		132	0	10	0	0	142
PIONEERTOWN	SAN BERNARDINO	YUCCA VALLEY	Pioneertown	All Clear					11/06/2020		11/07/2020		11/08/2020		11/09/2020							
SCOUT	SAN BERNARDINO		Northeast of Fawnskin	Update					11/06/2020	1500-1800	11/07/2020		11/08/2020		11/09/2020		4	0	0	0	0	4
SKY HI	SAN BERNARDINO		Lucerne Valley ; Fifteen mile Valley east of Milpas drive ; Crystal Creek N of Gateway Rd ; Cushenbury	Update					11/06/2020	1500-1800	11/07/2020		11/08/2020		11/09/2020		1478	0	33	57	32	1600
UTE	SAN BERNARDINO		North of Big Bear ; Apple Valley	Update					11/06/2020	1500-1800	11/07/2020		11/08/2020		11/09/2020		UNAVBL	UNAVBL	UNAVBL	UNAVBL	UNAVBL	UNAVBL
WEESHA	SAN BERNARDINO		Pinezanita	All Clear					11/06/2020		11/07/2020		11/08/2020		11/09/2020		52	0	0	0	0	52

Everbridge PPS Notification Audit Report 2020-11-06-2231 All Counties-RE

Notification ID	Message Title	Sent On
626313605940986	Important: SCE Re-Energize Notice for PPS Event in Mono County	Nov 06, 2020 19:09:12 PST
626313605940974	Important: SCE Re-Energize Notice for PPS Event in Mono County	Nov 06, 2020 19:20:46 PST
626313605941121	Important: SCE Re-Energize Notice for PPS Event in San Bernardino County	Nov 06, 2020 22:31:23 PST

From: SCELiaisonOfficer@sce.com
To: [SCE Liaison Officer](#)
Subject: Important: SCE Re-Energize Notice for PSPS Event in Mono County
Date: Friday, November 6, 2020 7:09:55 PM

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- **Circuit: TUFA**
- **County: Mono County**
- **Segment: Segment 2**
- **Unincorporated County Area: Chinatown; Mono City; and Mono Lake**
- **Re-Energized Date: 11/6/2020**
- **Re-Energized Time: 18:35**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

Recommended Language to Share with the Public: SCE is turning the power back

on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.

sce.com/PSPS is the site where customers may learn more about PSPS events in their area.

- Update customer contact information at sce.com/pspsalerts.

From: SCELiaisonOfficer@sce.com
To: [SCE Liaison Officer](#)
Subject: Important: SCE Re-Energize Notice for PSPS Event in Mono County
Date: Friday, November 6, 2020 7:22:00 PM

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- **Circuit: ROBINSON CREEK**
- **County: Mono County**
- **Segment: Segment 2**
- **Unincorporated County Area: Bridgeport Valley to Twin Lakes**
- **Re-Energized Date: 11/06/2020**
- **Re-Energized Time: 1824**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

Recommended Language to Share with the Public: SCE is turning the power back

on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.

sce.com/PSPS is the site where customers may learn more about PSPS events in their area.

- Update customer contact information at sce.com/pspsalerts.

From: SCELiaisonOfficer@sce.com
To: [SCE Liaison Officer](#)
Subject: Important: SCE Re-Energize Notice for PSPS Event in San Bernardino County
Date: Friday, November 6, 2020 10:31:55 PM

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- **Circuit: CAMPANULA**
- **County: San Bernardino County**
- **Segment: Segments 2&4**
- **Incorporated City of: Yucca Valley**
- **Unincorporated County Area: Rim Rock; Campanula**
- **Re-Energized Date: 11/06/20**
- **Re-Energized Time: 22:12**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

Recommended Language to Share with the Public: SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.

800-684-8123 is for all other billing and service inquiries.

- sce.com/PSPS is the site where customers may learn more about PSPS events in their area.
- Update customer contact information at sce.com/pspsalerts.

Notification ID	Message Title	Sent On
626313605940052	Important: SCE Update Notice for PPS Event in Mono County.	Nov 06, 2020 08:07:24 PST
626313605940060	Important: SCE Update Notice for PPS Event in Inyo County.	Nov 06, 2020 08:17:22 PST
626313605940065	Important: SCE Update Notice for PPS Event in San Bernardino County.	Nov 06, 2020 08:19:58 PST
626313605940074	Important: SCE Update Notice for PPS Event in Tuolumne County.	Nov 06, 2020 08:23:34 PST

Rocio M Contreras-Regalado

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Friday, November 6, 2020 8:08 AM
To: SCE Liaison Officer
Subject: Important: SCE Update Notice for PSPS Event in Mono County.
Attachments: SCE+LNO+POC+MONO+2020-11-06-Rpt+1.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Mono County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Southern California Edison LNO Circuit List with Periods of Concern
As of 11/06/2020 Circuit List All Counties Report #1

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspections.
Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.
Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.
Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See sce.com/safety/wildfire/paps for total customer counts by county.
Note 5: Please refer to definitions tab for additional information.
Note 6: Any circuits on the list that do not display period of concern times means those circuits have periods of concern that start beyond the time periods shown. Watch for more on subsequent reports.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MIL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)
BANTA	MONO		Lee Vining ; Lee Vining Canyon	No Change					11/06/2020	0900-1500	11/07/2020		11/08/2020		11/09/2020		131	2	13	1	1	148
BIRCHM	MONO		Paradise ; Portion of Swall Meadows	Update					11/06/2020	0900-2100	11/07/2020		11/08/2020		11/09/2020		6	0	0	0	0	6
CAIN RANCH	MONO		Tioga Gas Mart ; Pumice Valley	No Change					11/06/2020	0900-1500	11/07/2020		11/08/2020		11/09/2020		18	0	4	0	0	22
DYNAMO	MONO		Dunderberg Mill ; Bridgeport Feeder	Update					11/06/2020	0900-1500	11/07/2020		11/08/2020		11/09/2020		1	0	0	0	0	1
GULL LAKE	MONO		June Lake Down Canyon	Update					11/06/2020	0600-1500	11/07/2020		11/08/2020		11/09/2020		361	1	8	3	0	373
REVERSE PEAK	MONO		June Lake Village and Loop ; Crestview	Update					11/06/2020	0600-1500	11/07/2020		11/08/2020		11/09/2020		487	0	46	5	0	538
RHINEDOLLAR	MONO		Upper Lee Vining Canyon ; Tooluine	All Clear					11/06/2020		11/07/2020		11/08/2020		11/09/2020		3	0	26	0	0	29
TUFA	MONO		Christown ; Mono City ; and Mono Lake	Initial					11/06/2020	0600-1500	11/07/2020		11/08/2020		11/09/2020		103	0	3	0	0	106

Rocio M Contreras-Regalado

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Friday, November 6, 2020 8:18 AM
To: SCE Liaison Officer
Subject: Important: SCE Update Notice for PSPS Event in Inyo County.
Attachments: SCE+LNO+POC+INYO+2020-11-06-Rpt+1.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Inyo County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Southern California Edison LNO Circuit List with Periods of Concern
As of 11/06/2020 Circuit List All Counties Report #1

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspections.
Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.
Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.
Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See sce.com/safety/wildfire/paps for total customer counts by county.
Note 5: Please refer to Definitions tab for additional information.
Note 6: Any circuits on the list that do not display period of concern times means those circuits have periods of concern that start beyond the time periods shown. Watch for more on subsequent reports.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MIL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)
BIRCHM	INYO		Round Valley ; Scheelite ; Mesa ; West Bishop ; east of Grouse Mountain	Update					11/06/2020	0900-2100	11/07/2020		11/08/2020		11/09/2020		528	4	10	9	2	553

Rocio M Contreras-Regalado

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Friday, November 6, 2020 8:20 AM
To: SCE Liaison Officer
Subject: Important: SCE Update Notice for PSPS Event in San Bernardino County.
Attachments: SCE+LNO+POC+SAN+BERNARDINO+2020-11-06-Rpt+1.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **San Bernardino County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Southern California Edison LNO Circuit List with Periods of Concern
As of 11/06/2020 Circuit List All Counties Report #1

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspections.
Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.
Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.
Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See sca.com/safety/wildfire/paps for total customer counts by county.
Note 5: Please refer to Definitions tab for additional information.
Note 6: Any circuits on the list that do not display period of concern times means those circuits have periods of concern that start beyond the time periods shown. Watch for more on subsequent reports.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MBL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)
BEAR VALLEY	SAN BERNARDINO		Mill Creek Canyon ; Angelus Oaks ; Pinesanita ; Converse Flats ; Seven Oaks ; Forest Falls	No Change					11/06/2020	0900-1500	11/07/2020		11/08/2020		11/09/2020		31	0	0	1	0	32
BEAR VALLEY	SAN BERNARDINO	BIG BEAR LAKE		No Change					11/06/2020	0900-1500	11/07/2020		11/08/2020		11/09/2020		31	0	0	1	0	32
CAMP ANGELLUS	SAN BERNARDINO		Angelus Oaks ; Glen Martin	No Change					11/06/2020	0900-1500	11/07/2020		11/08/2020		11/09/2020		292	0	8	9	0	309
CUSHENBURY	SAN BERNARDINO		HWY CA 18 between North of Double and Cushenbury	All Clear					11/06/2020		11/07/2020		11/08/2020		11/09/2020		1	0	2	0	0	3
DOBLE	SAN BERNARDINO		Double ; Upper Holcomb Valley ; Arroyo Flats ; Furnace Canyon	Update					11/06/2020	0900-2100	11/07/2020		11/08/2020		11/09/2020		1	0	1	0	0	2
JENKS LAKE	SAN BERNARDINO		Seven Oaks ; Jenks Meadow ; Jenks Lake ; Barton Hills	No Change					11/06/2020	0900-1500	11/07/2020		11/08/2020		11/09/2020		132	0	10	0	0	142
SCOUT	SAN BERNARDINO		Northeast of Fawnskin	Update					11/06/2020	0900-2100	11/07/2020		11/08/2020		11/09/2020		4	0	0	0	0	4
SKY HI	SAN BERNARDINO		Lucerne Valley ; Fifteen mile Valley east of Millgas drive ; Crystal Creek N of Gateway Rd ; Cushenbury	Imminent De-Energized					11/06/2020	0900-1500	11/07/2020		11/08/2020		11/09/2020		1478	0	33	57	32	1600
UTE	SAN BERNARDINO		North of Big Bear ; Apple Valley	Update					11/06/2020	0900-2100	11/07/2020		11/08/2020		11/09/2020		UNAVBL	UNAVBL	UNAVBL	UNAVBL	UNAVBL	UNAVBL
WEESHA	SAN BERNARDINO		Pinesanita	No Change					11/06/2020	0900-1500	11/07/2020		11/08/2020		11/09/2020		52	0	0	0	0	52

Rocio M Contreras-Regalado

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Friday, November 6, 2020 8:24 AM
To: SCE Liaison Officer
Subject: Important: SCE Update Notice for PSPS Event in Tuolumne County.
Attachments: SCE+LNO+POC+TUOLUMNE+2020-11-06-Rpt+1.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Tuolumne County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Southern California Edison LNO Circuit List with Periods of Concern
As of 11/06/2020 Circuit List All Counties Report #1

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspections.
Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.
Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.
Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See sce.com/safety/wildfire/paps for total customer counts by county.
Note 5: Please refer to Definitions tab for additional information.
Note 6: Any circuits on the list that do not display period of concern times means those circuits have periods of concern that start beyond the time periods shown. Watch for more on subsequent reports.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MIL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)
RHINEDOLLAR	TUOLUMNE		Moraine Flat ; Tuolumne Meadows ; Dana Meadows	All Clear					11/06/2020		11/07/2020		11/08/2020		11/09/2020		3	0	26	0	0	29

Everbridge PSPS Notification Audit Report 2020-11-07-0830 San Bernardino County-IMRE

Notification ID	Message Title	Sent On
626588483848693	Important: SCE Imminent Re-Energize Notice for PSPS Event in San Bernardino County	Nov 07, 2020 08:30:20 PST

From: SCELiaisonOfficer@sce.com
To: [SCE Liaison Officer](#)
Subject: Important: SCE Imminent Re-Energize Notice for PSPS Event in San Bernardino County
Date: Saturday, November 7, 2020 8:31:22 AM
Importance: High

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have completed inspections, made any necessary repairs, and determined it is safe to begin **RE-ENERGIZING** the following circuit(s) or segments of circuit(s):

- **Circuit: SKY HI**
- **Segment(s): 4**
- **County: San Bernardino**
- **Unincorporated County Area: Lucerne Valley; Fifteen mile Valley east of Milpas drive; Crystal Creek N of Gateway Rd; CushenBury**

Circuit segments may be viewed at [sce.com/pmps](https://www.sce.com/pmps) and maps downloaded at [sce.com/maps](https://www.sce.com/maps).

SCE will also begin notifying customers that power will be turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working safely and as quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

Recommended Language to Share with the Public: SCE will begin turning power back on in your area. SCE has inspected its electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email

for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.

Update customer contact information at sce.com/pspsalerts.

Everbridge PPS Notification Audit Report 2020-11-07-1011 San Bernardino County-RE

Notification ID	Message Title	Sent On
626588483848810	Important: SCE Re-Energize Notice for PPS Event in San Bernardino County	Nov 07, 2020 10:11:53 PST

From: SCELiaisonOfficer@sce.com
To: [SCE Liaison Officer](#)
Subject: Important: SCE Re-Energize Notice for PSPS Event in San Bernardino County
Date: Saturday, November 7, 2020 10:12:26 AM

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- **Circuit: SKY HI**
- **County: San Bernardino County**
- **Unincorporated County Areas: Lucerne Valley; Fifteen mile Valley east of Milpas drive; Crystal Creek N of Gateway Rd; Cushenbury**
- **Re-Energized Date: 11/07/2020**
- **Re-Energized Time: 09:37**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

Recommended Language to Share with the Public: SCE is turning the power back

on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.

sce.com/PSPS is the site where customers may learn more about PSPS events in their area.

- Update customer contact information at sce.com/pspsalerts.

Everbridge PPS Notification Audit Report 2020-11-07-1225 All Counties-EC

Notification ID	Message Title	Sent On
626313605941129	Important: SCE All Clear Notice for PPS Event in Mono County.	Nov 06, 2020 22:48:26 PST
626313605941131	Important: SCE All Clear Notice for PPS Event in Inyo County.	Nov 06, 2020 22:52:02 PST
626588483848943	Important: SCE Event Concluded Notice for PPS Event in Santa Barbara County.	Nov 07, 2020 11:57:55 PST
626588483848949	Important: SCE Event Concluded Notice for PPS Event in Tuolumne County.	Nov 07, 2020 12:01:53 PST
626588483848958	Important: SCE Event Concluded Notice for PPS Event in Mono County.	Nov 07, 2020 12:10:59 PST
626588483848964	Important: SCE Event Concluded Notice for PPS Event in Inyo County.	Nov 07, 2020 12:18:02 PST
626588483848973	Important: SCE Event Concluded Notice for PPS Event in San Bernardino County.	Nov 07, 2020 12:25:54 PST

From: SCELiaisonOfficer@sce.com
To: [SCE Liaison Officer](#)
Subject: Important: SCE All Clear Notice for PSPS Event in Mono County
Date: Friday, November 6, 2020 10:48:58 PM

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines and the following circuit(s) are no longer under PSPS consideration:

- **Circuit: BIRCHIM**
- **County: Mono County**
- **Segment: Segment 4**
- **Unincorporated County Area: Paradise ; Portion of Swall Meadows**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

Recommended Language to Share with the Public: SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email

for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.

Update customer contact information at sce.com/pspsalerts.

From: SCELiaisonOfficer@sce.com
To: [SCE Liaison Officer](#)
Subject: Important: SCE All Clear Notice for PSPS Event in Inyo County
Date: Friday, November 6, 2020 10:52:34 PM

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines and the following circuit(s) are no longer under PSPS consideration:

- **Circuit: BIRCHIM**
- **County: Inyo County**
- **Segment: Segment 4**
- **Unincorporated County Area: Round Valley ; Scheelite ; Mesa ; West Bishop ; east of Grouse Mountain**

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

Recommended Language to Share with the Public: SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found,

by county, at [sce.com/maps](https://www.sce.com/maps).

- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

From: SCELiaisonOfficer@sce.com
To: [SCE Liaison Officer](#)
Subject: Important: SCE Event Concluded Notice for PSPS Event in Santa Barbara County.
Date: Saturday, November 7, 2020 11:58:33 AM

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected any lines that were de-energized due to PSPS, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** all circuits in your county. SCE's Incident Management Team is standing down and both SCE systems and staff have returned to normal status.

The following circuit is all clear:

- CONCEPCION

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

Recommended Language to Share with the Public: The power shutoff in your area has concluded. Customers in this area, however, may experience other weather-related or unplanned repair outages not related to the Public Safety Power Shutoff (PSPS). Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).

- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

From: SCELiaisonOfficer@sce.com
To: [SCE Liaison Officer](#)
Subject: Important: SCE Event Concluded Notice for PSPS Event in Tuolumne County.
Date: Saturday, November 7, 2020 12:02:30 PM

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected any lines that were de-energized due to PSPS, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** all circuits in your county. SCE's Incident Management Team is standing down and both SCE systems and staff have returned to normal status.

The following circuit is clear:

- RHINEDOLLAR

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

Recommended Language to Share with the Public: The power shutoff in your area has concluded. Customers in this area, however, may experience other weather-related or unplanned repair outages not related to the Public Safety Power Shutoff (PSPS). Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).

- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

From: SCELiaisonOfficer@sce.com
To: [SCE Liaison Officer](#)
Subject: Important: SCE Event Concluded Notice for PSPS Event in Mono County.
Date: Saturday, November 7, 2020 12:11:37 PM

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected any lines that were de-energized due to PSPS, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** all circuits in your county. SCE's Incident Management Team is standing down and both SCE systems and staff have returned to normal status.

The following circuits are All Clear:

- BANTA
- BIRCHIM
- CAIN RANCH
- DYNAMO
- GULL LAKE
- PICKLE MEADOWS
- REVERSE PEAK
- RHINEDOLLAR
- ROBINSON CREEK
- ROCKCREEK
- STROSNIDER
- TUFA

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

Recommended Language to Share with the Public: The power shutoff in your area has concluded. Customers in this area, however, may experience other weather-related or unplanned repair outages not related to the Public Safety Power Shutoff (PSPS). Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.

800-684-8123 is for all other billing and service inquiries.

- sce.com/PSPS is the site where customers may learn more about PSPS events in their area.
- Update customer contact information at sce.com/pspsalerts.

From: SCELiaisonOfficer@sce.com
To: [SCE Liaison Officer](#)
Subject: Important: SCE Event Concluded Notice for PSPS Event in Inyo County.
Date: Saturday, November 7, 2020 12:18:32 PM

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected any lines that were de-energized due to PSPS, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** all circuits in your county. SCE's Incident Management Team is standing down and both SCE systems and staff have returned to normal status.

The following circuits are All Clear:

- BIRCHIM
- SINKER
-

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

Recommended Language to Share with the Public: The power shutoff in your area has concluded. Customers in this area, however, may experience other weather-related or unplanned repair outages not related to the Public Safety Power Shutoff (PSPS). Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at

[sce.com/PSPS](https://www.sce.com/PSPS).

- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/pspss).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

From: SCELiaisonOfficer@sce.com
To: [SCE Liaison Officer](#)
Subject: Important: SCE Event Concluded Notice for PSPS Event in San Bernardino County.
Date: Saturday, November 7, 2020 12:26:48 PM

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected any lines that were de-energized due to PSPS, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** all circuits in your county. SCE's Incident Management Team is standing down and both SCE systems and staff have returned to normal status.

The following circuits are All Clear:

- BEAR VALLEY
- CAMP ANGELUS
- CAMPANULA
- CUSHENBURY
- DOBLE
- JENKS LAKE
- PIONEERTOWN
- SCOUT
- SKY HI
- UTE
- WEESHA

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

Recommended Language to Share with the Public: The power shutoff in your area

has concluded. Customers in this area, however, may experience other weather-related or unplanned repair outages not related to the Public Safety Power Shutoff (PSPS). Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.

[sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.

- Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Attachment B

Critical Infrastructure and Customer Notifications

11.07.2020 PSPS Activation
Customer Communication Notification Tracking Sheet

CIRCUIT STATUS				COMMUNICATIONS							PSPS PROTOCOL						
Circuits	D_ST_T	Downstreams	Parent Circuit	Counties	Initial (72 Hour)	2 Day (48 Hour)	1 Day (24 Hour)	Day Of	Update(s) (required daily unless circuit is de-energized)	All Clear	Imminent Shutdown Notification Date/Time	Imminent Shutdown Notification (Partial) Circuit Breaker(CB) or RAR or PS	De-Energized Notification Date/Time	De-Energized Notification (Partial) Circuit Breaker(CB) or RAR or PS	Prepare to Re-Energize Notification Date/Time	Prepare to Re-Energize Notification (Partial) Circuit Breaker(CB) or RAR or PS	Re-Energized Notification Date/Time
BIRCHIM	D			MONO; INYO	11/3/2020 14:01	11/3/2020 20:08	11/4/2020 11:18	11/5/2020 14:30	11/6/2020 8:33	11/6/2020 21:08	11/6/2020 15:06	RAR0323	11/6/2020 15:25, 11/6/2020 15:25	RAR0640, RAR0625	11/6/2020 18:06, 11/6/2020 18:06	RAR0640, RAR0625	11/6/2020 20:28, 11/6/2020 22:36
CAMPANULA CONWAY										11/7/2020 10:01 11/6/2020 20:11	11/6/2020 14:46 11/6/2020 8:45	CB CB					
DOBLE	D	SCOUT		SAN BERNARDINO	No CI	11/4/2020 11:18	11/5/2020 14:31	11/6/2020 8:33		11/6/2020 20:11							
PICKLE MEADOWS										11/6/2020 20:11	11/6/2020 12:49	CB					
PIONEERTOWN										11/6/2020 20:11	11/6/2020 14:47	RAR0409					
ROBINSON CREEK										11/6/2020 20:11	11/6/2020 9:08	RAR0154					
SCOUT			DOBLE		No CI	11/4/2020 11:18	11/5/2020 14:31	11/6/2020 8:33		11/6/2020 20:11			11/6/2020 13:00	CB	11/6/2020 14:36	CB	11/6/2020 18:53
STROSNIDER										11/6/2020 20:11			11/6/2020 13:17	CB	11/6/2020 14:35	CB	11/6/2020 16:37
UTE	D			SAN BERNARDINO	No Load						11/6/2020 12:20	CB					
APPLE VALLEY- COTTONWOOD- PLUESS-SAVAGE																	
BANTA	ST			SAN BERNARDINO													
	D			MONO		11/4/2020 11:18	11/5/2020 14:31	11/6/2020 8:33		11/6/2020 20:11							
BEAR VALLEY	D	JENKS LAKE, CAMP ANGELUS, WEESHA		SAN BERNARDINO			11/5/2020 14:30	11/6/2020 8:33		11/6/2020 20:11							
CAIN RANCH	D			MONO		11/4/2020 11:18	11/5/2020 14:31	11/6/2020 8:33		11/6/2020 20:11	11/6/2020 11:28	RAR0431					
CAMP ANGELUS			BEAR VALLEY				11/5/2020 14:30	11/6/2020 8:33		11/6/2020 20:11							
CASA DIABLO- CONTROL-SHERWIN	ST			MONO; INYO													
CASA DIABLO-RUSH CREEK	ST			MONO													
CONCEPCION	D			SANTA BARBARA	11/3/2020 14:01					11/3/2020 20:08							
CONTROL-PLANT 2	ST			MONO; INYO													
COTTONWOOD- PERMANENTE	ST			SAN BERNARDINO													
CLUSHENBURY	D	UTE		SAN BERNARDINO	11/3/2020 14:01	11/4/2020 11:18	11/5/2020 14:31			11/6/2020 8:33							
DYNAMO	D			MONO	No CI												
GULL LAKE	D			MONO	11/3/2020 14:01	11/3/2020 20:08	11/4/2020 11:18	11/5/2020 14:30	11/6/2020 8:33	11/6/2020 20:11							
JENKS LAKE			BEAR VALLEY				11/5/2020 14:30	11/6/2020 8:33		11/6/2020 20:11							
LEE VINING-POOLE- RUSH CREEK	ST	RHINEDOLLAR		MONO													
REVERSE PEAK	D			MONO	11/3/2020 14:01	11/3/2020 20:08	11/4/2020 11:18	11/5/2020 14:30	11/6/2020 8:33	11/6/2020 20:11	11/6/2020 11:04	CB					
RHINEDOLLAR			LEE VINING-POOLE-RUSH CREEK					11/5/2020 20:02		11/6/2020 8:33							
ROCKCREEK	D			MONO		11/4/2020 18:44	11/5/2020 14:31			11/5/2020 20:02							
SINKER	D			INYO		11/4/2020 18:44				11/5/2020 14:32							

No CI - No Critical Infrastructure
No Load - No customers on the circuit

Attachment C

PSPS Activation Customer Notification Messaging

Customer Automated Notifications - Messaging

72 hour Initial – Messaging

Voice/ Voice Mail/TTY:

This is an important safety message from Southern California Edison. Due to forecast fire weather conditions, SCE is exploring a potential Public Safety Power Shutoff of electrical lines in the ^city_variable^ area. These conditions may result in SCE turning off your power. SCE anticipates that this may occur on ^Day of week^^Month Day^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having your resiliency plan ready to execute. SCE will send daily updates until conditions improve. For additional information available, please contact your assigned SCE account representative, go to SCE.com/psps, or call SCE at 1-800-611-1911.

Text/SMS:

SCE Safety Alert: Due to forecast fire weather conditions, Southern California Edison is exploring a potential Public Safety Power Shutoff of electrical lines in the ^city_variable^ area. These conditions may result in SCE turning off your power. SCE anticipates that this may occur on ^Day of week^^Month Day^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having your resiliency plan ready to execute. SCE will send daily updates until conditions improve. For please contact your assigned SCE account representative, go to SCE.com/psps, or call SCE at 1-800-611-1911.

E-Mail:

Subject: Public Safety Power Shutoff (PSPS) Advanced Initial Notification – Critical Infrastructure

From: do_not_reply@scewebservices.com

Southern California Edison

Due to forecast fire weather conditions, SCE is exploring a potential Public Safety Power Shutoff of electrical lines in your area. These conditions may result in SCE turning off your power. SCE anticipates that this may occur on ^Day of week^^Month Day^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having your resiliency plan ready to execute. SCE will send daily updates until weather conditions improve.

The following address(es) are within areas being monitored:

Customer Name
13240 Riverview Dr.
Victorville, CA 92395-1234
Service Account: 3-XXX-XX45-67
Meter: 123456-654321
Rate: GS-2

For additional information including please visit sce.com/psps , contact your assigned SCE account representative, or call SCE at 1-800-611-1911.

Thank You,
Southern California Edison

48 Hour (Initial)

Voice/ Voice Mail/TTY:

This is an important safety message from Southern California Edison. Due to forecast fire weather conditions, Southern California Edison is exploring a potential Public Safety Power Shutoff of electrical lines in the ^city_variable^ area. These conditions may result in SCE turning off your power. SCE anticipates that this may occur on ^Day of week^ ^morning/afternoon/evening^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send daily updates until conditions improve. For more information, please visit sce.com/psps. Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

Text/SMS:

SCE Safety Alert: Due to forecast fire weather conditions, Southern California Edison is exploring a potential Public Safety Power Shutoff of electrical lines in the ^city_variable^ area. These conditions may result in SCE turning off your power. SCE anticipates that this may occur on ^Day of week^ ^morning/afternoon/evening^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send daily updates until conditions improve. For more information, please visit sce.com/psps. Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

E-Mail:

Subject: SCE Safety Alert: Public Safety Power Shutoff (PSPS) Initial Notification

From: do_not_reply@scewebservices.com

Southern California Edison

Due to forecast fire weather conditions, Southern California Edison is exploring a potential Public Safety Power Shutoff of electrical lines in your area. These conditions may result in SCE turning off your power. SCE anticipates that this may occur on ^Day of week^ ^morning/afternoon/evening^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send daily updates until conditions improve.

The following address(es) are within areas being monitored:

13240 Riverview Dr.
Victorville, CA 92395-1234
Service Account: 3-XXX-XX45-67
Meter: 123456-654321
Rate: GS-2

For more info such as expected duration: please visit www.sce.com/psps. Downed power line? Stay away, Call 911, and SCE at 1-800-611-1911.

Thank You,

Southern California Edison

24 Hour (Update)

Voice/ Voice Mail/TTY:

This is an important safety message from Southern California Edison. Due to forecast fire weather conditions, Southern California Edison continues to explore a potential Public Safety Power Shutoff of electrical lines in the ^city_variable^ area. These conditions may result in SCE turning off your power. SCE anticipates that this may occur on ^Day of week^ ^morning/afternoon/evening^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send daily updates until conditions improve. For more information, please visit sce.com/psps. Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

Text/SMS:

SCE Safety Alert: Due to forecast fire weather conditions, Southern California Edison continues to explore a potential Public Safety Power Shutoff of electrical lines in the ^city_variable^ area. These conditions may result in SCE turning off your power. SCE anticipates that this may occur on ^Day of week^ ^morning/afternoon/evening^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send daily updates until conditions improve. For more information, please visit sce.com/psps. Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

E-Mail:

Subject: SCE Safety Alert: Public Safety Power Shutoff (PSPS) Update Notification

From: do_not_reply@scewebservices.com

Southern California Edison

Due to forecast fire weather conditions, Southern California Edison continues to explore a potential Public Safety Power Shutoff of electrical lines in your area. These conditions may result in SCE turning off your power. SCE anticipates that this may occur on ^Day of week^ ^morning/afternoon/evening^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send daily updates until conditions improve.

The following address(es) are within areas being monitored:

13240 Riverview Dr.
Victorville, CA 92395-1234
Service Account: 3-XXX-XX45-67

Meter: 123456-654321

Rate: GS-2

For more info such as expected duration: please visit www.sce.com/psps. Downed power line? Stay away, Call 911, and SCE at 1-800-611-1911.

Thank You,

Southern California Edison

Imminent De-energization

Voice/ Voice Mail/TTY:

This an important safety message from Southern California Edison. Due to forecast fire weather conditions, SCE may proactively turn off power within the next 1 to 4 hours for a Public Safety Power Shutoff to the ^city_variable^ area though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send updates until conditions improve. For more information, please visit sce.com/psps. Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

Text/SMS:

SCE Safety Alert: Due to forecast fire weather conditions, SCE may proactively turn off power within the next 1 to 4 hours for a Public Safety Power Shutoff to the ^city_variable^ area though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send updates until conditions improve. For more information, please visit sce.com/psps. Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

E-Mail:

Subject: SCE Safety Alert: Public Safety Power Shutoff (PSPS) Imminent Shutoff Notice

From: do_not_reply@scewebservices.com

Southern California Edison

Due to forecast fire weather conditions, SCE may proactively turn off power within the next 1 to 4 hours for a Public Safety Power Shutoff to the ^city_variable^ area ^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send updates until conditions improve.

The following address(es) may be affected:

13240 Riverview Dr.
Victorville, CA 92395-1234
Service Account: 3-XXX-XX45-67
Meter: 123456-654321
Rate: GS-2

For more info such as expected duration: please visit www.sce.com/psps. Downed power line? Stay away, Call 911, and SCE at 1-800-611-1911.

Thank You,

Southern California Edison

Preparing to Re-Energize (Imminent Restoration)

Voice/ Voice Mail/TTY:

This is an important safety message from Southern California Edison. SCE will soon begin the process of inspecting electrical lines in the ^city variable^ area. Provided we find no safety concerns, we will begin the power restoration process. To ensure you are ready for service, turn off or unplug any appliances or equipment that may automatically start when your power is restored. For more information on SCE's restoration process, please visit sce.com/psps. Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

Text/SMS:

SCE Safety Alert: SCE will soon begin the process of inspecting electrical lines in the ^city variable^ area. Provided we find no safety concerns, we will begin the power restoration process. To ensure you are ready for service, turn off or unplug any appliances or equipment that may automatically start when your power is restored. For more information on SCE's restoration process, please visit sce.com/psps. Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

E-Mail:

Subject: SCE Safety Alert: Public Safety Power Shutoff (PSPS) Preparing to Re Energize Notification

From: do_not_reply@scewebservices.com

Southern California Edison

This is an important safety message from Southern California Edison.

SCE will soon begin the process of inspecting electrical lines in the ^city variable^ area. Provided we find no safety concerns, we will begin the power restoration process. To ensure you are ready for service, turn off or unplug any appliances or equipment that may automatically start when your power is restored.

The following address(es) are within areas SCE is preparing to re-energize:

13240 Riverview Dr.
Victorville, CA 92395-1234
Service Account: 3-XXX-XX45-67
Meter: 123456-654321
Rate: GS-2

For more information on SCE's restoration process, please visit sce.com/psps. Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

Thank You,

Southern California Edison

Shutoff

Voice/ Voice Mail/TTY:

This is an important safety message from Southern California Edison. Southern California Edison has proactively turned off power to the ^city_variable^ area due to fire weather conditions. Your power may be restored at any time. To ensure you are ready for service turn off or unplug any appliances or equipment that may automatically start when your power is restored. We will update you as conditions change. For more information, please visit sce.com/psps. If you see a downed power line, stay away, call 9 1 1, and report this to S C E at 1-800-611-1911.

Text/SMS:

SCE Safety Alert: Southern California Edison has proactively turned off power to the ^city_variable^ area due to fire weather conditions. Your power may be restored at any time. To ensure you are ready for service turn off or unplug any appliances or equipment that may automatically start when your power is restored. We will update you as conditions change. For more information, please visit sce.com/psps. If you see a downed power line, stay away, call 9 1 1, and report this to S C E at 1-800-611-1911.

E-Mail:

Subject: SCE Safety Alert: Public Safety Power Shutoff (PSPS) Notification

From: do_not_reply@scewebservices.com

Southern California Edison

This is an important safety message from Southern California Edison. Southern California Edison has proactively turned off power to your area due to fire weather conditions. Your power may be restored at any time. To ensure you are ready for service turn off or unplug any appliances or equipment that may automatically start when your power is restored. We will update you as conditions change.

The following address(es) may be affected:

13240 Riverview Dr.
Victorville, CA 92395-1234
Service Account: 3-XXX-XX45-67
Meter: 123456-654321
Rate: GS-2

For more information, please visit sce.com/psps. If you see a downed power line, stay away, call 9 1 1, and report this to S C E at 1-800-611-1911.

Thank You,

Southern California Edison

Restored

Voice /Voice Mail/TTY:

This is an important safety message from Southern California Edison. Southern California Edison proactively turned off power to the ^city_variable^ area on ^date variable^ date, due to fire weather conditions. Power has now been restored. If your power is still off, please call 1-800-611-1911 or visit sce.com/outage.

Text/SMS:

SCE Safety Alert: Southern California Edison proactively turned off power to the ^city_variable^ area on ^date variable^ date, due to fire weather conditions. Power has now been restored. If your power is still off, please call 1-800-611-1911 or visit sce.com/outage.

E-Mail:

Subject: SCE Safety Alert: Public Safety Power Shutoff (PSPS) Restoration Notification

From: do_not_reply@scewebservices.com

Southern California Edison

Southern California Edison proactively turned off power to the ^city_variable^ area on ^date variable^ date, due to fire weather conditions. Power has now been restored.

The following address(es) have been restored:

13240 Riverview Dr.
Victorville, CA 92395-1234
Service Account: 3-XXX-XX45-67
Meter: 123456-654321
Rate: GS-2

If your power is still off, please call 1-800-611-1911 or visit sce.com/outage.

Thank You,

Southern California Edison

Avoided/All Clear Notification - Messaging

Voice/ Voice Mail/TTY:

This is an important safety message from Southern California Edison. Due to forecast fire weather conditions, Southern California Edison continues to explore a potential Public Safety Power Shutoff of electrical lines in the ^city_variable^ area. These conditions may result in SCE turning off your power. SCE anticipates that this may occur on ^Day of week^ ^morning/afternoon/evening^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send daily updates until conditions improve. For more

information, please visit [sce.com/psps](https://www.sce.com/psps). Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

Text/SMS:

SCE Safety Alert: Due to forecast fire weather conditions, Southern California Edison continues to explore a potential Public Safety Power Shutoff of electrical lines in the ^city_variable^ area. These conditions may result in SCE turning off your power. SCE anticipates that this may occur on ^Day of week^ ^morning/afternoon/evening^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send daily updates until conditions improve. For more information, please visit [sce.com/psps](https://www.sce.com/psps). Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

E-Mail:

Subject: SCE Safety Alert: Public Safety Power Shutoff (PSPS) Update Notification

From: do_not_reply@scewebservices.com

Southern California Edison

Due to forecast fire weather conditions, Southern California Edison continues to explore a potential Public Safety Power Shutoff of electrical lines in your area. These conditions may result in SCE turning off your power. SCE anticipates that this may occur on ^Day of week^ ^morning/afternoon/evening^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send daily updates until conditions improve.

The following address(es) are within areas being monitored:

13240 Riverview Dr.
Victorville, CA 92395-1234
Service Account: 3-XXX-XX45-67
Meter: 123456-654321
Rate: GS-2

For more info such as expected duration: please visit www.sce.com/psps. Downed power line? Stay away, Call 911, and SCE at 1-800-611-1911.

Thank You,

Southern California Edison