

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X
2	Utility Name	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes (Optional):
3	PG&E	6/10/14	15.14	40.2059900	-122.2533300	Vegetation	Rural	< 0.25 Acres	Fire Agency	Red Bluff FD	101545144	12,000	Conductor	Overhead	Yes	6/10/14	15.14	Contact From Object	N.A.	Other	Electric Facility	Human Error	Conveyor belt contact	
4	PG&E	6/12/14	6.30	38.0437500	-122.7462400	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire et al	102230371	12,000	Conductor	Overhead	Yes	6/12/14	6.30	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown		
5	PG&E	6/13/14	9.19	36.9334800	-121.3885490	Vegetation	Rural	< 0.25 Acres	Fire Agency	Hollister FD	101703071	21,000	Conductor	Overhead	Yes	6/13/14	9.19	Contact From Object	N.A.	Vehicle	N.A.	Unknown	Human Error	
6	PG&E	6/14/14	8.47	37.4190050	-122.1807700	Vegetation	Rural	< 3 meters	Unknown		100275552	12,000	Conductor	Overhead	Yes	6/14/14	8.47	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
7	PG&E	6/14/14	11.01	37.1309150	-121.0919180	Vegetation	Rural	10 - 99 Acres	Fire Agency	CAL Fire	Pole 000/013	70,000	Conductor	Overhead	Yes	6/14/14	11.01	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown		
8	PG&E	6/15/14	8.47	38.9032500	-119.9714100	Vegetation	Rural	< 0.25 Acres	Fire Agency		23633 Shuffles Rd. Los Gatos	12,000	Conductor	Overhead	Yes	6/15/14	8.47	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
9	PG&E	6/15/14	17.28	37.9707710	-121.9849810	Vegetation	Urban	< 3 meters	Self Extinguished		4239 Teakwood Ct. Concord	0 - 750	Conductor	Overhead	Yes	6/15/14	17.28	Wire-Wire Contact	N.A.	N.A.	N.A.	Unknown	Weather	
10	PG&E	6/15/14	20.55	39.8878600	-122.1973690	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	101500605	12,000	Conductor	Overhead	Yes	6/15/14	20.55	Contact From Object	N.A.	Vehicle	N.A.	Unknown	Human Error	
11	PG&E	6/16/14	15.37	38.1681700	-120.6074690	Vegetation	Rural	< 0.25 Acres	Fire Agency		101280871	0 - 750	Conductor	Overhead	No			Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
12	PG&E	6/17/14	13.49	38.6667940	-122.5963970	Vegetation	Rural	< 3 meters	Fire Agency	Cal Fire	102247824	12,000	Conductor	Overhead	Yes	6/17/14	13.49	Contact From Object	N.A.	Vehicle	N.A.	Unknown	Human Error	
13	PG&E	6/17/14	14.50	40.9605800	-124.0339590	Vegetation	Rural	< 0.25 Acres	Unknown		100979528	0 - 750	Conductor	Overhead	Yes	6/17/14	14.50	Wire-Wire Contact	N.A.	N.A.	N.A.	Unknown		
14	PG&E	6/17/14	16.47	34.6860900	-120.4327320	Vegetation	Rural	< 3 meters	Self Extinguished		101894765	12,000	Conductor	Overhead	Yes	6/17/14	16.47	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	N.A.	Unknown	
15	PG&E	6/17/14	21.24	38.4180400	-121.1404610	Vegetation	Rural	10 - 99 Acres	Unknown		Twr. 052/320	115,000	Conductor	Overhead	Yes	6/17/14	21.24	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
16	PG&E	6/18/14	10.01	37.8010980	-121.2021560	Vegetation	Urban	26 - 99 Acres	Fire Agency	Manitaca FD	102085311	17,000	Conductor	Overhead	Yes	6/18/14	10.01	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	N.A.	Unknown	
17	PG&E	6/18/14	18.29	37.3175090	-120.5049050	Vegetation	Urban	< 0.25 Acres	Fire Agency	Cal Fire	101162090	0 - 750	Capacitor Bank	Overhead	No			Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown		
18	PG&E	6/19/14	16.32	37.9314600	-121.2989000	Vegetation	Urban	< 0.25 Acres	Unknown		102133758	0 - 750	Conductor	Overhead	No			Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	service conductor	
19	PG&E	6/19/14	18.54	38.7801990	-121.5007240	Vegetation	Rural	26 - 99 Acres	Fire Agency		101297449	12,000	Conductor	Overhead	Yes	6/19/14	18.54	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
20	PG&E	6/20/14	9.47	34.8650990	-120.3206720	Vegetation	Rural	< 0.25 Acres	Unknown		101862409	12,000	Conductor	Overhead	Yes	6/20/14	9.47	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
21	PG&E	6/20/14	12.00	39.6663370	-122.1968810	Vegetation	Rural	< 0.25 Acres	Unknown		100422609	0 - 750	Capacitor Bank	Overhead	No			Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown		
22	PG&E	6/20/14	14.15	40.7802300	-121.5028700	Vegetation	Rural	< 0.25 Acres	Fire Agency		101520035	12,000	Conductor	Overhead	Yes	6/20/14	14.15	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
23	PG&E	6/21/14	6.49	38.3753000	-122.5494000	Vegetation	Rural	< 0.25 Acres	Fire Agency		3111 WARM SPRINGS RD. GLEN ELLEN	12,000	Conductor	Overhead	Yes	6/21/14	6.49	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
24	PG&E	6/21/14	14.36	38.3644400	-122.2626490	Vegetation	Rural	< 3 meters	Fire Agency	Cal Fire	102286053	12,000	Conductor	Overhead	Yes	6/21/14	14.36	Contact From Object	N.A.	Vehicle	N.A.	Unknown	Human Error	
25	PG&E	6/22/14	8.19	34.8943890	-120.4244590	Vegetation	Urban	< 3 meters	Unknown		101864052	12,000	Conductor	Overhead	Yes	6/22/14	8.19	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
26	PG&E	6/23/14	6.04	37.5048000	-120.5074200	Vegetation	Rural	< 0.25 Acres	Unknown		Pole 007/019	70,000	Conductor	Overhead	Yes	6/23/14	6.04	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
27	PG&E	6/23/14	17.45	39.0640240	-121.0224860	Vegetation	Rural	26 - 99 Acres	Fire Agency		BET. MTR# 1007517420 & FUCO 7495	12,000	Conductor	Overhead	Yes	6/23/14	17.45	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
28	PG&E	6/24/14	7.11	36.7495400	-121.8570600	Vegetation	Rural	< 0.25 Acres	Fire Agency	Salinas FD	101712215	12,000	Conductor	Overhead	Yes	6/24/14	7.11	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
29	PG&E	6/24/14	7.48	37.9037000	-121.6791620	Other	Urban	< 3 meters	Fire Agency	Contra Costa FD	100485898	0 - 750	Conductor	Overhead	No			Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	dumpster burned	
30	PG&E	6/24/14	14.31	39.7856800	-121.9065900	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire	Mtr 36P580	12,000	Conductor	Overhead	Yes	6/24/14	14.31	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
31	PG&E	6/24/14	16.56	37.9740140	-121.3464620	Vegetation	Urban	< 0.25 Acres	Unknown		103190493	12,000	Conductor	Overhead	Yes	6/24/14	16.56	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
32	PG&E	6/24/14	17.12	38.1109730	-122.5645120	Vegetation	Urban	26 - 99 Acres	Fire Agency	Novato Fire Department	102223842	0 - 750	Conductor	Overhead	No			Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
33	PG&E	6/25/14	1.36	36.8908500	-121.7174600	Vegetation	Rural	< 0.25 Acres	Unknown		101697469	0 - 750	Conductor	Overhead	No			Contact From Object	N.A.	Balloons	Electric Facility	Human Error		
34	PG&E	6/25/14	8.51	34.8830400	-120.2776190	Vegetation	Rural	26 - 99 Acres	Fire Agency		LD SIDE MTR 1008835806	12,000	Conductor	Overhead	Yes	6/25/14	8.51	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
35	PG&E	6/25/14	8.53	39.0110100	-120.8960600	Vegetation	Rural	26 - 99 Acres	Unknown		Main Line N/O buck to 20340 Spring Garden # 1004520726	12,000	Conductor	Overhead	Yes	6/25/14	8.53	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused	
36	PG&E	6/25/14	21.47	37.9976630	-121.7691860	Vegetation	Rural	< 0.25 Acres	Unknown		100455766	12,000	Conductor	Overhead	Yes	6/25/14	21.47	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
37	PG&E	6/26/14	0.15	36.9002500	-119.9317700	Vegetation	Urban	< 0.25 Acres	Fire Agency		102258915	12,000	Conductor	Overhead	Yes	6/26/14	0.15	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
38	PG&E	6/28/14	23.04	37.8992070	-121.8608780	Vegetation	Rural	< 0.25 Acres	Unknown		100483886	21,000	Transformer	Overhead	Yes	6/28/14	23.04	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
39	PG&E	6/29/14	7.59	38.7794000	-121.5055490	Vegetation	Rural	< 0.25 Acres	Fire Agency		101297918	0 - 750	Transformer	Overhead	Yes	6/29/14	7.59	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown		
40	PG&E	6/29/14	8.23	39.0919800	-121.5430700	Vegetation	Urban	< 0.25 Acres	Unknown		SB 15745 ARBOGA RD 500' S/O FURNEAUX RD 2 SP EAST	12,000	Conductor	Overhead	Yes	6/29/14	8.23	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
41	PG&E	6/29/14	19.53	38.5208000	-123.0606700	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	3600 E. AUTSTIN CREEK RD	12,000	Conductor	Overhead	Yes	6/29/14	19.53	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
42	PG&E	6/30/14	14.08	38.4491800	-122.8727700	Vegetation	Rural	< 0.25 Acres	Unknown		102022582	0 - 750	Conductor	Overhead	No			Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
43	PG&E	6/30/14	18.25	39.1449270	-122.1318820	Vegetation	Rural	< 0.25 Acres	Unknown		101629033	12,000	Conductor	Overhead	Yes	6/30/14	18.25	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
44	PG&E	6/30/14	20.02	36.8080200	-119.9101390	Vegetation	Urban	< 0.25 Acres	Unknown		100625545	21,000	Conductor	Overhead	Yes	6/30/14	20.02	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
45	PG&E	7/1/14	3.46	37.9004730	-121.2602580	Vegetation	Rural	< 0.25 Acres	Unknown		2 POLES EAST OF C3412	12,000	Conductor	Overhead	Yes	7/1/14	3.46	Contact From Object	N.A.	Vehicle	N.A.	Unknown	Human Error	
46	PG&E	7/1/14	6.43	39.0062300	-122.8430300	Vegetation	Rural	26 - 99 Acres	Fire Agency	West Marin Fire	102258915	12,000	Conductor	Overhead	Yes	7/1/14	6.43	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
47	PG&E	7/1/14	9.45	37.4266900	-119.8809500	Vegetation	Rural	< 0.25 Acres	Unknown		101065832	21,000	Conductor	Overhead	Yes	7/1/14	9.45	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
48	PG&E	7/1/14	14.36	38.8648700	-121.7025500	Vegetation	Rural	< 0.25 Acres	Fire Agency	Yolo FD	101593404	12,000	Conductor	Overhead	Yes	7/1/14	14.36	Contact From Object	N.A.	Vehicle	Communication Facility	Human Error		
49	PG&E	7/1/14	18.43	37.0854220	-121.7607380	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	6770 Croy Rd, Morgan Hill	0 - 750	Conductor	Overhead	Yes	7/1/14	18.43	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
50	PG&E	7/2/14	13.17	38.2545710	-122.0509280	Vegetation	Urban	< 0.25 Acres	Fire Agency	Cal Fire	101565512	12,000	Conductor	Overhead	Yes	7/2/14	13.17	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
51	PG&E	7/2/14	14.29	40.4736600	-122.4737300	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	101481261	12,000	Conductor	Overhead	Yes	7/2/14	14.29	Vandalism/Theft	N.A.	N.A.	N.A.	Unknown	Third-party caused	
52	PG&E	7/																						

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X
Utility Name	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes (Optional):	
119	PG&E	8/3/14	16.11	38.6443750	-121.7880330	Vegetation	< 0.25 Acres	Unknown		MTR 1007460127		12,000	Conductor	Overhead	Yes	8/3/14	16.11	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
120	PG&E	8/4/14	4.18	37.1062600	-121.6366660	Vegetation	< 0.25 Acres	Fire Agency	Cal Fire	100606026	Verizon	21,000	Conductor	Overhead	No			Contact From Object	N.A.	Vehicle	Communication Facility	Human Error		
121	PG&E	8/5/14	0.08	38.7804600	-121.4893690	Vegetation	< 0.25 Acres	Fire Agency		101297005		12,000	Conductor	Overhead	Yes	8/5/14	0.08	Equipment/Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
122	PG&E	8/5/14	2.57	38.5704300	-121.1022700	Vegetation	< 0.25 Acres	Unknown		7150 MEARS DR #A AUBURN		12,000	Conductor	Overhead	Yes	8/5/14	2.57	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
123	PG&E	8/5/14	12.03	39.2154990	-121.3029290	Vegetation	26 - 9.99 Acres	Fire Agency	Cal Fire	Str. 010122		60,000	Conductor	Overhead	Yes	8/5/14	12.03	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
124	PG&E	8/5/14	14.60	38.3419700	-121.6319700	Vegetation	< 0.25 Acres	Fire Agency	Cal Fire	MTR 1009312709		0 - 750	Transformer	Overhead	Yes	8/5/14	14.60	Equipment/Facility Failure	Transformer	N.A.	N.A.	Unknown		
125	PG&E	8/5/14	16.13	37.5634100	-119.9395000	Vegetation	26 - 9.99 Acres	Fire Agency	Cal Fire	MTR 1006385335		0 - 750	Conductor	Overhead	No			Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
126	PG&E	8/5/14	17.12	36.9187600	-119.6766700	Vegetation	< 0.25 Acres	Fire Agency	Cal Fire	100725159		0 - 750	Conductor	Overhead	No			Unknown	N.A.	N.A.	N.A.	Unknown		
127	PG&E	8/5/14	21.41	38.0031100	-122.3270500	Vegetation	< 0.25 Acres	Fire Agency	Contra Costa FD	101426924		0 - 750	Conductor	Overhead	No			Unknown	N.A.	N.A.	N.A.	Unknown		
128	PG&E	8/8/14	18.17	40.0011200	-122.2260790	Vegetation	< 0.25 Acres	Fire Agency	Cal Fire	101530848		12,000	Conductor	Overhead	Yes	8/8/14	18.17	Contact From Object	N.A.	Vehicle	Pole	Human Error		
129	PG&E	8/9/14	2.53	38.3011000	-122.8963300	Vegetation	< 0.25 Acres	Unknown		2 SPANS SOURCE SIDE OF 30501 SHORLINE HWY, FALLON		12,000	Conductor	Overhead	Yes	8/9/14	2.53	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
130	PG&E	8/9/14	15.36	36.6851770	-119.0449600	Vegetation	< 0.25 Acres	Fire Agency	Cal Fire	MTR#1005057583		12,000	Conductor	Overhead	Yes	8/9/14	15.36	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
131	PG&E	8/11/14	9.23	37.9118400	-120.3488900	Vegetation	26 - 9.99 Acres	Fire Agency	Cal Fire	2 SPAN LOADSIDE FCO 20835		17,000	Conductor	Overhead	Yes	8/11/14	9.23	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
132	PG&E	8/11/14	14.35	39.6725230	-121.4983170	Vegetation	< 0.25 Acres	Unknown		1wr 022746		230,000	Other	Overhead	Yes	8/11/14	14.35	Contact From Object	N.A.	Other	Electric Facility	Weather	lightning strike	
133	PG&E	8/12/14	8.58	38.7405700	-121.7870400	Vegetation	< 3 meters	Unknown		S/S MONTE RD 4 SPANS S/O NASHUA RD, CASTROVILLE		21,000	Conductor	Overhead	Yes	8/12/14	8.58	Equipment/Facility Failure	Other	N.A.	N.A.	Unknown		
134	PG&E	8/12/14	8.42	39.2632400	-121.5974890	Other	Structure Only	Unknown		101287419		12,000	Conductor	Overhead	Yes	8/12/14	8.42	Contact From Object	N.A.	Vehicle	Pole	Human Error	vehicle burned	
135	PG&E	8/12/14	15.38	38.7771100	-120.2657500	Vegetation	26 - 9.99 Acres	Fire Agency		WEST SIDE OF SW 6161		12,000	Conductor	Overhead	Yes	8/12/14	15.38	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
136	PG&E	8/14/14	10.46	38.0123950	-120.5860520	Vegetation	< 3 meters	Unknown		101272971	AT&T	17,000	Conductor	Overhead	Yes	8/14/14	10.46	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
137	PG&E	8/14/14	14.57	38.5099100	-122.8371300	Vegetation	< 0.25 Acres	Fire Agency		102028597	AT&T	0 - 750	Conductor	Overhead	Yes	8/14/14	14.57	Wire-Wire Contact	N.A.	N.A.	N.A.	Unknown		
138	PG&E	8/15/14	11.01	40.5840531	-122.4446948	Vegetation	< 0.25 Acres	Fire Agency	Redding Fire Dept	101473764	AT&T	12,000	Conductor	Overhead	Yes	8/15/14	11.01	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
139	PG&E	8/16/14	7.30	39.2938500	-121.6378000	Vegetation	< 0.25 Acres	Unknown		mtr # 1007536106		12,000	Conductor	Overhead	Yes	8/16/14	7.30	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
140	PG&E	8/17/14	7.27	37.3220200	-119.6344690	Vegetation	< 0.25 Acres	Unknown		RISER 10393		12,000	Conductor	Overhead	Yes	8/17/14	7.27	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
141	PG&E	8/17/14	17.33	35.0578500	-118.9174880	Other	Structure Only	Unknown		100175838		12,000	Conductor	Overhead	Yes	8/17/14	17.33	Contact From Object	N.A.	Vehicle	Pole	Human Error	vehicle burned	
142	PG&E	8/19/14	3.06	37.6325800	-122.4526290	Other	Structure Only	Fire Agency		100316145	AT&T	12,000	Conductor	Overhead	Yes	8/19/14	3.06	Equipment/Facility Failure	Conductor	N.A.	N.A.	Unknown	vehicle burned	
143	PG&E	8/19/14	21.05	37.9165090	-120.1321820	Vegetation	< 3 meters	Fire Agency		Groveland Fire		17,000	Conductor	Overhead	Yes	8/19/14	21.05	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
144	PG&E	8/20/14	14.22	38.8305400	-121.2014190	Vegetation	< 0.25 Acres	Fire Agency		23111 ELMORE RD, GROVELAND		12,000	Conductor	Overhead	Yes	8/20/14	14.22	Equipment/Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
145	PG&E	8/20/14	16.07	40.1937990	-123.7675500	Vegetation	26 - 9.99 Acres	Fire Agency	Cal Fire	103316088		12,000	Conductor	Overhead	Yes	8/20/14	16.07	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
146	PG&E	8/21/14	0.00	37.3964600	-121.0715810	Vegetation	< 0.25 Acres	Unknown		Eastin Rd. south of Hwy 33, Crows Landing		12,000	Conductor	Overhead	No			Contact From Object	N.A.	Animal	Electric Facility	Unknown		
147	PG&E	8/23/14	8.36	37.9862600	-120.3918290	Vegetation	< 0.25 Acres	Fire Agency	Cal Fire	101049418	AT&T	17,000	Conductor	Overhead	No			Contact From Object	N.A.	Animal	Electric Facility	Unknown		
148	PG&E	8/24/14	11.08	37.9417917	-121.3182650	Vegetation	< 0.25 Acres	Fire Agency	Stockton FD	102109203	AT&T	12,000	Conductor	Overhead	Yes	8/24/14	11.08	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
149	PG&E	8/27/14	6.51	38.3603100	-122.0177800	Vegetation	< 0.25 Acres	Unknown		foothill w/o auburn, Vacaville		12,000	Conductor	Overhead	Yes	8/27/14	6.51	Contact From Object	N.A.	Vehicle	Pole	Human Error		
150	PG&E	8/27/14	15.19	38.5929500	-122.9183300	Vegetation	< 0.25 Acres	Unknown		3103 MILL CREEK RD		12,000	Conductor	Overhead	Yes	8/27/14	15.19	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
151	PG&E	8/28/14	0.00	40.3886240	-122.4068490	Vegetation	< 3 meters	Unknown		Gas Point Rd and Happy Valley Rd, Cottonwood	AT&T	0 - 750	Conductor	Overhead	No			Equipment/Facility Failure	Conductor	N.A.	N.A.	Unknown		
152	PG&E	8/28/14	13.51	36.2607363	-119.8573300	Vegetation	< 0.25 Acres	Fire Agency		Pole 003/003		70,000	Conductor	Overhead	Yes	8/28/14	13.51	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
153	PG&E	8/28/14	19.21	37.7871300	-120.7836490	Vegetation	< 0.25 Acres	Fire Agency	Cal Fire	1 SP N/O 6567		17,000	Conductor	Overhead	Yes	8/29/14	19.21	Contact From Object	N.A.	Vehicle	Pole	Human Error		
154	PG&E	8/30/14	12.08	39.7610900	-121.8593090	Vegetation	< 0.25 Acres	Fire Agency		100349953	AT&T	0 - 750	Conductor	Overhead	No			Unknown	N.A.	N.A.	N.A.	Unknown		
155	PG&E	8/30/14	15.40	37.6381467	-121.3341500	Vegetation	26 - 9.99 Acres	Fire Agency		102052361	AT&T	12,000	Fuse	Overhead	Yes	8/30/14	15.40	Equipment/Facility Failure	Fuse	N.A.	N.A.	Unknown		
156	PG&E	8/30/14	18.34	37.3551100	-121.7978700	Vegetation	< 3 meters	Unknown		100575446	AT&T	0 - 750	Conductor	Overhead	No			Wire-Wire Contact	N.A.	N.A.	N.A.	Unknown		
157	PG&E	8/31/14	2.12	38.4193700	-122.9496400	Vegetation	< 0.25 Acres	Unknown		2520 Steps Rd, Sebastopol		12,000	Conductor	Overhead	Yes	8/31/14	2.12	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
158	PG&E	9/1/14	15.58	37.0599600	-122.1662900	Vegetation	26 - 9.99 Acres	Fire Agency	Cal Fire	At FUCO 2541		12,000	Conductor	Overhead	Yes	9/1/14	15.58	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
159	PG&E	9/2/14	3.49	37.4946250	-122.1424080	Vegetation	< 0.25 Acres	Self Extinguished		Pole 000/003		115,000	Other	Overhead	Yes	9/2/14	3.49	Contamination	N.A.	N.A.	N.A.	Weather		
160	PG&E	9/3/14	7.05	38.3022350	-120.9474300	Vegetation	< 0.25 Acres	Fire Agency	Cal Fire	Fuse 8885		12,000	Transformer	Overhead	Yes	9/3/14	7.05	Unknown	N.A.	N.A.	N.A.	Unknown		
161	PG&E	9/3/14	13.21	37.9040960	-122.2965500	Vegetation	< 0.25 Acres	Fire Agency	Orinda FD	10N/OF SW 8455, EAST OF WILDCAT CANYON		12,000	Conductor	Overhead	Yes	9/3/14	13.21	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
162	PG&E	9/4/14	0.34	39.1451000	-122.3817700	Vegetation	< 0.25 Acres	Fire Agency		5 POLES E/O MTR 1007307850		12,000	Conductor	Overhead	Yes	9/4/14	0.34	Contact From Object	N.A.	Vehicle	Pole	Human Error		
163	PG&E	9/6/14	18.42	37.8708200	-121.3803367	Vegetation	26 - 9.99 Acres	Fire Agency		102064435		0 - 750	Conductor	Overhead	No			Unknown	N.A.	N.A.	N.A.	Unknown		
164	PG&E	9/7/14	8.33	36.5907400	-119.5211590	Vegetation	< 0.25 Acres	Fire Agency	Tulare County FD	100876971	AT&T	12,000	Conductor	Overhead	Yes	9/7/14	8.33	Equipment/Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
165	PG&E	9/9/14	9.54	39.1530600	-121.0770600	Vegetation	< 0.25 Acres	Unknown		100066768	AT&T	12,000	Other	Overhead	Yes	9/9/14	9.54	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
166	PG&E	9/10/14	0.00	39.1849600	-121.6886900	Vegetation	< 0.25 Acres	Unknown		North Township Rd, Sutter		0 - 750	Other	Overhead	No			Unknown	N.A.	N.A.	N.A.	Unknown		
167	PG&E	9/11/14	11.39	38.5383100	-121.0650900	Vegetation	26 - 9.99 Acres	Unknown		1001 BONNIE LN, AUBURN CA		12,000	Conductor	Overhead	Yes	9/11/14	11.39	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
168	PG&E	9/12/14	5.20	38.0281510	-121.1751640	Vegetation	< 0.25 Acres	Unknown		102127295	AT&T	12,000	Conductor	Overhead										

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X	
2	Utility Name	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes (Optional):	
235	PG&E	11/8/14	15.02	38.1820870	-122.6692940	Vegetation	Rural	< 3 meters	Customer		5450 RED HILL RD		0 - 750	Conductor	Overhead	No			Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
236	PG&E	11/9/14	6.34	37.9419180	-122.3755040	Vegetation	Rural	< 3 meters	Fire Agency	RICHMOND PD	101443361	AT&T	12,000	Conductor	Overhead	Yes	11/9/14	6.34	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
237	PG&E	11/14/14	12.37	37.6510500	-122.4540800	Vegetation	Urban	< 3 meters	Fire Agency	PACIFICA FD	ON #4 LINE SIDE OF 11949 & 6053		12,000	Conductor	Overhead	Yes	11/14/14	12.37	Contact From Object	N.A.	N.A.	Electric Facility	Human Error		
238	PG&E	11/16/14	5.29	37.5305067	-122.5165317	Vegetation	Rural	< 3 meters	Fire Agency	Cal Fire	2166 Vallemar Moss beach		12,000	Conductor	Overhead	Yes	11/16/14	5.29	Contact From Object	N.A.	N.A.	Vegetation	Electric Facility	Unknown	
239	PG&E	11/16/14	17.55	37.5118320	-121.5719010	Vegetation	Urban	< 0.25 Acres	Fire Agency	FREMONT FIRE DEPT	190 42979 EVERGLADES PARK DR		0 - 750	Conductor	Overhead	No			Contact From Object	N.A.	N.A.	Other	Electric Facility	Human Error	Soccer ball?
240	PG&E	11/17/14	17.15	38.0444400	-122.8006500	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Fire Agency	1 SPAN LD SIDE OF FUCO 6803		12,000	Conductor	Overhead	Yes	11/17/14	17.15	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Crossarm	Unknown	
241	PG&E	11/18/14	14.16	37.0353050	-122.0865650	Vegetation	Rural	< 0.25 Acres	Fire Agency	Felton Fire Dept.	101798988		21,000	Conductor	Overhead	Yes	11/18/14	14.16	Contact From Object	N.A.	N.A.	Vegetation	Electric Facility	Unknown	
242	PG&E	11/22/14	6.29	36.7472340	-119.7859090	Vegetation	Urban	< 3 meters	Fire Agency	FRESNO CITY FIRE	MTR# 1008712302		12,000	Conductor	Overhead	Yes	11/22/14	6.29	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
243	PG&E	11/23/14	5.45	40.1627590	-122.2381560	Vegetation	Urban	< 3 meters	Self Extinguished		MTR #1008299414		12,000	Conductor	Overhead	Yes	11/23/14	5.45	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
244	PG&E	11/24/14	15.29	37.4401800	-121.9187970	Vegetation	Urban	< 0.25 Acres	Fire Agency	Milpitas Fire Department	back yard of 599 Redwood ave		0 - 750	Unknown	Overhead	No			Unknown	N.A.	N.A.	N.A.	Unknown		
245	PG&E	11/28/14	1.17	37.9892410	-122.3146080	Vegetation	Urban	< 0.25 Acres	Fire Agency	Fire Agency	101425748	AT&T	0 - 750	Conductor	Overhead	No			Unknown	N.A.	N.A.	N.A.	Unknown		
246	PG&E	11/29/14	14.21	36.7278300	-119.7012190	Other	Urban	Structure Only	Fire Agency	Fire Agency	100814277	AT&T	0 - 750	Conductor	Overhead	No			Unknown	N.A.	N.A.	N.A.	Unknown	roof burned	
247	PG&E	12/8/14	9.51	36.8374800	-119.7899800	Vegetation	Urban	< 3 meters	Self Extinguished		101780312		21,000	Conductor	Overhead	Yes	12/8/14	9.51	Contact From Object	N.A.	N.A.	Animal	Electric Facility	Unknown	
248	PG&E	12/8/14	18.33	37.4630670	-122.2600940	Vegetation	Urban	< 0.25 Acres	Fire Agency	REDWOOD CITY FD	103030013	AT&T	12,000	Conductor	Overhead	Yes	12/8/14	18.33	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
249	PG&E	12/12/14	4.07	36.6378500	-121.8124600	Vegetation	Rural	< 3 meters	Utility: PG&E		101762582	AT&T	12,000	Conductor	Overhead	Yes	12/12/14	4.07	Contact From Object	N.A.	N.A.	Vegetation	Unknown		
250	PG&E	12/12/14	22.15	37.9817950	-122.2670467	Vegetation	Rural	< 3 meters	Unknown		IFO 75 RANCH RD WOODSIDE		12,000	Conductor	Overhead	Yes	12/12/14	22.15	Contact From Object	N.A.	N.A.	Vegetation	Electric Facility	Unknown	
251	PG&E	12/14/14	4.52	38.4200500	-120.8236890	Other	Rural	Structure Only	Fire Agency	Sutter creek fire	101238361		12,000	Conductor	Overhead	Yes	12/14/14	4.52	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	vehicle burned	
252	PG&E	12/19/14	13.50	37.4609790	-122.1768610	Vegetation	Urban	< 3 meters	Fire Agency	MENLO PARK	100298576	AT&T	12,000	Conductor	Overhead	Yes	12/19/14	13.50	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
253	PG&E	12/25/14	10.50	36.3837160	-121.8663000	Vegetation	Rural	< 3 meters	Fire Agency	Mid Valley FD ?	101669474	AT&T	12,000	Conductor	Overhead	Yes	12/25/14	10.50	Contact From Object	N.A.	N.A.	Vegetation	Electric Facility	Unknown	
254	PG&E	12/29/14	11.58	38.1661300	-122.2536090	Other	Urban	Structure Only	Fire Agency	VALLEJO FD	1740 BROADWAY		12,000	Conductor	Overhead	Yes	12/29/14	11.58	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	mobile home burned	
255	PG&E	12/30/14	9.00	38.4058600	-120.5153240	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	674 SMITTY LN		12,000	Conductor	Overhead	Yes	12/30/14	9.00	Contact From Object	N.A.	N.A.	Vegetation	Electric Facility	Unknown	
256	PG&E	12/30/14	15.53	38.0165160	-122.1366200	Other	Urban	Structure Only	Fire Agency	MARTINEZ FIRE	100444078		21,000	Conductor	Overhead	Yes	12/30/14	15.53	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	vehicle burned	
257	PG&E	01/08/15	15.18	37.36631	-121.88317	Other	Rural	< 0.25 Acres	Fire Agency	SJFD	100566657	None	12,000	Conductor	Subsurface	Yes	1/8/15	15.18	Contact From Object	N.A.	N.A.	Vehicle	Electric Facility	Human Error	
258	PG&E	01/10/15	13.07	38.08903	-122.20689	Vegetation	Urban	< 0.25 Acres	Utility: PG&E		102217759		12,000	Conductor	Overhead	Yes	1/10/15	13.07	Contact From Object	N.A.	N.A.	Animal	Electric Facility	Unknown	
259	PG&E	01/16/15	7.07	38.77533	-122.70044	Vegetation	Rural	< 3 meters	Fire Agency	Cal Fire	102167494	Pacific Bell	12,000	Conductor	Overhead	No			Unknown	N.A.	N.A.	Unknown	Unknown		
260	PG&E	01/28/15	3.51	37.05394	-122.15867	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE			12,000	Conductor	Overhead	Yes	1/28/15	3.51	Contact From Object	N.A.	N.A.	Vegetation	Electric Facility	Unknown	
261	PG&E	02/06/15	6.01	38.60589	-121.02213	Vegetation	Rural	< 3 meters	Fire Agency	Fire Agency	6661 Ryan Ranch Road, El Dorado Hills		21,000	Conductor	Overhead	Yes	2/6/15	6.01	Contact From Object	N.A.	N.A.	Vegetation	Electric Facility	Unknown	
262	PG&E	02/06/15	14.08	36.40321	-121.91088	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CAL FIRE	loadsides of 40283		12,000	Conductor	Overhead	Yes	2/6/15	14.08	Contact From Object	N.A.	N.A.	Vegetation	Electric Facility	Unknown	
263	PG&E	02/07/15	15.13	38.08712	-122.54963	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	NOVATO FIRE DEPARTMENT	103598139		12,000	Conductor	Overhead	Yes	2/7/15	15.13	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown		
264	PG&E	02/07/15	18.38	40.46741	-123.65446	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	mile marker 36.61, hwy 36, bridgeville		12,000	Conductor	Overhead	Yes	2/7/15	18.38	Equipment/ Facility Failure	N.A.	N.A.	Vegetation	Electric Facility	Unknown	
265	PG&E	02/13/15	16.01	35.36284	-118.96615	Vegetation	Urban	< 0.25 Acres	Fire Agency	Bakersfield FD	512 Wilma Street, Bakersfield		0 - 750	Conductor	Overhead	Yes	2/13/15	16.01	Contact From Object	N.A.	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused
266	PG&E	02/16/15	11.08	37.35996	-120.85233	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	10206051		12,000	Conductor	Overhead	Yes	2/16/15	11.08	Contact From Object	N.A.	N.A.	Vehicle	Human Error		
267	PG&E	02/17/15	16.46	39.76284	-121.58268	Vegetation	Urban	< 3 meters	Fire Agency	butte county	100324934	Pacific Bell	12,000	Conductor	Overhead	Yes	2/17/15	16.46	Contact From Object	N.A.	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused
268	PG&E	02/22/15	14.20	38.81600	-122.18318	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Caspy	101592201		21,000	Conductor	Overhead	Yes	2/22/15	14.20	Contact From Object	N.A.	N.A.	Vehicle	Pole	Human Error	
269	PG&E	02/23/15	2.05	39.30273	-121.01749	Vegetation	Rural	< 3 meters	Fire Agency	NEVADA CITY FIRE	100986316		12,000	Conductor	Overhead	Yes	2/23/15	2.05	Contact From Object	N.A.	N.A.	Vegetation	Electric Facility	Unknown	
270	PG&E	02/23/15	13.25	38.50455	-122.74081	Vegetation	Rural	< 0.25 Acres	Fire Agency	RINCON VALLEY	BEHIND 4870 CARRIAGE LN SANTA ROSA		12,000	Conductor	Overhead	Yes	2/23/15	13.25	Contact From Object	N.A.	N.A.	Vegetation	Electric Facility	Unknown	
271	PG&E	02/25/15	2.34	36.75618	-119.78001	Vegetation	Urban	< 3 meters	Fire Agency	CITY OF FRESNO	100869017	Pacific Bell	12,000	Fuse	Overhead	Yes	2/25/15	2.34	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown		
272	PG&E	02/25/15	16.42	34.89210	-120.50397	Vegetation	Rural	< 3 meters	Customer				0 - 750	Conductor	Overhead	Yes	2/25/15	16.42	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
273	PG&E	03/04/15	18.44	38.99945	-122.75451	Vegetation	Rural	< 0.25 Acres	Fire Agency	Kelseyville FD	102156367	Pacific Bell	12,000	Conductor	Overhead	Yes	3/4/15	18.44	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
274	PG&E	03/07/15	13.35	38.70909	-122.64837	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	14417 western mine rd, Middletown		12,000	Conductor	Overhead	Yes	3/7/15	13.35	Contact From Object	N.A.	N.A.	Vegetation	Electric Facility	Unknown	
275	PG&E	03/09/15	9.36	38.73283	-120.75239	Building	Urban	Structure Only	Unknown		101399208	Pacific Bell	12,000	Conductor	Overhead	Yes	3/9/15	9.36	Contact From Object	N.A.	N.A.	Animal	Electric Facility	Unknown	
276	PG&E	03/14/15	2.30	38.90381	-122.75790	Vegetation	Rural	< 0.25 Acres	Unknown		9210 Wildcat Road, Kelseyville		12,000	Conductor	Overhead	Yes	3/14/15	2.30	Contact From Object	N.A.	N.A.	Vegetation	Electric Facility	Unknown	
277	PG&E	03/14/15	14.17	38.82525	-121.13632	Vegetation	Rural	< 3 meters	Fire Agency	LOOMIS FIRE	100051369	Pacific Bell	0 - 750	Conductor	Overhead	No			Contact From Object	N.A.	N.A.	Balloons	Electric Facility	Human Error	
278	PG&E	03/14/15	22.09	36.89154	-121.71191	Vegetation	Urban	< 0.25 Acres	Fire Agency	CAL FIRE	103523395		21,000	Conductor	Overhead	Yes	3/14/15	22.09	Contact From Object	N.A.	N.A.	Vegetation	Electric Facility	Unknown	
279	PG&E	03/15/15	3.26	35.36933	-118.92904	Vegetation	Rural	< 0.25 Acres	Unknown		100216241	Pacific Bell	0 - 750	Conductor	Overhead	No			Unknown	N.A.	N.A.	Unknown	Unknown		
280	PG&E	03/15/15	3.38	36.93396	-119.78022	Vegetation	Rural	< 3 meters	Unknown		101121519	None	21,000	Conductor	Overhead	Yes	3/15/15	3.38	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown		
281	PG&E	03/15/15	22.47	38.33457	-120.53253	Vegetation	Rural	< 3 meters	Fire Agency	CAL FIRE	103106530		12,000	Conductor	Overhead	Yes	3/15/15	22.47	Contact From Object	N.A.	N.A.	Vehicle	Pole	Human Error	
282	PG&E	03/19/15	20.11	3																					

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X	
2	Utility Name	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes (Optional):	
351	PG&E	06/05/15	9:58	40.10703	-123.71422	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CAL FIRE	100986799		12,000	Conductor	Overhead	Yes	6/5/15	9:58	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	tie wire	
352	PG&E	06/05/15	14:40	37.95777	-120.45191	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	101012484		17,000	Conductor	Overhead	Yes	6/5/15	14:40	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
353	PG&E	06/05/15	15:15	36.77591	-119.77027	Vegetation	Urban	< 0.25 Acres	Fire Agency	CITY OF FRESNO	100857009	Pacific Bell	0 - 750	Transformer	Overhead	Yes	6/5/15	15:15	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown		
354	PG&E	06/05/15	22:13	38.77290	-121.46992	Vegetation	Rural	< 3 meters	Fire Agency	WATER	100064053		12,000	Capacitor Bank	Overhead	Yes	6/5/15	22:13	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown		
355	PG&E	06/06/15	11:24	39.80295	-121.90643	Vegetation	Rural	< 3 meters	Unknown		103433862	Pacific Bell	12,000	Conductor	Overhead	Yes	6/6/15	11:24	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
356	PG&E	06/06/15	13:50	36.98282	-120.03324	Vegetation	Rural	< 0.25 Acres	Unknown		101015092		12,000	Lightning Arrestor	Overhead	Yes	6/6/15	12:00	Equipment/ Facility Failure	Lightning Arrestor	N.A.	N.A.	Unknown		
357	PG&E	06/06/15	15:38	39.04089	-123.40189	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	11480 ANDERSON VALLEY WAY @ BRIDGE		12,000	Conductor	Overhead	Yes	6/6/15	15:38	Contact From Object	N.A.	N.A.	Vegetation	Electric Facility	Unknown	
358	PG&E	06/06/15	21:17	38.00575	-121.23822	Vegetation	Rural	< 0.25 Acres	Fire Agency	COUNTY FIRE	102135759	Pacific Bell	12,000	Conductor	Overhead	Yes	6/6/15	21:17	Contact From Object	N.A.	N.A.	Balloons	Electric Facility	Human Error	
359	PG&E	06/07/15	5:05	36.69606	-119.74880	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	FRESNO FIRE	103339346		12,000	Conductor	Overhead	Yes	6/7/15	5:05	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown		
360	PG&E	06/07/15	14:53	36.32160	-121.28363	Vegetation	Rural	< 0.25 Acres	Fire Agency	monterey county	peach and thorne greenfield	Pacific Bell	12,000	Unknown	Overhead	Yes	6/7/15	14:53	Unknown	N.A.	N.A.	Unknown			
361	PG&E	06/07/15	17:48	38.21794	-121.97524	Vegetation	Rural	100 - 299 Acres	Fire Agency	Suisun fire protection distict.	c/o's 278361		21,000	Conductor	Overhead	Yes	6/7/15	17:48	Vandalism/Theft	N.A.	N.A.	N.A.	Unknown	gun-shot conductor	
362	PG&E	06/08/15	14:18	38.17956	-120.95899	Vegetation	Rural	10 - 99 Acres	Fire Agency	CAL FIRE	102048579	Pacific Bell	12,000	Conductor	Overhead	Yes	6/8/15	14:18	Contact From Object	N.A.	N.A.	Vehicle	Pole	Human Error	
363	PG&E	06/08/15	16:12	38.11554	-122.55622	Vegetation	Rural	< 3 meters	Fire Agency	novato fire	front yard equestrian ct		0 - 750	Conductor	Overhead	No			Contact From Object	N.A.	N.A.	Vegetation	Electric Facility	Unknown	
364	PG&E	06/08/15	16:15	39.82356	-123.80531	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CAL FIRE	2 spans loadside 1741		12,000	Conductor	Overhead	Yes	6/8/15	16:15	Contact From Object	N.A.	N.A.	Vegetation	Electric Facility	Unknown	
365	PG&E	06/08/15	17:38	37.95220	-121.94406	Vegetation	Urban	< 3 meters	Unknown		17125		0 - 750	Conductor	Overhead	Yes	6/8/15	17:38	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
366	PG&E	06/08/15	18:32	37.94040	-122.07849	Vegetation	Urban	< 3 meters	Fire Agency	CONTRA COSTA FIRE	100462348	Pacific Bell	0 - 750	Conductor	Overhead	Yes	6/8/15	18:32	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown		
367	PG&E	06/09/15	1:19	40.54242	-122.23906	Vegetation	Rural	< 3 meters	Customer		101450096	Frontier	12,000	Transformer	Overhead	Yes	6/9/15	1:19	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown		
368	PG&E	06/09/15	11:51	36.48868	-119.58237	Building	Rural	Structure Only	Fire Agency	tulare county fire	4390 ave 352		12,000	Conductor	Overhead	Yes	6/9/15	11:51	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown		
369	PG&E	06/09/15	13:10	38.11758	-121.15094	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	WATERLOO MORADA FIRE DISTRICT	102076487		21,000	Conductor	Overhead	Yes	6/9/15	13:10	Contact From Object	N.A.	N.A.	Vehicle	Pole	Human Error	
370	PG&E	06/09/15	15:24	38.36510	-122.25410	Vegetation	Rural	10 - 99 Acres	Fire Agency	CAL FIRE	load side 2987	Yes	21,000	Conductor	Overhead	Yes	6/9/15	15:24	Contact From Object	N.A.	N.A.	Vegetation	Electric Facility	Unknown	
371	PG&E	06/09/15	16:20	38.38222	-122.43156	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	102269716	Pacific Bell	21,000	Unknown	Overhead	Yes	6/9/15	16:20	Unknown	N.A.	N.A.	N.A.	Unknown		
372	PG&E	06/09/15	21:21	38.93940	-121.24670	Vegetation	Rural	< 3 meters	Unknown		100035304	Pacific Bell	12,000	Conductor	Overhead	Yes	6/9/15	21:21	Contact From Object	N.A.	N.A.	Vegetation	Electric Facility	Unknown	
373	PG&E	06/10/15	12:00	39.13763	-121.63145	Vegetation	Urban	< 0.25 Acres	Fire Agency	YUBA CITY	101320887		12,000	Conductor	Overhead	Yes	6/10/15	12:00	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
374	PG&E	06/10/15	17:02	36.96710	-120.03552	Vegetation	Rural	< 3 meters	Unknown		101219691	Pacific Bell	0 - 750	Conductor	Overhead	No			Unknown	N.A.	N.A.	N.A.	Unknown		
375	PG&E	06/10/15	21:43	37.63912	-121.89433	Vegetation	Rural	< 3 meters	Fire Agency	PLEASANTON FIRE DEPT	100927124	Pacific Bell	12,000	Conductor	Overhead	Yes	6/10/15	21:43	Contact From Object	N.A.	N.A.	Vegetation	N.A.	Unknown	
376	PG&E	06/11/15	18:32	38.82212	-121.30605	Vegetation	Urban	< 0.25 Acres	Fire Agency	CITY OF ROCKLIN CAL FIRE	103861493		21,000	Switch	Overhead	Yes	6/11/15	18:32	Equipment/ Facility Failure	Switch	N.A.	N.A.	Unknown		
377	PG&E	06/12/15	9:04	39.39398	-122.22991	Vegetation	Rural	< 0.25 Acres	Fire Agency	WILLOWS FIRE DEPT.	100326792		21,000	Conductor	Overhead	Yes	6/12/15	9:04	Contact From Object	N.A.	N.A.	Other	Electric Facility	Human Error	crop duster hit line
378	PG&E	06/12/15	9:24	37.07609	-120.20027	Vegetation	Rural	< 3 meters	Self Extinguished		103204949		0 - 750	Conductor	Overhead	Yes	6/12/15	9:24	Unknown	N.A.	N.A.	N.A.	Unknown		
379	PG&E	06/12/15	10:48	38.42732	-122.85903	Vegetation	Rural	< 0.25 Acres	Fire Agency	GRATON FIRE DEP.	102023459	Pacific Bell	12,000	Conductor	Overhead	Yes	6/12/15	10:48	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
380	PG&E	06/12/15	13:07	40.40775	-122.41037	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CAL FIRE	ACROSS STREET FROM 4139 OLD HAPPY VALLEY RD		12,000	Lightning Arrestor	Overhead	No			Equipment/ Facility Failure	Lightning Arrestor	N.A.	N.A.	Unknown		
381	PG&E	06/12/15	16:01	37.92517	-122.07817	Vegetation	Urban	< 3 meters	Fire Agency	WALNUT CREEK FIRE	100478251	Pacific Bell	0 - 750	Transformer	Overhead	Yes	6/12/15	16:01	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown		
382	PG&E	06/12/15	23:32	39.23077	-121.15594	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	10903 PROSPECTOR RD ROUGH AND READY	Pacific Bell	21,000	Conductor	Overhead	Yes	6/12/15	23:32	Contact From Object	N.A.	N.A.	Vegetation	Electric Facility	Unknown	
383	PG&E	06/13/15	12:50	35.27221	-118.91221	Vegetation	Rural	< 3 meters	Fire Agency	Kern Co Fire Dept	103779942		0 - 750	Conductor	Overhead	No			Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
384	PG&E	06/14/15	12:19	39.74516	-121.84249	Vegetation	Urban	< 3 meters	Fire Agency	CHICO FIRE DEPT	100426666	Pacific Bell	0 - 750	Conductor	Overhead	No			Wire-Wire Contact	N.A.	N.A.	N.A.	Unknown		
385	PG&E	06/14/15	13:50	36.93633	-119.87030	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CAL FIRE	1215 mesa, madera		12,000	Conductor	Overhead	Yes	6/14/15	13:50	Contact From Object	N.A.	N.A.	Animal	Electric Facility	Unknown	
386	PG&E	06/15/15	15:35	37.18518	-121.75950	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	San Jose city	100618215	Pacific Bell	21,000	Conductor	Overhead	Yes	6/15/15	15:35	Contact From Object	N.A.	N.A.	Balloons	Electric Facility	Human Error	
387	PG&E	06/16/15	10:40	38.00621	-122.10918	Vegetation	Urban	.26 - 9.99 Acres	Unknown		1wr 008/058		115,000	Conductor	Overhead	Yes	6/16/15	10:40	Contact From Object	N.A.	N.A.	Other	Electric Facility	Unknown	bird-dropped material
388	PG&E	06/16/15	11:27	39.03816	-122.92637	Vegetation	Rural	< 0.25 Acres	Fire Agency	LAKEPORT FIRE	102165174	Pacific Bell	0 - 750	Conductor	Overhead	Yes	6/16/15	11:27	Contact From Object	N.A.	N.A.	Vegetation	Electric Facility	Unknown	
389	PG&E	06/17/15	10:32	37.76881	-120.90776	Vegetation	Rural	< 3 meters	Fire Agency	Escalon fire dept.	102090776		17,000	Conductor	Overhead	Yes	6/17/15	10:32	Contact From Object	N.A.	N.A.	Vehicle	Pole	Human Error	
390	PG&E	06/17/15	15:49	37.35161	-120.64202	Vegetation	Urban	< 3 meters	Fire Agency	CAL FIRE	8503 LONGVIEW ATWATER		0 - 750	Conductor	Overhead	No			Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
391	PG&E	06/17/15	18:35	35.33024	-119.01164	Vegetation	Urban	< 3 meters	Fire Agency	BCFD	100155778	Pacific Bell	21,000	Conductor	Overhead	Yes	6/17/15	18:35	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
392	PG&E	06/19/15	12:14	34.83564	-120.38433	Vegetation	Rural	10 - 99 Acres	Fire Agency	SANTA BARBARA COUNTY FIRE DEPT	103015189		12,000	Conductor	Overhead	Yes	6/19/15	12:14	Contact From Object	N.A.	N.A.	Animal	Electric Facility	Unknown	
393	PG&E	06/19/15	20:09	39.15973	-121.48652	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	101308410	Pacific Bell	0 - 750	Conductor	Overhead	Yes	6/19/15	20:09	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown		
394	PG&E	06/20/15	1:28	36.25480	-119.64349	Vegetation	Rural	< 3 meters	Fire Agency	CAL FIRE	100021218		12,000	Conductor	Overhead	Yes	6/20/15	1:28	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
395	PG&E	06/21/15	1:32	39.00797	-121.84400	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CAL FIRE	100021218		12,000	Conductor	Overhead	Yes	6/21/15	1:32	Contact From Object	N.A.	N.A.	Balloons	Electric Facility	Human Error	
396	PG&E	06/21/15	3:17	39.09559	-121.54211	Vegetation	Rural	10 - 99 Acres	Fire Agency	Wheatland fire dept	Transmission Sw 159 on the Pease - Rio-Oso 115kv line		115,000	Transformer	Overhead	Yes	6/21/15	3:17	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	Potential transformer	
397	PG&E	06/21/15	12:07	36.72248	-121.76673	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	NORTH COUNTY FIRE DEPARTMENT #1428		21,000	Conductor	Overhead	No			Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown			
398	PG&E	06/21/15	12:10	37.92730	-122.31824	Vegetation	Urban	< 0.25 Acres	Fire Agency	RICHMOND	KEY BLVD														

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X
2	Utility Name	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes (Optional):
467	PG&E	07/16/15	19:11	37.19894	-119.77123	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CAL FIRE	20334 ROAD 400		12,000	Conductor	Overhead	Yes	7/16/15	19:11	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
468	PG&E	07/16/15	19:27	37.76190	-120.82127	Vegetation	Urban	< 3 meters	Self Extinguished		102333491	Pacific Bell	0 - 750	Conductor	Overhead	Yes	7/16/15	19:27	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
469	PG&E	07/17/15	0:20	36.96718	-119.64365	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	100651276		0 - 750	Conductor	Overhead	Yes	7/17/15	0:20	Wire-Wire Contact	N.A.	N.A.	Unknown		
470	PG&E	07/17/15	0:53	34.86820	-120.32300	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	SANTA BARBARA COUNTY FIRE DEPT	EAST OF SISQUOOC SUB		12,000	Conductor	Overhead	Yes	7/17/15	0:53	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
471	PG&E	07/17/15	17:18	38.55961	-121.64346	Vegetation	Rural	< 3 meters	Unknown		121.64346		12,000	Conductor	Overhead	Yes	7/17/15	17:18	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
472	PG&E	07/18/15	17:00	38.83820	-123.82868	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CAL FIRE	In mid span between 2 poles. @ 46735 co. rd. 32B davis off HWY 1 PA		12,000	Conductor	Overhead	Yes	7/18/15	17:00	Contact From Object	N.A.	Other	Electric Facility	Unknown	
473	PG&E	07/18/15	18:59	39.71199	-123.32836	Vegetation	Rural	.26 - 9.99 Acres	Unknown				12,000	Conductor	Overhead	Yes	7/18/15	18:59	Contact From Object	N.A.	Other	Electric Facility	Unknown	
474	PG&E	07/19/15	9:44	35.21499	-120.61437	Vegetation	Rural	< 3 meters	Fire Agency	CAL FIRE	101930875		12,000	Conductor	Overhead	Yes	7/19/15	9:44	Contact From Object	N.A.	Other	Electric Facility	Weather	lightning strike
475	PG&E	07/19/15	19:36	38.65629	-121.79353	Vegetation	Urban	< 3 meters	Fire Agency	WOODLAND FIRE DEPT.	BASE OF TRANSMISSION / DISTRIBUTION POLE = 1/P/S/O FUSES # 8973		0 - 750	Conductor	Overhead	No			Contact From Object	N.A.	Animal	Electric Facility	Unknown	
476	PG&E	07/20/15	15:15	37.76203	-120.86637	Vegetation	Urban	< 0.25 Acres	Fire Agency	OAKDALE CITY FIRE			0 - 750	Conductor	Overhead	No			Unknown	N.A.	N.A.	Unknown		
477	PG&E	07/21/15	8:44	39.11813	-123.20113	Vegetation	Rural	< 0.25 Acres	Fire Agency	UKIAH FIRE	102178810	Pacific Bell	0 - 750	Unknown	Overhead	No			Unknown	N.A.	N.A.	Unknown		
478	PG&E	07/21/15	10:46	37.18055	-121.06247	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	e/o dmc s/o cotterwood		12,000	Conductor	Overhead	Yes	7/21/15	10:46	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
479	PG&E	07/22/15	11:03	38.12063	-122.24813	Vegetation	Urban	< 3 meters	Fire Agency	VALLEJO FD	102308149		0 - 750	Conductor	Overhead	No			Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
480	PG&E	07/22/15	14:21	38.79354	-120.71402	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	sl 3204 stope dr		12,000	Conductor	Overhead	Yes	7/22/15	14:21	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
481	PG&E	07/23/15	13:14	36.23983	-119.77674	Vegetation	Rural	< 0.25 Acres	Fire Agency	KINGS COUNTY	103242492		12,000	Conductor	Overhead	Yes	7/23/15	13:14	Contact From Object	N.A.	Vehicle	Pole	Human Error	
482	PG&E	07/23/15	20:04	38.00746	-121.84819	Vegetation	Rural	< 0.25 Acres	Unknown		Tower 006/081	YES	60,000	Unknown	Overhead	Yes	7/23/15	20:04	Unknown	N.A.	N.A.	Unknown		
483	PG&E	07/24/15	4:10	38.45227	-121.71819	Vegetation	Rural	< 0.25 Acres	Fire Agency	Dixon fire dept	101575623	Pacific Bell	12,000	Conductor	Overhead	Yes	7/24/15	4:10	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
484	PG&E	07/24/15	14:30	36.69127	-119.03117	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CAL FIRE	46970 DUNLAP RD	YES	0 - 750	Transformer	Overhead	Yes	7/24/15	14:30	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
485	PG&E	07/25/15	14:52	38.92645	-121.29455	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	wise rd west of gladding lincoln	None	12,000	Conductor	Overhead	Yes	7/25/15	14:52	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
486	PG&E	07/25/15	19:34	39.78477	-121.86082	Vegetation	Urban	< 0.25 Acres	Fire Agency	CAL FIRE	3668 hicks lane, chico		12,000	Conductor	Overhead	Yes	7/25/15	19:34	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
487	PG&E	07/26/15	12:25	39.15861	-121.06344	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	15499 ALLISON RANCHO RD		12,000	Conductor	Overhead	Yes	7/26/15	12:25	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
488	PG&E	07/27/15	9:41	37.65653	-121.75705	Vegetation	Rural	< 0.25 Acres	Fire Agency	LPFD	100926006	Pacific Bell	0 - 750	Conductor	Overhead	No			Contact From Object	N.A.	Animal	Electric Facility	Unknown	
489	PG&E	07/27/15	13:07	37.76730	-121.41998	Vegetation	Rural	< 0.25 Acres	Fire Agency	TRACY FIRE DEPT	AT C258; S/S ARBOR W/ MACARTHUR	None	0 - 750	Other	Overhead	No			Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
490	PG&E	07/27/15	15:33	38.41829	-122.71671	Building	Urban	.26 - 9.99 Acres	Fire Agency	CAL FIRE	2180 Corby Ave. Santa Rosa	None	0 - 750	Conductor	Overhead	No			Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
491	PG&E	07/27/15	15:57	39.07114	-121.47278	Vegetation	Rural	< 0.25 Acres	Fire Agency	Wheatland fire dept	101324044		12,000	Other	Overhead	Yes	7/27/15	15:57	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	Booster
492	PG&E	07/28/15	12:15	40.90857	-124.07159	Vegetation	Rural	< 0.25 Acres	Fire Agency	AGENCY3761	100973761	Pacific Bell	12,000	Lightning Arrestor	Overhead	Yes	7/28/15	12:15	Equipment/ Facility Failure	Lightning Arrestor	N.A.	N.A.	Unknown	
493	PG&E	07/28/15	12:19	37.76431	-121.34425	Vegetation	Rural	< 3 meters	Fire Agency	tracy fire dept	w/ berry ave on canal Blvd	Pacific Bell	12,000	Conductor	Overhead	Yes	7/28/15	12:19	Contact From Object	N.A.	Vehicle	Pole	Human Error	
494	PG&E	07/28/15	12:32	37.94288	-120.94398	Vegetation	Rural	< 3 meters	Fire Agency	CAL FIRE	Waverly Road and HWY 4, Farmington		0 - 750	Conductor	Overhead	No			Contact From Object	N.A.	Animal	Electric Facility	Unknown	
495	PG&E	07/29/15	13:30	38.55494	-122.83032	Vegetation	Urban	< 3 meters	Unknown		1031 Starr View Drive, Windsor		0 - 750	Conductor	Overhead	No			Contact From Object	N.A.	Other	Electric Facility	Human Error	hit by boom of bucket t
496	PG&E	07/29/15	23:34	37.36622	-121.84381	Vegetation	Urban	< 3 meters	Fire Agency	SJFD	IRO 751 FLEMING AVE IN FIELD NEAR DRY CREEK BED		12,000	Conductor	Overhead	Yes	7/29/15	23:34	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
497	PG&E	07/30/15	14:26	38.34592	-122.31054	Vegetation	Urban	< 0.25 Acres	Unknown	unknown	In ditch at base of pole. 12 by 60	Pacific Bell	0 - 750	Unknown	Overhead	No			Unknown	N.A.	N.A.	Unknown		
498	PG&E	07/30/15	14:55	38.44481	-121.82692	Building	Urban	Structure Only	Fire Agency	dixon fire dept	103309947		12,000	Transformer	Overhead	Yes	7/30/15	14:55	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
499	PG&E	07/30/15	15:19	39.23214	-121.05674	Vegetation	Urban	.26 - 9.99 Acres	Fire Agency	GRASS VALLEY FIRE DEPT	BEHIND 272 HUGHES RD. GRASS VALLEY		12,000	Conductor	Overhead	Yes	7/30/15	15:19	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
500	PG&E	07/30/15	17:38	40.52027	-122.23259	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	MTR 10061916		12,000	Conductor	Overhead	Yes	7/30/15	17:38	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
501	PG&E	07/30/15	17:56	37.90209	-120.17386	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CAL FIRE	101019808		17,000	Conductor	Overhead	Yes	7/30/15	17:56	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	osprey nest
502	PG&E	07/30/15	19:11	37.81024	-120.12872	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CAL FIRE			17,000	Conductor	Overhead	Yes	7/30/15	19:11	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
503	PG&E	07/31/15	15:57	36.79744	-119.81889	Vegetation	Urban	< 3 meters	Fire Agency	fresno fire dept	100856564	Pacific Bell	0 - 750	Conductor	Overhead	No			Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
504	PG&E	07/31/15	19:36	35.39864	-118.98998	Vegetation	Urban	< 0.25 Acres	Fire Agency	CITY OF BAKERSFIELD	100164905	Pacific Bell	0 - 750	Conductor	Overhead	No			Unknown	N.A.	N.A.	Unknown		
505	PG&E	07/31/15	22:45	38.38045	-120.56283	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CAL FIRE	ACROSS FROM 1958 QUAIL LN WEST POINT	None	12,000	Conductor	Overhead	Yes	7/31/15	22:45	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
506	PG&E	08/01/15	7:15	36.40289	-121.90944	Vegetation	Rural	< 0.25 Acres	Fire Agency	fire com	3spans roadside of 40283		12,000	Conductor	Overhead	Yes	8/1/15	7:15	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
507	PG&E	08/01/15	14:30	34.95239	-120.29522	Vegetation	Rural	10 - 99 Acres	Unknown	unknown	101868639		12,000	Conductor	Overhead	Yes	8/1/15	14:30	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
508	PG&E	08/02/15	8:08	37.53385	-120.32769	Vegetation	Rural	< 0.25 Acres	Unknown	unknown	Pole 013/002		70,000	Conductor	Overhead	Yes	8/2/15	8:08	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
509	PG&E	08/02/15	13:48	37.87996	-122.52679	Vegetation	Urban	< 0.25 Acres	Fire Agency	mill valley FD	102276049	Pacific Bell	0 - 750	Conductor	Overhead	No			Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
510	PG&E	08/02/15	16:24	37.83172	-120.15471	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	101078992		12,000	Conductor	Overhead	Yes	8/2/15	16:24	Unknown	N.A.	N.A.	Unknown		
511	PG&E	08/03/15	0:07	40.50560	-122.34702	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	COTTONWOOD FIRE DEPT	101503428	Pacific Bell	12,000	Conductor	Overhead	Yes	8/3/15	0:07	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
512	PG&E	08/03/15	17:53	39.38101	-121.18939	Vegetation	Rural	10 - 99 Acres	Fire Agency	CAL FIRE	Pole 000/008		60,000	Conductor	Overhead	Yes	8/3/15	17:53	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
513	PG&E	08/04/15	16:05	40.08216	-121.15383	Vegetation	Rural	< 0.25 Acres	Fire Agency	USFS	100441220	None	0 - 750	Fuse	Overhead	Yes	8/4/15	16:05	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
514	PG&E	08/04/15	17:57	37.58791	-120.22898	Vegetation	Rural	< 0.25 Acres	Unknown	unknown	Str. 007/019		70,000	Conductor	Overhead	Yes	8/4/15	17:57	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
515	PG&E	08/05/15	15:13	37.31997	-120.50507	Vegetation	Urban	< 0.25 Acres	Fire Agency	CAL FIRE	101162540		0 - 750	Capacitor Bank										

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X
2	Utility Name	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes (Optional):
583	PG&E	09/06/15	13:37	40.16625	-122.25692	Vegetation	Urban	< 3 meters	Fire Agency	Red Bluff fire dept	at switch 3571	0 - 750	Conductor	Overhead	Yes	9/6/15	13:37	Contact From Object	N.A.	Balloons	Electric Facility	Human Error		
584	PG&E	09/06/15	19:27	34.61954	-120.25339	Vegetation	Rural	< 0.25 Acres	Fire Agency	Santa Barbara County Fire	meter# 1008400678	12,000	Conductor	Overhead	Yes	9/6/15	19:27	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
585	PG&E	09/06/15	19:40	37.51330	-121.94693	Vegetation	Urban	< 3 meters	Customer		100943889	0 - 750	Conductor	Overhead	No			Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
586	PG&E	09/07/15	0:05	37.69131	-122.13884	Vegetation	Urban	< 0.25 Acres	Fire Agency	SAN LEANDRO		12,000	Conductor	Overhead	Yes	9/7/15	0:05	Contact From Object	N.A.	Vehicle	Pole	Human Error		
587	PG&E	09/08/15	8:19	37.41316	-121.88199	Vegetation	Urban	< 3 meters	Fire Agency	MILPITAS FD	100561024	0 - 750	Conductor	Overhead	No			Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
588	PG&E	09/09/15	6:44	38.82895	-123.01578	Vegetation	Rural	< 3 meters	Fire Agency	CLOVERDALE FIRE	102039036	0 - 750	Capacitor Bank	Overhead	No			Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown		
589	PG&E	09/09/15	10:47	37.10405	-121.88526	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	100520291	12,000	Conductor	Overhead	Yes	9/9/15	10:47	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
590	PG&E	09/10/15	5:42	37.46093	-121.84342	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CAL FIRE	100619766	0 - 750	Capacitor Bank	Overhead	No			Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown		
591	PG&E	09/10/15	16:24	38.50487	-122.35346	Vegetation	Rural	10 - 99 Acres	Fire Agency	CAL FIRE	103159970	21,000	Conductor	Overhead	Yes	9/10/15	16:24	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
592	PG&E	09/10/15	18:39	40.75692	-123.79577	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CAL FIRE	Pole 096/004	115,000	Conductor	Overhead	Yes	9/10/15	18:39	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
593	PG&E	09/11/15	6:38	37.52319	-122.26541	Other	Urban	Structure Only	Fire Agency	sc		12,000	Conductor	Overhead	Yes	9/11/15	6:38	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
594	PG&E	09/11/15	8:15	38.10938	-122.86999	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	102293992	12,000	Conductor	Overhead	Yes	9/11/15	8:15	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
595	PG&E	09/11/15	17:28	37.79722	-121.27472	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	MANTECA/LATHROP FIRE DEPT	102105463	0 - 750	Capacitor Bank	Overhead	No			Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown		
596	PG&E	09/12/15	9:51	39.11644	-121.06930	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CAL FIRE	101394996	115,000	Conductor	Overhead	Yes	9/12/15	9:51	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
597	PG&E	09/12/15	11:05	38.60304	-120.67409	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE		0 - 750	Conductor	Overhead	No			Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
598	PG&E	09/12/15	11:36	35.35576	-119.04595	Vegetation	Urban	< 3 meters	Fire Agency	Bakersfield FD	100194486	0 - 750	Conductor	Overhead	No			Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused	
599	PG&E	09/13/15	8:48	37.72455	-121.32594	Vegetation	Rural	< 3 meters	Fire Agency	TRACY FIRE DEPT	CRNR OF KASSON AND LORENZEN	12,000	Conductor	Overhead	Yes	9/13/15	8:48	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
600	PG&E	09/13/15	18:24	39.26731	-121.88308	Vegetation	Rural	< 0.25 Acres	Customer			0 - 750	Conductor	Overhead	No			Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
601	PG&E	09/15/15	22:05	36.58739	-119.56865	Vegetation	Rural	< 0.25 Acres	Fire Agency	COUNTY FIRE	100878350	0 - 750	Conductor	Overhead	Yes	9/15/15	22:05	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
602	PG&E	09/16/15	0:18	37.99140	-121.66822	Vegetation	Rural	< 3 meters	Fire Agency	EAST COUNTY FIRE	100457468	21,000	Conductor	Overhead	Yes	9/16/15	0:18	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
603	PG&E	09/18/15	16:23	37.86909	-121.20633	Vegetation	Rural	< 0.25 Acres	Fire Agency	FRENCH CAMP FIRE	IN CANAL AT 5027 FRENCH CAMP RD	12,000	Conductor	Overhead	Yes	9/18/15	16:23	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
604	PG&E	09/18/15	17:05	37.89200	-120.45508	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CAL FIRE	101019893	17,000	Conductor	Overhead	Yes	9/18/15	17:05	Contact From Object	N.A.	Vehicle	Pole	Human Error		
605	PG&E	09/19/15	9:51	38.47550	-122.90691	Vegetation	Rural	< 0.25 Acres	Fire Agency	FORESTVILLE	103334444	12,000	Conductor	Overhead	Yes	9/19/15	9:51	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
606	PG&E	09/20/15	18:53	39.86379	-121.65991	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE		12,000	Conductor	Overhead	Yes	9/20/15	18:53	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
607	PG&E	09/21/15	4:06	38.65967	-121.04035	Vegetation	Urban	< 0.25 Acres	Fire Agency	CAL FIRE	101381383	12,000	Conductor	Overhead	Yes	9/21/15	4:06	Wire-Wire Contact	N.A.	N.A.	Unknown			
608	PG&E	09/21/15	14:23	40.47863	-122.77105	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	101381383 mile marker 29.1, e of hairpin turn	12,000	Conductor	Overhead	Yes	9/21/15	14:23	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
609	PG&E	09/21/15	16:33	38.24517	-122.04115	Vegetation	Urban	< 0.25 Acres	Fire Agency	FAIRFIELD FIRE DEPT	REAR OF 900 TAF T	12,000	Conductor	Overhead	Yes	9/21/15	16:33	Contact From Object	N.A.	Balloons	Electric Facility	Unknown		
610	PG&E	09/22/15	0:44	39.00780	-122.89376	Vegetation	Rural	< 0.25 Acres	Fire Agency	LAKEPORT FIRE	102159765	12,000	Conductor	Overhead	Yes	9/22/15	0:44	Contact From Object	N.A.	Vehicle	Pole	Human Error		
611	PG&E	09/22/15	15:55	39.12244	-121.63922	Vegetation	Urban	< 0.25 Acres	Fire Agency	YUBA CITY	101300036	12,000	Conductor	Overhead	Yes	9/22/15	15:55	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
612	PG&E	09/22/15	20:07	38.47786	-121.98948	Vegetation	Rural	< 0.25 Acres	Fire Agency	WINTERS?	101577611	12,000	Conductor	Overhead	Yes	9/22/15	20:07	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
613	PG&E	09/24/15	1:40	37.99362	-122.33375	Vegetation	Urban	< 0.25 Acres	Unknown		101426065	12,000	Conductor	Overhead	Yes	9/24/15	1:40	Contact From Object	N.A.	Vehicle	Pole	Human Error		
614	PG&E	09/24/15	3:58	39.92032	-122.38591	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	103132877	0 - 750	Unknown	Overhead	No			Unknown	N.A.	N.A.	N.A.	Unknown		
615	PG&E	09/24/15	4:30	38.67690	-123.31398	Vegetation	Rural	< 0.25 Acres	Unknown		Str. 041/007	60,000	Conductor	Overhead	Yes	9/24/15	4:30	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
616	PG&E	09/24/15	13:56	39.35078	-121.24544	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	9692 Rices-Texas Hill rd	12,000	Conductor	Overhead	Yes	9/24/15	13:56	Contact From Object	N.A.	Vehicle	Pole	Human Error		
617	PG&E	09/25/15	13:31	37.26100	-120.19905	Vegetation	Rural	10 - 99 Acres	Fire Agency	CAL FIRE	2 POLES EAST OF MTR#1009626581	12,000	Conductor	Overhead	Yes	9/25/15	13:31	Vandalism/Theft	N.A.	N.A.	N.A.	Unknown		
618	PG&E	09/25/15	17:28	38.71896	-120.76934	Vegetation	Rural	< 0.25 Acres	Fire Agency	el dorado F D	101405928	12,000	Conductor	Overhead	Yes	9/25/15	17:28	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	gun-shot conductor	
619	PG&E	09/26/15	14:24	37.98601	-121.23012	Vegetation	Rural	< 0.25 Acres	Fire Agency	waterloo/morada	102125315	0 - 750	Conductor	Overhead	No			Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
620	PG&E	09/28/15	4:42	38.78772	-121.20832	Vegetation	Urban	< 3 meters	Fire Agency	n/a	100058887	0 - 750	Capacitor Bank	Overhead	No			Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown		
621	PG&E	09/28/15	9:42	37.96233	-122.17651	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CAL FIRE	100458692	12,000	Conductor	Overhead	Yes	9/28/15	9:42	Contact From Object	N.A.	Balloons	Electric Facility	Human Error		
622	PG&E	09/28/15	18:10	38.13502	-122.47704	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CAL FIRE	1 mile north of 37 on lakeville	12,000	Conductor	Overhead	Yes	9/28/15	18:10	Contact From Object	N.A.	Vehicle	Pole	Human Error		
623	PG&E	09/29/15	2:52	38.33700	-121.86009	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	VACAVILLE FD	FRY RD @ CLARK	21,000	Conductor	Overhead	Yes	9/29/15	2:52	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
624	PG&E	09/29/15	19:05	35.41976	-118.94899	Vegetation	Urban	< 0.25 Acres	Fire Agency	KERN COUNTY FIRE DEPARTMENT	100193545	12,000	Conductor	Overhead	Yes	9/29/15	19:05	Vandalism/Theft	N.A.	N.A.	N.A.	Human Error	gun-shot conductor	
625	PG&E	09/29/15	19:46	37.97786	-121.71949	Vegetation	Urban	< 0.25 Acres	Fire Agency	OAKLEY FIRE DEPARTMENT	100470700	0 - 750	Conductor	Overhead	No			Contact From Object	N.A.	Animal	Electric Facility	Unknown		
626	PG&E	09/30/15	1:03	37.35421	-122.15916	Vegetation	Rural	< 3 meters	Utility: S&E		100520776	12,000	Conductor	Overhead	Yes	9/30/15	16:41	Contact From Object	N.A.	Vegetation	N.A.	Human Error	Third-party caused	
627	PG&E	09/30/15	17:25	38.57469	-120.68203	Vegetation	Rural	< 0.25 Acres	Fire Agency	el dorado county	7901 sheandoah ln	21,000	Conductor	Overhead	Yes	9/30/15	17:25	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
628	PG&E	09/30/15	19:38	39.21883	-122.24643	Vegetation	Rural	< 0.25 Acres	Fire Agency	williams fire demp	101641855	12,000	Conductor	Overhead	Yes	9/30/15	19:38	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
629	PG&E	10/01/15	2:43	39.66657	-121.77421	Vegetation	Rural	< 3 meters	Fire Agency	NOT KNOWN-GONE ON ARRIVAL	100345398	0 - 750	Capacitor Bank	Overhead	No			Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown		
630	PG&E	10/01/15	11:28	37.50880	-120.34464	Vegetation	Rural	< 0.25 Acres	Unknown		Pole 019/007	70,000	Conductor	Overhead	Yes	10/1/15	11:28	Contamination	N.A.	N.A.	N.A.	Weather		
631	PG&E	10/01/15	13:13	37.62911	-122.11534	Vegetation	Rural	< 0.25 Acres	Fire Agency	HAYWARD	X ST FROM 25920 EDEN LANDING RD	0 - 750	Conductor	Overhead	No			Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
632	PG&E	10/02/15	19:16	36.94544	-119.83020	Vegetation	Rural	< 3 meters	Fire Agency	CAL FIRE	101121403	21,000	Conductor	Overhead	Yes									

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X
2	Utility Name	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes (Optional):
699	PG&E	3/28/16	12.16	39.74275	-121.82024	Vegetation	URBAN	< 3 meters	Fire Agency	Chico FD	100338028	PACIFIC BELL	12,000	Conductor	Overhead	Yes	3/28/16	12:16	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
700	PG&E	4/1/16	4.25	35.01641	-118.98213	Vegetation	RURAL	< 3 meters	Fire Agency	Kern County FD	100194594	None	12,000	Other	Overhead	Yes	4/1/16	4:25	Equipment/Facility Failure	Other	N.A.	N.A.	Unknown	
701	PG&E	4/2/16	3.48	35.37034	-118.97521	Vegetation	URBAN	< 0.25 Acres	Fire Agency	KCFD	100244829	None	0 - 750	Conductor	Overhead	No			Equipment/Facility Failure	Conductor	N.A.	N.A.	Unknown	
702	PG&E	4/2/16	7.06	35.03071	-120.52785	Vegetation	RURAL	< 3 meters	Fire Agency	SAN LUIS CO FIRE	101892796	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	4/2/16	7:06	Equipment/Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
703	PG&E	4/3/16	6.54	40.41751	-122.21092	Other	RURAL	Structure Only	Fire Agency	COTTONWOOD FIRE DEPT	101488627	PACIFIC BELL	12,000	Conductor	Overhead	Yes	4/3/16	6:54	Contact From Object	N.A.	Vehicle	Pole	Human Error	
704	PG&E	4/3/16	12.01	38.68044	-123.12498	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	101968191	None	12,000	Conductor	Overhead	Yes	4/3/16	12:01	Equipment/Facility Failure	Conductor	N.A.	N.A.	Unknown	
705	PG&E	4/4/16	0.08	37.75674	-121.41933	Vegetation	URBAN	< 3 meters	Fire Agency	Tracy FD	102119421	PACIFIC BELL	12,000	Conductor	Overhead	Yes	4/4/16	0:08	Equipment/Facility Failure	Conductor	N.A.	N.A.	Unknown	
706	PG&E	4/7/16	17.07	35.34199	-119.01752	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Bakersfield FD	100245953	None	0 - 750	Conductor	Overhead	Yes	4/7/16	17:07	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
707	PG&E	4/8/16	13.14	39.04293	-121.10020	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	100086751	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	4/8/16	13:14	Contact From Object	N.A.	Vehicle	Pole	Human Error	
708	PG&E	4/13/16	19.28	40.49535	-124.12191	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	103659313	None	12,000	Conductor	Overhead	Yes	4/13/16	19:28	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
709	PG&E	4/14/16	14.16	36.15837	-119.56502	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Kings County FD	100766367	None	12,000	Other	Overhead	Yes	4/14/16	14:16	Equipment/Facility Failure	Other	N.A.	N.A.	Unknown	
710	PG&E	4/18/16	18.14	37.79381	-120.98419	Vegetation	URBAN	< 3 meters	Fire Agency	Escalon Fire	102332958	None	0 - 750	Other	Overhead	No			Equipment/Facility Failure	Other	N.A.	N.A.	Unknown	
711	PG&E	4/20/16	16.39	39.40237	-122.01414	Vegetation	RURAL	< 3 meters	Unknown	Unknown	101641171	None	12,000	Conductor	Overhead	Yes	4/20/16	16:39	Equipment/Facility Failure	Other	N.A.	N.A.	Unknown	
712	PG&E	4/21/16	3.20	38.19073	-122.24723	Vegetation	URBAN	< 0.25 Acres	Fire Agency	American Canyon FD	102295263	PACIFIC BELL	12,000	Conductor	Overhead	Yes	4/21/16	3:20	Equipment/Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
713	PG&E	4/21/16	9.25	39.29298	-123.76901	Vegetation	RURAL	< 3 meters	Customer	N.A.	103312287	None	0 - 750	Other	Overhead	No			Equipment/Facility Failure	Other	N.A.	N.A.	Unknown	
714	PG&E	4/22/16	17.10	37.88750	-121.68648	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Brentwood FD	100506567	None	0 - 750	Transformer	Overhead	No			Equipment/Facility Failure	Transformer	N.A.	N.A.	Unknown	
715	PG&E	4/22/16	22.02	35.34916	-119.05375	Vegetation	URBAN	< 3 meters	Customer	N.A.	100156969	Yes	0 - 750	Transformer	Overhead	Yes	4/22/16	22:02	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
716	PG&E	4/23/16	18.32	36.49064	-119.62925	Vegetation	RURAL	< 0.25 Acres	Fire Agency	city of selma	100818205	None	12,000	Conductor	Overhead	Yes	4/23/16	18:32	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
717	PG&E	4/24/16	11.10	34.70896	-120.46117	Vegetation	URBAN	.26 - 9.99 Acres	Fire Agency	Santa Barbara County FD	101898989	None	12,000	Conductor	Overhead	Yes	4/24/16	11:10	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
718	PG&E	4/25/16	12.34	36.47607	-119.79041	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	100875278	None	12,000	Conductor	Overhead	Yes	4/25/16	12:34	Equipment/Facility Failure	Pole	N.A.	N.A.	Unknown	
719	PG&E	4/25/16	14.50	35.54445	-119.08687	Vegetation	RURAL	.26 - 9.99 Acres	Fire Agency	Kern County FD	100207184	None	12,000	Conductor	Overhead	Yes	4/25/16	14:50	Other	N.A.	N.A.	N.A.	Human Error	
720	PG&E	4/27/16	14.02	36.51612	-119.25966	Vegetation	RURAL	< 3 meters	Unknown	Unknown	100755216	Pacific Bell	12,000	Conductor	Overhead	Yes	4/27/16	14:02	Contact From Object	N.A.	Other	Electric Facility	Unknown	bird nest
721	PG&E	4/30/16	17.59	38.31420	-120.90148	Vegetation	RURAL	< 3 meters	Fire Agency	Kern County FD	103083239	None	12,000	Conductor	Overhead	Yes	4/30/16	17:59	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
722	PG&E	4/30/16	16.40	37.00965	-120.63785	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Merced County FD	103083239	None	12,000	Conductor	Overhead	Yes	4/30/16	16:40	Unknown	N.A.	N.A.	N.A.	Unknown	
723	PG&E	4/30/16	13.41	38.25979	-122.02549	Vegetation	URBAN	< 3 meters	Fire Agency	Fairfield FD	101580133	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	4/30/16	13:41	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
724	PG&E	5/2/16	10.05	37.91481	-120.61782	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	101283625	CALAVERAS TELL	17,000	Conductor	Overhead	Yes	5/2/16	10:05	Contact From Object	N.A.	Other	Electric Facility	Unknown	bird dropped snake
725	PG&E	5/9/16	17.05	35.98605	-119.42935	Vegetation	RURAL	< 3 meters	Unknown	Unknown	100663426	None	0 - 750	Other	Overhead	No			Equipment/Facility Failure	Other	N.A.	N.A.	Unknown	
726	PG&E	5/11/16	12.15	37.67808	-122.47884	Vegetation	URBAN	< 3 meters	Fire Agency	DALY CITY	103565907	None	0 - 750	Conductor	Overhead	Yes	5/11/16	12:15	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
727	PG&E	5/12/16	10.47	35.30243	-120.71591	Vegetation	RURAL	< 3 meters	Self Extinguished	N.A.	101937429	None	12,000	Conductor	Overhead	Yes	5/12/16	10:47	Equipment/Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
728	PG&E	5/12/16	13.35	40.45382	-124.04774	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	101006413	None	12,000	Conductor	Overhead	Yes	5/12/16	13:35	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
729	PG&E	5/12/16	20.15	35.19217	-120.45631	Vegetation	RURAL	< 3 meters	Self Extinguished	N.A.	101857280	None	12,000	Conductor	Overhead	Yes	5/12/16	20:15	Equipment/Facility Failure	Conductor	N.A.	N.A.	Unknown	
730	PG&E	5/14/16	15.06	37.96876	-121.67042	Vegetation	RURAL	< 0.25 Acres	Unknown	Unknown	100472239	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	5/14/16	15:06	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
731	PG&E	5/14/16	22.06	39.16360	-121.56126	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Marysville FD	101312807	None	12,000	Switch	Overhead	Yes	5/14/16	22:06	Equipment/Facility Failure	Switch	N.A.	N.A.	Unknown	
732	PG&E	5/15/16	15.54	36.79479	-119.39659	Vegetation	RURAL	100 - 299 Acres	Fire Agency	Cal Fire	100729855	None	12,000	Conductor	Overhead	Yes	5/15/16	15:54	Equipment/Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
733	PG&E	5/16/16	8.59	37.92926	-121.21642	Vegetation	URBAN	< 3 meters	Fire Agency	Unknown	102130216	PACIFIC BELL	12,000	Conductor	Overhead	Yes	5/16/16	8:59	Contact From Object	N.A.	Vehicle	Pole	Human Error	
734	PG&E	5/16/16	11.34	38.77343	-121.46921	Vegetation	RURAL	.26 - 9.99 Acres	Fire Agency	Cal Fire	103323287	None	12,000	Conductor	Overhead	Yes	5/16/16	11:34	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	
735	PG&E	5/17/16	10.01	35.23788	-118.96390	Vegetation	RURAL	< 3 meters	Fire Agency	KCFD	100135909	None	0 - 750	Transformer	Overhead	Yes	5/17/16	10:01	Equipment/Facility Failure	Transformer	N.A.	N.A.	Unknown	
736	PG&E	5/17/16	16.03	35.38565	-119.00746	Vegetation	URBAN	< 3 meters	Fire Agency	Bakersfield FD	100246655	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	5/17/16	16:03	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
737	PG&E	5/18/16	18.24	39.73815	-123.15874	Vegetation	RURAL	< 3 meters	Fire Agency	Cal Fire	100246655	None	12,000	Conductor	Overhead	Yes	5/18/16	18:24	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
738	PG&E	5/18/16	15.45	35.55502	-120.68032	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Atascadero FD	101901773	None	21,000	Conductor	Overhead	Yes	5/18/16	15:45	Equipment/Facility Failure	Crossarm	N.A.	N.A.	Unknown	
739	PG&E	5/18/16	20.04	40.47788	-122.40312	Vegetation	RURAL	< 3 meters	Fire Agency	County	102307139	PACIFIC BELL	12,000	Conductor	Overhead	Yes	5/18/16	20:04	Equipment/Facility Failure	Conductor	N.A.	N.A.	Unknown	
740	PG&E	5/19/16	1.42	34.66450	-120.39999	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Santa Barbara County FD	101916587	VERIZON CALIFO	12,000	Conductor	Overhead	Yes	5/19/16	1:42	Contact From Object	N.A.	Vehicle	Pole	Human Error	
741	PG&E	5/19/16	18.33	37.74005	-120.80338	Vegetation	RURAL	< 3 meters	Fire Agency	OAKDALE F.D.	102342932	None	17,000	Conductor	Overhead	Yes	5/19/16	18:33	Equipment/Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
742	PG&E	5/19/16	18.54	38.81683	-123.58429	Vegetation	RURAL	< 3 meters	Fire Agency	Grainia Firw	102183917	PACIFIC BELL	12,000	Conductor	Overhead	Yes	5/19/16	18:54	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
743	PG&E	5/20/16	15.01	39.05589	-123.45813	Vegetation	RURAL	.26 - 9.99 Acres	Fire Agency	Cal Fire	102198323	None	12,000	Conductor	Overhead	Yes	5/20/16	15:01	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
744	PG&E	5/20/16	18.54	37.30348	-121.83985	Vegetation	URBAN	.26 - 9.99 Acres	Fire Agency	San Jose Fire	103457021	None	21,000	Unknown	Overhead	Yes	5/20/16	18:54	Unknown	N.A.	N.A.	N.A.	Unknown	
745	PG&E	5/20/16	20.43	35.49647	-120.68064	Vegetation	URBAN	.26 - 9.99 Acres	Fire Agency	Atascadero FD	101897769	PACIFIC BELL	0 - 750	Unknown	Overhead	No			Other	N.A.	N.A.	N.A.	Unknown	
746	PG&E	5/21/16	17.44	37.36898	-120.67718	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	101162897	None	12,000	Other	Overhead	No			Equipment/Facility Failure	Other	N.A.	N.A.	Unknown	

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X
2	Utility Name	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes (Optional):
815	PG&E	6/21/16	10.09	39.02942	-121.29275	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	100024816	PACIFIC BELL	0 - 750	Conductor	Overhead	No	6/21/16	16:53	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
816	PG&E	6/21/16	16.53	38.42328	-122.54477	Vegetation	RURAL	< 0.25 Acres	Fire Agency	KENWOOD FIRE XST	102036904	Yes	0 - 750	Conductor	Overhead	Yes	6/21/16	16:53	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
817	PG&E	6/21/16	18.01	39.28517	-123.20530	Vegetation	RURAL	.26 - 9.99 Acres	Fire Agency	Cal Fire/Redwood Valley FD	102176908	PACIFIC BELL	12,000	Conductor	Overhead	Yes	6/21/16	18:01	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
818	PG&E	6/22/16	19.13	36.38751	-119.83496	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Kings County FD	100848643		0 - 750	Conductor	Overhead	Yes	6/22/16	19:13	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
819	PG&E	6/23/16	10.10	36.72434	-120.05534	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Fresno FD	100637712		0 - 750	Conductor	Overhead	Yes	6/23/16	10:10	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
820	PG&E	6/23/16	19.19	35.62119	-120.35618	Vegetation	RURAL	< 3 meters	Fire Agency	Cal Fire	101937184	KERMAN TELEPH	0 - 750	Conductor	Overhead	Yes	6/23/16	19:19	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
821	PG&E	6/23/16	21.33	38.12063	-121.95450	Vegetation	RURAL	.26 - 9.99 Acres	Fire Agency	Susun Fire Protection District.	10158702	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	6/23/16	21:33	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
822	PG&E	6/24/16	3.07	38.71917	-121.05460	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire/EDH FIRE DEPT	101376553		21,000	Conductor	Overhead	Yes	6/24/16	3:07	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
823	PG&E	6/24/16	14.38	40.22003	-122.28299	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	101526647		0 - 750	Unknown	Overhead	Yes	6/24/16	14:38	Unknown	N.A.	N.A.	Unknown		
824	PG&E	6/25/16	17.07	39.76026	-121.61876	Vegetation	URBAN	< 3 meters	Fire Agency	CAL FIRE/ PARADISE	100327279	PACIFIC BELL	12,000	Conductor	Overhead	Yes	6/25/16	17:07	Contact From Object	N.A.	Vehicle	Pole	Human Error	
825	PG&E	6/26/16	16.38	39.50417	-121.44753	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	100375810	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	6/26/16	16:38	Wire-Wire Contact	N.A.	N.A.	N.A.	Unknown	
826	PG&E	6/26/16	16.50	35.67721	-120.68396	Vegetation	RURAL	.26 - 9.99 Acres	Fire Agency	County	101869974	None	0 - 750	Conductor	Overhead	No	6/26/16	16:50	Vandalism/Theft	N.A.	N.A.	N.A.	Human Error	gunshot
827	PG&E	6/26/16	17.59	38.80870	-121.51591	Vegetation	RURAL	< 0.25 Acres	Fire Agency	PLEASANT GROVE FD - SUTTER COUNTY	101340542		12,000	Conductor	Overhead	Yes	6/26/16	17:59	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
828	PG&E	6/26/16	11.06	40.48320	-122.04660	Vegetation	RURAL	.26 - 9.99 Acres	Fire Agency	Cal Fire	101483777	FRONTIER	12,000	Conductor	Overhead	Yes	6/26/16	11:06	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
829	PG&E	6/27/16	11.12	36.90888	-119.52242	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	100726035	None	12,000	Lightning Arrestor	Overhead	Yes	6/27/16	11:12	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
830	PG&E	6/28/16	11.12	37.29978	-121.97660	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Unknown	100583023	PACIFIC BELL	12,000	Conductor	Overhead	Yes	6/28/16	11:40	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
831	PG&E	6/28/16	13.36	38.09613	-122.23043	Building	URBAN	Structure Only	Fire Agency	vall fire	102278744	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	6/28/16	13:36	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
832	PG&E	6/28/16	9.11	37.10045	-120.22491	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Chowchilla FD	103810794	None	12,000	Conductor	Overhead	Yes	6/28/16	9:11	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	third-party caused
833	PG&E	6/29/16	12.55	36.50044	-121.43470	Vegetation	URBAN	< 0.25 Acres	Customer	N.A.	101754504		0 - 750	Other	Overhead	No	6/29/16	12:55	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
834	PG&E	6/30/16	0.03	39.81570	-121.59940	Vegetation	RURAL	< 3 meters	Fire Agency	Cal Fire	101528146		12,000	Conductor	Overhead	Yes	6/30/16	0:03	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
835	PG&E	6/30/16	17.14	40.03530	-122.56939	Vegetation	RURAL	300 - 999 Acres	Fire Agency	Cal Fire	101528146		12,000	Conductor	Overhead	Yes	6/30/16	17:14	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
836	PG&E	6/30/16	14.20	37.99268	-120.39962	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Cal Fire	102327111	PACIFIC BELL	17,000	Conductor	Overhead	Yes	6/30/16	14:20	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
837	PG&E	7/1/16	22.03	37.92729	-122.31814	Vegetation	URBAN	.26 - 9.99 Acres	Fire Agency	CITY OF RICHMOND	101444612	PACIFIC BELL	4,000	Conductor	Overhead	Yes	7/1/16	22:03	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
838	PG&E	7/2/16	4.05	37.78048	-121.49741	Vegetation	RURAL	< 3 meters	Utility: PG&E	N.A.	102094598		12,000	Conductor	Overhead	Yes	7/2/16	4:05	Contact From Object	N.A.	Vehicle	Pole	Human Error	
839	PG&E	7/3/16	15.00	38.03483	-120.38088	Vegetation	RURAL	< 3 meters	Fire Agency	San Jose FD	101905907		17,000	Conductor	Overhead	Yes	7/3/16	15:00	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
840	PG&E	7/4/16	7.43	38.76231	-121.21425	Vegetation	RURAL	< 0.25 Acres	Fire Agency	South Placer FD	103810320		12,000	Conductor	Overhead	Yes	7/4/16	7:43	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
841	PG&E	7/5/16	8.35	36.23900	-120.30154	Vegetation	RURAL	.26 - 9.99 Acres	Fire Agency	Cal Fire	100743822		12,000	Conductor	Overhead	Yes	7/5/16	8:35	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
842	PG&E	7/5/16	10.36	36.28269	-120.26173	Vegetation	RURAL	.26 - 9.99 Acres	Fire Agency	Fresno County FD	100747232		0 - 750	Conductor	Overhead	Yes	7/5/16	10:36	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
843	PG&E	7/7/16	10.56	39.29658	-121.82628	Vegetation	RURAL	< 0.25 Acres	Fire Agency	LIVE OAK	101315522		12,000	Fuse	Overhead	Yes	7/7/16	10:56	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
844	PG&E	7/8/16	10.49	38.33731	-122.12112	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	102291118	PACIFIC BELL	12,000	Conductor	Overhead	Yes	7/8/16	10:49	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
845	PG&E	7/8/16	15.13	33.61428	-117.11102	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Unknown	103070565	None	0 - 750	Conductor	Overhead	No	7/8/16	15:13	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
846	PG&E	7/9/16	10.05	35.13105	-120.60887	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Unknown	101924844		12,000	Conductor	Overhead	Yes	7/9/16	10:05	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
847	PG&E	7/9/16	14.57	38.50353	-121.78264	Vegetation	RURAL	.26 - 9.99 Acres	Fire Agency	Dixon FD	101599862	None	0 - 750	Conductor	Overhead	No	7/9/16	14:57	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
848	PG&E	7/9/16	15.42	38.89276	-121.97476	Vegetation	RURAL	< 0.25 Acres	Fire Agency	DUGGAGAN FIRE	101602162	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	7/9/16	15:42	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
849	PG&E	7/9/16	19.22	37.31108	-121.83127	Vegetation	URBAN	< 3 meters	Fire Agency	San Jose FD	10059226	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	7/9/16	19:22	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
850	PG&E	7/12/16	14.18	35.34710	-120.38130	Vegetation	RURAL	.26 - 9.99 Acres	Fire Agency	Cal Fire	101879190		21,000	Conductor	Overhead	Yes	7/12/16	14:18	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
851	PG&E	7/13/16	10.20	37.32768	-122.07194	Vegetation	RURAL	.26 - 9.99 Acres	Fire Agency	Cal Fire/scfd	103510668		115,000	Conductor	Overhead	Yes	7/13/16	10:20	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
852	PG&E	7/14/16	13.44	35.38333	-118.92324	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Kern County FD	100119861		0 - 750	Capacitor Bank	Overhead	No	7/14/16	13:44	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
853	PG&E	7/15/16	5.19	35.18390	-120.50180	Vegetation	RURAL	< 3 meters	Fire Agency	Cal Fire	101846594		12,000	Conductor	Overhead	Yes	7/15/16	5:19	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
854	PG&E	7/15/16	14.09	38.69651	-120.85983	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	101412774	PACIFIC BELL	12,000	Conductor	Overhead	Yes	7/15/16	14:09	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	third-party caused
855	PG&E	7/15/16	14.26	38.13658	-122.70919	Vegetation	RURAL	.26 - 9.99 Acres	Fire Agency	NOVATO FIRE AND OTHERS	102013570	PACIFIC BELL	12,000	Conductor	Overhead	Yes	7/15/16	14:26	Contact From Object	N.A.	Vehicle	Pole	Human Error	
856	PG&E	7/15/16	17.09	35.35853	-119.04094	Vegetation	URBAN	< 3 meters	Fire Agency	CITY	100194332	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	7/15/16	17:09	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
857	PG&E	7/16/16	0.58	36.43790	-121.91583	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	101869758		12,000	Other	Overhead	Yes	7/16/16	0:58	Equipment/ Facility Failure	Voltage Regulator	N.A.	N.A.	Unknown	
858	PG&E	7/16/16	8.19	37.48278	-119.86999	Vegetation	RURAL	.26 - 9.99 Acres	Fire Agency	Cal Fire	101978104		0 - 750	Conductor	Overhead	No	7/16/16	8:19	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
859	PG&E	7/16/16	20.26	38.49443	-122.49443	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Cal Fire	102265740	None	12,000	Conductor	Overhead	Yes	7/16/16	20:26	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
860	PG&E	7/18/16	7.39	36.75720	-119.78072	Vegetation	URBAN	< 3 meters	Self Extinguished	N.A.	100896066	PACIFIC BELL	0 - 750	Capacitor Bank	Overhead	Yes	7/18/16	7:39	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
861	PG&E	7/18/16	9.11	36.99768	-119.98296	Vegetation	RURAL	< 3 meters	Fire Agency	Cal Fire	101017131	PACIFIC BELL	12,000	Conductor	Overhead	Yes	7/18/16	9:11	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
862	PG&E	7/18/16	15.56	37.32207	-121.80553	Vegetation	URBAN	.26 - 9.99 Acres	Fire Agency	San Jose FD	100579940		21,000											

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X
2	Utility Name	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes (Optional):
931	PG&E	8/16/16	13.18	40.34169	-123.88029	Vegetation	RURAL	< 0.25 Acres	Fire Agency	miranda/fruittand vol. calfire	10099019	None	12,000	Conductor	Overhead	Yes	8/16/16	13:18	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
932	PG&E	8/16/16	22.17	36.78699	-119.69569	Vegetation	URBAN	< 3 meters	Fire Agency	CLOVIS FIRE DEPT	100887618	None	12,000	Conductor	Overhead	Yes	8/16/16	22:17	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
933	PG&E	8/17/16	9.41	35.37087	-118.96842	Building	URBAN	Structure Only	Fire Agency	Kern County FD	101162417	None	21,000	Transformer	Overhead	Yes	8/17/16	9:41	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
934	PG&E	8/17/16	12.23	41.24964	-123.76707	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	103315791	None	12,000	Conductor	Overhead	Yes	8/17/16	12:23	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
935	PG&E	8/17/16	14.02	39.63510	-121.74794	Vegetation	RURAL	< 3 meters	Customer	N.A.	100437069	None	60,000	Conductor	Overhead	Yes	8/17/16	14:02	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	
936	PG&E	8/17/16	18.37	37.30779	-119.86108	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	101302932	None	21,000	Conductor	Overhead	Yes	8/17/16	18:37	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	
937	PG&E	8/18/16	15.22	36.61874	-119.44391	Vegetation	RURAL	< 3 meters	Self Extinguished	N.A.	100828791	None	0 - 750	Conductor	Overhead	Yes	8/18/16	15:22	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
938	PG&E	8/18/16	18.12	37.59560	-122.08648	Vegetation	URBAN	< 3 meters	Fire Agency	union city fd	100935109	VERIZON CALIFO	0 - 750	Fuse	Overhead	No			Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
939	PG&E	8/18/16	18.36	36.97014	-121.54598	Vegetation	RURAL	< 3 meters	Fire Agency	Santa Clara county fire	103553473	PACIFIC BELL	0 - 750	Capacitor Bank	Overhead	No			Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
940	PG&E	8/19/16	16.23	39.22351	-123.75500	Vegetation	RURAL	< 3 meters	Fire Agency	Albion-Little River FD	102206661	None	12,000	Conductor	Overhead	Yes	8/19/16	16:23	Contact From Object	N.A.	Vehicle	Pole	Human Error	
941	PG&E	8/20/16	18.51	36.45801	-119.34722	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Merced County FD	100729153	PACIFIC BELL	12,000	Conductor	Overhead	Yes	8/20/16	18:51	Contact From Object	N.A.	Vehicle	Pole	Human Error	
942	PG&E	8/21/16	13.02	38.44445	-122.24955	Vegetation	RURAL	.26 - 9.99 Acres	Fire Agency	Cal Fire	102291451	PACIFIC BELL	12,000	Conductor	Overhead	Yes	8/21/16	13:02	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
943	PG&E	8/22/16	16.10	37.96656	-120.23950	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Toulumne City FD	101043683	None	17,000	Conductor	Overhead	Yes	8/22/16	16:10	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
944	PG&E	8/23/16	16.03	38.87411	-119.88648	Vegetation	RURAL	< 3 meters	Customer	N.A.	100731257	None	0 - 750	Conductor	Overhead	Yes	8/23/16	16:03	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
945	PG&E	8/24/16	12.11	36.46335	-121.71202	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	101750810	PACIFIC BELL	12,000	Conductor	Overhead	Yes	8/24/16	12:11	Contact From Object	N.A.	Vehicle	Pole	Human Error	
946	PG&E	8/24/16	12.19	36.84572	-119.87620	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Fresno FD	103327750	None	21,000	Conductor	Overhead	Yes	8/24/16	12:19	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
947	PG&E	8/25/16	12.04	36.97263	-119.38162	Vegetation	RURAL	< 3 meters	Utility, PG&E	N.A.	100651318	PACIFIC BELL	0 - 750	Conductor	Overhead	No			Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
948	PG&E	8/25/16	11.31	37.37341	-122.08696	Vegetation	URBAN	< 3 meters	Self Extinguished	N.A.	100518445	PACIFIC BELL	12,000	Conductor	Overhead	Yes	8/25/16	11:31	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
949	PG&E	8/27/16	5.37	36.04388	-120.11166	Vegetation	RURAL	.26 - 9.99 Acres	Fire Agency	Kings County FD	103246130	None	70,000	Conductor	Overhead	Yes	8/27/16	5:37	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
950	PG&E	8/27/16	19.33	36.96458	-122.05289	Vegetation	URBAN	< 0.25 Acres	Fire Agency	SC FIRE DEPT & CDF	101677596	PACIFIC BELL	21,000	Conductor	Overhead	Yes	8/27/16	19:33	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
951	PG&E	8/28/16	16.49	36.56186	-119.71860	Vegetation	RURAL	< 3 meters	Fire Agency	Cal Fire	100683911	None	12,000	Conductor	Overhead	Yes	8/28/16	16:49	Contact From Object	N.A.	Vehicle	Pole	Human Error	
952	PG&E	8/29/16	16.25	38.26928	-121.60294	Vegetation	RURAL	< 0.25 Acres	Fire Agency	SAC FIRE	101583637	FRONTIER	21,000	Conductor	Overhead	Yes	8/29/16	16:25	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	
953	PG&E	8/30/16	16.01	36.59413	-121.92120	Vegetation	RURAL	.26 - 9.99 Acres	Fire Agency	Unknown	101734977	None	21,000	Conductor	Overhead	Yes	8/30/16	16:01	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
954	PG&E	8/30/16	16.14	38.05755	-122.16390	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Benicia FD	102284159	PACIFIC BELL	21,000	Conductor	Overhead	Yes	8/30/16	16:14	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	third-party caused
955	PG&E	8/30/16	19.27	39.92980	-122.12765	Vegetation	RURAL	< 0.25 Acres	Unknown	Unknown	100430821	None	12,000	Conductor	Overhead	Yes	8/30/16	19:27	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
956	PG&E	8/31/16	11.17	37.37206	-120.45039	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Merced County FD	101147802	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	8/31/16	11:17	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
957	PG&E	8/31/16	14.52	35.19180	-120.46971	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	101942860	None	12,000	Conductor	Overhead	Yes	8/31/16	14:52	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
958	PG&E	8/31/16	19.43	38.15100	-121.68037	Vegetation	RURAL	.26 - 9.99 Acres	Fire Agency	ISLETON	101685829	FRONTIER	21,000	Conductor	Overhead	Yes	8/31/16	19:43	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
959	PG&E	9/1/16	9.30	37.28144	-121.86030	Vegetation	URBAN	< 3 meters	Customer	N.A.	100617565	None	21,000	Conductor	Overhead	Yes	9/1/16	9:30	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
960	PG&E	9/1/16	13.08	38.46327	-122.81616	Vegetation	RURAL	< 3 meters	Fire Agency	WINDSOR AND SANTA ROSA FIRE	101956270	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/1/16	13:08	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
961	PG&E	9/2/16	12.42	38.38680	-122.75553	Vegetation	RURAL	< 3 meters	Fire Agency	Santa Rosa FD	101969369	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	9/2/16	12:42	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
962	PG&E	9/2/16	13.50	37.66811	-121.76805	Vegetation	URBAN	< 0.25 Acres	Fire Agency	LPFD	100954399	None	21,000	Conductor	Overhead	Yes	9/2/16	13:50	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	
963	PG&E	9/3/16	20.12	39.32230	-121.98490	Vegetation	RURAL	< 3 meters	Unknown	Unknown	101614478	None	12,000	Conductor	Overhead	Yes	9/3/16	20:12	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
964	PG&E	9/3/16	20.58	38.80805	-119.62789	Vegetation	RURAL	.26 - 9.99 Acres	Fire Agency	Unknown	103269240	None	12,000	Conductor	Overhead	Yes	9/3/16	20:58	Contact From Object	N.A.	Vehicle	Pole	Human Error	
965	PG&E	9/5/16	8.26	39.52329	-122.14619	Vegetation	RURAL	< 0.25 Acres	Unknown	Unknown	100430821	None	21,000	Conductor	Overhead	Yes	9/5/16	8:26	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
966	PG&E	9/7/16	19.37	37.99206	-122.54447	Vegetation	URBAN	< 3 meters	Fire Agency	San Rafael FD	102249944	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	9/7/16	19:37	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
967	PG&E	9/7/16	9.56	39.55281	-121.64163	Vegetation	RURAL	.26 - 9.99 Acres	Unknown	Unknown	103633028	None	60,000	Conductor	Overhead	Yes	9/7/16	9:56	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
968	PG&E	9/8/16	14.39	38.00133	-122.32902	Vegetation	URBAN	< 0.25 Acres	Fire Agency	PINOLE FIRE DEPT	101426911	None	12,000	Conductor	Overhead	Yes	9/8/16	14:39	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
969	PG&E	9/8/16	22.04	37.29175	-121.87109	Vegetation	URBAN	< 0.25 Acres	Fire Agency	San Jose FD	100598024	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	9/8/16	22:04	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
970	PG&E	9/9/16	10.57	36.85174	-119.62254	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Fresno County FD	100746408	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/9/16	10:57	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
971	PG&E	9/9/16	13.22	37.28367	-120.47405	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Cal Fire	101018780	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	9/9/16	13:22	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
972	PG&E	9/9/16	15.25	38.92020	-121.08588	Vegetation	URBAN	< 0.25 Acres	Fire Agency	Cal Fire	100036304	PACIFIC BELL	12,000	Capacitor Bank	Overhead	Yes	9/9/16	15:25	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
973	PG&E	9/10/16	2.09	37.18617	-120.67754	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Merced County FD	101072400	None	12,000	Conductor	Overhead	Yes	9/10/16	2:09	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
974	PG&E	9/11/16	21.24	36.86281	-119.72629	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Unknown	100852942	None	21,000	Conductor	Overhead	Yes	9/11/16	21:24	Contact From Object	N.A.	N.A.	Unknown		
975	PG&E	9/12/16	4.24	38.39990	-121.90201	Vegetation	RURAL	< 3 meters	Fire Agency	Cal Fire Hwy 1 Carmel Hill	101669614	None	12,000	Conductor	Overhead	Yes	9/12/16	4:24	Contact From Object	N.A.	Vegetation	N.A.	Unknown	
976	PG&E	9/12/16	12.38	38.78323	-120.60060	Vegetation	RURAL	.26 - 9.99 Acres	Fire Agency	Cal Fire	101421708	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	9/12/16	12:38	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
977	PG&E	9/12/16	18.47	36.53030	-119.30560	Vegetation	RURAL	< 0.25 Acres	Fire Agency	CUTLER FIRE	100807630	None	12,000	Conductor	Overhead	Yes	9/12/16	18:47	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
978	PG&E	9/12/16	20.42	37.35500	-121.93550	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Santa Clara county fire	100608192	None	12,000	Conductor	Over									

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X
Utility Name	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes (Optional):	
PG&E	10/31/16	17.04	36.66385	-119.74626	Vegetation	RURAL	.26 - 9.99 Acres	Fire Agency	Fresno County FD	100808306		12,000	Conductor	Overhead	Yes	10/31/16	17:04	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
PG&E	11/9/16	9.06	37.45316	-119.64132	Vegetation	RURAL	< 0.25 Acres	Fire Agency	US FOREST SERVICE	101071062		12,000	Conductor	Overhead	Yes	11/9/16	9:06	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	third-party caused	
PG&E	11/14/16	3.25	35.43969	-120.89022	Vegetation	URBAN	< 3 Meters	Fire Agency	CAYOUST FIRE	101853338	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	11/14/16	3:25	Equipment/Facility Failure	Other	N.A.	N.A.	Unknown		
PG&E	11/14/16	13.15	35.45772	-120.46186	Vegetation	RURAL	< 0.25 Acres	Fire Agency	Cal Fire	101895511		21,000	Conductor	Overhead	Yes	11/14/16	13:15	Equipment/Facility Failure	Pole	N.A.	N.A.	Unknown		
PG&E	11/15/16	17.27	38.72747	-121.05571	Vegetation	RURAL	< 0.25 Acres	Fire Agency	CAL FIRE/BUTTE COUNTY FIRE DEPT.	100327525	PACIFIC BELL	12,000	Conductor	Overhead	Yes	11/15/16	17:27	Contact From Object	N.A.	Vehicle	Pole	Human Error		
PG&E	11/20/16	11.04	38.03262	-123.78228	Vegetation	RURAL	< 3 Meters	Fire Agency	Cal Fire	102200173		12,000	Conductor	Overhead	Yes	11/20/16	11:04	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
PG&E	11/26/16	12.10	35.32208	-118.78080	Vegetation	RURAL	< 0.25 Acres	Utility: PG&E	N.A.	102300399		12,000	Conductor	Overhead	Yes	11/26/16	12:10	Equipment/Facility Failure	Insulator	N.A.	N.A.	Unknown		
PG&E	01/01/17	15.57	38.66287	-121.74803	Vegetation	Urban	< 3 Meters	Fire Agency	Woodland fire dept 530-666-8920	101589774	Unknown	0 - 750	Conductor	Overhead	Yes	1/1/17	15:57	Equipment/Facility Failure	Conductor	N.A.	N.A.	Unknown		
PG&E	01/10/17	15.55	38.75380	-121.15641	Building	Urban	Structure Only	Unknown	N.A.	100056079	Unknown	12,000	Conductor	Overhead	Yes	1/10/17	15:55	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
PG&E	01/18/17	15.34	37.38388	-121.80884	Building	Urban	Structure Only	Unknown	N.A.	100564835	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	1/18/17	15:34	Equipment/Facility Failure	Conductor	N.A.	N.A.	Unknown		
PG&E	01/29/17	09.45	38.36159	-121.95091	Building	Urban	Structure Only	Fire Agency	Unknown	8550	Unknown	12,000	Transformer	Subsurface	Yes	1/29/17	09:45	Equipment/Facility Failure	Transformer	N.A.	N.A.	Unknown		
PG&E	02/03/17	10.00	37.56153	-122.02772	Vegetation	Urban	< 3 Meters	Fire Agency	jeff	100938466	Unknown	12,000	Conductor	Overhead	Yes	2/3/17	10:00	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
PG&E	02/07/17	04.50	38.43314	-122.71902	Building	Urban	Structure Only	Fire Agency	Santa Rosa Fire Dept	102014637	PACIFIC BELL	12,000	Conductor	Overhead	Yes	2/7/17	04:50	Other	N.A.	N.A.	Unknown			
PG&E	03/16/17	12.43	38.27175	-122.01971	Other	Urban	< 0.25 Acres	Fire Agency	Unknown	101561532	PACIFIC BELL	12,000	Conductor	Overhead	Yes	3/16/17	12:43	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused	
PG&E	03/17/17	09.37	38.11532	-121.42216	Other	Rural	Structure Only	Fire Agency	911	102344732	PACIFIC BELL	21,000	Conductor	Overhead	Yes	3/17/17	09:37	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	third-party caused	
PG&E	03/19/17	17.06	39.76209	-121.85247	Vegetation	Urban	< 3 Meters	Fire Agency	CHICO FIRE DEPT 911	100441377	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	3/19/17	17:06	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
PG&E	03/23/17	07.04	37.36975	-121.85218	Other	Urban	< 3 Meters	Fire Agency	SJFD disp 408-277-8950 Incident# F170829041	103485262	Unknown	12,000	Transformer	Subsurface	Yes	3/23/17	07:04	Equipment/Facility Failure	Transformer	N.A.	N.A.	Unknown		
PG&E	03/28/17	12.15	34.88092	-120.41992	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	103397961	YES	12,000	Conductor	Overhead	Yes	3/28/17	12:15	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
PG&E	04/01/17	14.54	37.18823	-120.95764	Vegetation	Rural	< 0.25 Acres	Fire Agency	engine 74 mrced fire agency	102371865	Unknown	12,000	Conductor	Overhead	Yes	4/1/17	14:54	Equipment/Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
PG&E	04/04/17	13.29	35.68851	-120.76533	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	101945026	None	12,000	Conductor	Overhead	Yes	4/4/17	13:29	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused	
PG&E	04/04/17	14.54	37.29584	-121.93295	Vegetation	Urban	< 3 Meters	Customer	N.A.	100591136	None	12,000	Conductor	Overhead	Yes	4/4/17	14:54	Equipment/Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
PG&E	04/10/17	16.35	35.61751	-119.74296	Vegetation	Rural	< 3 Meters	Self Extinguished	N.A.	100128630	Unknown	21,000	Conductor	Overhead	No			Contact From Object	N.A.	Animal	Electric Facility	Unknown		
PG&E	04/13/17	14.21	37.79671	-121.25210	Other	Urban	Structure Only	Fire Agency	MANTECA CITY	102104500	VERIZON CALIFO	17,000	Conductor	Overhead	Yes	4/13/17	14:21	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
PG&E	04/16/17	15.14	35.58953	-119.14227	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103833904	Unknown	12,000	Conductor	Overhead	Yes	4/16/17	15:14	Equipment/Facility Failure	Other	N.A.	N.A.	Unknown		
PG&E	04/20/17	20.14	37.37407	-120.71688	Vegetation	Urban	< 3 Meters	Fire Agency	209-966-3621	101205903	Unknown	12,000	Transformer	Overhead	No			Contact From Object	N.A.	Transformer	Unknown			
PG&E	04/23/17	7.10	36.07345	-120.93450	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	101726333	Unknown	12,000	Conductor	Overhead	Yes	4/23/17	7:10	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused	
PG&E	04/24/17	11.52	36.18990	-121.15129	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101718856	None	12,000	Conductor	Overhead	Yes	4/24/17	11:52	Equipment/Facility Failure	Other	N.A.	N.A.	Unknown	tie wire	
PG&E	04/25/17	12.38	38.65832	-120.97622	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	101376746	Unknown	0 - 750	Transformer	Overhead	Yes	4/25/17	12:38	Equipment/Facility Failure	Transformer	N.A.	N.A.	Unknown		
PG&E	04/25/17	18.26	36.23725	-119.78071	Other	Rural	Structure Only	Self Extinguished	N.A.	100716676	Unknown	0 - 750	Conductor	Overhead	Yes	4/25/17	18:26	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused	
PG&E	04/26/17	15.55	38.15608	-121.67886	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAPT KENNY WILLIAMS (707)374-2233	103826165	Unknown	21,000	Conductor	Overhead	Yes	4/26/17	15:55	Contact From Object	N.A.	Other	Electric Facility	Other	bird's nest	
PG&E	04/28/17	5.55	34.58848	-120.10568	Vegetation	Rural	< 0.25 Acres	Fire Agency	805-683-2724	101900122	Unknown	12,000	Conductor	Overhead	Yes	4/28/17	5:55	Equipment/Facility Failure	Conductor	N.A.	N.A.	Unknown		
PG&E	04/28/17	14.35	37.12469	-121.62488	Vegetation	Urban	< 0.25 Acres	Fire Agency	Cal Fire	103098414	Unknown	0 - 750	Conductor	Overhead	Yes	4/28/17	14:35	Equipment/Facility Failure	Cal Fire	N.A.	N.A.	Unknown		
PG&E	04/28/17	15.49	38.76798	-119.96253	Vegetation	Rural	< 0.25 Acres	Fire Agency	chris paper fire investigator, 530/677-1868. incident #caaeu11821	101409833	PACIFIC BELL	21,000	Conductor	Overhead	Yes	4/28/17	15:49	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
PG&E	04/28/17	15.07	37.03486	-119.82423	Vegetation	Rural	< 3 Meters	Unknown	100878861	1023917	Unknown	12,000	Conductor	Overhead	Yes	4/28/17	15:07	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
PG&E	04/30/17	9.32	35.63491	-118.95629	Vegetation	Rural	< 0.25 Acres	Fire Agency	661-324-6551	102612308	Unknown	21,000	Conductor	Overhead	Yes	4/30/17	9:32	Equipment/Facility Failure	Other	N.A.	N.A.	Unknown		
PG&E	05/01/17	14.20	36.02269	-119.95837	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CORCORAN STATION 559-992-2156	102076015	Unknown	70,000	Conductor	Overhead	Yes	5/1/17	14:20	Contact From Object	N.A.	Other	Electric Facility	Other	bird's nest	
PG&E	05/03/17	10.04	36.81613	-119.63202	Vegetation	Rural	< 0.25 Acres	Fire Agency	eng 44 Eric connors 559-324-2294	100770906	PACIFIC BELL	12,000	Conductor	Overhead	Yes	5/3/17	10:04	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
PG&E	05/03/17	12.51	38.19080	-121.66150	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103834798	None	21,000	Conductor	Overhead	Yes	5/3/17	12:51	Equipment/Facility Failure	Conductor	N.A.	N.A.	Unknown		
PG&E	05/04/17	16.19	35.55728	-120.75348	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101934476	Unknown	21,000	Conductor	Overhead	Yes	5/4/17	16:19	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
PG&E	05/05/17	15.52	40.37758	-123.00187	Vegetation	Rural	< 3 Meters	Self Extinguished	N.A.	101501566	None	12,000	Conductor	Overhead	Yes	5/5/17	15:52	Equipment/Facility Failure	Conductor	N.A.	N.A.	Unknown		
PG&E	05/06/17	1.56	37.32997	-120.83297	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103834182	Unknown	12,000	Conductor	Overhead	Yes	5/6/17	1:56	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused	
PG&E	05/06/17	11.18	40.79512	-124.02902	Vegetation	Rural	< 3 Meters	Fire Agency	chief rick harden 7074423352	103661154	Unknown	12,000	Conductor	Overhead	Yes	5/6/17	11:18	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
PG&E	05/06/17	12.43	40.76227	-124.16195	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	100998152	Unknown	12,000	Conductor	Overhead	Yes	5/6/17	12:43	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
PG&E	05/06/17	15.00	39.24580	-123.77854	Vegetation	Urban	.26 - 9.99 Acres	Fire Agency	Unknown	102185559	Unknown	12,000	Conductor	Overhead	Yes	5/6/17	15:00	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
PG&E	05/06/17	23.46	36.16537	-120.37372	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire	100741510	PACIFIC BELL	12,000	Conductor	Overhead	Yes	5/6/17	23:46	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused	
PG&E	05/09/17	11.15	40.05970	-122.18895	Vegetation	Rural	< 3 Meters	Self Extinguished	N.A.	101531151	PACIFIC BELL	12,000	Conductor	Overhead	Yes	5/9/17	11:15	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused	
PG&E	05/09/17	15.57	39.54650	-121.85667	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100404826	Unknown	12,000	Conductor	Overhead	No			Equipment/Facility Failure	Pole	N.A.	N.A.	Unknown		
PG&E	05/09/17	18.26	40.86892	-123.51559	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	todd wright fire chief 5307392493	103796045	Unknown	12,000	Conductor	Overhead	Yes	5/9/17	18:26	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
PG&E	05/12/17	15.16	38.85066	-121.31683	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	102347828	Unknown	21,000	Conductor	Overhead	Yes	5/12/17	15:16	Contact From Object						

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X
2	Utility Name	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes (Optional):
1160	PG&E	06/17/17	15:49	36.93896	-119.68463	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	103406061	Unknown	21,000	Conductor	Overhead	Yes	6/17/17	15:49	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1161	PG&E	06/18/17	23:49	39.19494	-122.96321	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	102160657	Unknown	12,000	Conductor	Overhead	Yes	6/18/17	23:49	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1162	PG&E	06/18/17	12:22	36.72578	-119.79088	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	100894729	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	6/18/17	12:22	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1163	PG&E	06/18/17	13:10	38.23703	-122.67015	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	102007208	PACIFIC BELL	12,000	Conductor	Overhead	Yes	6/18/17	13:10	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
1164	PG&E	06/18/17	18:09	37.55165	-122.29253	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	100309853	Unknown	21,000	Conductor	Overhead	Yes	6/18/17	18:09	Equipment/ Facility Failure	Guy/Span Wire	N.A.	N.A.	Unknown	
1165	PG&E	06/18/17	20:16	38.88444	-122.02044	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	101850387	None	12,000	Lightning Arrestor	Overhead	Yes	6/18/17	20:16	Equipment/ Facility Failure	Lightning Arrestor	N.A.	N.A.	Unknown	
1166	PG&E	06/18/17	21:07	37.83974	-121.28643	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	102085809	Unknown	12,000	Conductor	Overhead	Yes	6/18/17	21:07	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1167	PG&E	06/18/17	22:12	38.53900	-122.79203	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	102029435	Unknown	12,000	Other	Overhead	Yes	6/18/17	22:12	Equipment/ Facility Failure	Voltage Regulator	N.A.	N.A.	Unknown	
1168	PG&E	06/18/17	23:12	36.75747	-119.66455	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	100780126	PACIFIC BELL	12,000	Conductor	Overhead	No			Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1169	PG&E	06/18/17	23:31	38.89731	-121.29467	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	103782395	Unknown	12,000	Conductor	Overhead	Yes	6/18/17	23:31	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1170	PG&E	06/19/17	01:23	35.36762	-118.95621	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	100252360	PACIFIC BELL	21,000	Conductor	Overhead	Yes	6/19/17	01:23	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1171	PG&E	06/19/17	13:51	39.90633	-122.17660	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	103841797	Unknown	12,000	Conductor	Overhead	Yes	6/19/17	13:51	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1172	PG&E	06/19/17	16:18	37.79272	-121.23058	Other	Urban	Structure Only	Utility: PG&E	N.A.	103582825	Unknown	17,000	Transformer	Subsurface	Yes	6/19/17	16:18	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
1173	PG&E	06/19/17	16:26	37.93783	-120.60897	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101282825	Unknown	17,000	Other	Overhead	No			Equipment/ Facility Failure	Recloser	N.A.	N.A.	Unknown	
1174	PG&E	06/19/17	17:31	36.76268	-120.37580	Vegetation	Rural	< 3 Meters	Unknown	N.A.	101094343	Unknown	12,000	Transformer	Overhead	Yes	6/19/17	17:31	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
1175	PG&E	06/19/17	18:00	38.45496	-121.82416	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	101594910	PACIFIC BELL	12,000	Lightning Arrestor	Overhead	Yes	6/19/17	18:00	Equipment/ Facility Failure	Lightning Arrestor	N.A.	N.A.	Unknown	
1176	PG&E	06/19/17	20:22	38.10123	-120.86969	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101233468	Unknown	12,000	Transformer	Overhead	Yes	6/19/17	20:22	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
1177	PG&E	06/20/17	00:49	39.74900	-121.89975	Vegetation	Rural	< 3 Meters	Fire Agency	Cal Fire	100437523	PACIFIC BELL	12,000	Conductor	Overhead	Yes	6/20/17	00:49	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1178	PG&E	06/20/17	09:12	39.19754	-121.49499	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101306700	Unknown	12,000	Conductor	Overhead	Yes	6/20/17	09:12	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1179	PG&E	06/20/17	10:08	39.03668	-121.07630	Vegetation	Urban	< 3 Meters	Fire Agency	JERRY GOOD 530 268-0844	100023174	None	12,000	Conductor	Overhead	Yes	6/20/17	10:08	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1180	PG&E	06/20/17	13:37	37.92473	-122.08954	Vegetation	Urban	< 3 Meters	Fire Agency	contra costa fire	100476159	PACIFIC BELL	12,000	Capacitor Bank	Overhead	Yes	6/20/17	13:37	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
1181	PG&E	06/20/17	15:17	40.11262	-123.76774	Vegetation	Rural	< 3 Meters	Fire Agency	Cal Fire	100987107	Unknown	12,000	Conductor	Overhead	Yes	6/20/17	15:17	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1182	PG&E	06/20/17	11:51	40.31566	-124.06111	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	101006039	Unknown	12,000	Conductor	Overhead	Yes	6/20/17	11:51	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1183	PG&E	06/20/17	18:32	37.92910	-121.23323	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	102132644	Unknown	12,000	Conductor	Overhead	Yes	6/20/17	18:32	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1184	PG&E	06/20/17	20:46	38.90784	-121.26030	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	100085621	PACIFIC BELL	12,000	Conductor	Overhead	Yes	6/20/17	20:46	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1185	PG&E	06/20/17	23:16	35.63750	-120.85660	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101873622	Unknown	12,000	Conductor	Overhead	Yes	6/20/17	23:16	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1186	PG&E	06/21/17	08:41	39.16997	-122.15731	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101637081	Unknown	12,000	Conductor	Overhead	Yes	6/21/17	08:41	Contact From Object	N.A.	Other	Electric Facility	Human Error	helicopter
1187	PG&E	06/21/17	14:23	38.99208	-121.35362	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	100027499	PACIFIC BELL	12,000	Transformer	Overhead	Yes	6/21/17	14:23	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
1188	PG&E	06/22/17	9:36	38.39647	-120.47274	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	101251777	Unknown	12,000	Conductor	Overhead	Yes	6/22/17	9:36	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
1189	PG&E	06/22/17	16:30	39.61307	-121.68724	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire	100347529	None	12,000	Conductor	Overhead	Yes	6/22/17	16:30	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1190	PG&E	06/22/17	18:07	38.75831	-120.71764	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	101401088	Unknown	12,000	Conductor	Overhead	Yes	6/22/17	18:07	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused
1191	PG&E	06/22/17	19:29	35.58886	-120.66910	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101912249	Unknown	21,000	Conductor	Overhead	Yes	6/22/17	19:29	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
1192	PG&E	06/23/17	13:00	39.30510	-122.48618	Vegetation	Rural	10 - 99 Acres	Fire Agency	Unknown	100329817	Unknown	0 - 750	Conductor	Overhead	Yes	6/23/17	13:00	Vandalism/Theft	N.A.	N.A.	N.A.	Human Error	power theft
1193	PG&E	06/23/17	20:09	40.38565	-122.28408	Vegetation	Urban	< 0.25 Acres	Fire Agency	Keith Foster 530-347-4737	101505644	Unknown	12,000	Conductor	Overhead	Yes	6/23/17	20:09	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	booster bank
1194	PG&E	06/23/17	23:46	39.76294	-121.86700	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100397376	None	12,000	Conductor	Overhead	Yes	6/23/17	23:46	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1195	PG&E	06/24/17	10:31	38.94379	-121.04466	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100090318	PACIFIC BELL	12,000	Transformer	Overhead	Yes	6/24/17	10:31	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
1196	PG&E	06/24/17	14:51	38.36218	-120.76381	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	101255656	Unknown	12,000	Fuse	Overhead	Yes	6/24/17	14:51	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
1197	PG&E	06/24/17	22:27	38.29083	-120.84900	Vegetation	Rural	10 - 99 Acres	Fire Agency	CONTACT BOBBY BOWMAN	101238865	None	12,000	Conductor	Overhead	Yes	6/24/17	22:27	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1198	PG&E	06/25/17	18:18	37.32357	-120.55914	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101159230	Unknown	12,000	Conductor	Overhead	Yes	6/25/17	0.7625	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1199	PG&E	06/25/17	0:23	39.40434	-123.38687	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	101293088	PACIFIC BELL	12,000	Conductor	Overhead	Yes	6/25/17	0.23	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
1200	PG&E	06/25/17	6:02	39.07743	-121.52937	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101314125	Unknown	12,000	Conductor	Overhead	Yes	6/25/17	6.02	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
1201	PG&E	06/25/17	15:37	34.93950	-119.69246	Vegetation	Rural	100 - 299 Acres	Fire Agency	805-686-5074	100191652	None	12,000	Conductor	Overhead	Yes	6/25/17	15:37	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
1202	PG&E	06/25/17	22:14	39.02503	-121.57873	Vegetation	Rural	< 3 Meters	Fire Agency	Olivehurst FD	101314072	Unknown	21,000	Conductor	Overhead	Yes	6/25/17	22:14	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1203	PG&E	06/26/17	8:18	37.27331	-120.52573	Vegetation	Urban	< 0.25 Acres	Self Extinguished	N.A.	103218794	Unknown	12,000	Conductor	Overhead	Yes	6/26/17	8:18	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
1204	PG&E	06/26/17	14:29	35.97817	-120.11894	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	HENNAGIN 569 386 555	103243976	Unknown	21,000	Conductor	Overhead	Yes	6/26/17	14:29	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1205	PG&E	06/27/17	9:23	37.95588	-122.61762	Vegetation	Rural	10 - 99 Acres	Fire Agency	marin county fire	102260068	UNFILED	12,000	Conductor	Overhead	Yes	6/27/17	9:23	Other	N.A.	N.A.	N.A.	Unknown	
1206	PG&E	06/27/17	17:47	39.51264	-122.20333	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100341056	None	21,000	Conductor	Overhead	Yes	6/27/17	17:47	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1207	PG&E																							

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X
2	Utility Name	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes (Optional):
1274	PG&E	07/20/17	20:57	37.73609	-122.49208	Building	Urban	Structure Only	Unknown	N.A.	101813719	Unknown	0 - 750	Conductor	Overhead	Yes	7/20/17	20:57	Wire-Wire Contact	N.A.	N.A.	N.A.	Unknown	
1275	PG&E	07/20/17	01:46	36.52545	-119.68200	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	100830639	Unknown	0 - 750	Lightning Arrestor	Overhead	Yes	7/20/17	01:46	Equipment/Facility Failure	Lightning Arrestor	N.A.	N.A.	Unknown	
1276	PG&E	07/20/17	04:27	38.06420	-120.87106	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	chris costales 209 754 2735	102142834	Unknown	12,000	Conductor	Overhead	Yes	7/20/17	04:27	Equipment/Facility Failure	Conductor	N.A.	N.A.	Unknown	
1277	PG&E	07/20/17	13:45	35.08036	-120.55383	Vegetation	Rural	10 - 99 Acres	Fire Agency	PAUL LEE 805 903-3416 INC # 8291	101941116	Unknown	12,000	Conductor	Overhead	Yes	7/20/17	13:45	Equipment/Facility Failure	Crossarm	N.A.	N.A.	Unknown	
1278	PG&E	07/20/17	17:00	37.92651	-121.23203	Vegetation	Urban	< 3 Meters	Customer	N.A.	103394380	PACIFIC BELL	12,000	Capacitor Bank	Overhead	Yes	7/20/17	17:00	Equipment/Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
1279	PG&E	07/21/17	13:27	38.26854	-120.93719	Vegetation	Rural	.26 - 9.99 Acres	Unknown	N.A.	101245424	Unknown	12,000	Conductor	Overhead	Yes	7/21/17	13:27	Contact From Object	Pole	N.A.	N.A.	Human Error	Third-party caused
1280	PG&E	07/21/17	20:26	41.06550	-121.39320	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	101549629	Unknown	12,000	Conductor	Overhead	Yes	7/21/17	20:26	Equipment/Facility Failure	Conductor	N.A.	N.A.	Unknown	
1281	PG&E	07/22/17	12:25	40.87950	-123.76380	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Josh ,comander chief of forest service.	100980577	Unknown	12,000	Conductor	Overhead	Yes	7/22/17	12:25	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused
1282	PG&E	07/22/17	14:38	37.29945	-122.16306	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	100265488	Unknown	12,000	Conductor	Overhead	Yes	7/22/17	14:38	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1283	PG&E	07/22/17	16:01	40.83143	-124.05389	Vegetation	Rural	< 0.25 Acres	Fire Agency	BATTALION CHIEF CURT WATKINS, 707-825.2000	100983827	PACIFIC BELL	12,000	Conductor	Overhead	Yes	7/22/17	16:01	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused
1284	PG&E	07/23/17	09:22	40.64201	-122.23025	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAPT? FRONTIER COMM	101459708	Unknown	12,000	Conductor	Overhead	Yes	7/23/17	09:22	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1285	PG&E	07/23/17	16:32	36.24055	-119.81283	Vegetation	Rural	< 0.25 Acres	Fire Agency	Brandon Jones (559) 852-2884	100783832	Unknown	12,000	Conductor	Overhead	Yes	7/23/17	16:32	Equipment/Facility Failure	Conductor	N.A.	N.A.	Unknown	
1286	PG&E	07/23/17	18:25	39.67233	-123.53360	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	103823226	Unknown	12,000	Conductor	Overhead	Yes	7/23/17	18:25	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1287	PG&E	07/23/17	19:41	36.21174	-119.90973	Vegetation	Rural	< 0.25 Acres	Fire Agency	TOM MCEWEN 805-903-3409	101933968	Unknown	12,000	Conductor	Overhead	Yes	7/23/17	19:41	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
1288	PG&E	07/24/17	14:01	37.26349	-122.33643	Vegetation	Rural	< 0.25 Acres	Fire Agency	mike klink 650-879-0121	100322130	Unknown	0 - 750	Conductor	Overhead	Yes	7/24/17	14:01	Equipment/Facility Failure	Conductor	N.A.	N.A.	Unknown	
1289	PG&E	07/24/17	16:07	37.25369	-121.96760	Vegetation	Urban	< 0.25 Acres	Fire Agency	C1702050039	102471162	Unknown	0 - 750	Conductor	Overhead	Yes	7/24/17	16:07	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1290	PG&E	07/24/17	19:31	38.35192	-120.71029	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	101263632	Unknown	12,000	Conductor	Overhead	Yes	7/24/17	19:31	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1291	PG&E	07/24/17	21:45	35.60243	-120.92107	Vegetation	Rural	10 - 99 Acres	Fire Agency	Unknown	101860186	Unknown	12,000	Conductor	Overhead	Yes	7/24/17	21:45	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1292	PG&E	07/25/17	15:51	38.37795	-122.53878	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	102031447	Unknown	12,000	Conductor	Overhead	Yes	7/25/17	15:51	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1293	PG&E	07/25/17	19:12	39.59970	-121.44490	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100403612	Unknown	12,000	Conductor	Overhead	Yes	7/25/17	19:12	Equipment/Facility Failure	Conductor	N.A.	N.A.	Unknown	
1294	PG&E	07/26/17	06:55	36.78124	-119.75525	Vegetation	Urban	< 3 Meters	Fire Agency	FRESNO FIRE, BATALION 1, FULMER 559 993 2661	100866522	PACIFIC BELL	12,000	Conductor	Overhead	Yes	7/26/17	06:55	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
1295	PG&E	07/28/17	14:02	40.99973	-121.95793	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	101512624	Unknown	12,000	Conductor	Overhead	Yes	7/28/17	14:02	Equipment/Facility Failure	Conductor	N.A.	N.A.	Unknown	
1296	PG&E	07/28/17	16:57	35.47270	-120.99080	Vegetation	Rural	10 - 99 Acres	Fire Agency	TOM MCEWEN 805-903-3409	101933968	Unknown	12,000	Conductor	Overhead	Yes	7/28/17	16:57	Equipment/Facility Failure	Conductor	N.A.	N.A.	Unknown	
1297	PG&E	07/28/17	19:20	35.72756	-120.99030	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	San Luis Obispo CDF	101945496	None	21,000	Conductor	Overhead	Yes	7/28/17	19:20	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1298	PG&E	07/29/17	13:18	39.46313	-121.45951	Vegetation	Rural	< 0.25 Acres	Fire Agency	russ howler 530 521 8056	103846763	Unknown	12,000	Conductor	Overhead	Yes	7/29/17	13:18	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
1299	PG&E	07/29/17	13:28	35.45229	-120.38344	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101889516	Unknown	0 - 750	Conductor	Overhead	Yes	7/29/17	13:28	Equipment/Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1300	PG&E	07/29/17	14:52	37.05999	-122.00113	Vegetation	Urban	< 0.25 Acres	Fire Agency	Scotts Valley Fire Dept.	101679068	PACIFIC BELL	21,000	Conductor	Overhead	Yes	7/29/17	14:52	Equipment/Facility Failure	Conductor	N.A.	N.A.	Unknown	
1301	PG&E	07/29/17	17:56	37.02507	-121.53583	Vegetation	Rural	< 3 Meters	Fire Agency	GEORGE MARSHALL	100610842	Unknown	21,000	Conductor	Overhead	Yes	7/29/17	17:56	Equipment/Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1302	PG&E	07/29/17	18:08	37.94875	-121.34571	Vegetation	Rural	< 0.25 Acres	Fire Agency	911	102126507	Unknown	12,000	Conductor	Overhead	Yes	7/29/17	18:08	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
1303	PG&E	07/29/17	20:45	35.45171	-120.61711	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	101941008	Unknown	0 - 750	Conductor	Overhead	Yes	7/29/17	20:45	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	Third-party caused
1304	PG&E	07/30/17	09:46	38.91318	-122.61788	Vegetation	Rural	< 0.25 Acres	Fire Agency	mike wink	102151066	None	0 - 750	Conductor	Overhead	Yes	7/30/17	09:46	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1305	PG&E	07/31/17	12:58	37.09707	-122.27955	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	101679025	Unknown	0 - 750	Conductor	Overhead	No	7/31/17	12:58	Equipment/Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1306	PG&E	08/03/17	14:10	35.97865	-120.11100	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	100866130	Unknown	21,000	Conductor	Overhead	Yes	7/31/17	14:10	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1307	PG&E	07/31/17	14:41	38.79675	-121.13288	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	103782414	Unknown	12,000	Conductor	Overhead	Yes	7/31/17	14:41	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1308	PG&E	08/01/17	12:23	36.04123	-119.50529	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	100661556	Unknown	0 - 750	Other	Overhead	Yes	8/1/17	12:23	Equipment/Facility Failure	Pole	N.A.	N.A.	Unknown	
1309	PG&E	08/02/17	9:42	39.22744	-123.10811	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	None	60,000	Conductor	Overhead	Yes	8/2/17	9:42	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
1310	PG&E	08/02/17	5:54	40.79856	-123.39614	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire	100974913	Unknown	12,000	Conductor	Overhead	Yes	8/2/17	5:54	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1311	PG&E	08/02/17	8:58	37.56179	-121.94860	Vegetation	Rural	< 0.25 Acres	Fire Agency	FREMONT FIRE DEPT. 911	100940374	PACIFIC BELL	12,000	Other	Overhead	Yes	8/2/17	8:58	Equipment/Facility Failure	Insulator	N.A.	N.A.	Unknown	
1312	PG&E	08/02/17	17:04	37.31632	-122.07225	Vegetation	Urban	< 0.25 Acres	Fire Agency	TONY RAINIERI 408-378-4010	100534186	Unknown	12,000	Conductor	Overhead	No	8/2/17	17:04	Equipment/Facility Failure	Conductor	N.A.	N.A.	Unknown	
1313	PG&E	08/02/17	18:16	37.39296	-120.62127	Vegetation	Urban	< 3 Meters	Fire Agency	2099663621	101190510	PACIFIC BELL	12,000	Transformer	Overhead	Yes	8/2/17	18:16	Equipment/Facility Failure	Transformer	N.A.	N.A.	Unknown	
1314	PG&E	08/03/17	10:53	39.07320	-121.08679	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	100072742	PACIFIC BELL	12,000	Conductor	Overhead	Yes	8/3/17	10:53	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
1315	PG&E	08/03/17	11:16	38.11924	-122.50154	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	SSR17215008	102272719	Unknown	115,000	Conductor	Overhead	Yes	8/3/17	11:16	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
1316	PG&E	08/03/17	22:44	39.07110	-121.48700	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	ART PAQUETTE 530-633-0861	101335644	Unknown	12,000	Conductor	Overhead	No	8/3/17	22:44	Contact From Object	N.A.	N.A.	N.A.	Unknown	
1317	PG&E	08/04/17	09:54	38.60394	-121.05918	Vegetation	Rural	< 3 Meters	Fire Agency	D. Franks 530-622-3858, Incident #022602	101411052	PACIFIC BELL	21,000	Capacitor Bank	Overhead	Yes	8/4/17	09:54	Equipment/Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
1318	PG&E	08/04/17	18:14	35.61928	-120.65890	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101912293	PACIFIC BELL	12,000	Fuse	Overhead	Yes	8/4/17	18:14	Equipment/Facility Failure	Fuse	N.A.	N.A.	Unknown	
1319	PG&E	08/05/17	08:33	38.45835	-120.86954	Vegetation	Rural	< 0.25 Acres	Fire Agency	JEFF MICHEL 530 409 2223	101236223	Unknown	0 - 750	Conductor	Overhead	Yes	8/5/17	08:33	Equipment/Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X
Utility Name	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes (Optional):	
1387	PG&E	09/02/17	16.18	37.26897	-121.80564	Vegetation	< 3 Meters	Fire Agency	Unknown	100584311	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	9/2/17	16:18	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
1388	PG&E	09/02/17	18.00	37.93380	-122.40690	Vegetation	< 0.25 Acres	Fire Agency	Unknown	102347407	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/2/17	18:00	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused	
1389	PG&E	09/03/17	7.12	37.37432	-122.21838	Vegetation	< 0.25 Acres	Fire Agency	Local	102071066	Unknown	12,000	Conductor	Overhead	Yes	9/3/17	7:12	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1390	PG&E	09/03/17	12.52	37.21616	-119.48067	Vegetation	1000 - 4999 Acres	Fire Agency	Cal Fire	103345573	Unknown	0 - 750	Conductor	Overhead	Yes	9/3/17	12:52	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1391	PG&E	09/03/17	17.52	37.49559	-119.83667	Vegetation	.26 - 9.99 Acres	Fire Agency	209-986-3621	101986621	Unknown	21,000	Transformer	Overhead	Yes	9/3/17	17:52	Contact From Object	N.A.	Other	Electric Facility	Weather	lightning strike	
1392	PG&E	09/03/17	22.27	36.98533	-122.01699	Vegetation	100 - 299 Acres	Fire Agency	CHRIS CHRISTOPHERSON 559-281-4320	100739435	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/3/17	22:27	Contact Between Third Party Facility	N.A.	Vegetation	N.A.	Weather		
1393	PG&E	09/04/17	0.57	36.80240	-119.82540	Vegetation	< 0.25 Acres	Fire Agency	Unknown	100856132	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	9/4/17	0:57	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1394	PG&E	09/04/17	3.29	39.83171	-121.84441	Vegetation	.26 - 9.99 Acres	Fire Agency	Cal Fire	102300100	PACIFIC BELL	12,000	Conductor	Overhead	No			Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
1395	PG&E	09/04/17	6.43	37.45463	-121.93311	Other	Structure Only	Customer	N.A.	100557780	PACIFIC BELL	21,000	Conductor	Overhead	Yes	09/04/17	6:43	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
1396	PG&E	09/05/17	1.24	39.43168	-121.55285	Vegetation	< 0.25 Acres	Fire Agency	Unknown	100420238	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/5/17	1:24	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1397	PG&E	09/05/17	6.58	39.67273	-123.51279	Vegetation	< 0.25 Acres	Customer	N.A.	102194697	VERIZON CALIF	12,000	Conductor	Overhead	Yes	9/5/17	6:58	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1398	PG&E	09/05/17	7.20	39.71095	-121.79724	Vegetation	< 3 Meters	Fire Agency	(530) 538-6841	1020355255	Unknown	12,000	Conductor	Overhead	Yes	9/5/17	7:20	Wire-Wire Contact	N.A.	N.A.	N.A.	Unknown		
1399	PG&E	09/05/17	13.51	38.18972	-121.31746	Vegetation	< 0.25 Acres	Fire Agency	Unknown	103218208	Unknown	12,000	Conductor	Overhead	Yes	9/5/17	13:51	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused	
1400	PG&E	09/05/17	17.51	38.34067	-122.25777	Vegetation	< 3 Meters	Fire Agency	Unknown	102284869	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/5/17	17:51	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
1401	PG&E	09/06/17	19.26	40.83290	-122.36350	Vegetation	< 0.25 Acres	Fire Agency	Unknown	103643183	Unknown	12,000	Conductor	Overhead	Yes	9/6/17	19:26	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1402	PG&E	09/06/17	20.06	37.29255	-122.29403	Vegetation	< 0.25 Acres	Fire Agency	Cal Fire	102256917	Unknown	12,000	Conductor	Overhead	Yes	9/6/17	20:06	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1403	PG&E	09/08/17	4.47	38.74778	-120.85905	Vegetation	.26 - 9.99 Acres	Fire Agency	Cal Fire	101391575	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/8/17	4:47	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1404	PG&E	09/08/17	17.21	38.60388	-120.92748	Vegetation	.26 - 9.99 Acres	Fire Agency	Cal Fire	101379094	PACIFIC BELL	21,000	Conductor	Overhead	Yes	9/8/17	17:21	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1405	PG&E	09/08/17	21.14	37.96038	-120.37636	Vegetation	.26 - 9.99 Acres	Fire Agency	John Lite 209-984-5623	101042521	Unknown	17,000	Conductor	Overhead	Yes	9/8/17	21:14	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1406	PG&E	09/09/17	18.36	36.66181	-121.54766	Vegetation	< 0.25 Acres	Fire Agency	Unknown	101769870	Unknown	12,000	Conductor	Overhead	Yes	9/9/17	18:36	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
1407	PG&E	09/10/17	1.22	39.25988	-121.49023	Vegetation	.26 - 9.99 Acres	Fire Agency	TYLER LOPEZ	101289867	None	12,000	Conductor	Overhead	Yes	9/10/17	1:22	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
1408	PG&E	09/10/17	16.30	37.30393	-120.52747	Vegetation	10 - 99 Acres	Fire Agency	Merced County FD	101161316	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	9/10/17	16:30	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
1409	PG&E	09/11/17	7.18	37.00083	-121.66674	Vegetation	< 3 Meters	Fire Agency	Unknown	100621936	VERIZON CALIF	0 - 750	Conductor	Overhead	No			Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1410	PG&E	09/11/17	8.50	36.95746	-121.84204	Vegetation	< 3 Meters	Self Extinguished	N.A.	101790954	PACIFIC BELL	21,000	Fuse	Overhead	Yes	9/11/17	8:50	Contact From Object	N.A.	Other	Electric Facility	Weather	lightning strike	
1411	PG&E	09/11/17	23.50	40.86724	-124.08827	Vegetation	< 3 Meters	Fire Agency	BOB	100984579	N.A.	12,000	Conductor	Overhead	Yes	9/11/17	23:50	Equipment/ Facility Failure	N.A.	Splice/Clamp/Connector	N.A.	Unknown		
1412	PG&E	09/12/17	9.24	39.74095	-121.60787	Vegetation	< 0.25 Acres	Fire Agency	Unknown	100330302	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/12/17	9:24	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused	
1413	PG&E	09/12/17	17.18	39.45106	-121.60519	Vegetation	.26 - 9.99 Acres	Fire Agency	tom klage 530 538-7888	100419482	Unknown	12,000	Conductor	Overhead	Yes	9/12/17	17:18	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1414	PG&E	09/14/17	11.02	39.11112	-121.55647	Vegetation	< 0.25 Acres	Fire Agency	Unknown	101320308	None	12,000	Switch	Overhead	Yes	9/14/17	11:02	Equipment/ Facility Failure	Switch	N.A.	N.A.	Unknown		
1415	PG&E	09/14/17	12.09	39.50393	-121.54528	Vegetation	< 0.25 Acres	Fire Agency	530-538-2448	100372805	Unknown	12,000	Conductor	Overhead	Yes	9/14/17	12:09	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
1416	PG&E	09/14/17	14.06	40.29421	-123.81736	Vegetation	< 0.25 Acres	Fire Agency	Cal Fire	100899497	Unknown	12,000	Conductor	Overhead	Yes	9/14/17	14:06	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1417	PG&E	09/15/17	14.55	39.74607	-121.48853	Vegetation	< 0.25 Acres	Fire Agency	Cal Fire	100335239	Unknown	12,000	Conductor	Overhead	Yes	9/15/17	14:55	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1418	PG&E	09/17/17	15.05	36.64729	-119.38613	Vegetation	< 3 Meters	Customer	N.A.	100738741	VERIZON CALIF	0 - 750	Conductor	Overhead	Yes	9/17/17	15:05	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1419	PG&E	09/17/17	17.38	38.99459	-121.02607	Vegetation	< 0.25 Acres	Fire Agency	Unknown	10029537	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/17/17	17:38	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
1420	PG&E	09/18/17	13.01	39.38858	-121.40538	Vegetation	< 3 Meters	Fire Agency	Cal Fire	103795057	Unknown	0 - 750	Conductor	Overhead	Yes	9/18/17	13:01	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
1421	PG&E	09/18/17	15.10	39.60135	-121.05451	Vegetation	< 0.25 Acres	Fire Agency	Cal Fire	103849874	Unknown	12,000	Conductor	Overhead	Yes	9/18/17	15:10	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1422	PG&E	09/18/17	18.01	38.21975	-122.54300	Vegetation	.26 - 9.99 Acres	Fire Agency	Cal Fire	101997149	Unknown	12,000	Conductor	Overhead	Yes	9/18/17	18:01	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused	
1423	PG&E	09/18/17	19.01	38.07423	-122.82861	Vegetation	< 0.25 Acres	Fire Agency	Unknown	102229215	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/18/17	19:01	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1424	PG&E	09/18/17	23.50	37.90879	-120.48652	Vegetation	10 - 99 Acres	Fire Agency	incident comander geoff marshall 209-419-4407	101040882	Unknown	17,000	Conductor	Overhead	Yes	9/18/17	23:50	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
1425	PG&E	09/19/17	19.13	35.47836	-119.29591	Vegetation	< 0.25 Acres	Fire Agency	Unknown	102027112	Unknown	12,000	Conductor	Overhead	Yes	9/19/17	19:13	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused	
1426	PG&E	09/20/17	2.06	37.25968	-122.32223	Vegetation	< 0.25 Acres	Fire Agency	Unknown	100322388	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/20/17	2:06	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused	
1427	PG&E	09/20/17	8.41	36.94037	-120.90142	Vegetation	10 - 99 Acres	Fire Agency	Cal Fire	100232808	None	70,000	Conductor	Overhead	Yes	9/20/17	8:41	Contact From Object	N.A.	Other	Electric Facility	Other	bird's nest	
1428	PG&E	09/21/17	8.39	39.61470	-121.72582	Vegetation	< 0.25 Acres	Customer	N.A.	100347380	Unknown	0 - 750	Conductor	Overhead	Yes	9/21/17	8:39	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown		
1429	PG&E	09/22/17	14.28	36.09612	-120.05766	Vegetation	< 0.25 Acres	Fire Agency	SAME AS TAG. FD NOT STANDING BY UPON ARRIVAL	100663084	Unknown	12,000	Capacitor Bank	Overhead	No			Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown		
1430	PG&E	09/23/17	9.16	37.01267	-120.62562	Vegetation	< 0.25 Acres	Fire Agency	Cal Fire	101181497	Unknown	12,000	Conductor	Overhead	Yes	9/23/17	9:16	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown		
1431	PG&E	09/23/17	14.17	40.65090	-122.29740	Vegetation	.26 - 9.99 Acres	Fire Agency	DARREN STEWART 448-2421	101467221	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/23/17	14:17	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused	
1432	PG&E	09/24/17	2.13	38.10460	-120.98901	Vegetation	10 - 99 Acres	Fire Agency	Cal Fire	100161297	Unknown	60,000	Conductor	Overhead	Yes	9/24/17	2:13	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown		
1433	PG&E	09/24/17	7.54	37.40140	-122.02740	Vegetation	< 3 Meters	Fire Agency	Unknown	100515206	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/24/17	7:54	Contact From Object	N.A.	Animal	Electric Facility	Unknown		
1434	PG&E	09/24/17	16.42	38.36890	-122.96670	Vegetation	.26 - 9.99 Acres	Fire Agency	DOUG JONES	101973946	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/24/17	16:42	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown		
1435	PG&E	09/25/17																						

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X
2	Utility Name	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes (Optional):
1499	PG&E	10/18/17	13:58	37.63605	-122.07925	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	100952408	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	10/18/17	13:58	Contact From Object	N.A.	Vehicle	N.A.	Human Error	
1500	PG&E	10/20/17	5:59	36.74748	-119.76295	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	100859667	Unknown	12,000	Conductor	Overhead	Yes	10/20/17	5:59	Equipment/Facility Failure	Insulator	N.A.	N.A.	Unknown	
1501	PG&E	10/20/17	6:18	39.29221	-121.01573	Vegetation	Rural	< 3 Meters	Fire Agency	PHILLIP NUNNINK INCIDENT # 27272	100087647	PACIFIC BELL	12,000	Conductor	Overhead	Yes	10/20/17	6:18	Equipment/Facility Failure	Conductor	N.A.	N.A.	Unknown	
1502	PG&E	10/20/17	9:06	36.03599	-120.05797	Vegetation	Rural	300 - 999 Acres	Fire Agency	Unknown	Pole 009/009	Unknown	70,000	Conductor	Overhead	Yes	10/20/17	9:06	Contact From Object	N.A.	Other	Electric Facility	Other	bird's nest
1503	PG&E	10/20/17	13:43	35.35300	-119.98730	Vegetation	Rural	10 - 99 Acres	Fire Agency	Kevin McLean Office(805)593-3421, Cell(805)903-3421	10136483	Unknown	12,000	Conductor	Overhead	Yes	10/20/17	13:43	Equipment/Facility Failure	Conductor	N.A.	N.A.	Unknown	
1504	PG&E	10/20/17	13:45	34.55317	-120.53029	Vegetation	Rural	100 - 299 Acres	Fire Agency	Unknown	101921492	Unknown	12,000	Conductor	Overhead	Yes	10/20/17	13:45	Equipment/Facility Failure	Crossarm	N.A.	N.A.	Unknown	
1505	PG&E	10/20/17	14:00	36.92155	-119.72828	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100727124	Unknown	21,000	Fuse	Overhead	Yes	10/20/17	14:00	Equipment/Facility Failure	Other	N.A.	N.A.	Unknown	
1506	PG&E	10/21/17	15:08	39.06400	-122.77645	Vegetation	Rural	< 3 Meters	Fire Agency	Cal Fire	102155186	PACIFIC BELL	12,000	Conductor	Overhead	Yes	10/21/17	15:08	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1507	PG&E	10/21/17	16:05	37.59108	-122.00995	Vegetation	Urban	.26 - 9.99 Acres	Fire Agency	Unknown	103516949	Unknown	0 - 750	Conductor	Overhead	Yes	10/21/17	16:05	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	Third-party caused
1508	PG&E	10/23/17	19:34	36.07720	-121.01900	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	101736398	Unknown	12,000	Conductor	Overhead	Yes	10/23/17	19:34	Equipment/Facility Failure	Conductor	N.A.	N.A.	Unknown	
1509	PG&E	10/23/17	21:24	37.37133	-122.34799	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	100270421	Unknown	12,000	Conductor	Overhead	Yes	10/23/17	21:24	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1510	PG&E	10/24/17	15:23	36.85988	-121.79474	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101789001	PACIFIC BELL	21,000	Conductor	Overhead	Yes	10/24/17	15:23	Equipment/Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1511	PG&E	10/26/17	10:53	36.40356	-121.91219	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	101777002	Unknown	12,000	Conductor	Overhead	Yes	10/26/17	10:53	Equipment/Facility Failure	Insulator	N.A.	N.A.	Unknown	
1512	PG&E	10/28/17	15:26	39.45162	-123.38381	Vegetation	Rural	< 3 Meters	Fire Agency	Cal Fire	102209084	Unknown	12,000	Conductor	Overhead	Yes	10/28/17	15:26	Contact From Object	N.A.	Vehicle	Communication Facility	Human Error	
1513	PG&E	10/28/17	20:06	35.02222	-118.76915	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	100223850	Unknown	12,000	Conductor	Overhead	Yes	10/28/17	20:06	Equipment/Facility Failure	Fuse	N.A.	N.A.	Unknown	
1514	PG&E	10/31/17	18:56	39.00345	-121.69065	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	Pole 010/208	Unknown	60,000	Conductor	Overhead	Yes	10/31/17	18:56	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	Third-party caused
1515	PG&E	10/31/17	21:02	39.11189	-122.91633	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	Structure 020/003	Unknown	60,000	Conductor	Overhead	Yes	10/31/17	21:02	Equipment/Facility Failure	Insulator	N.A.	N.A.	Unknown	
1516	PG&E	11/06/17	9:59	37.14600	-121.66753	Vegetation	Rural	< 0.25 Acres	Fire Agency	INCIDENT # 1717CASC008183	103570543	YES	21,000	Conductor	Overhead	Yes	11/6/17	9:59	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1517	PG&E	11/06/17	15:06	38.29980	-122.50300	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	101982913	PACIFIC BELL	12,000	Conductor	Overhead	Yes	11/6/17	15:06	Equipment/Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1518	PG&E	11/08/17	07:11	37.73669	-120.34587	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	101191714	PACIFIC BELL	12,000	Conductor	Overhead	Yes	11/8/17	07:11	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1519	PG&E	11/08/17	14:53	37.79198	-122.22211	Building	Urban	Structure Only	Fire Agency	Unknown	101352529	Unknown	4,000	Conductor	Overhead	Yes	11/8/17	14:53	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1520	PG&E	11/11/17	11:57	35.11908	-120.39364	Vegetation	Rural	< 0.25 Acres	Fire Agency	Jordan Dayley ph#929-3911.engine#3467	101931190	PACIFIC BELL	12,000	Conductor	Overhead	Yes	11/11/17	11:57	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1521	PG&E	11/12/17	19:44	36.73779	-119.77691	Building	Urban	< 0.25 Acres	Fire Agency	capt will johnson	100871063	Unknown	12,000	Capacitor Bank	Overhead	Yes	11/12/17	19:44	Equipment/Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
1522	PG&E	11/14/17	08:23	37.32400	-120.81456	Vegetation	Rural	< 3 Meters	Fire Agency	cammu #023223	101723997	Unknown	12,000	Transformer	Overhead	Yes	11/14/17	08:23	Equipment/Facility Failure	Transformer	N.A.	N.A.	Unknown	
1523	PG&E	11/17/17	09:53	37.08018	-120.01945	Other	Rural	< 3 Meters	Utility; PG&E	N.A.	101029626	Unknown	12,000	Fuse	Overhead	Yes	11/17/17	09:53	Equipment/Facility Failure	Fuse	N.A.	N.A.	Unknown	
1524	PG&E	11/20/17	08:32	38.75835	-120.84385	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	101389405	PACIFIC BELL	12,000	Conductor	Overhead	Yes	11/20/17	08:32	Equipment/Facility Failure	Conductor	N.A.	N.A.	Unknown	
1525	PG&E	11/20/17	20:05	35.49951	-118.90994	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	661-324-6551	103782809	None	0 - 750	Conductor	Overhead	Yes	11/20/17	20:05	Equipment/Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1526	PG&E	11/21/17	11:55	37.61013	-121.33324	Vegetation	Rural	< 0.25 Acres	Fire Agency	tracy fire dept	102053617	PACIFIC BELL	12,000	Conductor	Overhead	Yes	11/21/17	11:55	Equipment/Facility Failure	Conductor	N.A.	N.A.	Unknown	
1527	PG&E	11/22/17	13:44	36.75202	-121.66363	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	101354362	Unknown	12,000	Conductor	Overhead	Yes	11/22/17	13:44	Equipment/Facility Failure	Insulator	N.A.	N.A.	Unknown	
1528	PG&E	11/23/17	16:29	35.77554	-120.69413	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101860971	Unknown	12,000	Conductor	Overhead	Yes	11/23/17	16:29	Equipment/Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1529	PG&E	11/24/17	10:33	36.62133	-120.06165	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	KERMAN FIRE DEP.	100700090	Unknown	12,000	Conductor	Overhead	Yes	11/24/17	10:33	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1530	PG&E	11/29/17	6:29	36.01436	-119.95559	Vegetation	Rural	< 3 Meters	Utility; PG&E	N.A.	100693913	Unknown	12,000	Conductor	Overhead	Yes	11/29/17	6:29	Equipment/Facility Failure	Conductor	N.A.	N.A.	Unknown	
1531	PG&E	11/29/17	10:10	36.70981	-119.56321	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	100815464	VERIZON CALIFO	0 - 750	Conductor	Overhead	Yes	11/29/17	10:10	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused
1532	PG&E	11/27/17	7:01	39.74474	-121.66812	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	101123997	Unknown	12,000	Conductor	Overhead	Yes	11/27/17	7:01	Equipment/Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1533	PG&E	11/27/17	11:11	37.12962	-122.31244	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100268264	Unknown	12,000	Conductor	Overhead	Yes	11/27/17	11:11	Equipment/Facility Failure	Conductor	N.A.	N.A.	Unknown	
1534	PG&E	11/28/17	15:49	36.49743	-119.79086	Vegetation	Rural	< 3 Meters	Self Extinguished	N.A.	100806272	Unknown	12,000	Other	Overhead	Yes	11/28/17	15:49	Equipment/Facility Failure	Voltage Regulator	N.A.	N.A.	Unknown	
1535	PG&E	11/29/17	17:34	38.68410	-120.65461	Vegetation	Rural	< 3 Meters	Fire Agency	Cal Fire	101419450	PACIFIC BELL	21,000	Conductor	Overhead	Yes	11/29/17	17:34	Equipment/Facility Failure	Conductor	N.A.	N.A.	Unknown	
1536	PG&E	12/07/17	12:25	34.71151	-120.17715	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	Pole 015/220	Unknown	115,000	Unknown	Overhead	No	N.A.	N.A.	Unknown	N.A.	N.A.	N.A.	Unknown	
1537	PG&E	12/12/17	4:40	39.77107	-121.59727	Building	Urban	Structure Only	Fire Agency	paradise fire city department	100324902	PACIFIC BELL	12,000	Fuse	Overhead	Yes	12/12/17	4:40	Equipment/Facility Failure	Insulator	N.A.	N.A.	Unknown	
1538	PG&E	12/13/17	12:13	35.59220	-120.64741	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103390807	Unknown	21,000	Other	Overhead	Yes	12/13/17	12:13	Equipment/Facility Failure	Recloser	N.A.	N.A.	Unknown	
1539	PG&E	12/14/17	1:33	37.19789	-121.83746	Building	Rural	Structure Only	Fire Agency	Unknown	100622323	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	12/14/17	1:33	Equipment/Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1540	PG&E	12/14/17	17:16	34.58783	-120.35663	Vegetation	Rural	10 - 99 Acres	Fire Agency	Unknown	101911004	VERIZON CALIFO	12,000	Conductor	Overhead	Yes	12/14/17	17:16	Equipment/Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1541	PG&E	12/16/17	7:01	39.74474	-122.19612	Building	Urban	Structure Only	Fire Agency	ORLANDO CITY FIRE DEPT	100428554	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	12/16/17	7:01	Equipment/Facility Failure	Conductor	N.A.	N.A.	Unknown	
1542	PG&E	12/16/17	11:51	38.81706	-122.70412	Vegetation	Urban	.26 - 9.99 Acres	Fire Agency	Shawn Chare	102167231	PACIFIC BELL	12,000	Conductor	Overhead	Yes	12/16/17	11:51	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1543	PG&E	12/16/17	13:39	37.97022	-121.64092	Vegetation	Rural	< 0.25 Acres	Fire Agency	FIRE CAPTAIN ON DUTY	100473121	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	12/16/17	13:39	Equipment/Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1544	PG&E	12/16/17	16:03	35.65299	-120.49459	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103311190	Unknown	21,000	Conductor	Overhead	Yes	12/16/17	16:03	Other	N.A.	N.A.	N.A.	Unknown	
1545	PG&E	12/19/17	7:05	36.27152	-120.39270	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100													

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X
2	Utility Name	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes (Optional):
1613	PG&E	5/29/18	15:52	37.50916	-121.95447	Vegetation	Rural	< 0.25 Acres	Fire Agency	925-422-7595	07589613	N.A.	21,000	Conductor	Subsurface	Yes	5/29/18	15:52	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1614	PG&E	5/30/18	13:00	38.52754	-121.82136	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	01641285	None	12,000	Conductor	Overhead	Yes	5/30/18	13:00	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
1615	PG&E	5/30/18	16:58	38.32472	-121.82347	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	03900943	Unknown	21,000	Conductor	Overhead	Yes	5/30/18	16:58	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1616	PG&E	5/31/18	6:30	38.97449	-121.61015	Vegetation	Rural	< 0.25 Acres	Fire Agency	Sutter County FD	03127037	None	12,000	Conductor	Overhead	Yes	5/31/18	6:30	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1617	PG&E	5/31/18	8:50	36.16735	-119.86120	Vegetation	Rural	< 0.25 Acres	Fire Agency	on-site	00688476	Unknown	12,000	Conductor	Overhead	Yes	5/31/18	8:50	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	third-party caused
1618	PG&E	5/31/18	12:28	36.77108	-119.74169	Vegetation	Urban	< 0.25 Acres	Fire Agency	Garcia	00841706	AT&T	12,000	Conductor	Overhead	Yes	5/31/18	12:28	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
1619	PG&E	5/31/18	14:34	35.48476	-119.04683	Vegetation	Rural	< 0.25 Acres	Fire Agency	REPORT NUMBER 1821047---(661) 324-6551	00114852	Unknown	12,000	Conductor	Overhead	Yes	5/31/18	14:34	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1620	PG&E	6/2/18	12:02	40.45529	-122.32007	Vegetation	Rural	< 0.25 Acres	Fire Agency	STATION 63 RESPONDED	014196970	AT&T	12,000	Conductor	Overhead	Yes	6/2/18	12:02	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1621	PG&E	6/2/18	16:11	37.31560	-122.02224	Vegetation	Urban	< 0.25 Acres	Fire Agency	Santa Clara County Fire	100555119	AT&T	12,000	Conductor	Overhead	Yes	6/2/18	16:11	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1622	PG&E	6/2/18	21:37	37.31096	-121.90709	Vegetation	Urban	< 3 meters	Fire Agency	San Jose FD	03781309	Unknown	12,000	Conductor	Overhead	Yes	6/2/18	21:37	Unknown	N.A.	N.A.	Unknown		
1623	PG&E	6/3/18	8:39	39.80416	-122.34618	Vegetation	Rural	10 - 99 Acres	Fire Agency	Unknown	03387870	Unknown	0 - 750	Conductor	Overhead	Yes	6/3/18	8:39	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1624	PG&E	6/3/18	15:01	36.83235	-121.36275	Vegetation	Rural	10 - 99 Acres	Fire Agency	CAL FIRE	03901497	AT&T	21,000	Conductor	Overhead	Yes	6/3/18	15:01	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1625	PG&E	6/3/18	15:08	39.51566	-121.54214	Vegetation	Urban	< 3 meters	Customer	N.A.	00374172	Unknown	12,000	Conductor	Overhead	Yes	6/3/18	15:08	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1626	PG&E	6/4/18	8:25	35.45929	-120.49212	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	01885513	Unknown	0 - 750	Conductor	Overhead	Yes	6/4/18	9:25	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1627	PG&E	6/4/18	13:18	37.01585	-120.00117	Vegetation	Rural	.26 - 9.99 Acres	Unknown	N.A.	01108691	Unknown	12,000	Conductor	Overhead	Yes	6/4/18	13:18	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1628	PG&E	6/4/18	14:31	35.13330	-119.48131	Vegetation	Urban	.26 - 9.99 Acres	Fire Agency	Unknown	00193277	None	12,000	Conductor	Overhead	Yes	6/4/18	14:31	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1629	PG&E	6/4/18	14:45	36.51822	-119.63143	Vegetation	Rural	< 3 meters	Unknown	N.A.	00831403	Unknown	12,000	Conductor	Overhead	Yes	6/4/18	14:45	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1630	PG&E	6/4/18	17:38	36.40021	-120.98505	Vegetation	Rural	1000 - 4999 Acres	Fire Agency	CAL FIRE	03850438	Unknown	12,000	Conductor	Overhead	Yes	6/4/18	17:38	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1631	PG&E	6/4/18	17:38	36.37923	-120.90840	Vegetation	Rural	300 - 999 Acres	Fire Agency	CAL FIRE	01733595	Unknown	12,000	Conductor	Overhead	Yes	6/4/18	17:38	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1632	PG&E	6/4/18	21:42	35.36297	-118.98465	Vegetation	Urban	< 3 meters	Fire Agency	Unknown	00146786	Yes	0 - 750	Conductor	Overhead	Yes	6/4/18	21:42	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1633	PG&E	6/5/18	10:13	40.61831	-122.31731	Vegetation	Rural	< 0.25 Acres	Fire Agency	JASON COLLINS 530-225-4628	010467801	None	12,000	Conductor	Overhead	Yes	6/5/18	10:13	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1634	PG&E	6/5/18	11:46	38.24644	-122.44939	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	01998865	Unknown	12,000	Conductor	Overhead	Yes	6/5/18	11:46	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	third-party caused
1635	PG&E	6/5/18	13:45	38.54320	-122.72020	Vegetation	Rural	< 3 meters	Unknown	N.A.	02031673	AT&T	12,000	Conductor	Overhead	Yes	6/5/18	13:45	Contact From Object	N.A.	N.A.	Unknown		
1636	PG&E	6/5/18	16:46	38.72446	-120.80200	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	03667302	AT&T	12,000	Conductor	Overhead	Yes	6/5/18	16:46	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	third-party caused
1637	PG&E	6/5/18	19:10	35.87633	-119.54339	Vegetation	Rural	< 0.25 Acres	Fire Agency	LT. Stewart (559) 949-8343 dstewart@co.tulare.ca.us	00649683	Unknown	12,000	Conductor	Overhead	Yes	6/5/18	19:10	Vandalism/Theft	N.A.	N.A.	Unknown		
1638	PG&E	6/6/18	10:32	36.28370	-119.77342	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Kings County FD	00711710	AT&T	0 - 750	Conductor	Overhead	Yes	6/6/18	10:32	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1639	PG&E	6/6/18	11:07	38.27343	-122.43845	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	02005548	AT&T	12,000	Conductor	Overhead	Yes	6/6/18	11:07	Wire-Wire Contact	N.A.	N.A.	Unknown	Work error	
1640	PG&E	6/6/18	15:00	38.79495	-121.48476	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Adrian Rogers (530) 682-7908	03815399	AT&T	12,000	Conductor	Overhead	Yes	6/6/18	15:00	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1641	PG&E	6/6/18	16:28	38.08008	-121.22891	Vegetation	Rural	< 0.25 Acres	Fire Agency	Fire Chief Steve Henry 6925 E. Foppiano Ln Stockton Ca 95212 209931-3107	02105447	AT&T	12,000	Conductor	Overhead	Yes	6/6/18	16:28	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1642	PG&E	6/6/18	19:13	37.14599	-121.66763	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	03790604	None	0 - 750	Conductor	Overhead	Yes	6/6/18	19:13	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1643	PG&E	6/6/18	19:21	38.01119	-121.08517	Vegetation	Rural	.26 - 9.99 Acres	Unknown	N.A.	03351403	Unknown	12,000	Conductor	Overhead	Yes	6/6/18	19:21	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	third-party caused
1644	PG&E	6/6/18	21:06	38.15100	-121.68037	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	01865829	Frontier	21,000	Conductor	Overhead	Yes	6/6/18	21:06	Unknown	N.A.	N.A.	Unknown		
1645	PG&E	6/8/18	17:10	35.47698	-120.65407	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	01936165	Unknown	12,000	Conductor	Overhead	Yes	6/8/18	17:10	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1646	PG&E	6/8/18	19:03	35.15397	-120.59403	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	01852092	AT&T	12,000	Conductor	Overhead	Yes	6/8/18	19:03	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1647	PG&E	6/9/18	0:46	35.07448	-120.51670	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	01927520	Unknown	12,000	Conductor	Overhead	Yes	6/9/18	0:46	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1648	PG&E	6/9/18	16:02	37.87853	-121.64742	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	east county fire	00497205	Unknown	21,000	Conductor	Overhead	Yes	6/9/18	16:02	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1649	PG&E	6/10/18	17:19	38.41570	-122.91838	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	01978419	AT&T	12,000	Conductor	Overhead	Yes	6/10/18	17:19	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1650	PG&E	6/11/18	14:20	38.89753	-121.31194	Vegetation	Urban	.26 - 9.99 Acres	Fire Agency	CAL FIRE	00042575	N.A.	12,000	Conductor	Subsurface	Yes	6/11/18	14:20	Contact From Object	N.A.	Other	Electric Facility	Unknown	
1651	PG&E	6/11/18	17:49	34.73294	-120.08608	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	03015183	Unknown	0 - 750	Conductor	Overhead	Yes	6/11/18	17:49	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	third-party dig in
1652	PG&E	6/11/18	19:59	38.23105	-120.79440	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CAL FIRE	01620000	None	60,000	Conductor	Overhead	Yes	6/11/18	19:59	Contaminant	N.A.	N.A.	Unknown		
1653	PG&E	6/12/18	8:55	35.85075	-119.89146	Vegetation	Rural	10 - 99 Acres	Fire Agency	Jason Brown 559-935-0756	00649777	None	21,000	Conductor	Overhead	Yes	6/12/18	8:55	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1654	PG&E	6/12/18	12:12	38.58904	-121.51999	Vegetation	Urban	< 3 meters	Fire Agency	West Sac FD	01657851	Unknown	12,000	Conductor	Overhead	Yes	6/12/18	12:12	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
1655	PG&E	6/13/18	2:53	36.89639	-121.83738	Vegetation	Rural	< 3 meters	Fire Agency	Sean Murray -Phone # 831-728-8290 and cell # 831254-1716	01699116	AT&T	21,000	Conductor	Overhead	Yes	6/13/18	2:53	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
1656	PG&E	6/13/18	11:18	35.29270	-120.42897	Vegetation	Rural	< 3 meters	Customer	N.A.	01884565	Unknown	12,000	Conductor	Overhead	Yes	6/13/18	11:18	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1657	PG&E	6/13/18	16:27	36.63005	-119.98967	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	00667215	Unknown	12,000	Conductor	Overhead	Yes	6/13/18	16:27	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1658	PG&E	6/13/18	22:40	38.49014	-122.66614	Vegetation	Rural	< 0.25 Acres	Fire Agency	SRS181640125	01966547	Unknown	12,000	Conductor	Overhead	Yes	6/13/18	22:40	Equipment/ Facility Failure	Voltage Regulator	N.A.	N.A.	Unknown	
1659	PG&E	6/14/18	14:25	39.52464	-121.46257	Vegetation	Urban	< 0.25 Acres	Fire Agency	Mike Waters (investigator 530 538-7888)	00426966	None	12,000	Conductor	Overhead	Yes	6/14/18	14:25	Contact From Object	N.A.	Other	Electric Facility	Human Error	bucket truck
1660	PG&E																							

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X
2	Utility Name	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes (Optional):
1723	PG&E	7/2/18	2:26	37.70867	-121.27728	Vegetation	Rural	< 3 meters	Fire Agency	209236-8105	103921895	Unknown	17,000	Conductor	Overhead	Yes	7/2/18	2:26	Equipment /Facility Failure	Insulator	N.A.	N.A.	Unknown	
1724	PG&E	7/2/18	5:12	38.60918	-122.45947	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	707-967-1467	102252558	AT&T	21,000	Conductor	Overhead	Yes	7/2/18	5:12	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1725	PG&E	7/2/18	11:35	39.09951	-122.90008	Vegetation	Rural	< 3 meters	Unknown	N.A.	102146848	Unknown	12,000	Conductor	Overhead	Yes	7/2/18	11:35	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1726	PG&E	7/2/18	17:15	36.60519	-119.82395	Vegetation	Rural	< 3 meters	Customer	N.A.	100753607	Unknown	12,000	Conductor	Overhead	Yes	7/2/18	17:15	Equipment /Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1727	PG&E	7/3/18	18:02	39.71125	-121.82622	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	103387781	Unknown	12,000	Conductor	Overhead	Yes	7/3/18	18:02	Unknown	N.A.	N.A.	N.A.	Unknown	
1728	PG&E	7/4/18	15:26	39.55378	-123.42549	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CAL FIRE	102196183	Verizon	12,000	Conductor	Overhead	Yes	7/4/18	15:26	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	third-party caused
1729	PG&E	7/5/18	12:45	39.77857	-121.86991	Vegetation	Urban	< 3 meters	Customer	N.A.	103350704	Unknown	0 - 750	Conductor	Overhead	Yes	7/5/18	12:45	Equipment /Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1730	PG&E	7/6/18	17:13	35.02903	-120.52785	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103401924	Unknown	12,000	Conductor	Overhead	Yes	7/6/18	17:13	Equipment /Facility Failure	Conductor	N.A.	N.A.	Unknown	
1731	PG&E	7/6/18	20:39	37.38323	-120.61507	Vegetation	Urban	< 0.25 Acres	Unknown	N.A.	103217389	Unknown	12,000	Conductor	Overhead	No	N.A.	N.A.	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	third-party caused
1732	PG&E	7/7/18	6:11	38.08360	-121.85496	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101582721	Frontier	21,000	Conductor	Overhead	Yes	7/7/18	6:11	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1733	PG&E	7/7/18	9:05	39.27449	-121.66469	Vegetation	Urban	< 3 meters	Unknown	N.A.	101327124	Unknown	12,000	Conductor	Overhead	Yes	7/7/18	9:05	Contact From Object	N.A.	Other	Electric Facility	Human Error	third-party caused
1734	PG&E	7/7/18	20:24	35.02115	-120.50036	Vegetation	Urban	< 0.25 Acres	Unknown	N.A.	101893417	AT&T	12,000	Conductor	Overhead	Yes	7/7/18	20:24	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1735	PG&E	7/8/18	19:32	38.77362	-122.06208	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101661938	None	21,000	Conductor	Overhead	Yes	7/8/18	19:32	Equipment /Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1736	PG&E	7/8/18	20:04	39.79149	-123.19813	Vegetation	Rural	< 3 meters	Unknown	N.A.	102182026	Verizon	12,000	Conductor	Overhead	Yes	7/8/18	20:04	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1737	PG&E	7/9/18	7:27	35.07852	-120.39481	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101981368	Unknown	12,000	Conductor	Overhead	Yes	7/9/18	7:27	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1738	PG&E	7/10/18	6:05	38.85410	-121.18056	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	100052871	AT&T	12,000	Conductor	Overhead	Yes	7/10/18	5:05	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1739	PG&E	7/10/18	6:45	37.08496	-122.07441	Vegetation	Urban	< 0.25 Acres	Fire Agency	CAL FIRE	101675262	AT&T	0 - 750	Conductor	Overhead	Yes	7/10/18	6:45	Equipment /Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1740	PG&E	7/10/18	18:58	40.13842	-122.20849	Vegetation	Rural	< 3 meters	Unknown	N.A.	101538131	Unknown	12,000	Conductor	Overhead	Yes	7/10/18	18:58	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1741	PG&E	7/11/18	2:11	37.71042	-121.47328	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101538131	None	115,000	Conductor	Overhead	Yes	7/11/18	2:11	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	third-party caused
1742	PG&E	7/11/18	10:10	37.07247	-120.94945	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	103920696	None	12,000	Conductor	Overhead	Yes	7/11/18	10:10	Equipment /Facility Failure	Pole	N.A.	N.A.	Unknown	
1743	PG&E	7/13/18	8:10	37.09974	-120.83611	Vegetation	Rural	< 3 meters	Fire Agency	Merced FD	101178812	Unknown	12,000	Capacitor Bank	Overhead	No	N.A.	N.A.	Equipment /Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
1744	PG&E	7/13/18	10:59	39.48359	-123.79238	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	102184869	AT&T	12,000	Conductor	Overhead	Yes	7/13/18	10:59	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1745	PG&E	7/13/18	15:45	40.48310	-122.32250	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	103160260	Unknown	12,000	Conductor	Overhead	Yes	7/13/18	15:45	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1746	PG&E	7/13/18	18:51	39.77898	-122.14092	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	100421715	Unknown	12,000	Conductor	Overhead	Yes	7/13/18	18:51	Equipment /Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1747	PG&E	7/14/18	11:34	38.40265	-122.54991	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	103141862	Verizon	12,000	Conductor	Overhead	Yes	7/14/18	11:34	Equipment /Facility Failure	Other	N.A.	N.A.	Unknown	
1748	PG&E	7/14/18	12:40	38.57926	-122.87798	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103122744	AT&T	12,000	Conductor	Overhead	Yes	7/14/18	12:40	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1749	PG&E	7/14/18	12:56	39.20931	-121.19695	Vegetation	Rural	< 0.25 Acres	Fire Agency	INFO	100068833	None	21,000	Conductor	Overhead	Yes	7/14/18	12:56	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1750	PG&E	7/14/18	14:44	38.95242	-121.24673	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100035452	AT&T	12,000	Conductor	Overhead	Yes	7/14/18	14:44	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1751	PG&E	7/14/18	15:01	37.83874	-121.01651	Vegetation	Rural	.26 - 9.99 Acres	Unknown	N.A.	102330872	Unknown	17,000	Conductor	Overhead	Yes	7/14/18	15:01	Equipment /Facility Failure	Conductor	N.A.	N.A.	Unknown	
1752	PG&E	7/14/18	15:58	35.42813	-119.05902	Vegetation	Urban	< 3 meters	Unknown	N.A.	100238826	None	12,000	Conductor	Overhead	Yes	7/14/18	15:58	Equipment /Facility Failure	Fuse	N.A.	N.A.	Unknown	
1753	PG&E	7/14/18	21:38	36.33141	-121.88287	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	ASSISTED JAIME	101672234	Unknown	12,000	Conductor	Overhead	Yes	7/14/18	21:38	Contact From Object	N.A.	Animal	Pole	Other	bull rubbing pole
1754	PG&E	7/15/18	10:06	35.53008	-119.07180	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	100206898	Unknown	12,000	Conductor	Overhead	Yes	7/15/18	10:06	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1755	PG&E	7/16/18	12:57	35.59011	-120.64335	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101904896	Unknown	21,000	Capacitor Bank	Overhead	Yes	7/16/18	12:57	Equipment /Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
1756	PG&E	7/17/18	5:59	37.93801	-122.51415	Vegetation	Rural	< 3 meters	Unknown	N.A.	102231901	Unknown	12,000	Conductor	Overhead	Yes	7/17/18	5:59	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1757	PG&E	7/17/18	11:11	35.69857	-120.97769	Vegetation	Rural	10 - 99 Acres	Fire Agency	007640	103886652	Unknown	21,000	Conductor	Overhead	Yes	7/17/18	11:11	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1758	PG&E	7/17/18	11:58	37.22171	-121.67779	Vegetation	Rural	< 0.25 Acres	Fire Agency	Luis Morado state arson fire fighter	100601345	Unknown	12,000	Conductor	Overhead	Yes	7/17/18	11:58	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1759	PG&E	7/17/18	15:16	39.00625	-122.87632	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	102158497	Unknown	0 - 750	Conductor	Overhead	Yes	7/17/18	15:16	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1760	PG&E	7/17/18	15:53	35.34975	-119.03619	Vegetation	Urban	< 3 meters	Unknown	N.A.	100244890	Yes	0 - 750	Conductor	Overhead	Yes	7/17/18	15:53	Equipment /Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1761	PG&E	7/17/18	16:53	38.39550	-122.92120	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	101978449	AT&T	12,000	Conductor	Overhead	Yes	7/17/18	16:53	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1762	PG&E	7/17/18	19:40	40.59275	-122.48856	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101477082	AT&T	12,000	Conductor	Overhead	Yes	7/17/18	19:40	Equipment /Facility Failure	Transformer	N.A.	N.A.	Unknown	
1763	PG&E	7/18/18	1:14	38.36714	-120.55778	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CAL FIRE	101247987	Unknown	12,000	Conductor	Overhead	Yes	7/18/18	1:14	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1764	PG&E	7/18/18	3:48	37.12889	-121.85867	Vegetation	Urban	< 3 meters	Unknown	N.A.	103426203	Yes	21,000	Conductor	Overhead	Yes	7/18/18	3:48	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1765	PG&E	7/18/18	7:16	35.61704	-119.19527	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	103909160	None	12,000	Conductor	Overhead	Yes	7/18/18	7:16	Equipment /Facility Failure	Transformer	N.A.	N.A.	Unknown	
1766	PG&E	7/18/18	11:19	39.07137	-121.46298	Vegetation	Rural	.26 - 9.99 Acres	Unknown	N.A.	101324059	Unknown	12,000	Conductor	Overhead	Yes	7/18/18	11:19	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1767	PG&E	7/18/18	14:50	38.98919	-121.31662	Vegetation	Rural	10 - 99 Acres	Fire Agency	Fire insp. Cris Mertens 530-277-2322	100028525	Unknown	12,000	Conductor	Overhead	Yes	7/18/18	14:50	Equipment /Facility Failure	Fuse	N.A.	N.A.	Unknown	
1768	PG&E	7/19/18	0:08	36.93722	-119.45570	Vegetation	Rural	< 0.25 Acres	Fire Agency	incident # 10559	100677019	AT&T	12,000	Conductor	Overhead	Yes	7/19/18	0:08	Equipment /Facility Failure	Other	N.A.	N.A.	Unknown	
1769	PG&E	7/19/18	5:29	40.19184	-123.53734	Vegetation	Rural	< 0.25 Acres	Fire Agency	fire captain	103909820	Unknown	12,000	Conductor	Overhead	Yes	7/19/18	5:29	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1770	PG&E	7/19/18	10:44	36.22216	-119.77959	Vegetation	Rural	< 3 meters	Utility: PG&E	N.A.														

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X
2	Utility Name	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes (Optional):
1834	PG&E	8/10/18	12:54	38.79902	-120.72997	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CAL FIRE	101386272	AT&T	12,000	Conductor	Overhead	Yes	8/10/18	12:54	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1835	PG&E	8/10/18	15:39	38.20251	-122.15789	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103697205	Unknown	12,000	Conductor	Overhead	Yes	8/10/18	15:39	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1836	PG&E	8/10/18	19:18	35.76524	-120.31365	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	18ca-slu-008722 dennis 805 543 4244	101876421	Unknown	21,000	Conductor	Overhead	Yes	8/10/18	19:18	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1837	PG&E	8/10/18	20:18	39.20932	-121.06149	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	100075517	AT&T	12,000	Conductor	Overhead	Yes	8/10/18	20:18	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1838	PG&E	8/11/18	16:58	38.19525	-120.67578	Vegetation	Rural	< 0.25 Acres	Fire Agency	DON YOUNG	101250814	Unknown	12,000	Conductor	Overhead	Yes	8/11/18	16:58	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1839	PG&E	8/12/18	11:42	35.83265	-119.25446	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	100140950	None	12,000	Conductor	Overhead	Yes	8/12/18	11:42	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1840	PG&E	8/12/18	14:46	38.64428	-120.92115	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	101410516	Unknown	21,000	Conductor	Overhead	Yes	8/12/18	14:46	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1841	PG&E	8/13/18	15:11	37.88318	-121.24832	Vegetation	Rural	< 3 meters	Unknown	N.A.	102137301	Unknown	12,000	Conductor	Overhead	Yes	8/13/18	15:11	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1842	PG&E	8/13/18	15:33	38.70800	-120.96247	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101377799	Unknown	21,000	Conductor	Overhead	Yes	8/13/18	15:33	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1843	PG&E	8/13/18	18:43	36.22648	-121.11113	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CAL FIRE	101729151	Unknown	12,000	Conductor	Overhead	Yes	8/13/18	18:43	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
1844	PG&E	8/14/18	6:43	40.68604	-122.14102	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	j. zulliger 530-225-2420	103379643	Unknown	12,000	Conductor	Overhead	Yes	8/14/18	6:43	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
1845	PG&E	8/14/18	15:18	36.96557	-121.86813	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	103128221	AT&T	21,000	Conductor	Overhead	Yes	8/14/18	15:18	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1846	PG&E	8/14/18	15:46	38.08782	-122.60016	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103918882	Verizon	0 - 750	Conductor	Overhead	Yes	8/14/18	15:46	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1847	PG&E	8/17/18	9:38	40.29968	-122.33216	Vegetation	Rural	< 0.25 Acres	Fire Agency	chief	101509747	AT&T	12,000	Conductor	Overhead	Yes	8/17/18	9:38	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1848	PG&E	8/17/18	17:18	37.52758	-121.96984	Vegetation	Urban	< 3 meters	Self Extinguished	N.A.	100946234	AT&T	0 - 750	Conductor	Overhead	Yes	8/17/18	17:18	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1849	PG&E	8/18/18	11:38	38.40263	-121.96348	Vegetation	Urban	< 0.25 Acres	Unknown	N.A.	100946234	None	115,000	Conductor	Overhead	Yes	8/18/18	6:15	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
1850	PG&E	8/20/18	5:26	37.13339	-121.62820	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	103560218	Unknown	21,000	Capacitor Bank	Overhead	Yes	8/20/18	5:26	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
1851	PG&E	8/20/18	9:34	39.80138	-121.58133	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	104040441	Unknown	12,000	Conductor	Overhead	Yes	8/20/18	9:34	Contact From Object	N.A.	Other	Electric Facility	Human Error	PG&E contractor
1852	PG&E	8/20/18	10:06	37.03260	-120.40587	Vegetation	Rural	.26 - 9.99 Acres	Self Extinguished	N.A.	101090947	Unknown	12,000	Lightning Arrestor	Overhead	Yes	8/20/18	10:06	Equipment/ Facility Failure	Lightning Arrestor	N.A.	N.A.	Unknown	
1853	PG&E	8/21/18	0:23	37.06248	-120.05214	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CAL FIRE	103117111	Unknown	17,000	Conductor	Overhead	Yes	8/21/18	0:23	Unknown	N.A.	N.A.	N.A.	Unknown	
1854	PG&E	8/21/18	10:13	38.69721	-120.88896	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101385436	Unknown	12,000	Conductor	Overhead	Yes	8/21/18	10:13	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1855	PG&E	8/22/18	17:24	37.95191	-120.31033	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CAL FIRE	101030620	Unknown	17,000	Conductor	Overhead	Yes	8/22/18	17:24	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	dampeners
1856	PG&E	8/22/18	21:56	39.04251	-120.96946	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100024728	Verizon	12,000	Conductor	Overhead	Yes	8/22/18	21:56	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1857	PG&E	8/23/18	14:23	34.60805	-120.19370	Vegetation	Urban	< 3 meters	Fire Agency	Unknown	101917609	Unknown	12,000	Conductor	Overhead	Yes	8/23/18	14:23	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1858	PG&E	8/23/18	16:06	36.73488	-120.11071	Vegetation	Rural	< 3 meters	Fire Agency	TRUCK 21 MENDOZA (559)621-4181	103285879	Unknown	12,000	Conductor	Overhead	Yes	8/23/18	16:06	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	third-party caused
1859	PG&E	8/24/18	1:38	39.20293	-121.27660	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CAL FIRE	100087059	AT&T	21,000	Conductor	Overhead	Yes	8/24/18	1:38	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
1860	PG&E	8/24/18	5:03	39.11839	-121.01545	Vegetation	Rural	< 0.25 Acres	Fire Agency	JIM SMITH BATT CHIEF 3	100097647	Unknown	12,000	Conductor	Overhead	Yes	8/24/18	5:03	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	third-party caused
1861	PG&E	8/25/18	17:15	40.57299	-122.23861	Vegetation	Rural	< 0.25 Acres	Fire Agency	BRIAN NOEL (530)448-2411	101472424	Frontier	12,000	Conductor	Overhead	Yes	8/25/18	17:15	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1862	PG&E	8/26/18	15:29	39.35990	-121.12090	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	100107472	Unknown	12,000	Conductor	Overhead	Yes	8/26/18	15:29	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1863	PG&E	8/26/18	16:50	39.75851	-123.23590	Vegetation	Rural	< 0.25 Acres	Fire Agency	HOWARD FOREST	102183272	Verizon	12,000	Conductor	Overhead	Yes	8/26/18	16:50	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1864	PG&E	8/27/18	5:54	36.78654	-119.52214	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100798371	Unknown	12,000	Conductor	Overhead	Yes	8/27/18	5:54	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1865	PG&E	8/27/18	13:56	37.01266	-121.60258	Vegetation	Urban	< 0.25 Acres	Unknown	N.A.	103918532	Verizon	21,000	Conductor	Overhead	Yes	8/27/18	13:56	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1866	PG&E	8/27/18	16:45	36.74888	-119.74714	Vegetation	Urban	< 0.25 Acres	Unknown	N.A.	100845137	Unknown	0 - 750	Conductor	Overhead	Yes	8/27/18	16:45	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1867	PG&E	8/28/18	2:00	36.56454	-119.60596	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	100864815	AT&T	12,000	Conductor	Overhead	Yes	8/28/18	2:00	Unknown	N.A.	N.A.	N.A.	Unknown	
1868	PG&E	8/28/18	12:50	40.21391	-123.58960	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CAL FIRE	102081818	Unknown	12,000	Conductor	Overhead	Yes	8/28/18	12:50	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1869	PG&E	8/28/18	16:14	39.22843	-123.19955	Vegetation	Rural	< 0.25 Acres	Fire Agency	howard forest	102174042	AT&T	12,000	Conductor	Overhead	Yes	8/28/18	16:14	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	third-party caused
1870	PG&E	8/29/18	16:19	38.77321	-121.43101	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	103918537	Unknown	12,000	Conductor	Overhead	Yes	8/29/18	16:19	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
1871	PG&E	8/30/18	15:38	38.25442	-122.57541	Vegetation	Rural	.26 - 9.99 Acres	Unknown	N.A.	101990006	Unknown	12,000	Conductor	Overhead	Yes	8/30/18	15:38	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1872	PG&E	8/31/18	5:07	36.78753	-119.65516	Vegetation	Rural	< 0.25 Acres	Fire Agency	CLOVIS F.D.	103281648	None	12,000	Conductor	Overhead	Yes	8/31/18	5:07	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1873	PG&E	8/31/18	12:30	37.99166	-121.34775	Vegetation	Urban	< 0.25 Acres	Unknown	N.A.	103193823	Unknown	21,000	Conductor	Overhead	Yes	8/31/18	12:30	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
1874	PG&E	8/31/18	13:02	40.47750	-122.48470	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103918932	Unknown	12,000	Conductor	Overhead	Yes	8/31/18	13:02	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1875	PG&E	8/31/18	18:04	39.57850	-123.38420	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CAL FIRE	102196393	Unknown	12,000	Conductor	Overhead	Yes	8/31/18	18:04	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1876	PG&E	8/31/18	18:09	37.05480	-122.04720	Vegetation	Urban	< 0.25 Acres	Fire Agency	CAL FIRE	101803212	Unknown	21,000	Conductor	Overhead	Yes	8/31/18	18:09	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1877	PG&E	9/1/18	14:25	36.80878	-121.59157	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAL FIRE	101352222	None	115,000	Conductor	Overhead	Yes	9/1/18	14:25	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1878	PG&E	9/2/18	15:36	37.47140	-122.42476	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Arie Delay 659-740-4636	103080872	Unknown	12,000	Capacitor Bank	Overhead	Yes	9/2/18	15:36	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
1879	PG&E	9/2/18	16:11	37.26526	-121.80508	Vegetation	Urban	< 3 meters	Unknown	N.A.	103436542	Unknown	0 - 750	Conductor	Overhead	Yes	9/2/18	16:11	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1880	PG&E	9/2/18	23:18	37.79415	-121.57733	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	102051470	Unknown	12,000	Conductor	Overhead	Yes	9/2/18	23:18	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X
2	Utility Name	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes (Optional):
1949	PG&E	10/20/18	14:31	40.52180	-124.11374	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CAL FIRE	Sir. 003/000	None	60,000	Conductor	Overhead	Yes	10/20/18	14:31	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
1950	PG&E	10/21/18	0:32	35.50348	-120.60252	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101886776	Unknown	21,000	Conductor	Overhead	Yes	10/21/18	0:32	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1951	PG&E	10/24/18	7:08	37.94751	-120.26713	Vegetation	Rural	< 0.25 Acres	Fire Agency	SCOTT PITTMAN 209-768-8182 TCU INCIDENT# 012528	101047865	Unknown	17,000	Conductor	Overhead	Yes	10/24/18	7:08	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1952	PG&E	10/24/18	14:18	36.72648	-119.10859	Vegetation	Rural	10 - 99 Acres	Fire Agency	CHRIS CHRISTOPHERSON (559)493-4320 I.C. #18CAFKU015649	100891946	None	12,000	Conductor	Overhead	Yes	10/24/18	14:18	Vandalism/Theft	N.A.	N.A.	N.A.	Human Error	gun-shot conductor
1953	PG&E	10/25/18	18:47	35.55862	-118.81679	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	GREG BLACK (661)391-7000	100203660	None	0 - 750	Conductor	Overhead	Yes	10/25/18	18:47	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1954	PG&E	10/26/18	2:11	37.75530	-122.43449	Vegetation	Urban	< 3 meters	Unknown	N.A.	101838487	AT&T	0 - 750	Conductor	Overhead	Yes	10/26/18	2:11	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1955	PG&E	10/26/18	20:55	40.15279	-122.36340	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAPT. ROB WAELTY 530-527-6113	101553579	Unknown	12,000	Conductor	Overhead	Yes	10/26/18	20:55	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1956	PG&E	10/28/18	8:50	36.37919	-121.84544	Vegetation	Rural	< 0.25 Acres	Fire Agency	TONY (831) 625-6415	101672342	Unknown	12,000	Conductor	Overhead	Yes	10/28/18	8:50	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1957	PG&E	10/29/18	19:09	39.46452	-122.24875	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100343112	None	21,000	Conductor	Overhead	Yes	10/29/18	19:09	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1958	PG&E	10/30/18	15:40	37.17790	-120.63088	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101185288	Unknown	12,000	Conductor	Overhead	Yes	10/30/18	15:40	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1959	PG&E	10/31/18	12:50	37.33476	-121.93699	Vegetation	Urban	< 3 meters	Fire Agency	San Jose FD	103780642	AT&T	12,000	Capacitor Bank	Overhead	Yes	10/31/18	12:50	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
1960	PG&E	11/1/18	20:45	38.37200	-123.05070	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	103852431	AT&T	12,000	Conductor	Overhead	Yes	11/1/18	20:45	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1961	PG&E	11/7/18	15:49	37.00035	-121.98019	Vegetation	Urban	< 0.25 Acres	Unknown	N.A.	101684527	Unknown	21,000	Capacitor Bank	Overhead	Yes	11/7/18	15:49	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
1962	PG&E	11/8/18	11:41	34.86490	-120.34016	Vegetation	Rural	10 - 99 Acres	Unknown	N.A.	101862240	Verizon	12,000	Conductor	Overhead	Yes	11/8/18	11:41	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1963	PG&E	11/8/18	13:19	38.78841	-120.15288	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101407590	AT&T	21,000	Conductor	Overhead	Yes	11/8/18	13:19	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1964	PG&E	11/8/18	21:30	36.78366	-119.49885	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	103818023	Unknown	12,000	Conductor	Overhead	Yes	11/8/18	21:30	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
1965	PG&E	11/9/18	4:49	39.82344	-121.83816	Vegetation	Rural	.26 - 9.99 Acres	Unknown	N.A.	100402367	AT&T	12,000	Conductor	Overhead	Yes	11/9/18	4:49	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1966	PG&E	11/9/18	8:59	37.28095	-122.12144	Vegetation	Rural	.26 - 9.99 Acres	Unknown	N.A.	100546562	AT&T	12,000	Conductor	Overhead	Yes	11/9/18	8:59	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1967	PG&E	11/9/18	15:34	35.05121	-118.81118	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	103930710	None	12,000	Conductor	Overhead	Yes	11/9/18	15:34	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1968	PG&E	11/10/18	13:31	37.04673	-121.98533	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CAL FIRE	101671641	Unknown	21,000	Conductor	Overhead	Yes	11/10/18	13:31	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1969	PG&E	11/11/18	4:18	38.43408	-122.55220	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	102032588	Unknown	0 - 750	Conductor	Overhead	Yes	11/11/18	4:18	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1970	PG&E	11/11/18	10:40	37.09842	-120.74163	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	103934503	Unknown	12,000	Conductor	Overhead	Yes	11/11/18	10:40	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1971	PG&E	11/11/18	13:06	37.32020	-122.00234	Vegetation	Urban	< 0.25 Acres	Unknown	N.A.	103927631	AT&T	12,000	Capacitor Bank	Overhead	Yes	11/11/18	13:06	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
1972	PG&E	11/12/18	5:17	38.48517	-122.80465	Vegetation	Rural	< 3 meters	Unknown	N.A.	102027067	Unknown	12,000	Conductor	Overhead	Yes	11/12/18	5:17	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1973	PG&E	11/12/18	14:39	36.99296	-120.03718	Vegetation	Rural	< 3 meters	Unknown	N.A.	101015260	AT&T	12,000	Conductor	Overhead	Yes	11/12/18	14:39	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1974	PG&E	11/13/18	11:34	34.99420	-118.99239	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	100195031	None	0 - 750	Conductor	Overhead	Yes	11/13/18	11:34	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1975	PG&E	11/13/18	15:41	37.06438	-121.95780	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101680441	AT&T	0 - 750	Conductor	Overhead	Yes	11/13/18	15:41	Other	N.A.	N.A.	N.A.	Human Error	Grow house
1976	PG&E	11/15/18	6:09	38.35991	-122.36818	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	102241814	AT&T	0 - 750	Conductor	Overhead	Yes	11/15/18	6:09	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1977	PG&E	11/15/18	6:34	38.60816	-120.95323	Vegetation	Rural	< 0.25 Acres	Self Extinguished	N.A.	101414740	Unknown	12,000	Conductor	Overhead	Yes	11/15/18	6:34	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
1978	PG&E	11/16/18	17:02	38.75743	-120.90115	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101409894	AT&T	21,000	Conductor	Overhead	Yes	11/16/18	17:02	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1979	PG&E	11/17/18	17:20	38.70824	-120.69266	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101421319	Unknown	12,000	Conductor	Overhead	Yes	11/17/18	17:20	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
1980	PG&E	11/18/18	1:37	34.95261	-120.43642	Other	Urban	< 3 meters	Unknown	N.A.	103420365	N.A.	12,000	Transformer	Padmounted	Yes	11/18/18	1:37	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
1981	PG&E	11/18/18	14:31	40.79679	-124.13375	Building	Rural	Structure Only	Fire Agency	Unknown	100974986	Unknown	0 - 750	Conductor	Overhead	Yes	11/18/18	14:31	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	third-party caused
1982	PG&E	11/19/18	9:46	38.50528	-121.89559	Vegetation	Rural	< 3 meters	Unknown	N.A.	101577202	Unknown	12,000	Conductor	Overhead	Yes	11/19/18	9:46	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	third-party caused
1983	PG&E	11/20/18	13:07	35.30425	-120.80477	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101928023	Unknown	12,000	Conductor	Overhead	Yes	11/20/18	13:07	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
1984	PG&E	11/21/18	2:16	40.43827	-124.38470	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101005309	Frontier	12,000	Conductor	Overhead	Yes	11/21/18	2:16	Vandalism/Theft	N.A.	N.A.	N.A.	Human Error	gun-shot conductor
1985	PG&E	11/23/18	22:14	38.26658	-122.02117	Building	Urban	Structure Only	Unknown	N.A.	101668121	AT&T	12,000	Conductor	Overhead	Yes	11/23/18	22:14	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
1986	PG&E	12/12/18	12:09	38.72702	-120.79470	Vegetation	Rural	< 3 meters	Unknown	N.A.	101404403	AT&T	0 - 750	Conductor	Overhead	Yes	12/12/18	12:09	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1987	PG&E	12/14/18	10:32	40.43788	-123.78337	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101009136	Unknown	12,000	Conductor	Overhead	Yes	12/14/18	10:32	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
1988	PG&E	12/31/18	21:43	39.73802	-122.01630	Vegetation	Rural	< 3 meters	Unknown	N.A.	103801376	None	12,000	Conductor	Overhead	Yes	12/31/18	21:43	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	