

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X	
Utility Name	Fire Start	Location Info	Fire Specifics	Utility Facility	Outage Info	Suspected Initiating Event		Equipment / Facility Failure		Contact From Object		Facility Contacted		Contributing Factor		Notes								
Column1	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Volts (V)	Equipment Involved With Ignition	Type	Was There an Outage	Date2	Time3							
1 SCE	5/29/14	18:00	33.9036301	-118.0366983	Other	Urban	Less Than .25 Acres	Fire Agency	Santa Fe Springs	14051 Marquadt, Santa Fe	None	66kV	Other	Overhead	No			Unknown						
4 SCE	6/5/14	9:20	34.5550460	-118.1177890	Other	Rural	Less Than .25 Acres	Fire Agency	LA County	700 East Ave. S. Palmdale	None	12kV	Conductor	Overhead	No			Contact From Object	Other	Electric Facility	Unknown			
5 SCE	6/8/14	18:00	33.6808854	-117.9487188	Other	Urban	Less Than .25 Acres	Fire Agency	Huntington Beach	19391, 19381, 19371, Pilca	None	12kV	Other	Overhead	No			Contact From Object	Balloons	Electric Facility	None			
6 SCE	6/13/14	13:00	35.7151000	-118.5110670	Vegetation	Rural	1000 - 4999 Acres	Fire Agency	Cal Fire	West of Lake Isabella & Sd	None	66kV	Other	Overhead	No			Unknown						
7 SCE	6/18/14	15:00	34.1626420	-118.6762220	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	LA County	Location of Fire 726730E	None	16kV	Conductor	Overhead	Yes			Unknown						
8 SCE	6/23/14	13:15	Not Provided	-117.72947	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire	00 Old Stage, Glenville, C	Unknown	12kV	Conductor	Overhead	Yes			6/23/2014	16:20	Contact From Object	Vegetation	Electric Facility	Unknown	
9 SCE	6/27/14	11:06	34.6284170	-119.5302740	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Ventura County	N Ventura Ave	None	16kV	Conductor	Overhead	Yes			6/27/14	11:06	Contact From Object	Animal	Electric Facility	Unknown	
10 SCE	7/3/14	11:30	34.4529320	-119.7547730	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Fire Department	C/O Football and Rose In	Phone & Cable	16kV	Conductor	Overhead	No			Other						
11 SCE	7/24/14	13:00	33.5444395	-117.1158394	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Not provided	39613 Liefer Rd., Temecula	None	12kV	Lightning Arrestor	Overhead	No			Equipment/Facility Failure	Lightning Arrestor					
12 SCE	7/27/14	18:00	36.0501990	-119.0547840	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Tulare County Fire	1785 W. POPLAR AVE., P	Unknown	12kV	Conductor	Overhead	No			Contact From Object		Electric Facility	Unknown			
13 SCE	7/29/14	8:23	34.4529320	-117.1827210	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Riverside County	UG-5057024,rouse rd, mer	None	12kV	Conductor	Overhead	No			Equipment/Facility Failure	Conductor					
14 SCE	7/30/14	15:00	34.1593370	-117.2980800	Vegetation	Urban	26 - 9.99 Acres	Fire Agency	San Bernardino Fire	3750 MAYFIELD PL SAAN	None	12kV	Other	Overhead	Yes			7/30/14	15:00	Contact From Object	Vegetation	Electric Facility	Human Error	Tree trimmer dropped palm frond on wires.
15 SCE	7/31/14	16:00	33.7927568	-117.2831691	Other	Rural	Less Than .25 Acres	Fire Agency	Perris Fire Department	22597 FORREST RD, Perr	Phone & Cable	12kV	Other	Overhead	No			Unknown						
16 SCE	8/3/14	20:00	36.3425640	-119.3758970	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Visalia Fire Department	NS of Goshen Ave. 1/4 mi	None	12kV	Conductor	Overhead	No			Contact From Object	Balloons	Pole	Unknown			
17 SCE	8/12/14	13:29	34.3867900	-119.3145000	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Ventura County	SANTA ANA BL S/O SANTA	Unknown	16kV	Conductor	Overhead	Yes			Contact From Object	Vehicle	Pole	Unknown			
18 SCE	8/16/14	9:00	33.3373223	-117.0152138	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Hemet Fire Department	810 S CRAWSTON AVE, Hem	None	12kV	Other	Overhead	Yes			8/16/14	9:00	Equipment/Facility Failure	Conductor	Unknown		
19 SCE	8/17/14	15:00	33.7469820	-117.7982737	Vegetation	Urban	Less Than .25 Acres	Fire Agency	OC Fire Authority	1622 alta vista dr. santia	None	12kV	Transformer	Overhead	Yes			8/17/14	16:00	Equipment/Facility Failure	Transformer	Unknown		
20 SCE	8/24/14	8:30	34.0087540	-117.4021760	Building	Urban	26 - 9.99 Acres	Fire Agency	Riverside County FD	5795 Kenwood Pl Pole 20	None	12kV	Other	Overhead	Yes			8/24/14	8:30	Other				
21 SCE	8/30/14	15:30	34.1709350	-117.2956550	Vegetation	Urban	26 - 9.99 Acres	Fire Agency	San Bernardino Fire	4718 Acacia San Bernadin	Phone & Cable	4kV	Other	Overhead	No			Equipment/Facility Failure	Splice/Clamp/Connector					
22 SCE	9/5/14	14:00	34.0276135	-117.9071504	Other	Urban	Less Than .25 Acres	Fire Agency	West Covina FD	1829 Greenleaf Dr. West C	None	12kV	Other	Subsurface	Yes			9/5/14	14:00	Equipment/Facility Failure	Splice/Clamp/Connector			
23 SCE	9/6/14	14:00	33.8780461	-117.5195693	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Riverside County	13462 magnolia ave. coror	Unknown	12kV	Conductor	Overhead	Yes			9/6/14	14:00	Unknown				
24 SCE	9/8/14	11:55	34.5600120	-118.0410940	Other	Urban	Less Than .25 Acres	Fire Agency	LA County	37316 50TH ST EAST PAL	Phone & Cable	12kV	Conductor	Overhead	No			Contact From Object		Electric Facility	Unknown			
25 SCE	9/15/14	16:00	34.1740188	-118.0579900	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Sierra Madre FD	rear of 630 Sierra Meadow	Unknown	16kV	Other	Overhead	Yes			9/15/14	15:54	Contact From Object	Balloons	Electric Facility	None	
26 SCE	9/19/14	23:20	34.0382540	-118.8719920	Vegetation	Rural	Less Than .25 Acres	Fire Agency	LA County	32008 PACIFIC COAST HI	Phone & Cable	16kV	Transformer	Overhead	No			Contact From Object						
27 SCE	10/3/14	15:00	34.0468915	-117.9851278	Other	Urban	Less Than .25 Acres	Unknown	San Bernardino Fire	11604546 n/e corner of pu	Unknown	12kV	Other	Overhead	No			Contact From Object	Other	Electric Facility	Unknown			
28 SCE	10/4/14	16:00	34.1652250	-117.3866230	Other	Urban	Less Than .25 Acres	Fire Agency	Thousand Oaks	2497 W. 3rd Ave San Bern	Unknown	4kV	Other	Overhead	Yes			10/4/14	16:00	Unknown				
29 SCE	10/10/14	16:24	34.2049210	-118.8746730	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Thousand Oaks	73 TRIANGLE ST THOUS	Unknown	16kV	Conductor	Overhead	Yes			10/10/14	16:24	Contact From Object	Vegetation	Electric Facility	Unknown	
30 SCE	11/7/14	17:00	Not Provided	Not Provided	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Redondo Beach Fire Dept	509 s Lucia redondo beach	Unknown	16kV	Conductor	Overhead	Yes			11/7/2014	19:00	Equipment/Facility Failure	Splice/Clamp/Connector			
31 SCE	11/10/14	Not Provided	Not Provided	Not Provided	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Arcadia Fire Department	R/O School on Santa Anita	None	4kV	Conductor	Overhead	Yes			11/10/14	Not Provided	Equipment/Facility Failure	Conductor			
32 SCE	11/13/14	12:00	34.4934020	-117.1863970	Building	Urban	Less Than .25 Acres	Fire Agency	Apple Valley Fire Department	21838 Ottawa 4559358E	Unknown	12kV	Other	Overhead	No			Contact Between Third Party Facility on Pole and Supply Lines						
33 SCE	11/16/14	13:30	34.0480460	-118.6829900	Vegetation	Urban	Less Than .25 Acres	Fire Agency	LA County	R/O 23347 PALM CANYON	Unknown	16kV	Conductor	Overhead	Yes			11/16/14	13:30	Contact From Object	Vegetation	Electric Facility	Unknown	
34 SCE	11/17/14	4:30	34.3128590	-118.8983360	Other	Rural	Less Than .25 Acres	Fire Agency	Ventura County	11856 Broadway rd, moor	Unknown	16kV	Transformer	Overhead	No			Contact From Object		Electric Facility	Unknown			
35 SCE	11/21/14	4:41	34.0891120	-117.3711820	Vegetation	Urban	Less Than .25 Acres	Fire Agency	RIALTO FD	VACANT FIELD, VACANT L	Unknown	12kV	Other	Overhead	No			Contact From Object						
36 SCE	12/2/14	10:00	34.1058474	-117.7881530	Other	Urban	Less Than .25 Acres	Fire Agency	La Verne Fire Department	1025 Bonta Ave., La Verne	Phone & Cable	12kV	Capacitor Bank	Overhead	Yes			12/2/14	10:00	Unknown				
37 SCE	12/3/14	19:00	33.0376980	-117.7595747	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Comona Fire Department	1852 GARLAND ST, POM	None	12kV	Conductor	Overhead	Yes			12/3/14	19:00	Equipment/Facility Failure	Conductor	Unknown		
38 SCE	12/4/14	4:30	34.0119761	-117.9708730	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Chino Fire Department	Rochlen St. off Kwis privac	None	12kV	Other	Overhead	Yes			12/4/14	4:00	Contact From Object				
39 SCE	12/5/14	2:52	33.9397026	-117.6114641	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Chino Fire Department	1744 Hellman Chino, CA C	None	12kV	Other	Overhead	No			Contact From Object						
40 SCE	12/12/14	1:30	35.9219806	-119.0178838	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Tulare County Fire Department	7260 Rd. 248 Terra Bella,	None	12kV	Conductor	Overhead	No			Contact From Object	Vegetation	Electric Facility	Weather			
41 SCE	12/27/14	8:17	34.0719543	-117.8398907	Vegetation	Urban	Less Than .25 Acres	Fire Agency	LA County	covina hills x CALLE FRAN	Phone & Cable	12kV	Switch	Overhead	Yes			Contact From Object	Animal	Pole	Unknown			
42 SCE	1/4/15	13:00	33.9539015	-118.3682332	Other	Urban	Less Than .25 Acres	Fire Agency	Los Angeles County Fire	Pole 1879055E	Phone & Cable	16kV	Conductor	Overhead	Yes			1/4/15	13:00	Unknown				
43 SCE	1/26/15	17:30	34.1314861	-117.8376444	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Glendora Fire Department	Pole 1384657E	Phone & Cable	12kV	Conductor	Overhead	Yes			1/26/15	17:30	Contact From Object	Vegetation	Electric Facility	Weather	
44 SCE	2/6/15	13:15	37.4539600	-118.5841960	Vegetation	Rural	Greater than 5000 Acres	Fire Agency	Various Fire Agencies	Between Poles 1854107E	Phone & Cable	12kV	Conductor	Overhead	Yes			2/6/15	13:15	Unknown				
45 SCE	2/22/15	9:52	34.2848680	-119.2172930	Vegetation	Rural	10 - 99 Acres	Fire Agency	Ventura Fire Department	Pole 1717878E	Phone & Cable	16kV	Other	Overhead	Yes			2/22/15	10:49	Unknown				
46 SCE	3/23/15	17:20	34.4354600	-119.826270	Other	Urban	Less Than .25 Acres	Fire Agency	Santa Barbara County Fire	Pole 807632E	Phone & Cable	16 kV	Conductor	Overhead	Yes			3/23/15	19:19	Equipment/Facility Failure	Transformer			
47 SCE	3/26/15	14:09	33.9493510	-117.9247230	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Twister 12kV at La Habra Sub and Whippstock 12kV		None	12kV	Conductor	Overhead	Yes			3/26/15	14:09	Contact From Object	Other	Electric Facility	Unknown	
48 SCE	3/26/15	17:57	33.8513739	-117.5672290	Other	Urban	Less Than .25 Acres	Fire Agency	Corona Fire Department	Owens 33kV at Corona Sub carrying Cupples 33kV	None	33kV	Other	Overhead	Yes			3/26/15	17:57	Equipment/Facility Failure	Other			
49 SCE	3/30/15	15:14	33.9105800	-117.8533700	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Orange County Fire Authority	Cancun 12kV at Brea Sub in Placentia	None	12kV	Conductor	Overhead	Yes			3/30/15	15:24	Contact From Object	Other	Electric Facility	Unknown	
50 SCE	4/8/15	14:00	36.1065620	-119.0314670	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Tulare County Fire	Lewis Hill Porterville, ca -	Phone & Cable	12kV	Other	Overhead	Yes			4/8/15	14:10	Other				
51 SCE	4/8/15	13:05	34.1781090	-118.8684250	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Ventura County Fire	Pole 2240858E	None	16kV	Conductor	Overhead	Yes			4/8/15	13:05	Contact From Object	Animal	Electric Facility	Unknown	
52 SCE	4/8/15	16:52	36.1059070	-119.0416470	Other	Urban	Less Than .25 Acres	Fire Agency	Tulare County Fire	Pole 1004338E	None	12kV	Conductor	Overhead	Yes			4/8/15	16:52	Equipment/Facility Failure	Crossarm			
53 SCE	4/11/15	14:27	34.0354730	-118.1327740	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Monterey Park Fire Department	Pole 4356231E	Phone & Cable	4kV	Other	Overhead	Yes			4/11/15	14:27	Equipment/Facility Failure	Other			
54 SCE	4/12/15	6:32	34																					

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X			
2	Utility Name	Fire Start	Latitude	Longitude	Material at Origin	Location Info	Land Use at Origin	Size	Suppressed by	Fire Specifics	Suppressing Agency	Facility Identification	Other Companies	Utility Facility	Equipment Involved With Ignition	Type	Was There an Outage	Date2	Date3	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes		
3	Column1	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Fire Specifics	Suppressing Agency	Facility Identification	Other Companies	Utility Facility	Equipment Involved With Ignition	Type	Was There an Outage	Date2	Date3	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes		
119	SCE	8/12/15	12:00	35.1772470	-118.3373190	Vegetation	Rural	Less Than .25 Acres	Self Extinguished					120 V	Conductor	Subsurface	Yes	8/12/15	11:07	Other				Human Error	Third Party dug into marked SCE secondary cables.		
120	SCE	9/21/15	23:10	36.2355530	-119.3528250	Vegetation	Rural	26 - 9.99 Acres	Fire Agency		Tulare Fire Department	4335326E - J STREET S/O CARTMILL AVE		12kV	Other	Overhead	Yes	8/22/15	2:19	Vandalism/Theft				Outside Force			
121	SCE	8/24/15	22:00	33.8839290	-118.2115660	Building	Urban	Less Than .25 Acres	Fire Agency		Compton Fire Department	2239623E: MAYO AVE P/L	Phone & Cable	4kV	Conductor	Overhead	Yes	8/24/15	21:41	Unknown				Unknown			
122	SCE	8/27/15	6:21	34.0644690	-117.8910950	Vegetation	Urban	Less Than .25 Acres	Fire Agency		West Covina Fire Department	Pole 534400E		12kV	Conductor	Overhead	Yes	8/27/15	6:21	Contact From Object	Vegetation			Electric Facility	Unknown		
123	SCE	8/27/15	10:20	34.2538130	-118.8660450	Other	Urban	Less Than .25 Acres	Fire Agency		Ventura County Fire	Morganstein 16kV out of Moorpark Sub		16kV	Conductor	Overhead	Yes	8/27/15	10:20	Contact From Object	Animal			Electric Facility	None		
124	SCE	9/3/15	17:00	36.8936000	-119.4571000	Vegetation	Rural	10 - 99 Acres	Fire Agency		Cal Fire	East of Watts Valley Rd and Pittman Hill Rd, East		220kV	Conductor	Overhead	Yes	9/3/15	16:15	Contact From Object	Balloons			Electric Facility	None		
125	SCE	9/7/15	17:58	35.8554700	-119.0944400	Vegetation	Rural	Less Than .25 Acres	Self Extinguished			Welch 12kV at Vestal Sub		12kV	Conductor	Overhead	Yes	9/7/15	17:58	Contact From Object	Balloons			Electric Facility	None		
126	SCE	9/9/15	13:22	34.0414910	-118.7724050	Vegetation	Urban	Less Than .25 Acres	Fire Agency		Los Angeles County Fire	Pole 899836E	Phone & Cable	12kV	Other	Overhead	Yes	9/9/15	13:22	Equipment/Facility Failure	Splice/Clamp/Connector				Unknown		
127	SCE	9/9/15	13:59	33.5499250	-117.2125150	Other	Urban	Less Than .25 Acres	Fire Agency		Murrieta Fire Department	Tackle Line out of Stadler Sub		12kV	Conductor	Overhead	Yes	9/9/15	13:59	Other					Weather		
128	SCE	9/11/15	9:10	34.0875990	-117.4330630	Other	Urban	Less Than .25 Acres	Fire Agency		Fontana Fire Department	Pole 1554125E beyond RC	Phone & Cable	12kV	Lightning Arrestor	Overhead	Yes	9/11/15	3:10	Equipment/Facility Failure	Lightning Arrestor				Unknown		
129	SCE	9/20/15	19:07	34.0243510	-118.1176780	Other	Urban	Less Than .25 Acres	Fire Agency		Unknown	1270852E: MERLE DR. S4	Phone & Cable	16kV	Transformer	Overhead	Yes	9/20/15	19:07	Equipment/Facility Failure	Transformer				Unknown		
130	SCE	9/20/15	16:31	34.0632990	-118.6479180	Other	Urban	26 - 9.99 Acres	Fire Agency		Los Angeles County Fire	Pole 1578711E	Phone & Cable	12kV	Conductor	Overhead	Yes	9/20/15	16:31	Contact From Object	Vehicle			Pole	None		
131	SCE	9/26/15	13:48	34.0772940	-118.6935680	Vegetation	Urban	Less Than .25 Acres	Fire Agency		Los Angeles County Fire	Pole 770514E		16kV	Conductor	Overhead	Yes	9/26/15	13:48	Contact From Object	Vegetation			Electric Facility	Human Error		
132	SCE	10/9/15	14:00	33.5752390	-117.1700440	Vegetation	Rural	26 - 9.99 Acres	Fire Agency		Riverside Fire Department	BEHIND ADDRESS 28151 CELIA RD / PROPRET		12kV	Other	Overhead	No			Equipment/Facility Failure	Insulator				Unknown		
133	SCE	10/9/15	11:39	33.9333110	-117.8530940	Vegetation	Urban	Less Than .25 Acres	Fire Agency		Los Angeles County Fire	Acapulco 12kv out of Brea Sub.		12kV	Conductor	Overhead	Yes	10/9/15	11:39	Contact From Object	Other			Electric Facility	Unknown		
134	SCE	10/11/15	10:02	33.9440460	-116.4703550	Other	Urban	Less Than .25 Acres	Fire Agency		Cal Fire	Cal Fire 12kv Line at Coffee Sub. Pole in Desert Hot		12kV	Conductor	Overhead	Yes	10/11/15	10:02	Contact From Object	Vehicle			Pole	None		
135	SCE	10/12/15	13:02	33.6318500	-117.3378472	Other	Urban	Less Than .25 Acres	Fire Agency		Riverside County Fire	4844065E: 18193 BRIGHTMAN AVE. LAKE ELSI		12kV	Transformer	Overhead	Yes	10/12/15	13:02	Equipment/Facility Failure	Transformer				Unknown		
136	SCE	10/27/15	19:47	33.5350600	-117.7687930	Other	Urban	Less Than .25 Acres	Unknown			4139544E: 818 BLUEBIRD	Phone & Cable	33kV	Conductor	Overhead	Yes	10/27/15	19:47	Equipment/Facility Failure	Splice/Clamp/Connector				Unknown		
137	SCE	10/30/15	12:45	34.0538200	-117.2678850	Vegetation	Urban	Less Than .25 Acres	Fire Agency		Loma Linda Fire Department	pole 1609cwt	Phone & Cable	12kV	Conductor	Overhead	No			Contact From Object	Vegetation			Electric Facility	Weather		
138	SCE	10/30/15	22:23	33.7902580	-116.9650950	Other	Urban	Less Than .25 Acres	Unknown			Pole 1084993E	Phone & Cable	12kV	Other	Overhead	Yes	10/30/15	22:23	Unknown				Unknown			
139	SCE	11/2/15	18:07	34.2969760	-118.3163390	Vegetation	Urban	Less Than .25 Acres	Fire Agency		Los Angeles County Fire	Lopez 16kV out of San Fernando Sub		16kV	Conductor	Overhead	Yes	11/2/15	18:07	Contact From Object					Unknown		
140	SCE	11/7/15	2:24	34.1708026	-118.8684867	Vegetation	Urban	10 - 99 Acres	Fire Agency		Ventura County Fire	Pole No. 4505362E		16kV	Switch	Overhead	Yes	11/7/15	2:24	Unknown				Balloons	Electric Facility	Unknown	
141	SCE	11/13/15	7:04	34.2199580	-119.0382170	Vegetation	Urban	Less Than .25 Acres	Fire Agency		Ventura County Fire	Crosson 16kV at Camarillo Sub		16kV	Conductor	Overhead	Yes	11/13/15	7:04	Contact From Object	Animal			Electric Facility	None		
142	SCE	11/13/15	7:31	33.6394980	-117.7609780	Vegetation	Urban	Less Than .25 Acres	Fire Agency		Orange County Fire	Santiago-Borreago 66 kV		66kV	Conductor	Overhead	Yes	11/13/15	7:31	Contact From Object	Animal			Electric Facility	None		
143	SCE	11/18/15	6:31	34.1283510	-117.6895780	Vegetation	Urban	Less Than .25 Acres	Fire Agency		Upland Fire Department	Padua-Layfair 66kV		66kV	Conductor	Overhead	Yes	11/18/15	6:31	Contact From Object	Other			Electric Facility	Unknown		
144	SCE	11/20/15	20:07	34.0155350	-117.9534360	Vegetation	Urban	Less Than .25 Acres	Fire Agency		Los Angeles County Fire	1860773E 15930 E VALLEY BLVD, city of industry		12kV	Conductor	Overhead	Yes	11/20/15	20:07	Unknown					Unknown		
145	SCE	11/20/15	20:07	34.0155350	-117.9534360	Other	Urban	Less Than .25 Acres	Fire Agency		Los Angeles County Fire	Grazdie 12kV out of Walnut Sub		12kV	Conductor	Overhead	Yes	11/20/15	20:07	Contact From Object	Animal			Electric Facility	None		
146	SCE	11/24/15	1:17	33.7443310	-118.4070210	Other	Urban	Less Than .25 Acres	Fire Agency		Los Angeles County Fire	Ambersky 16kV at Marymount Sub, Pole in Rancho Palos Verdes		16kV	Conductor	Overhead	Yes	11/24/15	1:17	Equipment/Facility Failure	Conductor				Unknown		
147	SCE	12/8/15	19:08	34.2188030	-119.2492490	Vegetation	Rural	Less Than .25 Acres	Customer			Pole 1748635E	Phone & Cable	16kV	Transformer	Overhead	No			Contamination				Unknown			
148	SCE	12/11/15	12:21	34.0380730	-118.7701600	Other	Urban	26 - 9.99 Acres	Fire Agency		Los Angeles County Fire	Culbert 12kV at Latigo Sub. Near Latigo Canyon		12kV	Conductor	Overhead	Yes	12/11/15	12:21	Wire-Wire Contact					Weather		
149	SCE	1/1/16	10:13	34.0007670	-118.0812670	Other	Urban	Less Than .25 Acres	Fire Agency		LACFD	OH-4615530E FRONTIER COMMUN		12 kV	Conductor	Overhead	Yes	1/1/16	10:13	Contact From Object	Balloons			Electric Facility	None		
150	SCE	1/5/16	20:51	34.0627270	-118.0528980	Other	Urban	Less Than .25 Acres	Fire Agency		LACFD	9900 block of East Garvey Ave, El Monte		4 kV	Conductor	Overhead	Yes	1/5/16	20:51	Equipment/Facility Failure	Pole				Unknown		
151	SCE	1/16/16	15:20	34.4095710	-118.6815700	Vegetation	Rural	Less Than .25 Acres	Fire Agency		LACFD	OH-848266E		16 kV	Conductor	Overhead	Yes	1/16/16	15:20	Equipment/Facility Failure	Other				Unknown		
152	SCE	1/28/16	22:07	33.9642210	-118.1488130	Vegetation	Urban	Less Than .25 Acres	Fire Agency		LACFD	OH-820509E	FRONTIER COMMUN	16 kV	Conductor	Overhead	Yes	1/28/16	22:07	Contact From Object					Unknown		
153	SCE	2/3/16	17:46	34.7182510	-118.3025180	Vegetation	Rural	Less Than .25 Acres	Fire Agency		LACFD	OH-1355070E	FRONTIER COMMUN	120/240 V	Conductor	Overhead	No			Unknown					Unknown		
154	SCE	2/7/16	9:31	34.1370600	-117.5141240	Vegetation	Rural	Less Than .25 Acres	Fire Agency		SBCFD	OH-4275464E	FRONTIER COMMUN	12 kV	Conductor	Overhead	Yes	2/7/16	9:31	Equipment/Facility Failure	Conductor				Unknown		
155	SCE	2/8/16	8:22	34.1060570	-117.4402780	Vegetation	Urban	Less Than .25 Acres	Fire Agency		SBCFD	OH-1420984E	AT&T WIRELESS SEN	12 kV	Conductor	Overhead	Yes	2/8/16	8:22	Equipment/Facility Failure	Conductor				Unknown		
156	SCE	2/9/16	19:13	33.7790240	-118.1401670	Vegetation	Urban	Less Than .25 Acres	Fire Agency		Long Beach Fire Department	OH-2381945E	FRONTIER COMMUN	12 kV	Other	Overhead	Yes	2/9/16	19:13	Equipment/Facility Failure	Other				Unknown		
157	SCE	2/10/16	18:56	34.2186560	-118.2539580	Vegetation	Urban	Less Than .25 Acres	Fire Agency		Ventura County FD	OH-11925380E		16 kV	Other	Overhead	Yes	2/10/16	18:56	Equipment/Facility Failure	Other				Unknown		
158	SCE	2/12/16	20:02	33.9880310	-118.0717540	Vegetation	Urban	Less Than .25 Acres	Fire Agency		LACFD	OH-845479E	FRONTIER COMMUN	12 kV	Conductor	Overhead	Yes	2/12/16	20:02	Contact From Object	Vegetation			Electric Facility	Unknown		
159	SCE	2/16/16	15:18	34.2056930	-118.8432950	Vegetation	Urban	Less Than .25 Acres	Fire Agency		Ventura County FD	OH-4544696E	FRONTIER COMMUN	16 kV	Conductor	Overhead	No			Contact From Object	Vegetation			Electric Facility	Unknown		
160	SCE	2/22/16	17:04	34.4491640	-119.5844980	Vegetation	Rural	Less Than .25 Acres	Fire Agency		Montecito Fire Department	OH-1082380E	FRONTIER COMMUN	16 kV	Conductor	Overhead	Yes	2/22/16	17:04	Equipment/Facility Failure	Conductor				Unknown		
161	SCE	2/24/16	15:06	34.9470000	-118.1417210	Vegetation	Rural	Less Than .25 Acres	Fire Agency		Kern County Fire Department	OH-706814E	AT&T CALIFORNIA	16 kV	Conductor	Overhead	No			Contact From Object	Animal			Electric Facility	Unknown		
162	SCE	2/27/16	0:49	33.9134180	-116.8003250	Other	Urban	Less Than .25 Acres	Fire Agency		Cal Fire	OH-1989045E		12 kV	Conductor	Overhead	Yes	2/27/16	0:49	Contact From Object	Vehicle			Pole	Unknown		
163	SCE	3/11/16	7:53	33.9059430	-117.9237840	Vegetation	Urban	Less Than .25 Acres	Fire Agency		Fullerton Fire Department	OH-740325H	TIME WARNER CABL	12 kV	Conductor	Overhead	Yes	3/11/16	7:53	Contact From Object	Vegetation			Electric Facility	Unknown		
164	SCE	3/17/16	14:53	34.0059170	-117.9663880	Vegetation	Urban	Less Than .25 Acres	Fire Agency		LACFD	OH-1892584E	TIME WARNER CABL	12 kV	Conductor	Overhead	Yes	3/17/16	14:53	Contact From Object	Vehicle			Pole			

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X	
1	Utility Name	Fire Start	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Utility Facility	Equipment Involved With Ignition	Type	Was There an Outage	Date2	Time3	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes	
2	Column1	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Utility Facility	Equipment Involved With Ignition	Type	Was There an Outage	Date2	Time3	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes
230	SCE	10/23/16	9:40	34.4602810	-119.2852650	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Ventura County FD	900 Rice Road Ojai		120/240 V	Conductor	Overhead	No			Equipment/Facility Failure	Conductor			Unknown	
231	SCE	10/26/16	12:19	34.7081290	-118.5367490	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	LACFD	ELIZABETH LAKE ROAD AND KINGS CANYON		12 kV	Conductor	Overhead	Yes	10/26/16	12:19	Contact From Object	Vegetation	Electric Facility		Unknown	
232	SCE	10/28/16	10:13	34.1020580	-117.8206300	Other	Urban	Less Than .25 Acres	Fire Agency	LACFD	OH-1180540E		120/240 V	Conductor	Overhead	Yes	10/28/16	10:13	Equipment/Facility Failure	Conductor			Unknown	
233	SCE	10/29/16	18:42	34.2149030	-119.1889710	Other	Urban	Less Than .25 Acres	Self Extinguished		940 Huntswood Way, Oxnard		16 kV	Conductor	Overhead	No			Equipment/Facility Failure	Conductor			Unknown	
234	SCE	11/3/16	22:37	33.7300240	-117.9839590	Other	Urban	Less Than .25 Acres	Fire Agency	Huntington Fire Department	OH-1787899E		12 kV	Conductor	Overhead	Yes	11/3/16	22:37	Contact From Object		Balloons	Electric Facility		Unknown
235	SCE	11/11/16	4:16	33.6309420	-117.9348070	Other	Urban	Structure Only	Fire Agency	Newport Fire Department	864 Production Pl. Newport Beach		12 kV	Conductor	Overhead	Yes	11/16/16	4:18	Equipment/Facility Failure	Conductor			Unknown	
236	SCE	11/16/16	13:45	33.9168380	-118.0339500	Vegetation	Urban	Less Than .25 Acres	Fire Agency	LACFD	OH-1914521E	TIME WARNER CABL	12 kV	Conductor	Overhead	Yes	11/16/16	13:45	Equipment/Facility Failure	Conductor			Unknown	
237	SCE	11/20/16	11:15	34.1883400	-118.8742520	Vegetation	Rural	Less Than .25 Acres	Self Extinguished		OH-1473501E	TIME WARNER CABL	16 kV	Conductor	Overhead	No			Contact From Object	Animal	Electric Facility		Unknown	
238	SCE	11/22/16	15:20	36.3134220	-119.1710520	Vegetation	Rural	Less Than .25 Acres	Unknown		1970 North Anderson Road, Exeter		12 kV	Conductor	Overhead	Yes	11/22/16	15:20	Contact From Object	Animal	Electric Facility		Unknown	
239	SCE	12/1/16	8:54	33.6919790	-117.7031110	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Orange County Fire Authority	OH-2257796E		12 kV	Conductor	Overhead	No			Contact From Object	Other	Electric Facility		Unknown	
240	SCE	12/2/16	21:26	34.3812290	-118.4131810	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Orange County Fire Authority	OH-4527700E		66 kV	Conductor	Overhead	No			Contact From Object	Vegetation	Electric Facility		Unknown	
241	SCE	12/16/16	19:31	33.8120810	-118.0238250	Building	Urban	Structure Only	Fire Agency	Orange County Fire Authority	10332 Florence Ave., Buena Park		120/240 V	Conductor	Overhead	Yes	12/16/16	19:31	Equipment/Facility Failure	Conductor			Unknown	
242	SCE	12/19/16	8:18	34.0231980	-117.8529840	Vegetation	Urban	Less Than .25 Acres	Unknown		UG-5048396		12 kV	Conductor	Subsurface	Yes	12/19/16	8:18	Equipment/Facility Failure	Other			Unknown	
243	SCE	12/26/16	8:02	34.1675510	-116.1070320	Vegetation	Rural	Less Than .25 Acres	Utility		OH-4803462E		33 kV	Conductor	Overhead	Yes	12/26/16	8:02	Contact From Object				Unknown	
244	SCE	12/30/16	11:42	34.1231260	-118.7229630	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	LACFD	OH-1927507E	AT&T CALIFORNIA	16 kV	Conductor	Overhead	Yes	12/30/16	11:42	Contact From Object	Animal	Electric Facility		Unknown	
245	SCE	1/13/17	11:05	33.7610280	-116.6947830	Vegetation	Rural	Less Than .25 Acres	Unknown		OH-2206325	FRONTIER COMMUN	12kV	Conductor	Overhead	Yes	1/13/17	11:05	Contact From Object		Vegetation	Electric Facility		Unknown
246	SCE	1/14/17	1:21	34.2555110	-118.9950720	Vegetation	Rural	Less Than .25 Acres	Fire Agency		OH-802855E	FRONTIER COMMUN	16kV	Conductor	Overhead	Yes	1/14/17	1:21	Contact From Object				Unknown	
247	SCE	1/28/17	18:15	33.9900380	-118.3702570	Vegetation	Urban	Less Than .25 Acres	Self Extinguished		OH-X5037878		120/240 V	Conductor	Overhead	Yes	1/28/17	18:15	Equipment/Facility Failure	Conductor			Unknown	
248	SCE	1/31/17	2:10	33.9900380	-118.3702570	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Hesperia FD	PS 522		115 kV	Conductor	Overhead	No			Equipment/Facility Failure	Other			Unknown	
249	SCE	2/8/17	2:20	33.6897030	-117.8527580	Other	Urban	Less Than .25 Acres	Fire Agency	Orange County Fire Authority	OH-1838346E	XO COMMUNICATION	66kV	Conductor	Overhead	Yes	2/8/17	2:20	Unknown				Unknown	
250	SCE	3/10/17	15:46	33.7871030	-117.9122940	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Garden Grove FD	OH-2095520E		12kV	Conductor	Overhead	Yes	3/10/17	15:46	Contact From Object		Vegetation	Electric Facility		Unknown
251	SCE	3/11/17	17:22	34.1284770	-117.2525400	Vegetation	Rural	Less Than .25 Acres	Self Extinguished		OH-4067378E	FRONTIER COMMUN	12kV	Lightning Arrestor	Overhead	Yes	3/11/17	17:22	Equipment/Facility Failure	Lightning Arrestor			Unknown	
252	SCE	3/13/17	13:42	33.9536060	-118.0665250	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Santa Fe Springs Fire Department	OH-4209839E		12kV	Conductor	Overhead	Yes	3/13/17	13:42	Contact From Object		Vehicle	Pole		Unknown
253	SCE	3/15/17	13:23	34.0534485	-116.9710052	Vegetation	Rural	Less Than .25 Acres	Fire Agency	CalFire	OH-2326555E	FRONTIER COMMUN	12kV	Conductor	Overhead	Yes	3/15/17	13:23	Contact From Object		Animal	Electric Facility		Unknown
254	SCE	3/17/17	17:14	34.5759060	-118.2629170	Vegetation	Rural	Less Than .25 Acres	Fire Agency	LACFD	OH-4493963E		12kV	Conductor	Overhead	Yes	3/17/17	17:14	Contact From Object		Vehicle	Pole		Unknown
255	SCE	3/30/17	14:37	34.8903362	-117.0150230	Vegetation	Urban	Structure Only	Fire Agency	Barstow FD	OH-3284433E		12kV	Conductor	Overhead	Yes	3/30/17	14:37	Equipment/Facility Failure	Pole			Unknown	Weather
256	SCE	4/9/17	1:51	33.9900380	-118.3702570	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Ontario Fire Department	PS 493		12kV	Conductor	Overhead	Yes	4/9/17	1:51	Contact From Object		Vehicle	Pole		Unknown
257	SCE	4/16/17	15:39	34.4556008	-119.2557185	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Ventura County FD	OH-4495331E	AT&T CALIFORNIA	16kV	Conductor	Overhead	Yes	4/16/17	15:39	Contact From Object		Vegetation	Electric Facility		Unknown
258	SCE	4/22/17	11:23	35.8628425	-119.2525648	Vegetation	Rural	Structure Only	Self Extinguished		OH-1501428E		12kV	Conductor	Overhead	Yes	4/22/17	11:23	Unknown				Unknown	
259	SCE	4/23/17	16:24	34.5961900	-118.2426980	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Palmdale Fire Department	OH-4336106E	AT&T CALIFORNIA	12kV	Conductor	Overhead	Yes	4/23/17	16:24	Unknown				Unknown	
260	SCE	4/28/17	23:15	33.9900380	-118.3702570	Vegetation	Rural	Less Than .25 Acres	Unknown		PS533		16kV	Conductor	Overhead	Yes	4/28/17	23:15	Contact From Object		Vegetation	Electric Facility		Unknown
261	SCE	4/28/17	10:59	33.9286440	-116.6421190	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Riverside Fire Department	OH-1905185E		4 kV	Conductor	Overhead	Yes	4/28/17	10:59	Unknown				Unknown	
262	SCE	4/28/17	10:37	36.4356275	-119.1907857	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Tulare Fire Department	OH-4600856E	AT&T CALIFORNIA	12kV	Conductor	Overhead	Yes	4/28/17	10:37	Contact From Object		Vehicle	Pole		Unknown
263	SCE	4/29/17	16:08	33.8983710	-117.2207070	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Riverside Fire Department	OH-3129235	FRONTIER COMMUN	12kV	Conductor	Overhead	Yes	4/29/17	16:08	Equipment/Facility Failure	Conductor			Unknown	
264	SCE	4/29/17	3:17	34.1268230	-118.0734630	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Monrovia Fire Department	OH-695124H	AT&T CALIFORNIA	16kV	Conductor	Overhead	Yes	4/29/17	3:53	Equipment/Facility Failure	Conductor			Unknown	
265	SCE	5/11/17	20:04	34.1571170	-118.0444800	Vegetation	Rural	Less Than .25 Acres	Fire Agency	LACFD	OH-11834480	NEXTG NETWORKS	16kV	Conductor	Overhead	Yes	5/11/17	20:04	Contact From Object		Vegetation	Electric Facility		Unknown
266	SCE	5/11/17	5:40	38.0209440	-119.1607600	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAiFire	OH-1580964E		55kV	Conductor	Overhead	No			Contact From Object				Unknown	Bird Poop
267	SCE	5/31/17	7:01	33.8718439	-118.2682003	Vegetation	Urban	Less Than .25 Acres	Fire Agency	LACFD	OH-X5050253		16kV	Conductor	Overhead	Yes	5/31/17	7:01	Contact From Object		Balloons	Electric Facility		Unknown
268	SCE	5/31/17	5:40	34.2644820	-118.7690480	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Ventura County FD	OH-1840411E		16kV	Conductor	Overhead	Yes	5/31/17	5:40	Contact From Object		Animal	Electric Facility		Unknown
269	SCE	5/11/17	12:27	34.4127010	-118.6702310	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	LACFD	OH-848255E		16kV	Conductor	Overhead	Yes	5/11/17	12:27	Contact From Object		Balloons	Electric Facility		Unknown
270	SCE	5/14/17	11:15	33.6416147	-117.1676704	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Riverside Fire Department	OH-2283870E		115 kV	Conductor	Overhead	Yes	5/14/17	11:15	Contact From Object		Balloons	Electric Facility		Unknown
271	SCE	5/15/17	13:54	35.427678	-118.8050080	Vegetation	Rural	100 - 299 Acres	Fire Agency	CalFire	OH-2283870E	Verizon Wireless	166kV	Conductor	Overhead	No			Contact From Object		Animal	Electric Facility		Unknown
272	SCE	5/19/17	17:57	33.8693010	-117.8315319	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Placentia Fire Department	OH-1789272E	VERIZON WIRELESS	12kV	Conductor	Overhead	Yes	5/19/17	17:57	Contact From Object		Animal	Electric Facility		Unknown
273	SCE	5/19/17	15:51	33.6443658	-117.8573583	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Newport Fire Department	OH-4248432E		12kV	Conductor	Overhead	Yes	5/19/17	15:51	Contact From Object		Balloons	Electric Facility		Unknown
274	SCE	5/20/17	17:28	33.7067865	-117.1388210	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Riverside Fire Department	OH-4788465E		12kV	Conductor	Overhead	Yes	5/20/17	17:28	Contact From Object		Balloons	Electric Facility		Unknown
275	SCE	5/20/17	15:24	33.7816957	-117.9083331	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Garden Grove FD	OH-1405576E		12kV	Conductor	Overhead	Yes	5/20/17	15:24	Contact From Object		Balloons	Electric Facility		Unknown
276	SCE	5/20/17	9:43	34.0425507	-118.6437934	Vegetation	Urban	Less Than .25 Acres	Self Extinguished		OH-788558E	AT&T CALIFORNIA	16kV	Conductor	Overhead	Yes	5/20/17	9:43	Equipment/Facility Failure	Other			Unknown	
277	SCE	5/22/17	11:27	34.5100480	-117.2909710	Vegetation	Rural	Less Than .25 Acres	Fire Agency	San Bernardino FD	OH-1966164E		12kV	Conductor	Overhead	Yes	5/22/17	11:27	Contact From Object		Other	Electric Facility		Unknown
278	SCE	5/23/17	12:07	34.4203573	-117.1746778																			

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X
Utility Name	Fire Start	Latitude	Longitude	Material at Origin	Location Info	Fire Specifics	Utility Facility	Outage Info	Field Observations															
2	Column1	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Equipment Involved With Ignition	Type	Was There an Outage	Date2	Time3	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes	
344	SCE	11/11/17	10:32	34.4271160	-119.6440520	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Santa Barbara Fire Department	OH-4255539E	NEXTG NETWORKS,LLC	4 kV Conductor	Overhead	Yes	11/11/17	10:32:00	Contact From Object		Vegetation	Electric Facility	Unknown		
345	SCE	11/11/17	3:27	34.0044624	-117.6486525	Vegetation	Urban	Less Than .25 Acres	Utility	OH-4019309E			66kV Conductor	Overhead	No			Contact From Object		Balloons	Electric Facility	Unknown		
346	SCE	11/13/17	13:49	33.7390980	-117.2777800	Vegetation	Rural	Less Than .25 Acres	Unknown	OH-4059962E	FRONTIER COMMUN		12kV Conductor	Overhead	Yes	11/13/17	13:49	Equipment/Facility Failure	Splice/Clamp/Connector			Unknown		
347	SCE	12/1/17	14:29	33.7614500	-117.2666690	Vegetation	Rural	26 - 99 Acres	Unknown	OH-4404592E	FRONTIER COMMUN		12kV Conductor	Overhead	Yes	12/1/17	14:29	Equipment/Facility Failure	Crossarm			Unknown		
348	SCE	12/5/17	11:38	33.9570100	-117.8613240	Vegetation	Urban	Less Than .25 Acres	Fire Agency	OH-788945H	NEXTG NETWORKS,LLC		12kV Conductor	Overhead	Yes	12/5/17	11:38	Contact From Object		Balloons	Electric Facility	Unknown		
349	SCE	12/21/17	23:40	34.1795290	-118.1337690	Vegetation	Urban	Less Than .25 Acres	Fire Agency	OH-4513407E			120/240 V Conductor	Overhead	Yes	12/21/17	23:40	Contact From Object		Vegetation	Electric Facility	Unknown		
350	SCE	12/18/18	18:28	34.0481200	-119.0899050	Vegetation	Urban	Less Than .25 Acres	Fire Agency	10834255E	AT&T CALIFORNIA		16 kV Conductor	Overhead	Yes	1/8/18	18:28	Equipment/Facility Failure				Unknown		
351	SCE	1/9/18	3:46	34.0600190	-118.3223630	Vegetation	Urban	Less Than .25 Acres	Fire Agency	1085977E	AT&T CALIFORNIA		16 kV Conductor	Overhead	Yes	1/8/18	3:48	Contact From Object		Other	Balloons	Electric Facility	Unknown	
352	SCE	1/25/18	14:05	34.0856470	-118.0652070	Vegetation	Urban	Less Than .25 Acres	Fire Agency	1429951E	AT&T CALIFORNIA		16 kV Conductor	Overhead	Yes	1/25/18	14:05	Equipment/Facility Failure		Other	Balloons	Electric Facility	Unknown	
353	SCE	1/31/18	8:29	33.7073850	-117.0523880	Vegetation	Urban	Less Than .25 Acres	Fire Agency	42334368E			12 kV Conductor	Overhead	Yes	1/31/18	8:29	Contact From Object		Animal	Electric Facility	Unknown		
354	SCE	2/12/18	17:07	33.8986570	-118.3536360	Vegetation	Urban	Less Than .25 Acres	Fire Agency	1099427E			16 kV Conductor	Overhead	Yes	2/12/18	17:07	Contact From Object		Balloons	Electric Facility	Unknown		
355	SCE	2/13/18	5:34	34.0502871	-118.6455857	Vegetation	Urban	Less Than .25 Acres	Fire Agency	4521770E	CHARTER COMMUNI		16 kV Conductor	Overhead	Yes	2/13/18	5:34	Contact From Object		Vehicle	Pole		Unknown	
356	SCE	2/14/18	11:12	34.0626319	-118.0655046	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Garvey/Rosemead, South El Monte			16 kV Transformer	Overhead	Yes	2/14/18	11:12	Unknown				Unknown		
357	SCE	2/23/18	9:29	33.9584900	-118.2317200	Vegetation	Urban	Less Than .25 Acres	Unknown	1698684E			120/240 V Conductor	Overhead	Yes	2/23/18	9:29	Contact From Object				Unknown		
358	SCE	2/25/18	13:07	34.0146050	-118.4486740	Vegetation	Urban	Less Than .25 Acres	Fire Agency	828710E	FRONTIER COMMUN		16 kV Conductor	Overhead	Yes	2/25/18	13:07	Contact From Object		Vegetation	Electric Facility	Unknown		
359	SCE	2/28/18	10:35	33.9537110	-118.3446400	Vegetation	Urban	Less Than .25 Acres	Fire Agency	1701012E	AT&T CALIFORNIA, S		16 kV Conductor	Overhead	Yes	2/28/18	10:35	Contact From Object		Animal	Electric Facility	Unknown		
360	SCE	3/15/18	9:08	34.2068390	-119.1445920	Vegetation	Urban	Less Than .25 Acres	Fire Agency	1603338E	FRONTIER COMMUN		16 kV Conductor	Overhead	Yes	3/15/18	9:08	Contact From Object		Balloons	Electric Facility	Unknown		
361	SCE	3/18/18	13:07	33.7372000	-117.9850500	Vegetation	Urban	Less Than .25 Acres	Fire Agency	1220403E	FRONTIER COMMUN		12 kV Conductor	Overhead	Yes	3/18/18	13:07	Contact From Object		Balloons	Electric Facility	Unknown		
362	SCE	4/9/18	13:32	34.2823140	-119.2868970	Vegetation	Urban	Less Than .25 Acres	Fire Agency	1477463E	AT&T CALIFORNIA		16 kV Conductor	Overhead	Yes	4/9/18	13:32	Wire-Wire Contact				Human Error		
363	SCE	4/10/18	12:33	34.3977580	-117.3571060	Vegetation	Rural	Less Than .25 Acres	Self Extinguished	4066725E	CHARTER COMMUNI		12 kV Conductor	Overhead	Yes	4/10/18	12:33	Contact From Object		Balloons	Electric Facility	Unknown		
364	SCE	4/12/18	16:33	33.9927930	-117.9944570	Vegetation	Urban	Less Than .25 Acres	Fire Agency	4159279E			4 kV Conductor	Overhead	Yes	4/12/18	16:33	Wire-Wire Contact				Unknown		
365	SCE	4/13/18	10:26	34.1225290	-117.2470138	Vegetation	Urban	Less Than .25 Acres	Unknown	25571 Walker St, San Brdo			4 kV Conductor	Overhead	Yes	4/13/18	10:26	Contact From Object		Balloons	Electric Facility	Unknown		
366	SCE	4/14/18	17:18	34.0616185	-118.0505980	Vegetation	Urban	Less Than .25 Acres	Fire Agency	4294956E			16 kV Transformer	Overhead	Yes	4/14/18	17:18	Equipment/Facility Failure		Other		Unknown		
367	SCE	4/15/18	15:08	34.8629640	-118.1782030	Vegetation	Rural	Less Than .25 Acres	Fire Agency	992250E	AT&T CALIFORNIA		4 kV Conductor	Overhead	Yes	4/15/18	15:08	Contact From Object		Balloons	Electric Facility	Unknown		
368	SCE	4/16/18	6:27	33.9499190	-117.9928990	Vegetation	Urban	Less Than .25 Acres	Unknown	4705273e			12 kV Conductor	Overhead	Yes	4/16/18	6:27	Equipment/Facility Failure		Switch		Unknown		
369	SCE	4/17/18	0:04	33.9848650	-118.0591220	Vegetation	Urban	Less Than .25 Acres	Fire Agency	2274423E	FRONTIER COMMUN		4 kV Conductor	Overhead	Yes	4/17/18	0:04	Equipment/Facility Failure		Transformer		Unknown		
370	SCE	4/19/18	21:58	34.6269800	-119.3147700	Vegetation	Urban	Less Than .25 Acres	Fire Agency	2334378E	AT&T CALIFORNIA		12 kV Conductor	Overhead	Yes	4/19/18	21:58	Equipment/Facility Failure		Conductor		Unknown		
371	SCE	4/20/18	8:38	34.4627930	-119.8958140	Vegetation	Urban	26 - 99 Acres	Fire Agency	1300 Ellwood Ranch Rd, Goleta			12 kV Conductor	Overhead	Yes	4/20/18	8:38	Contact From Object		Vehicle	Pole		Unknown	
372	SCE	4/22/18	13:31	33.8575210	-118.2223140	Vegetation	Urban	Less Than .25 Acres	Unknown	1978567E	AT&T CALIFORNIA		16 kV Conductor	Overhead	Yes	4/22/18	13:31	Contact From Object		Animal	Electric Facility	Unknown		
373	SCE	4/28/18	17:03	33.7873100	-117.2614238	Vegetation	Urban	26 - 99 Acres	Unknown	22942 La More Rd, Perris			16 kV Conductor	Overhead	Yes	4/28/18	17:03	Contact From Object		Balloons	Electric Facility	Unknown		
374	SCE	4/28/18	14:23	33.6820370	-117.3276028	Vegetation	Urban	10 - 99 Acres	Fire Agency	Langstaff & Camino Del Norte in Lake			33 kV Conductor	Overhead	Yes	4/28/18	14:23	Contact From Object		Balloons	Electric Facility	Unknown		
375	SCE	4/29/18	11:31	33.6962960	-117.2060890	Vegetation	Urban	26 - 99 Acres	Fire Agency	Riverside Fire Department	29234 Murrieta Rd, sun City, X St Westridge		12 kV Conductor	Overhead	Yes	4/29/18	11:31	Contact From Object		Balloons	Electric Facility	Unknown		
376	SCE	5/2/18	14:56	33.7899710	-118.3367549	Vegetation	Urban	Less Than .25 Acres	Unknown	198352E			16 kV Conductor	Overhead	Yes	5/2/18	14:56	Contact From Object		Balloons	Electric Facility	Unknown		
377	SCE	5/3/18	16:57	33.9753780	-117.2326921	Vegetation	Urban	Less Than .25 Acres	Unknown	HEACOCK CROSS RECHE VISTA CITY OF MOR			12 kV Conductor	Overhead	Yes	5/3/18	16:57	Equipment/Facility Failure		Other		Unknown		
378	SCE	5/9/18	17:52	33.9236300	-117.9988670	Vegetation	Urban	Less Than .25 Acres	Fire Agency	1398814E	FRONTIER COMMUN		16 kV Conductor	Overhead	Yes	5/9/18	17:52	Contact From Object		Vegetation	Electric Facility	Unknown		
379	SCE	5/11/18	18:22	34.0728400	-117.2844670	Vegetation	Urban	Less Than .25 Acres	Fire Agency	1531988E			12 kV Conductor	Overhead	Yes	5/11/18	18:22	Vandalism/Theft				Unknown		
380	SCE	5/16/18	18:26	34.5245000	-117.3404745	Vegetation	Urban	Less Than .25 Acres	Fire Agency	1517340E			12 kV Conductor	Overhead	Yes	5/16/18	18:26	Contact From Object		Balloons	Electric Facility	Unknown		
381	SCE	5/21/18	12:24	33.5053510	-117.1877870	Vegetation	Urban	Less Than .25 Acres	Unknown	35418779E			12 kV Conductor	Subsurface	Yes	5/21/18	12:24	Equipment/Facility Failure		Splice/Clamp/Connector		Unknown		
382	SCE	5/26/18	18:16	36.2117360	-119.3142963	Vegetation	Urban	Less Than .25 Acres	Fire Agency	2200 E Tulare Av, Tulare			12 kV Conductor	Overhead	Yes	5/26/18	18:16	Contact From Object		Balloons	Electric Facility	Unknown		
383	SCE	5/31/18	16:03	36.3264679	-119.3675661	Vegetation	Urban	Less Than .25 Acres	Fire Agency	4141017E	COMCAST OF SIERR		12 kV Conductor	Overhead	Yes	5/31/18	16:03	Contact From Object		Animal	Electric Facility	Unknown		
384	SCE	6/2/18	10:41	35.8930670	-118.9207053	Vegetation	Rural	26 - 99 Acres	Fire Agency	Avenue 56 and Old Stage Road in Ducor.			12 kV Conductor	Overhead	Yes	6/2/18	11:12	Contact From Object		Animal	Electric Facility	Unknown		
385	SCE	6/5/18	21:51	33.9371090	-117.1755337	Vegetation	Urban	Less Than .25 Acres	Unknown	Eucalyptus and auto mall drive			12 kV Conductor	Overhead	Yes	6/5/18	21:51	Contact From Object		Vehicle	Pole		Unknown	
386	SCE	6/6/18	0:13	33.9389270	-117.1296760	Vegetation	Urban	Less Than .25 Acres	Fire Agency	4275896E			16 kV Conductor	Overhead	Yes	6/6/18	0:13	Contact From Object		Vehicle	Pole		Unknown	
387	SCE	6/6/18	23:50	34.0947870	-118.0455850	Vegetation	Urban	26 - 99 Acres	Fire Agency	628981E	AT&T CALIFORNIA		16 kV Transformer	Overhead	Yes	6/6/18	23:50	Equipment/Facility Failure		Transformer		Unknown		
388	SCE	6/8/18	11:53	34.9140150	-116.9886001	Vegetation	Urban	Less Than .25 Acres	Unknown	SOAPMINE RD, X HWY 58 SAN BERNARDINO			12 kV Conductor	Overhead	Yes	6/8/18	11:53	Contact From Object		Vehicle	Pole		Unknown	
389	SCE	6/10/18	6:07	33.9458590	-117.3913028	Vegetation	Urban	Less Than .25 Acres	Fire Agency	1763430E			12 kV Conductor	Overhead	Yes	6/10/18	6:07	Contact From Object		Animal	Electric Facility	Unknown		
390	SCE	6/12/18	13:27	34.0308890	-117.1207670	Vegetation	Urban	Less Than .25 Acres	Fire Agency	400764E	FRONTIER COMMUN		12 kV Conductor	Overhead	Yes	6/12/18	13:27	Contact From Object		Vehicle	Pole		Unknown	
391	SCE	6/13/18	20:30	34.9882770	-117.8922990	Vegetation	Urban	Less Than .25 Acres	Fire Agency	OH-4168509E			115 kV Conductor	Overhead	Yes	6/13/18	20:30	Unknown				Unknown		
392	SCE	6/13/18	20:49	36.2042210	-119.0927292	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Lindsay-Strathmore 66 kv			66 kV Conductor	Overhead	Yes	6/13/18	20:49	Equipment/Facility Failure		Splice/Clamp/Connector		Unknown		
393	SCE	6/15/18	17:04	34.3701920	-117.3179030	Vegetation	Rural	Less Than .25 Acres	Fire Agency	4769611E			12 kV Conductor	Overhead	Yes	6/15/18	17:04	Contact From Object		Vehicle	Pole		Unknown	
394	SCE	6/17/18	11:52	33.7548370																				