

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X	
2	Utility Name	Date	Time	Latitude	Longitude	Location Info	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Utility Facility	Equipment Involved With Ignition	Type	Was There an Outage	Date2	Time3	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes
112	SDG&E	10/16/17	10:20	33.0697000	-116.8813000	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CALFIRE	P112774 / c236		12kV	Conductor	Overhead	No			Contact From Object			Electric Facility	Other		
113	SDG&E	10/18/17	7:20	33.9932254	-117.1232409	Vegetation	Urban	Less Than .25 Acres	Unknown		P10506 Cir 859		12kV	Conductor	Overhead	No			Contact From Object		Vehicle	Pole	Human Error		
114	SDG&E	10/22/17	10:22	33.0990000	-117.1390000	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Rnch Snta Fe	P250055 Circuit 182		12kV	Conductor	Overhead	Yes	10/22/17	10:22	Contact From Object		Other	Electric Facility	Human Error		
115	SDG&E	10/25/17	13:02	33.2856840	-117.0275340	Vegetation	Rural	Less Than .25 Acres	Fire Agency	CALFIRE	P416197, Circuit 908		12kV	Other	Overhead	No			Equipment/Facility Failure			Electric Facility	Weather		
116	SDG&E	12/10/17	2:58	33.2738680	-116.9536750	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CALFIRE	P813516		12kV	Transformer	Overhead	No			Equipment/Facility Failure		Splice/Clamp/Connector		None		
117	SDG&E	12/10/17	5:26	33.2800000	-116.9500000	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CALFIRE	P32240		12kV	Conductor	Overhead	Yes	12/10/17	5:26	Contact From Object			Electric Facility	Weather		
118	SDG&E	2/8/18	10:07	33.2071000	-117.2072000	Vegetation	Rural	Less Than .25 Acres	Fire Agency	North County Fire	P213833		12kV	Conductor	Overhead	Yes	2/8/18	10:07	Contact From Object			Electric Facility	Human Error		
119	SDG&E	2/16/18	16:50	32.6275960	-116.9408520	Vegetation	Urban	Less Than .25 Acres	Utility		C-594		12kV	Conductor	Overhead	Yes	2/16/18	14:02	Contact From Object		Balloons	Electric Facility	Outside Force		
120	SDG&E	4/12/18	19:33	32.6965100	-117.0492940	Vegetation	Urban	Less Than .25 Acres	Fire Agency	SDFD	Z89883		12kV	Conductor	Overhead	No			Contact From Object			Electric Facility	Other		
121	SDG&E	4/16/18	14:24	33.4176000	-117.6058000	Vegetation	Urban	Less Than .25 Acres	Fire Agency	OCFA	P121389		12kV	Conductor	Overhead	No			Contact From Object			Electric Facility	Weather		
122	SDG&E	4/18/18	15:25	33.2410000	-117.3470000	Vegetation	Rural	Less Than .25 Acres	Fire Agency	CPFD	Z223638		230kV	Conductor	Overhead	No			Contact From Object			Electric Facility	Other		
123	SDG&E	4/22/18	14:00	32.8370000	-117.1840000	Vegetation	Urban	Less Than .25 Acres	Fire Agency	SDFD	P729991 Cir. 275		12kV	Conductor	Overhead	Yes	4/22/18	14:00	Contact From Object		Balloons	Electric Facility	None		
124	SDG&E	5/1/18	21:29	32.6847520	-117.1011690	Vegetation	Urban	Less Than .25 Acres	Fire Agency	National City	Z730733		69kV	Conductor	Overhead	No			Contact From Object			Electric Facility	Outside Force		
125	SDG&E	5/22/18	14:23	33.3620000	-117.0320000	Vegetation	Rural	10 - 99 Acres	Fire Agency	CALFIRE	P214790 Cir.217		12kV	Conductor	Overhead	Yes	5/22/18	14:02	Contact From Object		Balloons	Electric Facility	Other		
126	SDG&E	6/1/18	14:00	33.0990000	-117.0440000	Vegetation	Rural	Less Than .25 Acres	Utility		P618454		12kV	Conductor	Overhead	No			Wire-Wire Contact			Electric Facility	Other		
127	SDG&E	6/12/18	9:00	32.7060000	-116.3960000	Vegetation	Rural	Less Than .25 Acres	Fire Agency	CAL FIRE	P44708 Cir. 458		12kV	Conductor	Overhead	Yes	6/12/18	9:00	Contact From Object			Electric Facility	None		
128	SDG&E	6/12/18	15:14	32.8640000	-116.7470000	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Fire Agency	P871937 Cir. 357		12kV	Conductor	Overhead	Yes	6/12/18	14:38	Contact From Object		Balloons	Electric Facility	None		
129	SDG&E	6/22/18	9:46	32.5670000	-116.9410000	Vegetation	Rural	Less Than .25 Acres	Fire Agency	SDFD	Z100698 Cir. 535		12kV	Switch	Overhead	Yes	6/22/18	9:42	Switch				Unknown		
130	SDG&E	6/29/18	13:06	32.6450000	-117.0560000	Vegetation	Rural	Less Than .25 Acres	Fire Agency	Chula Vista	Z182447 Cir. 341		12kV	Other	Overhead	Yes	6/29/18	13:06	Equipment/Facility Failure		Guy/Span Wire		Unknown		
131	SDG&E	7/6/18	10:26	32.6203150	-116.7649300	Vegetation	Rural	10 - 99 Acres	Fire Agency	CalFire	P177572, Station 157-825, C157		12kV	Transformer	Overhead	No			Equipment/Facility Failure		Transformer				
132	SDG&E	7/8/18	16:16	32.6348850	-117.1030420	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Chula Vista	P100601, C255		12kV	Switch	Overhead	Yes	7/8/18	16:16	Other				Other		
133	SDG&E	7/22/18	23:19	33.3010000	-116.3510000	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Borrego Springs FD	374759 Cir 170		12kV	Conductor	Overhead	Yes	7/22/18	23:19	Contact From Object			Electric Facility	None		
134	SDG&E	7/30/18	12:11	32.8680680	-117.1902280	Vegetation	Urban	26 - 9.99 Acres	Fire Agency	SDFD&MCMIR	Z90115 Cir 968		12kV	Conductor	Overhead	No			Contact From Object			Electric Facility	Other		
135	SDG&E	8/9/18	12:00	33.2130000	-117.3350000	Vegetation	Urban	Less Than .25 Acres	Fire Agency	Oceanside FD	P226873 Cir 194		12kV	Conductor	Overhead	No			Equipment/Facility Failure		Other		Other		
136	SDG&E	8/19/18	18:35	32.7001804	-116.8638674	Vegetation	Rural	Less Than .25 Acres	Fire Agency	CAL FIRE	P254640 Cir 75		12kV	Conductor	Overhead	Yes	7/19/18	18:35	Contact From Object		Balloons	Electric Facility	Other		
137	SDG&E	9/14/18	10:00	33.3177060	-117.2228440	Vegetation	Rural	Less Than .25 Acres	Fire Agency	MVU & NCFPD	P213051 Cir 233		12kV	Conductor	Overhead	No			Contact Between Third Party Facility on Pole and Supply Lines		Vehicle	Communication Facility	Human Error		
138	SDG&E	9/14/18	15:02	32.7896790	-117.0808820	Vegetation	Urban	Less Than .25 Acres	Fire Agency	SDFD	P279980J Cir 702		12kV	Other	Overhead	Yes	9/14/18	15:48	Equipment/Facility Failure				None		
139	SDG&E	10/12/18	12:30	32.8019070	-117.1493760	Vegetation	Urban	Less Than .25 Acres	Utility		Z96245		69kV	Other	Overhead	No			Contact From Object		Vehicle		Human Error		
140	SDG&E	10/12/18	10:00	33.3013270	-116.9129450	Vegetation	Rural	Less Than .25 Acres	Utility		Z118027		69kV	Conductor	Overhead	No			Contact From Object		Vehicle		Human Error		
141	SDG&E	10/15/18	10:21	33.3190990	-117.2596710	Vegetation	Rural	Less Than .25 Acres	Customer		P112366		12kV	Conductor	Overhead	Yes	10/15/18	12:02	Equipment/Facility Failure				None		
142	SDG&E	11/26/18	1:51	33.4313920	-117.5951950	Vegetation	Urban	26 - 9.99 Acres	Fire Agency	OCFA	P25325		12kV	Conductor	Overhead	Yes	11/26/18	1:45	Contact From Object		Balloons	Electric Facility	None		
143	SDG&E	12/2/18	11:25	33.2800000	-117.4040000	Vegetation	Rural	Less Than .25 Acres	Self Extinguished		Z223659		230kV	Conductor	Overhead	Yes	12/2/18	11:25	Contact From Object		Other	Electric Facility	None		