

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X
2	Utility Name	Fire Start				Location Info			Fire Specifics		Utility Facility		Outage Info			Suspected Initiating Event		Field Observations						
3	Column1	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date2	Time3		Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes
4	SCE	5/29/14	18:00	33.9036301	-118.0368983	Other	Urban	Less Than 25 Acres	Fire Agency	Santa Fe Springs	14051 Marquadt, Santa Fe	None	66kV	Other	Overhead	No				Unknown				
5	SCE	6/5/14	9:20	34.5550460	-118.1177890	Other	Rural	Less Than 25 Acres	Fire Agency	LA County	700 East Ave. S. Palmdale	None	12kV	Conductor	Overhead	No				Contact From Object	Other	Electric Facility	Unknown	
6	SCE	6/8/14	18:00	33.6808854	-117.9487188	Other	Urban	Less Than 25 Acres	Fire Agency	Huntington Beach	19391, 19381, 19371, Pitca	None	12kV	Other	Overhead	No				Contact From Object	Balloons	Electric Facility	None	
7	SCE	6/13/14	13:00	35.7151000	-118.5110670	Vegetation	Rural	1000 - 4999 Acres	Fire Agency	Cal Fire	West of Lake Isabella & So	None	66kV	Other	Overhead	No				Unknown				
8	SCE	6/18/14	15:00	34.1626420	-118.6767220	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	LA County	Location of Fire 726730E	None	16kV	Conductor	Overhead	Yes	6/18/14	Unknown		Unknown				
9	SCE	6/23/14	13:15	Not Provided	-118.72947	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire	00 Old Stage, Glennville,	Unknown	12kV	Conductor	Overhead	Yes	6/23/2014	16:20		Contact From Object	Vegetation	Electric Facility	Unknown	
10	SCE	6/27/14	11:06	34.6084170	-117.0502740	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Ventura County	810 S CRAWSTON AVE, 44	None	16kV	Conductor	Overhead	Yes	6/27/14	11:06		Contact From Object	Animal	Electric Facility	Unknown	
11	SCE	7/31/14	11:30	33.7468620	-117.7892737	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Fire Department	622 alla Vista Dr, santa fe	Phone & Cable	16kV	Transformer	Overhead	No								
12	SCE	7/24/14	13:00	33.5444355	-117.458394	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Not provided	39613 Lieder Rd, Temecul	None	12kV	Lightning Arrestor	Overhead	No				Equipment/Facility Failure	Lightning Arrestor			
13	SCE	7/27/14	18:00	36.0501990	-119.0574840	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Tulare County Fire	1785 W. POPLAR AVE., P	Unknown	12kV	Conductor	Overhead	No				Contact From Object	Vegetation	Electric Facility	Unknown	
14	SCE	7/29/14	8:23	34.4529320	-117.1872710	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Riverside County	UG-5057024 rouse rd, mer	None	12kV	Conductor	Overhead	No				Equipment/Facility Failure	Conductor			
15	SCE	7/31/14	16:00	33.7927568	-117.2831691	Other	Rural	Less Than 25 Acres	Fire Agency	Perris Fire Department	22597 FORREST RD, Perr	Phone & Cable	12kV	Other	Overhead	No				Unknown				
16	SCE	8/3/14	20:00	36.3425640	-119.3756970	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Visalia Fire Department	NS of Goshen Ave. 1/4 mi	None	12kV	Conductor	Overhead	No				Contact From Object	Balloons	Pole	Unknown	
17	SCE	8/12/14	13:29	34.3867900	-119.3145000	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Ventura County	SANTA ANA BL S/O SANI	Unknown	16kV	Conductor	Overhead	Yes	8/12/14	12:05		Contact From Object	Vehicle	Pole	Unknown	Outside Force
18	SCE	8/16/14	9:00	33.7337323	-117.0152318	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Hemet Fire Department	810 S CRAWSTON AVE, 44	Phone	12kV	Other	Overhead	Yes	8/16/14	9:00		Equipment/Facility Failure	Conductor			
19	SCE	8/17/14	15:00	33.7468620	-117.7892737	Vegetation	Urban	Less Than 25 Acres	Fire Agency	OC Fire Authority	622 alla Vista Dr, santa fe	None	12kV	Transformer	Overhead	No				Equipment/Facility Failure	Transformer			
20	SCE	8/24/14	8:30	34.0087540	-117.4021760	Vegetation	Urban	26 - 9.99 Acres	Fire Agency	Riverside County FD	5755 Kennard Pl, Pole 20	None	12kV	Other	Overhead	Yes	8/24/14	8:30		Equipment/Facility Failure				
21	SCE	8/30/14	15:30	34.1709350	-117.2956550	Vegetation	Urban	26 - 9.99 Acres	Fire Agency	San Bernardino Fire	4718 Acacia San Bernadin	Phone & Cable	4kV	Other	Overhead	No				Equipment/Facility Failure	Splice/Clamp/Connector			
22	SCE	9/5/14	14:00	34.0276135	-117.9071504	Other	Urban	Less Than 25 Acres	Fire Agency	West Covina FD	1829 Greenleaf Dr, West C	None	12kV	Other	Subsurface	Yes	9/5/14	14:00		Equipment/Facility Failure	Splice/Clamp/Connector			
23	SCE	9/6/14	14:00	33.8780461	-117.5195693	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Riverside County	13462 magnolia ave, coron	Unknown	12kV	Conductor	Overhead	Yes	9/6/14	14:00		Unknown				
24	SCE	9/8/14	11:55	34.5600120	-118.0401940	Other	Urban	Less Than 25 Acres	Fire Agency	LA County	37316 50TH ST EAST PAL	Phone & Cable	12kV	Conductor	Overhead	No				Contact From Object	Vegetation	Electric Facility	Unknown	
25	SCE	9/15/14	16:00	34.1740188	-118.0575900	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Sierra Madre FD	rear of 630 Sierra Meadow	Unknown	16kV	Other	Overhead	Yes	9/15/14	15:54		Contact From Object	Balloons	Electric Facility	None	
26	SCE	9/19/14	23:20	34.0382540	-118.8719920	Vegetation	Rural	Less Than 25 Acres	Fire Agency	LA County	32008 PACIFIC COAST H	Phone & Cable	16kV	Transformer	Overhead	No				Contamination				
27	SCE	10/3/14	15:00	34.0468915	-117.9851278	Other	Urban	Less Than 25 Acres	Unknown		1160454e n/e corner of pu	Unknown	12kV	Other	Overhead	No				Contact From Object	Other	Electric Facility	Unknown	
28	SCE	10/4/14	16:00	34.1652250	-117.3566230	Other	Urban	Less Than 25 Acres	Fire Agency	San Bernardino Fire	2497 W. 3rd Ave San Bern	Unknown	4kV	Other	Overhead	Yes	10/4/14	16:00		Unknown				
29	SCE	10/10/14	16:24	34.2049210	-118.3746730	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Thousand Oaks	73 TRIANGLE SRT THOUS	Unknown	16kV	Conductor	Overhead	Yes	10/10/14	16:24		Contact From Object	Vegetation	Electric Facility	Unknown	
30	SCE	10/17/14	17:00	Not Provided	Not Provided	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Redondo Beach Fire Dgpt	509 s Lucia redondo beach	Unknown	16kV	Conductor	Overhead	No				Equipment/Facility Failure	Splice/Clamp/Connector			
31	SCE	11/10/14	Not Provided	Not Provided	Not Provided	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Arcadia Fire Department	R/O School on Santa Anita	None	4kV	Conductor	Overhead	Yes	11/10/14	Not Provided		Equipment/Facility Failure	Conductor			
32	SCE	11/13/14	12:00	34.4934020	-117.1863970	Building	Urban	Less Than 25 Acres	Fire Agency	Apple Valley Fire Department	21838 Ottawa 4559358E	Unknown	12kV	Other	Overhead	No				Contact Between Third Party Facility on Pole and Supply Lines				
33	SCE	11/16/14	13:30	34.0480460	-118.6829900	Vegetation	Urban	Less Than 25 Acres	Fire Agency	LA County	R/O 23347 PALM CANYON	Unknown	16kV	Conductor	Overhead	Yes	11/16/14	13:30		Contact From Object	Vegetation	Electric Facility	Unknown	
34	SCE	11/17/14	4:30	34.3128590	-118.8983360	Other	Rural	Less Than 25 Acres	Fire Agency	Ventura County	11856 Broadway rd, moort	Unknown	16kV	Transformer	Overhead	No				Wire-Wire Contact				
35	SCE	11/21/14	4:41	34.0891120	-117.3711820	Vegetation	Urban	Less Than 25 Acres	Fire Agency	RIALTO FD	VACANT FIELD, VACANT L	Unknown	12kV	Other	Overhead	No				Other				
36	SCE	12/2/14	10:00	34.1058474	-117.7881530	Other	Urban	Less Than 25 Acres	Fire Agency	La Verne Fire Department	1025 Bonita Ave., La Verne	Phone & Cable	12kV	Capacitor Bank	Overhead	Yes	12/2/14	10:00		Vandalism/Theft				Lightning strike.
37	SCE	12/3/14	19:00	34.0376890	-117.7595747	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Pomona Fire Department	1852 GARLAND ST, POM	None	12kV	Conductor	Overhead	Yes	12/3/14	19:00		Equipment/Facility Failure	Conductor			
38	SCE	12/4/14	4:00	34.0119761	-117.9708730	Vegetation	Urban	Less Than 25 Acres	Fire Agency	LA County	Rochlen St. off kwis priv	Phone & Cable	12kV	Conductor	Overhead	Yes	12/4/14	4:00		Other				
39	SCE	12/12/14	2:52	33.9391028	-118.4043690	Vegetation	Rural	Less Than 25 Acres	Fire Agency	China Fire Department	1744 Hillside China, CA 9	None	12kV	Other	Overhead	No				Vandalism/Theft				
40	SCE	12/12/14	1:30	35.9219806	-119.0178838	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Tulare County Fire Department	7260 Rd. 248 Terra Bella,	None	12kV	Conductor	Overhead	No				Contact From Object	Vegetation	Electric Facility	Weather	
41	SCE	12/27/14	8:17	34.0719543	-117.8389807	Vegetation	Urban	Less Than 25 Acres	Fire Agency	LA County	covina hills x CALLE FRAN	Phone & Cable	12kV	Switch	Overhead	Yes				Contact From Object	Animal	Pole	Unknown	Outside Force
42	SCE	1/4/15	13:00	33.9359015	-118.3682332	Other	Urban	Less Than 25 Acres	Fire Agency	Los Angeles County Fire	Pole 1879055E	Phone & Cable	16kV	Conductor	Overhead	Yes	1/4/15	13:00		Unknown				
43	SCE	1/26/15	17:30	34.1314861	-117.8376444	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Glendora Fire Department	Pole 1384657E	Phone & Cable	12kV	Conductor	Overhead	Yes	1/26/15	17:30		Contact From Object	Vegetation	Electric Facility	Weather	
44	SCE	2/6/15	13:15	37.4539600	-118.5841960	Vegetation	Rural	Greater than 5000 Acres	Fire Agency	Various Fire Agencies	Between Poles 1854107E	Phone & Cable	12kV	Conductor	Overhead	Yes	2/6/15	13:15		Unknown				
45	SCE	2/22/15	9:52	34.2848680	-119.2172930	Vegetation	Rural	10 - 99 Acres	Fire Agency	Ventura Fire Department	Pole 1718768E	Phone & Cable	16kV	Other	Overhead	Yes	2/22/15	10:49		Unknown				
46	SCE	3/23/15	17:20	34.4354600	-119.8226270	Other	Urban	Less Than 25 Acres	Fire Agency	Santa Barbara County Fire	Pole 807632E	Phone & Cable	16 kV	Conductor	Overhead	Yes	3/23/15	19:19		Equipment/Facility Failure	Transformer			
47	SCE	3/26/15	14:09	33.9459510	-117.9247230	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Los Angeles County Fire	Twister 12kV at La Habra Sub and Whipstick 12kV	12kV	Conductor	Overhead	Yes	3/26/15	14:09		Contact From Object	Other	Electric Facility	Unknown		
48	SCE	3/26/15	17:57	33.8513739	-117.5872259	Other	Urban	Less Than 25 Acres	Fire Agency	Corona Fire Department	Owens 33kV at Corona Sub carrying Cupples 33kV	12kV	Other	Overhead	Yes	3/26/15	17:57		Equipment/Facility Failure	Other				
49	SCE	3/30/15	15:14	33.9010590	-117.8533700	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Orange County Fire Authority	Concun 12kV at Bras Sub in Placentia	12kV	Conductor	Overhead	Yes	3/30/15	15:24		Contact From Object	Other	Electric Facility	Unknown		
50	SCE	4/8/15	14:00	36.1065820	-119.0314670	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Tulare County Fire	Lewis Hill Porterville, ca - 8	Phone & Cable	12kV	Other	Overhead	Yes	4/8/15	14:10		Other				
51	SCE	4/8/15	13:05	34.1781090	-118.8684250	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Ventura County Fire	Pole 2240858E	Phone & Cable	16kV	Conductor	Overhead	Yes	4/8/15	13:05		Contact From Object	Animal	Electric Facility	Unknown	
52	SCE	4/8/15	16:52	36.1059070	-119.0416470	Other	Rural	Less Than 25 Acres	Fire Agency	Tulare County Fire	Pole 1004338E	12kV	Conductor	Overhead	Yes	4/8/15	16:52		Equipment/Facility Failure	Crossarm				
53	SCE	4/11/15	14:27	34.0354730	-118.1327740	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Monterey Park Fire Department	Pole 4356231E	Phone & Cable	4kV	Other	Overhead	Yes	4/11/15	14:27		Equipment/Facility Failure	Other			
54	SCE	4/12/1																						

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X
2	Utility Name	Fire Start				Location Info				Fire Specifics			Utility Facility			Outage Info					Field Observations			
3	Column1	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date2	Time3	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes
118	SCE	8/2/15	14:00	34.0326300	-117.1610770	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Redlands Fire Department	Pole 1375879E	Phone & Cable	12kV	Conductor	Overhead	Yes	8/2/15	14:00	Equipment/Facility Failure	Other			Unknown	
119	SCE	8/12/15	12:00	35.1772470	-118.3373190	Vegetation	Rural	Less Than 25 Acres	Self Extinguished		Pole 2135290E		120 V	Conductor	Subsurface	Yes	8/12/15	11:07	Other				Human Error	Third Party dug into marked SCE secondary cables.
120	SCE	8/21/15	23:10	36.2355530	-119.3528250	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Tulare Fire Department	4335336E - J STREET S/O CARTMILL AVE		12kV	Other	Overhead	Yes	8/22/15	2:19	Other				Unknown	Outside Force
121	SCE	8/24/15	22:00	33.8832930	-118.2115660	Building	Urban	Less Than 25 Acres	Fire Agency	Compton Fire Department	2239623E - MAYO AVE PA	Phone & Cable	12kV	Conductor	Overhead	Yes	8/24/15	21:41	Unknown				Unknown	Unknown
122	SCE	8/27/15	6:21	34.0844690	-117.9810950	Vegetation	Urban	Less Than 25 Acres	Fire Agency	West Covina Fire Department	Pole 534400E		12kV	Conductor	Overhead	Yes	8/27/15	6:21	Contact From Object	Vegetation	Electric Facility	Unknown	Unknown	Unknown
123	SCE	8/27/15	10:20	34.2538130	-118.8660450	Other	Urban	Less Than 25 Acres	Fire Agency	Ventura County Fire	Morganstein 16kV out of Moorpark Sub		16kV	Conductor	Overhead	Yes	8/27/15	10:20	Contact From Object	Animal	Electric Facility	None	Unknown	Unknown
124	SCE	9/3/15	17:00	36.8936000	-119.4571000	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire	East of Watts Valley Rd and Pittman Hill Rd. East		220kV	Conductor	Overhead	Yes	9/3/15	16:15	Contact From Object	Balloons	Electric Facility	None	Unknown	Unknown
125	SCE	9/7/15	17:58	35.8554700	-119.0944400	Vegetation	Rural	Less Than 25 Acres	Self Extinguished		Welch 12kV at Vestal Sub		12kV	Conductor	Overhead	Yes	9/7/15	17:58	Contact From Object	Balloons	Electric Facility	None	Unknown	Unknown
126	SCE	9/9/15	13:22	34.0419410	-118.7724050	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Los Angeles County Fire	Pole 899836E	Phone & Cable	12kV	Other	Overhead	Yes	9/9/15	13:22	Equipment/Facility Failure	Splice/Clamp/Connector			Unknown	Unknown
127	SCE	9/9/15	13:59	33.5499250	-117.2125150	Other	Urban	Less Than 25 Acres	Fire Agency	Murrieta Fire Department	Tackle Line out of Stadler Sub		12kV	Conductor	Overhead	Yes	9/9/15	13:59	Other				Unknown	Unknown
128	SCE	9/11/15	3:10	34.0875990	-117.4330630	Other	Urban	Less Than 25 Acres	Fire Agency	Fontana Fire Department	Pole 1554125E beyond RC	Phone & Cable	12kV	Lightning Arrestor	Overhead	Yes	9/11/15	3:10	Equipment/Facility Failure	Lightning Arrestor			Unknown	Unknown
129	SCE	9/20/15	19:07	34.0243510	-118.1178780	Other	Urban	Less Than 25 Acres	Unknown		1270852E- MERLE DR. SA	Phone & Cable	16kV	Transformer	Overhead	Yes	9/20/15	19:07	Equipment/Facility Failure	Transformer			Unknown	Unknown
130	SCE	9/20/15	16:31	34.0632990	-118.6479180	Other	Urban	26 - 9.99 Acres	Fire Agency	Los Angeles County Fire	Pole 1576711E		12kV	Conductor	Overhead	Yes	9/20/15	16:31	Contact From Object	Vehicle	Pole	None	Unknown	Unknown
131	SCE	9/26/15	13:48	34.0712940	-118.9335680	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Los Angeles County Fire	Pole 770574E		16kV	Conductor	Overhead	Yes	9/26/15	13:48	Contact From Object	Vegetation	Electric Facility	None	Unknown	Human Error
132	SCE	10/9/15	14:00	33.5752390	-117.1700440	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Riverside Fire Department	BEHIND ADDRESS 28151 CELIA RD / PROPERT		12kV	Other	Overhead	No			Equipment/Facility Failure	Insulator			Unknown	Unknown
133	SCE	10/9/15	11:39	33.9333110	-117.8530940	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Los Angeles County Fire	Acapulco 12kV out of Brea Sub		12kV	Conductor	Overhead	Yes	10/9/15	11:39	Contact From Object				Unknown	Other
134	SCE	10/11/15	10:02	33.9440460	-116.4750350	Other	Urban	Less Than 25 Acres	Fire Agency	Cal Fire	Cafe 12kV Line at Coffee Sub. Pole in Desert Hot S		12kV	Conductor	Overhead	Yes	10/11/15	10:02	Contact From Object	Vehicle	Pole	None	Unknown	Unknown
135	SCE	10/12/15	13:02	33.6318500	-117.3378472	Other	Urban	Less Than 25 Acres	Fire Agency	Riverside County Fire	4844065E- 18193 BRIGHTMAN AVE. LAKE ELSIN		12kV	Transformer	Overhead	Yes	10/12/15	13:02	Equipment/Facility Failure	Transformer			Unknown	Unknown
136	SCE	10/27/15	19:47	33.5350600	-117.7687930	Other	Urban	Less Than 25 Acres	Unknown		4139544E- 818 BLUEBIRD	Phone & Cable	33kV	Conductor	Overhead	Yes	10/27/15	19:47	Equipment/Facility Failure	Splice/Clamp/Connector			Unknown	Unknown
137	SCE	10/30/15	12:45	34.0538200	-117.2678850	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Loma Linda Fire Department	pole 160900	Phone & Cable	12kV	Conductor	Overhead	No			Contact From Object	Vegetation	Electric Facility	Weather	Unknown	Unknown
138	SCE	10/30/15	22:23	33.7902580	-116.9605090	Other	Urban	Less Than 25 Acres	Unknown		Pole 1084963E	Phone & Cable	12kV	Other	Overhead	Yes	10/30/15	22:23	Unknown				Unknown	Unknown
139	SCE	11/2/15	18:07	34.2969760	-118.3763390	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Los Angeles County Fire	Lopez 16kV out of San Fernando Sub		16kV	Conductor	Overhead	Yes	11/2/15	18:07	Contact From Object	Balloons	Electric Facility	None	Unknown	Unknown
140	SCE	11/7/15	2:24	34.1708020	-118.8884867	Vegetation	Urban	10 - 99 Acres	Fire Agency	Ventura County Fire	Pole No. 4505352E		16kV	Switch	Overhead	Yes	11/7/15	2:24	Unknown				Unknown	Unknown
141	SCE	11/13/15	17:04	34.2191980	-118.5282700	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Ventura County Fire	Crosson 16kV at Camarillo Sub		16kV	Conductor	Overhead	Yes	11/13/15	17:04	Contact From Object	Animal	Electric Facility	None	Unknown	Unknown
142	SCE	11/13/15	7:31	33.6384980	-117.7600710	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Orange County Fire	Santiago-Borrego 66 kV		66kV	Conductor	Overhead	Yes	11/13/15	7:31	Contact From Object	Animal	Electric Facility	None	Unknown	Unknown
143	SCE	11/18/15	6:31	34.1283510	-117.6895780	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Upland Fire Department	Padua-Layfair 66kV		66kV	Conductor	Overhead	Yes	11/18/15	6:31	Contact From Object	Other	Electric Facility	Unknown	Unknown	Unknown
144	SCE	11/20/15	20:07	34.0155350	-117.9534360	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Los Angeles County Fire	1860773E- 15930 E VALLEY BLVD. city of industry		12kV	Conductor	Overhead	Yes	11/20/15	20:07	Unknown				Unknown	Unknown
145	SCE	11/20/15	20:07	34.0155350	-117.9534360	Other	Urban	Less Than 25 Acres	Fire Agency	Los Angeles County Fire	Graziade 12kV out of Walnut Sub		12kV	Conductor	Overhead	Yes	11/20/15	20:07	Contact From Object	Animal	Electric Facility	None	Unknown	Unknown
146	SCE	11/24/15	1:17	33.7443170	-118.4070210	Other	Urban	Less Than 25 Acres	Fire Agency	Los Angeles County Fire	Ambersky 16kV at Marymount Sub. Pole in Rancho Palos Verdes		16kV	Conductor	Overhead	Yes	11/24/15	1:17	Equipment/Facility Failure	Conductor			Unknown	Unknown
147	SCE	12/8/15	19:08	34.2188030	-119.2492490	Vegetation	Rural	Less Than 25 Acres	Customer		Pole 1748635E	Phone & Cable	16kV	Transformer	Overhead	No			Equipment/Facility Failure	Contamination			Unknown	Unknown
148	SCE	12/11/15	12:21	34.0380730	-118.7701600	Other	Urban	26 - 9.99 Acres	Fire Agency	Los Angeles County Fire	Cuthbert 12kV at Latigo Sub. Near Latigo Canyon		12kV	Conductor	Overhead	Yes	12/11/15	12:21	Wire-Wire Contact				Unknown	Unknown
149	SCE	1/1/16	10:13	34.0007670	-118.0812670	Vegetation	Urban	Less Than 25 Acres	Fire Agency	LACFD	OH-4615530E	FRONTIER COMMUNI	12 kV	Conductor	Overhead	Yes	1/1/16	10:13	Contact From Object	Balloons	Electric Facility	None	Unknown	Unknown
150	SCE	1/1/16	20:51	34.0232720	-118.0528980	Other	Urban	Less Than 25 Acres	Fire Agency	LACFD	9600 block of East Garvey Ave. El Monte		4 kV	Conductor	Overhead	Yes	1/1/16	20:51	Equipment/Facility Failure	Pole			Unknown	Unknown
151	SCE	1/16/16	15:20	34.4095710	-118.6815700	Vegetation	Rural	Less Than 25 Acres	Fire Agency	LACFD	OH-848100E	FRONTIER COMMUNI	16 kV	Conductor	Overhead	Yes	1/16/16	15:20	Contact From Object	Other			Unknown	Unknown
152	SCE	1/28/16	22:07	33.9642210	-118.1488130	Vegetation	Urban	Less Than 25 Acres	Fire Agency	LACFD	OH-820509E	FRONTIER COMMUNI	16 kV	Conductor	Overhead	Yes	1/28/16	22:07	Contact From Object	Balloons	Electric Facility	None	Unknown	Unknown
153	SCE	2/3/16	17:46	34.7182510	-118.3025180	Vegetation	Rural	Less Than 25 Acres	Fire Agency	LACFD	OH-1355070E	FRONTIER COMMUNI	120/240 V	Conductor	Overhead	No			Unknown				Unknown	Unknown
154	SCE	2/7/16	9:31	34.1370600	-117.5141240	Vegetation	Rural	Less Than 25 Acres	Fire Agency	SBCFD	OH-4275464E	FRONTIER COMMUNI	12 kV	Conductor	Overhead	Yes	2/7/16	9:31	Equipment/Facility Failure	Conductor			Unknown	Unknown
155	SCE	2/8/16	8:22	34.1065070	-117.4402780	Vegetation	Urban	Less Than 25 Acres	Fire Agency	SBCFD	OH-1420896E	AT&T WIRELESS SER	12 kV	Conductor	Overhead	Yes	2/8/16	8:22	Equipment/Facility Failure	Conductor			Unknown	Unknown
156	SCE	2/9/16	19:13	33.7790240	-118.1401670	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Long Beach Fire Department	OH-2381948E	FRONTIER COMMUNI	12 kV	Other	Overhead	Yes	2/9/16	19:13	Equipment/Facility Failure	Other			Unknown	Unknown
157	SCE	2/10/16	18:56	34.2186560	-119.2539580	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Ventura County FD	OH-4423101E		16 kV	Other	Overhead	Yes	2/10/16	18:56	Equipment/Facility Failure	Other			Unknown	Unknown
158	SCE	2/12/16	20:02	33.9680310	-118.0717540	Vegetation	Urban	Less Than 25 Acres	Fire Agency	LACFD	OH-845479E	FRONTIER COMMUNI	12 kV	Conductor	Overhead	Yes	2/12/16	20:02	Contact From Object	Vegetation	Electric Facility	Unknown	Unknown	Unknown
159	SCE	2/16/16	15:18	34.2056930	-118.4323950	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Ventura County FD	OH-4544669E	FRONTIER COMMUNI	16 kV	Conductor	Overhead	No			Contact From Object	Vegetation	Electric Facility	Unknown	Unknown	Unknown
160	SCE	2/22/16	17:04	34.4491680	-119.5844980	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Montecito Fire Department	OH-1082380E	FRONTIER COMMUNI	16 kV	Conductor	Overhead	Yes	2/22/16	17:04	Equipment/Facility Failure	Conductor			Unknown	Unknown
161	SCE	2/24/16	15:06	34.9470000	-118.1417210	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Kern County Fire Department	OH-706814E	AT&T CALIFORNIA	16 kV	Conductor	Overhead	Yes	11/13/15	7:04	Contact From Object	Animal	Electric Facility	Unknown	Unknown	Unknown
162	SCE	2/27/16	0:49	33.9134180	-118.8003250	Other	Rural	Less Than 25 Acres	Fire Agency	Cal Fire	OH-1989045E		12 kV	Conductor	Overhead	Yes	2/27/16	0:49	Contact From Object	Vehicle	Pole	Unknown	Unknown	Unknown
163	SCE	3/11/16	7:53	33.9059430	-117.9237840	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Fullerton Fire Department	OH-740325H	TIME WARNER CABL	12 kV	Conductor	Overhead	Yes	3/11/16	7:53	Contact From Object	Vegetation	Electric Facility	Unknown	Unknown	Unknown
164	SCE	3/17/16	14:53	34.0059170	-117.9663880	Vegetation	Urban	Less Than 25 Acres	Fire Agency	LACFD	OH-1892254E	TIME WARNER CABL	12 kV	Conductor	Overhead	Yes	3/17/16	14:53	Contact From Object	Vehicle	Pole	Unknown	Unknown	Unknown
165	SCE	3/23/16	11:45	34.1369140	-117.5061030	Vegetation	Urban																	

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X
2	Utility Name	Fire Start	Location Info	Fire Specifics	Utility Facility	Outage Info	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes												
3	Column1	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date2	Time3						
229	SCE	10/22/16	15:17	34.3812290	-118.4131810	Other	Rural	Less Than 25 Acres	Fire Agency	LACFD	RAR 0038		16kV	Conductor	Overhead	Yes	10/22/16	15:17	Contact From Object					
230	SCE	10/23/16	9:40	34.4602810	-119.2852650	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Ventura County FD	900 Rice Road Ojai		120/240V	Conductor	Overhead	No			Equipment/Facility Failure	Conductor				
231	SCE	10/26/16	12:19	34.7081290	-118.5367490	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	LACFD	ELIZABETH LAKE ROAD AND KINGS CANYON R		12kV	Conductor	Overhead	Yes	10/26/16	12:19	Contact From Object					
232	SCE	10/28/16	10:13	34.1020580	-117.8206030	Other	Urban	Less Than 25 Acres	Fire Agency	LACFD	OH-1180540E		120/240V	Conductor	Overhead	Yes	10/28/16	10:13	Equipment/Facility Failure	Conductor				
233	SCE	10/29/16	18:42	34.2149030	-119.1889710	Other	Urban	Less Than 25 Acres	Self Extinguished		340 Huntswood Way, Oxnard		16kV	Conductor	Overhead	No			Equipment/Facility Failure	Other				
234	SCE	11/3/16	22:37	33.7300240	-117.9839590	Other	Urban	Less Than 25 Acres	Fire Agency	Huntington Fire Department	OH-1787899E		12kV	Conductor	Overhead	Yes	11/3/16	22:37	Contact From Object					
235	SCE	11/11/16	4:18	33.6309420	-117.9348070	Other	Urban	Structure Only	Fire Agency	Newport Fire Department	864 Production Pl. Newport Beach		12kV	Conductor	Overhead	Yes	11/16/16	4:18	Equipment/Facility Failure	Conductor				
236	SCE	11/16/16	13:45	33.9168380	-118.0039950	Vegetation	Urban	Less Than 25 Acres	Fire Agency	LACFD	OH-1914521E		13kV	Conductor	Overhead	Yes	11/16/16	13:45	Equipment/Facility Failure	Conductor				
237	SCE	11/20/16	11:15	34.1883400	-118.8742520	Vegetation	Rural	Less Than 25 Acres	Self Extinguished		OH-1473501E		16kV	Conductor	Overhead	No			Contact From Object					
238	SCE	11/22/16	15:20	36.3134220	-119.1710520	Vegetation	Rural	Less Than 25 Acres	Unknown		1970 North Anderson Road, Exeter		12kV	Conductor	Overhead	Yes	11/22/16	15:20	Contact From Object					
239	SCE	12/1/16	8:54	33.8919790	-117.7031110	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Orange County Fire Authority	OH-2257796E		12kV	Conductor	Overhead	No			Contact From Object					
240	SCE	12/2/16	21:26	34.3812290	-118.4131810	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Orange County Fire Authority	OH-457270E		66kV	Conductor	Overhead	No			Contact From Object					
241	SCE	12/16/16	19:31	33.8120810	-118.0238250	Building	Urban	Structure Only	Fire Agency	Orange County Fire Authority	10332 Florence Ave., Buena Park		120/240V	Conductor	Overhead	Yes	12/16/16	19:31	Equipment/Facility Failure	Conductor				
242	SCE	12/19/16	8:18	34.0231980	-117.8529840	Vegetation	Urban	Less Than 25 Acres	Unknown		UG-504396E		12kV	Conductor	Subsurface	Yes	12/19/16	8:18	Equipment/Facility Failure	Other				
243	SCE	12/26/16	8:02	34.1675510	-116.1070320	Vegetation	Rural	Less Than 25 Acres	Utility		OH-4803462E		33kV	Conductor	Overhead	Yes	12/26/16	8:02	Contact From Object					
244	SCE	12/30/16	11:42	34.1231260	-118.7229630	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	LACFD	OH-1927507E	AT&T CALIFORNIA	16kV	Conductor	Overhead	Yes	12/30/16	11:42	Contact From Object					
245	SCE	1/13/17	11:05	33.7610280	-116.6947830	Vegetation	Rural	Less Than 25 Acres	Unknown		OH-2206325E	FRONTIER COMMUNI	12kV	Conductor	Overhead	Yes	1/13/17	11:05	Contact From Object					
246	SCE	1/14/17	1:21	34.2655510	-118.9650270	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Ventura County FD	OH-802859E	FRONTIER COMMUNI	16kV	Conductor	Overhead	Yes	1/14/17	1:21	Contact From Object					
247	SCE	1/28/17	18:15	33.9903080	-118.3702570	Vegetation	Urban	Less Than 25 Acres	Self Extinguished		OH-25037878E		120/240V	Conductor	Overhead	Yes	1/28/17	18:15	Equipment/Facility Failure	Conductor				
248	SCE	1/31/17	2:10	33.9903080	-118.3702570	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Hesperia FD	PS 822		115kV	Conductor	Overhead	No			Equipment/Facility Failure	Other				
249	SCE	2/8/17	2:20	33.8897030	-117.8527880	Other	Urban	Less Than 25 Acres	Fire Agency	Orange County Fire Authority	OH-1838346E	XO COMMUNICATION	66kV	Conductor	Overhead	Yes	2/8/17	2:20	Unknown					
250	SCE	3/10/17	15:46	33.7871030	-117.9122940	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Garden Grove FD	OH-2095520E		12kV	Conductor	Overhead	Yes	3/10/17	15:46	Contact From Object					
251	SCE	3/11/17	17:22	34.1284770	-117.2622540	Vegetation	Rural	Less Than 25 Acres	Self Extinguished		OH-4067378E	FRONTIER COMMUNI	12kV	Lightning Arrestor	Overhead	Yes	3/11/17	17:22	Equipment/Facility Failure	Lightning Arrestor				
252	SCE	3/13/17	13:42	33.9536060	-118.0656250	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Santa Fe Springs Fire Department	OH-4209839E		12kV	Conductor	Overhead	Yes	3/13/17	13:42	Contact From Object					
253	SCE	3/15/17	13:23	34.0534485	-116.9710052	Vegetation	Rural	Less Than 25 Acres	Fire Agency	CalFire	OH-2326555E	FRONTIER COMMUNI	12kV	Conductor	Overhead	Yes	3/15/17	13:23	Contact From Object					
254	SCE	3/17/17	17:14	34.5759060	-118.2629170	Vegetation	Rural	Less Than 25 Acres	Fire Agency	LACFD	OH-4493863E		12kV	Conductor	Overhead	Yes	3/17/17	17:14	Contact From Object					
255	SCE	3/30/17	14:37	34.890382	-117.0150329	Vegetation	Rural	Structure Only	Fire Agency	Barstow FD	OH-328443S		12kV	Conductor	Overhead	Yes	3/30/17	14:37	Equipment/Facility Failure	Pole			Weather	
256	SCE	4/3/17	1:51	33.9903080	-118.3702570	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Ontario Fire Department	PS 493		12kV	Conductor	Overhead	Yes	4/3/17	1:51	Contact From Object					
257	SCE	4/16/17	15:39	34.4556008	-119.2571855	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Ventura County FD	OH-4495331E	AT&T CALIFORNIA	16kV	Conductor	Overhead	Yes	4/16/17	15:39	Contact From Object					
258	SCE	4/22/17	11:23	35.8628425	-119.2525648	Vegetation	Rural	Structure Only	Self Extinguished		OH-1501428E		12kV	Conductor	Overhead	Yes	4/22/17	11:23	Unknown					
259	SCE	4/23/17	16:24	34.5961900	-118.2428980	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Palmdale Fire Department	OH-4336106E	AT&T CALIFORNIA	12kV	Conductor	Overhead	Yes	4/23/17	16:24	Unknown					
260	SCE	4/28/17	23:15	33.9903080	-118.3702570	Vegetation	Rural	Less Than 25 Acres	Unknown		PS533		16kV	Conductor	Overhead	Yes	4/28/17	23:15	Contact From Object					
261	SCE	4/28/17	10:59	33.9286440	-116.6421190	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Riverside Fire Department	OH-1905185E		4kV	Conductor	Overhead	Yes	4/28/17	10:59	Unknown					
262	SCE	4/28/17	10:37	36.4356275	-119.1907857	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Tulare Fire Department	OH-4600865E	AT&T CALIFORNIA	12kV	Conductor	Overhead	Yes	4/28/17	10:37	Contact From Object					
263	SCE	4/29/17	16:08	33.8983710	-117.2207070	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Riverside Fire Department	OH-312923S	FRONTIER COMMUNI	12kV	Conductor	Overhead	Yes	4/29/17	16:08	Equipment/Facility Failure	Conductor				
264	SCE	4/29/17	3:17	34.1268230	-118.0734630	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Monrovia Fire Department	OH-695124H	AT&T CALIFORNIA	16kV	Conductor	Overhead	Yes	4/29/17	3:53	Equipment/Facility Failure	Conductor				
265	SCE	5/1/17	20:04	34.1571170	-118.0444480	Vegetation	Rural	Less Than 25 Acres	Fire Agency	LACFD	OH-5X5095E	NEXTG NETWORKS	16kV	Conductor	Overhead	Yes	5/1/17	20:04	Contact From Object					
266	SCE	5/1/17	5:40	38.0200760	-119.1607800	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CalFire	OH-158064E		55kV	Conductor	Overhead	No			Contaminated					
267	SCE	5/3/17	7:01	33.8718439	-118.2682003	Vegetation	Urban	Less Than 25 Acres	Fire Agency	LACFD	OH-3500025E		16kV	Conductor	Overhead	Yes	5/3/17	7:01	Contact From Object					
268	SCE	5/3/17	5:40	34.2644820	-118.7690480	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Ventura County FD	OH-1840416E		16kV	Conductor	Overhead	Yes	5/3/17	5:40	Contact From Object					
269	SCE	5/11/17	12:27	34.4127010	-118.6702310	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	LACFD	OH-848256E		16kV	Conductor	Overhead	Yes	5/11/17	12:27	Contact From Object					
270	SCE	5/14/17	11:15	33.6416147	-117.1676704	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Riverside Fire Department	OH-2283870E		115kV	Conductor	Overhead	Yes	5/14/17	11:15	Contact From Object					
271	SCE	5/15/17	13:54	35.427678	-118.8050080	Vegetation	Rural	100 - 299 Acres	Fire Agency	CalFire	OH-1789272E		166kV	Conductor	Overhead	No			Contact From Object					
272	SCE	5/19/17	17:57	33.8693010	-117.8315319	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Placentia Fire Department	OH-1789272E	VERIZON WIRELESS	12kV	Conductor	Overhead	Yes	5/19/17	17:57	Contact From Object					
273	SCE	5/19/17	15:51	33.6443658	-117.8573583	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Newport Fire Department	OH-4248432E		12kV	Conductor	Overhead	Yes	5/19/17	15:51	Contact From Object					
274	SCE	5/20/17	17:28	33.7067865	-117.1388210	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Riverside Fire Department	OH-4768465E		12kV	Conductor	Overhead	Yes	5/20/17	17:28	Contact From Object					
275	SCE	5/20/17	15:24	33.7816957	-117.9083331	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Garden Grove FD	OH-1435576E	AT&T CALIFORNIA	12kV	Conductor	Overhead	Yes	5/20/17	15:24	Contact From Object					
276	SCE	5/20/17	9:43	34.0425507	-118.6431934	Vegetation	Urban	Less Than 25 Acres	Self Extinguished		OH-783599E	FRONTIER COMMUNI	16kV	Conductor	Overhead	Yes	5/20/17	9:43	Equipment/Facility Failure	Other				
277	SCE	5/22/17	11:27	34.5100480	-117.2909710	Vegetation	Rural	Less Than 25 Acres	Fire Agency	San Bernardino FD	OH-1966164E		12kV	Conductor	Overhead	Yes	5/22/17	11:27	Contact From Object					
278	SCE	5/23/17	12:07	34.4203573	-117.1746778	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Apple Valley FD	OH-4832950E		12kV	Conductor	Overhead	Yes	5/23/17	12:07	Unknown					
279	SCE	5/24/17	10:05	34.4231795	-117.1775193	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CalFire	OH-2300688E	FRONTIER COMMUNI	120/240V	Conductor	Overhead	Yes	5/24/17	10:05	Equipment/Facility Failure					



1	2	A			B			C			D			E			F			G			H			I			J			K			L			M			N			O			P			Q			R			S			T			U			V			W			X		
		Utility Name	Fire Start	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Equipment Involved With Ignition	Type	Was There an Outage	Date2	Time3	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes																																																		
459	SCE	1/23/19	18:57	34.2768400	-118.7847260	Vegetation	Urban	Less Than 25 Acres	Utility		OH-1831781E	NA	16kV	Other	Overhead	Yes	1/23/19	18:57	Contact From Object		Other	Electric Facility	Other																																																		
460	SCE	2/8/19	18:11	34.2793220	-118.7787340	Vegetation	Urban	Less Than 25 Acres	Unknown		OH-1542322E	AT&T Communications	12kV	Transformer	Overhead	Yes	2/8/19	18:11	Contact From Object		Animal	Electric Facility	Outside Force																																																		
461	SCE	3/3/19	14:25	33.8666430	-116.5520750	Vegetation	Urban	Less Than 25 Acres	Unknown		OH-4493741E	NA	12kV	Conductor	Overhead	Yes	3/3/19	14:25	Equipment/Facility Failure	Conductor		Unknown																																																			
462	SCE	3/16/19	17:58	33.8182440	-117.8024740	Vegetation	Rural	26 - 9.99 Acres	Unknown		OH-1729510E	NA	12kV	Conductor	Overhead	Yes	3/16/19	17:58	Equipment/Facility Failure	Crossarm		Unknown																																																			
463	SCE	3/25/19	10:31	33.9906380	-117.8814570	Building	Urban	Less Than 25 Acres	Unknown		OH-4668167E	FRONTIER COMMUNI	12kV	Conductor	Overhead	Yes	3/25/19	10:31	Contact From Object		Balloons	Electric Facility	Unknown																																																		
464	SCE	3/27/19	14:39	34.0823170	-117.9132300	Other	Urban	Less Than 25 Acres	Unknown		OH-1165772E	FRONTIER COMMUNI	12kV	Conductor	Overhead	No			Contact From Object		Balloons	Electric Facility	Unknown																																																		
465	SCE	3/30/19	19:30	34.2243670	-119.1403310	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Ventura County Fire Department	OH-4551685E	NA	66kV	Conductor	Overhead	Yes	11/1/19	11:58	Equipment/Facility Failure		Splice/Clamp/Connector	Electric Facility	Unknown																																																		
466	SCE	4/8/19	15:30	34.0794620	-118.1515570	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Alhambra Fire Department	OH-4038025E	NA	16kV	Conductor	Overhead	Yes	4/8/19	15:30	Contact From Object		Animal	Electric Facility	Outside Force																																																		
467	SCE	4/9/19	4:53	34.2770183	-119.3047240	Vegetation	Urban	Less Than 25 Acres	Utility		OH-4754671E	AT&T Communications	16kV	Capacitor Bank	Overhead	No			Equipment/Facility Failure		Capacitor Bank	Electric Facility	Weather																																																		
468	SCE	4/9/19	13:57	33.8556150	-116.5576770	Other	Urban	Less Than 25 Acres	Unknown		OH-4854654E	NA	12kV	Conductor	Overhead	Yes	4/9/19	13:57	Wire-Wire Contact			Electric Facility	Weather																																																		
469	SCE	4/14/19	13:40	34.0173670	-117.9171380	Vegetation	Rural	Less Than 25 Acres	Unknown		OH-1034259E	NA	12kV	Conductor	Overhead	Yes	4/14/19	13:40	Contact From Object		Balloons	Electric Facility	Other																																																		
470	SCE	4/15/19	7:28	34.3040230	-119.9417270	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Ventura County Fire Department	UG-5563403	NA	16kV	Other	Padmount	Yes	4/15/19	7:28	Contact From Object		Animal	Electric Facility	Outside Force																																																		
471	SCE	4/19/19	14:05	34.5113190	-117.3125590	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Victorville Fire Department	OH-4615681E	FRONTIER COMMUNI	12kV	Conductor	Overhead	No			Contact From Object		Vegetation	Electric Facility	Outside Force																																																		
472	SCE	4/21/19	12:08	36.3061660	-119.6729960	Vegetation	Rural	Less Than 25 Acres	Unknown		OH-1643672E	AT&T Communications	12kV	Conductor	Overhead	Yes	4/21/19	12:08	Equipment/Facility Failure	Conductor		Electric Facility	Outside Force																																																		
473	SCE	4/22/19	1:56	34.2027540	-118.8507500	Vegetation	Urban	Less Than 25 Acres	Unknown		OH-1188370E	FRONTIER COMMUNI	16kV	Switch	Overhead	Yes	4/22/19	1:56	Contact From Object		Vegetation	Electric Facility	Outside Force																																																		
474	SCE	4/22/19	17:03	34.4143230	-117.2215190	Other	Rural	Less Than 25 Acres	Fire Agency	Apple Valley Fire Department	OH-2155251E	NA	12kV	Transformer	Overhead	Yes	4/23/19	17:03	Contact From Object		Animal	Electric Facility	Outside Force																																																		
475	SCE	4/23/19	21:06	34.2146700	-117.0973150	Vegetation	Rural	Less Than 25 Acres	Unknown		OH-1027559E	FRONTIER COMMUNI	12kV	Conductor	Overhead	No			Contact From Object		Unknown	Electric Facility	Unknown																																																		
476	SCE	4/23/19	8:08	33.8347710	-118.0544060	Building	Urban	Less Than 25 Acres	Unknown		OH-1802525E	FRONTIER COMMUNI	12kV	Conductor	Overhead	No			Contact From Object		Vehicle	Electric Facility	Human Error																																																		
477	SCE	4/24/19	9:06	34.6747633	-118.2543875	Vegetation	Rural	Less Than 25 Acres	Unknown		OH-4755152E	NA	16kV	Switch	Overhead	Yes	4/24/19	9:06	Contact From Object		Animal	Electric Facility	Outside Force																																																		
478	SCE	4/24/19	12:07	34.1360480	-116.1815450	Vegetation	Rural	Less Than 25 Acres	Unknown		OH-1692954E	NA	25kV	Conductor	Overhead	Yes	4/24/19	12:07	Wire-Wire Contact			Electric Facility	Other																																																		
479	SCE	5/21/19	21:16	34.4156150	-118.7819640	Vegetation	Urban	26 - 9.99 Acres	Unknown		OH-4510190E	NA	16kV	Conductor	Overhead	Yes	5/21/19	21:16	Contact From Object		Balloons	Electric Facility	Outside Force																																																		
480	SCE	5/4/19	17:14	33.8403580	-117.5209420	Building	Urban	Less Than 25 Acres	Self Extinguished		OH-728825	NA	16kV	Other	Overhead	Yes	5/4/19	17:14	Contact From Object		Animal	Electric Facility	Outside Force																																																		
481	SCE	5/10/19	7:31	34.7328350	-118.1841550	Vegetation	Rural	Less Than 25 Acres	Unknown		OH-4487590E	NA	12kV	Switch	Overhead	Yes	5/10/19	7:31	Contact From Object		Animal	Electric Facility	Outside Force																																																		
482	SCE	5/14/19	18:26	33.5911870	-114.6748840	Other	Rural	Less Than 25 Acres	Fire Agency	Blythe Fire Department	OH-4800765E	NA	33kV	Transformer	Overhead	Yes	5/14/19	18:26	Contamination	Transformer		Electric Facility	Unknown																																																		
483	SCE	5/21/19	14:48	33.8559700	-116.5566290	Vegetation	Urban	Less Than 25 Acres	Utility		OH-3354225E	FRONTIER COMMUNI	12kV	Conductor	Overhead	Yes	5/21/19	14:48	Wire-Wire Contact			Electric Facility	Unknown																																																		
484	SCE	5/26/19	16:05	34.5326640	-117.3005040	Other	Rural	Less Than 25 Acres	Unknown		OH-4279765E	FRONTIER COMMUNI	12kV	Conductor	Overhead	Yes	5/26/19	14:27	Wire-Wire Contact			Electric Facility	Weather																																																		
485	SCE	6/1/19	11:30	34.5198150	-118.2147730	Vegetation	Rural	Less Than 25 Acres	Self Extinguished		OH-692807E	AT&T Communications	12kV	Conductor	Overhead	No			Equipment/Facility Failure	Conductor	Animal	Electric Facility	Human Error																																																		
486	SCE	6/21/19	14:13	34.5363693	-117.6846770	Vegetation	Rural	Less Than 25 Acres	Unknown		OH-6933081E	NA	12kV	Fuse	Overhead	No			Contact From Object		Transformer	Electric Facility	Human Error																																																		
487	SCE	6/21/19	18:43	34.0709790	-117.4860040	Building	Urban	Less Than 25 Acres	Fire Agency	Fontana Fire Department	OH-872188E	AT&T Communications	12kV	Conductor	Overhead	Yes	6/21/19	18:43	Contact From Object		Animal	Electric Facility	Outside Force																																																		
488	SCE	6/5/19	10:34	35.9136630	-119.2059640	Vegetation	Rural	Less Than 25 Acres	Unknown		OH-1441940E	NA	12kV	Transformer	Overhead	Yes	6/5/19	10:04	Contact From Object		Vehicle	Electric Facility	Outside Force																																																		
489	SCE	6/6/19	9:00	34.4733550	-118.3921240	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Valencia Fire Department	OH-4419830E	NA	16kV	Conductor	Overhead	Yes	6/6/19	9:10	Equipment/Facility Failure	Conductor		Electric Facility	Human Error																																																		
490	SCE	6/6/19	13:52	36.4167860	-118.9102420	Vegetation	Rural	Less Than 25 Acres	Unknown		OH-1382763E	AT&T Communications	12kV	Conductor	Overhead	No			Contact From Object		Vehicle	Electric Facility	Outside Force																																																		
491	SCE	6/7/19	7:54	36.0550210	-118.9491070	Other	Rural	Less Than 25 Acres	Fire Agency	Porterville Fire Department	OH-4099154E	AT&T Communications	12kV	Conductor	Overhead	Yes	6/7/19	7:54	Contact From Object		Vehicle	Electric Facility	Outside Force																																																		
492	SCE	6/10/19	15:43	34.4684090	-117.4435520	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Victorville Fire Department	OH-4185203E	FRONTIER COMMUNI	12kV	Conductor	Overhead	Yes	6/10/19	15:43	Contact From Object		Other	Electric Facility	Outside Force																																																		
493	SCE	6/11/19	16:31	34.0550590	-117.8815050	Vegetation	Urban	Less Than 25 Acres	Fire Agency	West Covina Fire Department	OH-1528040E	FRONTIER COMMUNI	12kV	Conductor	Overhead	Yes	6/11/19	16:20	Other			Electric Facility	Human Error																																																		
494	SCE	6/11/19	17:03	33.8240130	-117.2974470	Vegetation	Rural	Less Than 25 Acres	Utility		UG-5608461	NA	12kV	Conductor	Padmount	No			Contact From Object		Vegetation	Electric Facility	Human Error																																																		
495	SCE	6/13/19	7:05	33.8123755	-118.1784180	Other	Urban	Less Than 25 Acres	Unknown		OH-1621549E	NA	12kV	Conductor	Overhead	Yes	6/13/19	9:37	Wire-Wire Contact			Electric Facility	Outside Force																																																		
496	SCE	6/17/19	11:48	34.6818180	-118.4247590	Other	Urban	Less Than 25 Acres	Fire Agency	Tulare Fire Department	OH-1254275E	AT&T Communications	12kV	Conductor	Overhead	Yes	6/17/19	11:48	Contact From Object		Vehicle	Communication Facility	Outside Force																																																		
497	SCE	6/18/19	15:04	34.0464018	-117.6763894	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Ontario Fire Department	OH-2194146E	NA	12kV	Switch	Overhead	Yes	6/18/19	15:04	Equipment/Facility Failure	Switch		Electric Facility	Outside Force																																																		
498	SCE	6/20/19	6:18	34.1140480	-117.2340520	Vegetation	Urban	Less Than 25 Acres	Fire Agency	CAL Fire	OH-622103E	AT&T Communications	12kV	Conductor	Overhead	Yes	6/20/19	6:18	Equipment/Facility Failure	Insulator		Electric Facility	Outside Force																																																		
499	SCE	6/20/19	14:08	34.2298460	-117.4048020	Vegetation	Rural	Less Than 25 Acres	Fire Agency	San Bern. Fire Department	OH-2013715E	FRONTIER COMMUNI	12kV	Conductor	Overhead	No			Contact From Object		Vegetation	Electric Facility	Human Error																																																		
500	SCE	6/23/19	14:38	33.6416340	-117.2420260	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Local Fire Department	OH-4561512E	NA	12kV	Conductor	Overhead	Yes	6/23/19	14:38	Contact From Object		Balloons	Electric Facility	Outside Force																																																		
501	SCE	6/25/19	14:31	34.2903060	-118.2884600	Vegetation	Rural	Less Than 25 Acres	Unknown		OH-3134E	LADWP	16kV	Conductor	Overhead	Yes	6/25/19	14:31	Wire-Wire Contact			Electric Facility	Weather																																																		
502	SCE	6/27/19	9:07	36.0329840	-119.0972800	Vegetation	Rural	Less Than 25 Acres	Self Extinguished		OH-4351620E	NA	12kV	Conductor	Overhead	Yes	6/27/19	9:07	Contact From Object		Animal	Electric Facility	Outside Force																																																		
503	SCE	6/27/19	12:18	34.8928460	-116.9787500	Vegetation	Rural	Less Than 25 Acres	Unknown		OH-1793713E	FRONTIER COMMUNI	12kV	Conductor	Overhead	Yes	6/27/19	12:18	Contact From Object		Balloons	Electric Facility	Outside Force																																																		
504	SCE	7/4/19	1:09	36.0633400	-119.1469060	Vegetation	Rural	Less Than 25 Acres	Unknown		OH-820741E	AT&T Communications	12kV	Conductor	Overhead	Yes	7/8/19	12:47	Equipment/Facility Failure	Conductor		Electric Facility	Human Error																																																		
505	SCE	7/8/19	12:47	34.5226230	-117.4360290	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	San Bern. Fire Department	OH-2043007E	FRONTIER COMMUNI	12kV	Conductor	Overhead	Yes	7/8/19	12:47	Contact From Object		Vehicle	Electric Facility	Outside Force																																																		
506	SCE	7/7/19	6:28	36.0991133	-119.4290390	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Local Fire Department	OH-474611E	NA	12kV	Conductor	Overhead	Yes	7/7/19	6:28	Equipment/Facility Failure			Electric Facility	Outside Force																																																		
507	SCE	7/7/19	8:39	34.1468990	-117.8899720	Other	Urban	Less Than 25 Acres	Fire Agency	LA County Fire Department	OH-4110272E	FRONTIER COMMUNI	12kV	Conductor	Overhead	Yes	7/7/19	8:09	Contact From Object		Animal	Electric Facility	Other																																																		
508	SCE	7/15/19	22:43	34.1087230	-118.0169070	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Local Fire Department	OH-4437103E	NA	16kV	Conductor	Overhead	Yes	7/15/19	22:43	Equipment/Facility Failure		Fuse	Electric Facility																																																			

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X
2	Utility Name	Fire Start		Location Info			Fire Specifics			Utility Facility			Outage Info			Field Observations								
3	Column1	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date2	Time3	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes
575	SCE	7/27/19	12:02	34.493200	-117.573065	Other	Rural	Less Than 25 Acres	Unknown		OH-2122305E	NA	12kV	Conductor	Overhead	No			Vandalism/Theft			Electric Facility	Unknown	
576	SCE	9/7/19	17:36	33.766729	-117.22938	Other	Rural	Less Than 25 Acres	Fire Agency	Riverside County Fire Department	OH-4112261E	NA	12kV	Conductor	Overhead	No			Other				Unknown	
577	SCE	9/24/19	14:50	34.157427	-117.344169	Vegetation	Urban	Less Than 25 Acres	Fire Agency	San Bern. Fire Department	OH-4809453E	NA	4kV	Conductor	Overhead	Yes	9/24/19	14:50	Contact From Object		Vegetation	Electric Facility	Unknown	
578	SCE	10/8/19	8:22	34.137645	-118.028901	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Arcadia Fire Department	OH-4757377E	AT&T Communications	16kV	Conductor	Overhead	Yes	10/8/19	8:22	Contact From Object		Vegetation	Electric Facility	Unknown	
579	SCE	11/24/19	11:40	33.7412000	-117.1549000	Other	Urban	Less Than 25 Acres	Fire Agency	CAL Fire	M15-T2	NA	33kV	Conductor	Overhead	No			Equipment/Facility Failure	Insulator			Unknown	
580	SCE	11/29/19	13:02	34.443255	-119.78964	Other	Urban	Less Than 25 Acres	Unknown		OH-1453784E	Crown Castle	16kV	Conductor	Overhead	No			Contact From Object		Balloons	Electric Facility	Unknown	
581	SCE	8/13/19	12:00	36.083424	-119.023454	Building	Rural	Less Than 25 Acres	Unknown		OH-1687439E	Charter Communicatio	12kV	Meter	Overhead	No			Vandalism/Theft			Electric Facility	Human Error	
582	SCE	6/19/19	16:54	34.0078000	-117.9515000	Other	Urban	Less Than 25 Acres	Unknown		N/A	NA	66kV	Conductor	Overhead	No			Contact From Object		Balloons	Electric Facility	Other	