

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X
1	Utility Name	Fire Start	Latitude	Longitude	Location Info	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Utility Facility	Equipment Involved With Ignition	Type	Was There an Outage	Date2	Time3	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes
2	SDG&E	1/1/14 18:45	33.1179000	-117.0780000	Vegetation	Urban	Less Than 25 Acres	Customer		P11112		12kV	Other	Overhead	Yes	1/1/14	18:45	Equipment/Facility Failure	Splice/Clamp/Connector			Other	
3	SDG&E	3/5/14 9:49	33.2038000	-117.1142000	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	P515262		12kV	Conductor	Overhead	Yes	3/12/14	9:49	Equipment/Facility Failure	Splice/Clamp/Connector			Other	
4	SDG&E	4/15/14 8:20	32.6778000	-117.0460000	Vegetation	Urban	Less Than 25 Acres	Fire Agency	S.D.F.D.	Z180434		12kV	Conductor	Overhead	No			Equipment/Facility Failure	Guy/Span Wire			None	
5	SDG&E	4/17/14 16:42	33.2203000	-117.3380000	Vegetation	Urban	Less Than 25 Acres	Fire Agency	OFD	TL23010		230kV	Conductor	Overhead	No			Equipment/Facility Failure		Vehicle	Electric Facility	Human Error	
6	SDG&E	4/27/14 12:00	32.2415000	-117.3470000	Vegetation	Rural	Less Than 25 Acres	Utility		TL 6912, Z122445	none	69kV	Other	Overhead	No			Equipment/Facility Failure				None	
7	SDG&E	4/28/14 13:30	33.2926	-116.948	Vegetation	Rural	Less Than 25 Acres	Fire Agency	CALFIRE	Circuit 214, P215546	none	12kV	Conductor	Overhead	Yes	4/28/2014	13:30	Equipment/Facility Failure	Splice/Clamp/Connector			None	
8	SDG&E	4/28/14 16:20	33.2887000	-116.9560000	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Cal Fire	P812595		12kV	Conductor	Overhead	Yes	4/28/14	16:20	Contact From Object		Vehicle	Pole	Human Error	
9	SDG&E	4/29/14 10:05	33.3181000	-117.2200000	Vegetation	Rural	Less Than 25 Acres	Fire Agency	CALFIRE	Circuit 233, P213051	none	12kV	Conductor	Overhead	Yes	4/29/14	10:05	Contact From Object		Vehicle	Electric Facility	Outside Force	
10	SDG&E	4/29/14 13:40	33.1264000	-117.0160000	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Escondido FD	Circuit 455, P316707	none	12kV	Conductor	Overhead	Yes	4/29/14	13:40	Contact From Object		Vehicle	Pole	Outside Force	
11	SDG&E	4/29/14 16:49	32.7186000	-117.0960000	Vegetation	Urban	Less Than 25 Acres	Fire Agency	SD Fire-Rescue	Circuit 323, P476600	none	12kV	Conductor	Overhead	Yes	4/29/14	16:49	Contact From Object		Vegetation	Electric Facility	Weather	
12	SDG&E	5/1/14 6:48	32.8640000	-116.8990000	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Lakeside FD	Circuit 242, P372465	AT&T	12kV	Conductor	Overhead	Yes	5/1/14	6:48	Contact Between Third Party Facility on Pole and Supply Lines				Weather	
13	SDG&E	5/13/14 9:00	32.8405000	-116.7200000	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	P177622		12kV	Conductor	Overhead	No			Wire-Wire Contact				Weather	
14	SDG&E	5/13/14 8:35	32.7543000	-116.7800000	Vegetation	Rural	Less Than 25 Acres	Fire Agency	CAL FIRE	P274777		240V	Conductor	Overhead	No			Contact From Object				Other	
15	SDG&E	5/19/14 18:30	33.1073000	-117.1640000	Vegetation	Urban	26 - 9.99 Acres	Fire Agency	Cal Fire	P211709	AT&T	12kV	Conductor	Overhead	Yes	5/19/14	18:30	Contact From Object				Other	
16	SDG&E	5/28/14 15:50	32.9808000	-117.2482000	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Cal Fire	P313228		12kV	Conductor	Overhead	Yes			Contact From Object		Vehicle	Pole	Human Error	
17	SDG&E	5/31/14 11:30	33.3146000	-116.8661000	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	P219919		12kV	Conductor	Overhead	Yes	5/31/14	11:30	Contact From Object				Other	
18	SDG&E	6/4/14 9:30	33.0191000	-116.8280000	Vegetation	Rural	Less Than 25 Acres	Fire Agency	CALFIRE	TL 637, Circuit 970, Z416592	none	69kV	Conductor	Overhead	Yes	6/4/14	9:30	Contact From Object				Human Error	
19	SDG&E	6/17/14 15:30	32.5640000	-117.0320000	Vegetation	Rural	Less Than 25 Acres	Fire Agency	SDFD	P192047		12kV	Switch	Overhead	Yes	6/17/14	15:30	Equipment/Facility Failure		Switch		None	
20	SDG&E	7/4/14 12:00	32.7563000	-116.9260000	Vegetation	Urban	Less Than 25 Acres	Fire Agency	CALFIRE	Circuit 96, P471597	none	12kV	Conductor	Overhead	Yes			Contact From Object				None	
21	SDG&E	7/6/14 11:14	33.0283000	-116.9260000	Vegetation	Rural	Less Than 25 Acres	Fire Agency	CALFIRE	Circuit 972, P319081	none	12kV	Conductor	Overhead	Yes	7/6/14	11:14 a.m.	Contact From Object				None	
22	SDG&E	7/22/14 10:25	32.7899000	-116.8455000	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Cal Fire	P276288	AT&T	12kV	Conductor	Overhead	Yes			Contact From Object				None	
23	SDG&E	8/28/14 9:30	33.0191000	-116.8281000	Vegetation	Rural	Less Than 25 Acres	Fire Agency	CALFIRE	Z416585		12kV	Conductor	Overhead	Yes			Contact From Object				Human Error	
24	SDG&E	9/2/14 11:15	33.1527200	-117.1607800	Vegetation	Rural	Less Than 25 Acres	Fire Agency	San Marcos	P219744	none	12kV	Fuse	Overhead	Yes	9/2/14	11:15	Contact From Object		Balloons	Pole	Outside Force	
25	SDG&E	9/11/14 11:56	33.2769000	-117.1345000	Vegetation	Rural	Less Than 25 Acres	Fire Agency	CALFIRE	P619040	none	12kV	Transformer	Overhead	Yes	9/11/14	11:56	Equipment/Facility Failure	Transformer			None	
26	SDG&E	9/13/14 20:30	32.7211000	-116.7801000	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	Cir 157, P106190		12kV	Conductor	Overhead	Yes	9/13/14	20:00	Unknown				Unknown	
27	SDG&E	9/15/14 12:53	32.7360000	-117.0137000	Vegetation	Urban	Less Than 25 Acres	Fire Agency	San Miguel FD	Cir 162, P161277		240V	Conductor	Overhead	Yes	9/15/14	12:53	Contact From Object				Other	
28	SDG&E	9/24/14 19:45	33.0513000	-116.8479000	Vegetation	Rural	Less Than 25 Acres	Fire Agency	CALFIRE	Cir. RA1 P169791		4kV	Conductor	Overhead	Yes	9/24/12	19:45	Contact From Object				Other	
29	SDG&E	10/7/14 13:38	33.0389800	-117.1705000	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CALFIRE	Z519759		240kV	Conductor	Overhead	Yes	10/7/2014	13:42	Contact From Object				Other	
30	SDG&E	10/11/14 4:00	32.9460000	-116.8466000	Vegetation	Rural	Less Than 25 Acres	Fire Agency	CALFIRE	P972639		12kV	Conductor	Overhead	Yes	10/11/14	4:00	Contact From Object				Other	
31	SDG&E	11/19/14 9:30	32.8421000	-116.8605000	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	Cir. 246 P272232	none	12kV	Conductor	Overhead	Yes	11/19/14	18:00	Contact From Object				Other	
32	SDG&E	2/7/15 13:36	32.9210000	-117.0137000	Vegetation	Rural	Less Than 25 Acres	Utility		TL 23041	none	230kV	Conductor	Overhead	Yes	2/7/15	13:36	Contact From Object				Other	
33	SDG&E	6/9/15 5:50	32.9003000	-117.2309000	Vegetation	Urban	Less Than 25 Acres	Fire Agency	S.D. City	Z53404		69kV	Conductor	Overhead	Yes	6/9/15	5:45	Contact From Object				Human Error	
34	SDG&E	10/31/15 13:04:00	33.3391670	-117.4947500	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Pendleton	Z233694		230V	Conductor	Overhead	No			Contact From Object				Other	
35	SDG&E	4/9/15 17:23	32.7233000	-116.8922000	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	P171928		12kV	Other	Overhead	No			Unknown				Other	
36	SDG&E	5/28/15 12:45	32.7265000	-116.9922000	Vegetation	Rural	Less Than 25 Acres	Self Extinguished		P196508		12kV	Conductor	Overhead	Yes	5/28/15	12:45	Contact From Object				Other	
37	SDG&E	4/12/15 14:30	32.7523000	-117.3257000	Vegetation	Rural	100 - 299 Acres	Fire Agency	Pendleton	P164638		12kV	Lightning Arrestor	Overhead	No			Equipment/Facility Failure	Lightning Arrestor			None	
38	SDG&E	7/13/15 23:45	32.7629700	-116.8994900	Vegetation	Rural	Less Than 25 Acres	Self Extinguished		Z971870 Cir 23041		230kV	Conductor	Overhead	No			Contact From Object				Other	
39	SDG&E	8/8/15 10:00	33.1973000	-117.2308000	Vegetation	Urban	Less Than 25 Acres	Customer		P17530J		4kV	Conductor	Overhead	Yes	8/8/15	10:00	Contact From Object		Balloons	Electric Facility	Outside Force	
40	SDG&E	4/12/15 12:31	33.0117000	-116.8660000	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	P214319		12kV	Conductor	Overhead	Yes	4/12/15	12:30	Contact From Object				Other	
41	SDG&E	4/29/15 12:00	32.6061000	-116.6960400	Vegetation	Rural	Less Than 25 Acres	Fire Agency	CAL FIRE	P175961	none	12kV	Conductor	Overhead	Yes	4/29/15	12:00	Equipment/Facility Failure	Splice/Clamp/Connector			Unknown	
42	SDG&E	5/17/15 6:55	33.1808000	-117.2064000	Vegetation	Rural	Less Than 25 Acres	Self Extinguished		P15839		12kV	Conductor	Overhead	Yes	5/17/15	7:06	Contact From Object				Other	
43	SDG&E	7/7/15 15:00	32.7443000	-117.0498000	Vegetation	Urban	Less Than 25 Acres	Utility		Z371043 Cir. 160		12kV	Conductor	Overhead	Yes	7/7/15	13:00	Contact From Object				Other	
44	SDG&E	2/11/15 15:30	32.8941000	-116.9393000	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Lakeside Fire	Service span off 237657		12kV	Conductor	Overhead	Yes			Contact From Object				Weather	
45	SDG&E	4/18/15 12:00	32.7764000	-116.9309000	Vegetation	Rural	Less Than 25 Acres	Fire Agency	CAL FIRE	P677849		220v	Conductor	Overhead	No			Contact From Object				None	
46	SDG&E	7/17/15 9:48	33.1750420	-117.0125000	Vegetation	Rural	Less Than 25 Acres	Fire Agency	CAL FIRE	P213348		12kV	Conductor	Overhead	No			Contact From Object				Human Error	
47	SDG&E	7/27/15 14:30	33.0665000	-116.5790000	Vegetation	Rural	Less Than 25 Acres	Fire Agency	CAL FIRE	P212008		12kV	Conductor	Overhead	Yes	7/27/15	14:30	Contact From Object				Other	
48	SDG&E	8/23/15 15:00	32.2729100	-117.1521000	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	P415300		12kV	Conductor	Overhead	Yes	8/23/15	15:00	Contact From Object				Weather	
49	SDG&E	12/26/15 3:04	33.1323000	-117.0895000	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Escondido	P218563		12kV	Conductor	Overhead	Yes	12/26/15	3:04	Contact From Object				Weather	
50	SDG&E	8/13/15 20:33	33.2457100	-116.6769000	Vegetation	Rural	Less Than 25 Acres	Fire Agency	CAL FIRE	P19586		12kV	Conductor	Overhead	Yes	8/13/15	20:33	Unknown				Unknown	
51	SDG&E	8/15/15 17:30	32.7417200	-116.9685000	Other	Urban	Less Than 25 Acres	Customer		P273868		4kV	Other	Overhead	No			Equipment/Facility Failure	Splice/Clamp/Connector			None	
52	SDG&E	3/19/15 23:50	33.0323780	-117.0159000	Vegetation	Rural	Less Than 25 Acres	Fire Agency	S.D. City	P179156		12kV	Conductor	Overhead	Yes	3/19/15	23:50	Contact From Object		Vehicle	Pole	Human Error	
53	SDG&E	9/1/15 8:50	32.6690000	-116.2860000	Vegetation	Rural																	

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X
2	Utility Name	Fire Start	Latitude	Longitude	Location Info	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Utility Facility	Equipment Involved With Ignition	Type	Was There an Outage	Date2	Time3	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes
115	SDG&E	10/25/17	13.02	33.2856840	-117.0275340	Vegetation	Rural	Less Than 25 Acres	Fire Agency	CALFIRE	P416197 Circuit 908		12kV Other	Overhead	No			Equipment/Facility Failure	Other				Weather	None
116	SDG&E	12/10/17	2.58	33.2738680	-116.9536750	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CALFIRE	P813516		12kV Transformer	Overhead	No			Equipment/Facility Failure	Splice/Clamp/Connector				Weather	None
117	SDG&E	12/10/17	5.26	33.2800000	-116.9550000	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CALFIRE	P32240		12kV Conductor	Overhead	Yes	12/10/17	5:26	Contact From Object		Vegetation	Electric Facility	Weather	None	
118	SDG&E	2/8/18	10.07	33.2071000	-117.2072000	Vegetation	Rural	Less Than 25 Acres	Fire Agency	North County Fire	P213833		12kV Conductor	Overhead	Yes	2/8/18	10:07	Contact From Object		Vegetation	Electric Facility	Human Error	None	
119	SDG&E	2/16/18	16.50	32.6275960	-116.9408520	Vegetation	Urban	Less Than 25 Acres	Utility		C-594		12kV Conductor	Overhead	Yes	2/16/18	14:02	Contact From Object		Balloons	Electric Facility	Outside Force	None	
120	SDG&E	4/12/18	19.33	32.6965100	-117.0492940	Vegetation	Urban	Less Than 25 Acres	Fire Agency	SDFD	Z89883		12kV Conductor	Overhead	No			Contact From Object		Balloons	Electric Facility	Other	None	
121	SDG&E	4/16/18	14.24	33.4176000	-117.6058000	Vegetation	Urban	Less Than 25 Acres	Fire Agency	OCFA	P121389		12kV Conductor	Overhead	No			Contact From Object		Vegetation	Electric Facility	Weather	None	
122	SDG&E	4/18/18	15.25	33.2410000	-117.3470000	Vegetation	Rural	Less Than 25 Acres	Fire Agency	CPFD	Z223638		230kV Conductor	Overhead	No			Contact From Object		Animal	Electric Facility	Other	None	
123	SDG&E	4/22/18	14.00	32.8370000	-117.1840000	Vegetation	Urban	Less Than 25 Acres	Fire Agency	SDFD	P729991 Cir. 275		12kV Conductor	Overhead	Yes	4/22/18	14:00	Contact From Object		Balloons	Electric Facility	None	None	
124	SDG&E	5/1/18	21.29	32.6847520	-117.1011690	Vegetation	Urban	Less Than 25 Acres	Fire Agency	National City	Z730733		69kV Conductor	Overhead	No			Contact From Object		Vehicle	Electric Facility	Outside Force	None	
125	SDG&E	5/22/18	14.23	33.3620000	-117.0320000	Vegetation	Rural	10 - 99 Acres	Fire Agency	CALFIRE	P214790 Cir.217		12kV Conductor	Overhead	Yes	5/22/18	14:02	Contact From Object		Balloons	Electric Facility	Other	None	
126	SDG&E	6/1/18	14.00	33.0990000	-117.0440000	Vegetation	Rural	Less Than 25 Acres	Utility		P618454		12kV Conductor	Overhead	No			Wire-Wire Contact					Other	None
127	SDG&E	6/12/18	9.00	32.7060000	-116.3960000	Vegetation	Rural	Less Than 25 Acres	Fire Agency	CAL FIRE	P44708 Cir. 458		12kV Conductor	Overhead	Yes	6/12/18	9:00	Contact From Object		Animal	Electric Facility	None	None	
128	SDG&E	6/12/18	15.14	32.8640000	-116.7470000	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Fire Agency	P871937 Cir. 357		12kV Conductor	Overhead	Yes	6/12/18	14:38	Contact From Object		Balloons	Electric Facility	None	None	
129	SDG&E	6/22/18	9.46	32.5670000	-116.9410000	Vegetation	Rural	Less Than 25 Acres	Fire Agency	SDFD	Z100698 Cir. 535		12kV Switch	Overhead	Yes	6/22/18	9:42	Switch					Unknown	None
130	SDG&E	6/29/18	13.06	32.8450000	-117.0560000	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Chula Vista	Z182447 Cir. 341		12kV Other	Overhead	Yes	6/29/18	13:06	Equipment/Facility Failure		Guy/Span Wire			Unknown	None
131	SDG&E	7/6/18	10.26	32.6203150	-116.7649300	Vegetation	Rural	10 - 99 Acres	Fire Agency	CalFire	P177572 Station 157-825, C157		12kV Transformer	Overhead	No			Equipment/Facility Failure		Transformer			Unknown	None
132	SDG&E	7/8/18	16.16	32.6348850	-117.1030420	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Chula Vista	P100601, C255		12kV Switch	Overhead	Yes	7/8/18	16:16	Other			Electric Facility	Other	None	
133	SDG&E	7/22/18	23.19	33.3010000	-116.3510000	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Borrego Springs FD	374759 Cir 170		12kV Conductor	Overhead	Yes	7/22/18	23:19	Contact From Object		Vegetation	Electric Facility	None	None	
134	SDG&E	7/30/18	12.11	32.8680680	-117.1902260	Vegetation	Urban	26 - 9.99 Acres	Fire Agency	SDFD&MCMIR	Z90115 Cir 968		12kV Conductor	Overhead	No			Contact From Object		Balloons	Electric Facility	Other	None	
135	SDG&E	8/9/18	12.00	33.2130000	-117.3350000	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Oceanside FD	P226873 Cir 194		12kV Conductor	Overhead	No			Equipment/Facility Failure		Other			Other	None
136	SDG&E	8/19/18	18.35	32.7001804	-116.8638674	Vegetation	Rural	Less Than 25 Acres	Fire Agency	CAL FIRE	P254640 Cir 75		12kV Conductor	Overhead	Yes	7/19/18	18:35	Contact From Object		Balloons	Electric Facility	Other	None	
137	SDG&E	9/14/18	10.00	33.3177060	-117.2228440	Vegetation	Rural	Less Than 25 Acres	Fire Agency	MVU & NCFPD	P213051 Cir 233	Telecom/cable	12kV Conductor	Overhead	No			Contact Between Third Party Facility on Pole and Supply Lines		Vehicle	Communication Facility	Human Error	None	
138	SDG&E	9/14/18	15.02	32.7896790	-117.0808820	Vegetation	Urban	Less Than 25 Acres	Fire Agency	SDFD	P279980J Cir 702		12kV Other	Overhead	Yes	9/14/18	15:48	Equipment/Facility Failure					None	None
139	SDG&E	10/12/18	12.30	32.8019070	-117.1493760	Vegetation	Urban	Less Than 25 Acres	Utility		Z96245		69kV Other	Overhead	No			Contact From Object		Vehicle			Human Error	None
140	SDG&E	10/12/18	10.00	33.3013270	-116.9129450	Vegetation	Rural	Less Than 25 Acres	Utility		Z118027		69kV Conductor	Overhead	No			Contact From Object		Vehicle			Human Error	None
141	SDG&E	10/15/18	10.21	33.3190990	-117.2596710	Vegetation	Rural	Less Than 25 Acres	Customer		P112366		12kV Conductor	Overhead	Yes	10/15/18	12:02	Equipment/Facility Failure					None	None
142	SDG&E	11/26/18	1.51	33.4313920	-117.5951950	Vegetation	Urban	26 - 9.99 Acres	Fire Agency	OCFA	P25325		12kV Conductor	Overhead	Yes	11/26/18	1:45	Contact From Object		Balloons	Electric Facility	Other	None	
143	SDG&E	12/2/18	11.25	33.2800000	-117.4040000	Vegetation	Rural	Less Than 25 Acres	Self Extinguished		Z223659		230kV Conductor	Overhead	Yes	12/2/18	11:25	Contact From Object		Other	Electric Facility	None	None	
144	SDG&E	1/16/19	16.55	33.4210000	-117.6100000	Vegetation	Urban	Less Than 25 Acres	Fire Agency	OCFA	P29955		12 kV Other	Overhead	No			Equipment/Facility Failure		Crossarm			Weather	None
145	SDG&E	4/15/19	14.05	32.7883007	-116.8898419	Vegetation	Rural	Less Than 25 Acres	Fire Agency	CalFire	P74970 and P74971	Telco	12 kV Conductor	Overhead	Yes	4/15/19	12:51	Wire-Wire Contact					Outside Force	None
146	SDG&E	6/12/19	22.05	33.0484270	-116.8578150	Vegetation	Rural	Less Than 25 Acres	Fire Agency	CalFire	W100304		12 kV Switch	Overhead	Yes	6/12/19	22:17	Contact From Object		Vehicle	Electric Facility	None	None	
147	SDG&E	7/3/19	15.15	33.0112640	-116.8492200	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Ramona	P815903	Telco	120/208 Conductor	Overhead	No			Equipment/Facility Failure		Conductor			Unknown	None
148	SDG&E	7/5/19	12.32	33.1584479	-117.2220482	Vegetation	Urban	Less Than 25 Acres	Fire Agency	San Marcos	P415472		12kV Conductor	Overhead	Yes	7/5/19	12:19	Contact From Object		Vehicle	Pole	Human Error	None	
149	SDG&E	7/12/19	13.52	33.1268020	-117.3034710	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Carlsbad	Z710094		230 kV Conductor	Overhead	Yes	7/12/19	13:51	Contact From Object		Balloons	Electric Facility	Other	None	
150	SDG&E	7/16/19	7.36	33.1696590	-117.1460730	Vegetation	Rural	Less Than 25 Acres	Fire Agency	San Marcos	P114649		12kV Conductor	Overhead	Yes	7/16/19	7:53	Wire-Wire Contact					None	None
151	SDG&E	7/16/19	19.08	33.1904440	-117.1212380	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Deer Springs	P610712	Telco	12kV Conductor	Overhead	Yes	7/16/19	19:08	Contact Between Third Party Facility on Pole and Supply Lines		Vegetation	Electric Facility	Other	None	
152	SDG&E	8/5/19	14.14	32.7885890	-117.1232970	Vegetation	Urban	Less Than 25 Acres	Utility		Z479779		12 kV Switch	Overhead	No			Equipment/Facility Failure		Other			None	None
153	SDG&E	8/30/19	17.50	33.2452250	-117.3729400	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Camp Pendleton	Z223445		230kV Other	Overhead	Yes	8/30/19	17:50	Unknown					Unknown	None
154	SDG&E	9/10/19	12.59	32.5640000	-117.0330000	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	San Diego	P194970		12kV Switch	Overhead	Yes	9/10/19	12:55	Equipment/Facility Failure		Switch			None	None
155	SDG&E	9/11/19	14.17	33.2260000	-117.0850000	Vegetation	Rural	Less Than 25 Acres	Fire Agency	CalFire	P228412		12kV Lightning Arrestor	Overhead	Yes	9/11/19	14:17	Contact From Object		Animal	Electric Facility	None	None	
156	SDG&E	9/13/19	11.27	32.7870000	-117.0070000	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Heartland	P378838		12kV Other	Overhead	Yes	9/13/19	11:27	Equipment/Facility Failure		Splice/Clamp/Connector			Unknown	None
157	SDG&E	9/30/19	2.59	33.2618110	-116.3705100	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Ramona	P277947		12kV Other	Overhead	Yes	9/30/19	2:59	Equipment/Facility Failure		Guy/Span Wire			Other	None
158	SDG&E	10/17/19	12.15	33.2736111	-116.3930556	Vegetation	Urban	Less Than 25 Acres	Utility		P236651J		120/240 Conductor	Overhead	No			Other					Human Error	None
159	SDG&E	10/19/19	13.10	33.2316810	-117.2593290	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Oceanside	meter pole Station 901-1460		240V Conductor	Overhead	Yes	10/19/19	13:10	Other		Other			Human Error	None
160	SDG&E	10/24/19	10.13	32.8357120	-116.7251660	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Alpine FD	P377113	Telco	12kV Fuse	Overhead	Yes	10/24/19	10:13	Equipment/Facility Failure		Fuse			None	None
161	SDG&E	10/25/19	3.26	33.1209560	-117.1585700	Vegetation	Urban	26 - 9.99 Acres	Fire Agency	CalFire	P211697	Telco	12kV Other	Overhead	Yes	10/25/19	3:26	Equipment/Facility Failure					Other	None
162	SDG&E	11/1/19	5.49	33.0924247	-117.0206295	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Escondido FD	P15147	Telco	12kV Conductor	Overhead	Yes	11/1/19	5:48	Contact From Object					None	None
163	SDG&E	11/4/19	15.30	33.2284550	-116.7574580	Vegetation	Rural	Less Than 25 Acres	Utility		P19533		12kV Conductor	Overhead	Yes	11/4/19	15:30	Equipment/Facility Failure		Other			None	None
164	SDG&E	11/12/19	7.51	33.1902760	-117.3697730	Other	Urban	Less Than 25 Acres	Fire Agency	Oceanside FD	P22213	Tele&Cbl	120/240 Conductor	Overhead	Yes	11/12/19	7:51	Equipment/Facility Failure		Conductor				