

## Short Investigation Form

**Incident Number:** E20140612-04

**Date:** 3/4/15

**Engineer:** Raymond Cho

**Utility:** Pacific Gas and Electric (PG&E)

**Address:** Snyder between Mountain View and Petaluma

**City:** Santa Rosa

**County:** Sonoma

Yes	In File	N/A	
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Obtained and reviewed Utility's Initial and Final Reports.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Discussed the incident with the utility's representative.
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Confirmed the information in the Utility's Initial and Final Reports.
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Obtained and reviewed Inspection (or other applicable) Records.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Obtained and reviewed local Fire Department/CDF reports.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Other reports. Specify.

**Brief description:**

On June 12, 2014, a line recloser on PG&E circuit, Bellevue – 2103, opened resulting in an outage for 1,027 customers. All customers were restored within two hours.

My investigation did not find a cause for the fault that opened the line recloser. No PG&E facilities were found damaged or in need of repair. I did not find a violation of CPUC rules and regulations.

The Assigned Engineer has reviewed the evidence, discussed the incident with his supervisor and did not find any violations of the Commission General Orders or Public Utilities Code. Therefore, the incident is closed and no other report will be prepared at this time.

\_\_\_\_\_  
Engineer Signature

\_\_\_\_\_  
Supervisor Signature