

Short Investigation Form

Incident Number: E20130501-04

Date: 3/6/2015

Engineer: Ivan Garcia

Utility: PG&E

Address: 18101 Highway 128

City: Calistoga

County: Napa

Yes	In File	N/A	
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Obtained and reviewed Utility's Initial and Final Reports.
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Discussed the incident with the utility's representative.
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Confirmed the information in the Utility's Initial and Final Reports.
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Obtained and reviewed Inspection (or other applicable) Records.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Obtained and reviewed local Fire Department/CDF reports.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Other reports.

Brief description:

On May 1, 2013 at 0118 hours an oak tree failed below ground level due to catastrophic root failure and fell into the Calistoga 1101 12 kV circuit in the city of Calistoga. The tree failure caused three other trees to come down on the same circuit and create a structure fire and major property damage.

The incident caused an outage to 361 customers on the Calistoga 1101 12 kV circuit, and all customers were restored by 1356 hours. PG&E replaced the down conductors on the same day.

The Assigned Engineer has reviewed the evidence, discussed the incident with his supervisor and did not find any violations of the Commission General Orders or Public Utilities Code. Therefore, the incident is closed and no other report will be prepared at this time.

Engineer Signature

Supervisor Signature