

From: USRB
Sent: Thursday, October 26, 2017 10:34 AM
To: SED-Gas Section-South; SED-Gas Section-North; TerKeurst, Charlotte; Palmer, Leslie L.; SED-Electric Safety and Reliability Branch - North; SED-Electric Safety and Reliability Branch - South
Subject: FW: Electric Safety Incident Reported- PG&E Incident No: 171026-8601

From: webmaster@cpuc.ca.gov
Sent: Thursday, October 26, 2017 10:33:41 AM (UTC-08:00) Pacific Time (US & Canada)
To: USRB
Cc: ldtd@pge.com
Subject: Electric Safety Incident Reported- PG&E Incident No: 171026-8601

The Following information regarding this incident has been reported:

Reporting Date: 10/26/2017 10:28:56 AM
Incident Date: 10/8/2017 @ 9:45 p.m.
Reported By: Laxmi D Terala, Compliance Specialist, Expert
Utility Name: PG&E
Phone Number: (925)768-6603
Email Address: ldtd@pge.com

Incident Location: [REDACTED] Calistoga, Napa

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? Yes (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? No
- Media Coverage? No

Cause of Incident: Other (Other Cause:)

Agencies on Scene:

Facilities Affected:

- Utilities Facilities: [REDACTED]
- Voltage (KV): [REDACTED]
- Customer's Facilities:

DigIn Information:

- Excavator Name:
- Contact:
- Phone: (____)____ - _____

Incident Recovery:

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

Summary: On Wednesday, October 26, 2017, near the City of Calistoga, Napa County, CalFire took possession of a set of three in-service distribution line fused cutouts at [REDACTED] on the [REDACTED] circuit, two sets of in-service transformer fused cutouts, and a secondary service line that had detached from the fire-damaged home at [REDACTED]. CalFire also took possession of multiple sections of customer-owned overhead conductor that served multiple pieces of customer-owned equipment on the property. No damage to PG&E equipment was readily apparent. This information is preliminary and PG&E is fully cooperating with Cal Fire.