

**From:** USRB  
**Sent:** Monday, October 09, 2017 6:17 PM  
**To:** SED-Gas Section-South; SED-Gas Section-North; TerKeurst, Charlotte; Palmer, Leslie L.; SED-Electric Safety and Reliability Branch - North; SED-Electric Safety and Reliability Branch - South  
**Subject:** FW: Electric Safety Incident Reported- PG&E Incident No: 171009-8554

---

**From:** webmaster@cpuc.ca.gov  
**Sent:** Monday, October 09, 2017 6:17:09 PM (UTC-08:00) Pacific Time (US & Canada)  
**To:** USRB  
**Cc:** CLF8@pge.com  
**Subject:** Electric Safety Incident Reported- PG&E Incident No: 171009-8554

**The Following information regarding this incident has been reported:**

**Reporting Date:** 10/9/2017 6:11:28 PM  
**Incident Date:** 10/9/2017 @ 10:00 a.m.  
**Reported By:** Charles Filmer, Compliance Specialist  
**Utility Name:** PG&E  
**Phone Number:** (530)902-5685  
**Email Address:** CLF8@pge.com

**Incident Location:** 22894 Highway 26 West Point, Calaveras

**Reasons For Reporting:**

- Fatalities? No (Utility: , Others: )
- Names of Fatalities:
- Injuries? (Utility: , Others: )
- Names of Injured:
- Damage? Yes (Utility: , Others: )
- Interruption? (Total Customers: , Total Hours: )
- Operator Judgement? No
- Media Coverage? No

**Cause of Incident:** Falling Branch (Other Cause: )

**Agencies on Scene:** Fire,

**Facilities Affected:**

- Utilities Facilities: West Point 1102
- Voltage (KV): 12
- Customer's Facilities:

**DigIn Information:**

- Excavator Name:
- Contact:
- Phone: (\_\_\_\_)\_\_\_\_-\_\_\_\_

**Incident Recovery:**

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

**Summary:** This afternoon, October 9, 2017, north of the community of West Point in Calaveras County, PG&E identified a broken tree limb and wire down on the West Point 1102 (12 kV) at 22894 Highway 26, West Point. The tree appeared to be rooted approximately 50 feet from the distribution conductors. This information is preliminary.