

**From:** USRB  
**Sent:** Tuesday, October 10, 2017 9:10 PM  
**To:** SED-Gas Section-South; SED-Gas Section-North; TerKeurst, Charlotte; Palmer, Leslie L.; SED-Electric Safety and Reliability Branch - North; SED-Electric Safety and Reliability Branch - South  
**Subject:** FW: Electric Safety Incident Reported- PG&E Incident No: 171010-8558

**Follow Up Flag:** Flag for follow up  
**Flag Status:** Completed

---

**From:** webmaster@cpuc.ca.gov  
**Sent:** Tuesday, October 10, 2017 9:10:28 PM (UTC-08:00) Pacific Time (US & Canada)  
**To:** USRB  
**Cc:** CLF8@pge.com  
**Subject:** Electric Safety Incident Reported- PG&E Incident No: 171010-8558

**The Following information regarding this incident has been reported:**

**Reporting Date:** 10/10/2017 9:08:09 PM  
**Incident Date:** 10/8/2017 @ 10:00 p.m.  
**Reported By:** Charles Filmer, Compliance specialist  
**Utility Name:** PG&E  
**Phone Number:** (530)902-5685  
**Email Address:** CLF8@pge.com

**Incident Location:** 8555 Sonoma Highway (Hwy 12) Kenwood, Sonoma

**Reasons For Reporting:**

- Fatalities? No (Utility: , Others: )
- Names of Fatalities:
- Injuries? (Utility: , Others: )
- Names of Injured:
- Damage? Yes (Utility: , Others: )
- Interruption? (Total Customers: , Total Hours: )
- Operator Judgement? No
- Media Coverage? No

**Cause of Incident:** Falling Tree (Other Cause: )

**Agencies on Scene:** Fire,

**Facilities Affected:**

- Utilities Facilities: Dunbar 1101
- Voltage (KV): 12
- Customer's Facilities:

**DigIn Information:**

- Excavator Name:
- Contact:
- Phone: (\_\_\_\_) \_\_\_\_ - \_\_\_\_

**Incident Recovery:**

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

**Summary:** This afternoon, 10 October 2017, in Kenwood, Sonoma County, PG&E identified a broken tree and wire down on the Dunbar 1101 (12kV) at 8555 Sonoma Hwy. An approximately 60-foot eucalyptus tree that was rooted approximately 50 feet from the lines had fallen, taking down all three primary conductors to the ground. This information is preliminary and PG&E is fully cooperating with Cal Fire.