

From: USRB
Sent: Wednesday, October 11, 2017 4:06 PM
To: SED-Gas Section-South; SED-Gas Section-North; TerKeurst, Charlotte; Palmer, Leslie L.; SED-Electric Safety and Reliability Branch - North; SED-Electric Safety and Reliability Branch - South
Subject: FW: Electric Safety Incident Reported- PG&E Incident No: 171011-8562

From: webmaster@cpuc.ca.gov
Sent: Wednesday, October 11, 2017 4:05:31 PM (UTC-08:00) Pacific Time (US & Canada)
To: USRB
Cc: CLF8@pge.com
Subject: Electric Safety Incident Reported- PG&E Incident No: 171011-8562

The Following information regarding this incident has been reported:

Reporting Date: 10/11/2017 4:01:41 PM
Incident Date: 10/8/2017 @ 11:55 p.m.
Reported By: Charles Filmer, Compliance Specialist
Utility Name: PG&E
Phone Number: (530)902-5685
Email Address: CLF8@pge.com

Incident Location: Near Pomo Road and Sulphur Bank Road Clearlake, Lake

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? Yes (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? No
- Media Coverage? No

Cause of Incident: Other (Other Cause: broken pole)

Agencies on Scene: Fire,

Facilities Affected:

- Utilities Facilities: Redbud 1102
- Voltage (KV): 12
- Customer's Facilities:

DigIn Information:

- Excavator Name:
- Contact:
- Phone: (____)____ - _____

Incident Recovery:

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

Summary: Yesterday evening, 10 October 2017, near Clearlake, Lake County, PG&E identified two broken poles on the Redbud 1102 (12kV) Circuit near Pomo Rd. and Sulphur Bank Rd. The top section of Fuse Cutout Pole 1447 had broken and fallen to the ground. Additionally, a pole one span to the west was burned and had also fallen to the ground. Cal Fire has taken possession of the top section of Fuse Cutout Pole 1447 that fell to the ground, as well as the bottom portion of the same pole where the break occurred (above the communication conductors). This information is preliminary and PG&E is fully cooperating with Cal Fire.