

**From:** USRB  
**Sent:** Wednesday, October 11, 2017 10:55 PM  
**To:** SED-Gas Section-South; SED-Gas Section-North; TerKeurst, Charlotte; Palmer, Leslie L.; SED-Electric Safety and Reliability Branch - North; SED-Electric Safety and Reliability Branch - South  
**Subject:** FW: Electric Safety Incident Reported- PG&E Incident No: 171011-8563

---

**From:** webmaster@cpuc.ca.gov  
**Sent:** Wednesday, October 11, 2017 10:54:43 PM (UTC-08:00) Pacific Time (US & Canada)  
**To:** USRB  
**Cc:** CLF8@pge.com  
**Subject:** Electric Safety Incident Reported- PG&E Incident No: 171011-8563

**The Following information regarding this incident has been reported:**

**Reporting Date:** 10/11/2017 10:50:37 PM  
**Incident Date:** 10/8/2017 @ 11:00 p.m.  
**Reported By:** Charles Filmer, Compliance specialist  
**Utility Name:** PG&E  
**Phone Number:** (530)902-5685  
**Email Address:** CLF8@pge.com

**Incident Location:** 11253 Orion Way Grass Valley, Nevada

**Reasons For Reporting:**

- Fatalities? No (Utility: , Others: )
- Names of Fatalities:
- Injuries? (Utility: , Others: )
- Names of Injured:
- Damage? Yes (Utility: , Others: )
- Interruption? (Total Customers: , Total Hours: )
- Operator Judgement? No
- Media Coverage? No

**Cause of Incident:** Falling Tree (Other Cause: )

**Agencies on Scene:** Fire,

**Facilities Affected:**

- Utilities Facilities: Grass Valley 1103
- Voltage (KV): 12
- Customer's Facilities:

**DigIn Information:**

- Excavator Name:
- Contact:
- Phone: (\_\_\_\_)\_\_\_\_-\_\_\_\_

**Incident Recovery:**

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

**Summary:** Yesterday afternoon, 10 October 2017, near Grass Valley, Nevada County, PG&E identified a broken tree and wire down on the Grass Valley 1103 (12kV) Circuit near 11253 Orion Way. A green, healthy ponderosa pine tree, approximately 80 feet tall and rooted six to eight feet from the distribution conductors, broke at the base and fell taking all three primary conductors to the ground. The property loss, reported as a garage with three vintage cars, is believed to exceed \$50,000. This information is preliminary and PG&E is fully cooperating with Cal Fire.