

From: USRB
Sent: Thursday, October 12, 2017 8:10 PM
To: SED-Gas Section-South; SED-Gas Section-North; TerKeurst, Charlotte; Palmer, Leslie L.; SED-Electric Safety and Reliability Branch - North; SED-Electric Safety and Reliability Branch - South
Subject: FW: Electric Safety Incident Reported- PG&E Incident No: 171012-8565

From: webmaster@cpuc.ca.gov
Sent: Thursday, October 12, 2017 8:09:43 PM (UTC-08:00) Pacific Time (US & Canada)
To: USRB
Cc: CLF8@pge.com
Subject: Electric Safety Incident Reported- PG&E Incident No: 171012-8565

The Following information regarding this incident has been reported:

Reporting Date: 10/12/2017 8:06:43 PM
Incident Date: 10/8/2017 @ 11:20 p.m.
Reported By: Charles Filmer, Compliance specialist
Utility Name: PG&E
Phone Number: (530)902-5685
Email Address: CLF8@pge.com

Incident Location: near 11218 Lone Lobo Trail near Nevada City , Nevada

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? Yes (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? No
- Media Coverage? No

Cause of Incident: Falling Tree (Other Cause:)

Agencies on Scene: Fire,

Facilities Affected:

- Utilities Facilities: Narrows 2102
- Voltage (KV): 21
- Customer's Facilities:

DigIn Information:

- Excavator Name:
- Contact:
- Phone: (____)____-____

Incident Recovery:

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

Summary: This afternoon near Nevada City in Nevada County, PG&E identified a tree that fell on the Narrows 2102 (21 kV) Circuit near 11218 Lone Lobo Trail. The ponderosa tree was rooted downhill, approximately 50 feet from the distribution conductors. PG&E's meteorology department determined that there were wind gusts in the area up to 40 m.p.h. prior to the event. Cal Fire has removed the tree and has taken possession of the primary conductors. This information is preliminary and PG&E is fully cooperating with Cal Fire.