

**From:** USRB  
**Sent:** Friday, October 13, 2017 7:42 PM  
**To:** SED-Gas Section-South; SED-Gas Section-North; TerKeurst, Charlotte; Palmer, Leslie L.; SED-Electric Safety and Reliability Branch - North; SED-Electric Safety and Reliability Branch - South  
**Subject:** FW: Electric Safety Incident Reported- PG&E Incident No: 171013-8569

---

**From:** webmaster@cpuc.ca.gov  
**Sent:** Friday, October 13, 2017 7:41:43 PM (UTC-08:00) Pacific Time (US & Canada)  
**To:** USRB  
**Cc:** CLF8@pge.com  
**Subject:** Electric Safety Incident Reported- PG&E Incident No: 171013-8569

**The Following information regarding this incident has been reported:**

**Reporting Date:** 10/13/2017 7:38:47 PM  
**Incident Date:** 10/8/2017 @ 11:20 p.m.  
**Reported By:** Charles Filmer, Compliance specialist  
**Utility Name:** PG&E  
**Phone Number:** (530)902-5685  
**Email Address:** CLF8@pge.com

**Incident Location:** 167 Darby Road Bangor, Butte

**Reasons For Reporting:**

- Fatalities? No (Utility: , Others: )
- Names of Fatalities:
- Injuries? (Utility: , Others: )
- Names of Injured:
- Damage? Yes (Utility: , Others: )
- Interruption? (Total Customers: , Total Hours: )
- Operator Judgement? No
- Media Coverage? No

**Cause of Incident:** Falling Branch (Other Cause: )

**Agencies on Scene:** Fire,

**Facilities Affected:**

- Utilities Facilities: Bangor 1101
- Voltage (KV): 12
- Customer's Facilities:

**DigIn Information:**

- Excavator Name:
- Contact:
- Phone: (\_\_\_\_)\_\_\_\_-\_\_\_\_\_

**Incident Recovery:**

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

**Summary:** This afternoon near Bangor, Butte County, PG&E identified a broken oak tree limb and wire down on the Bangor 1101 (12kV) at 167 Darby Road. PG&E's meteorology department determined that there were wind gusts in the area up to 67 m.p.h. prior to the event. Cal Fire has taken possession of a section of the primary conductor. This information is preliminary and PG&E is fully cooperating with Cal Fire.