

**From:** USRB  
**Sent:** Friday, October 20, 2017 9:41 AM  
**To:** SED-Gas Section-South; SED-Gas Section-North; TerKeurst, Charlotte; Palmer, Leslie L.; SED-Electric Safety and Reliability Branch - North; SED-Electric Safety and Reliability Branch - South  
**Subject:** FW: Electric Safety Incident Reported- PG&E Incident No: 171020-8586

---

From: [webmaster@cpuc.ca.gov](mailto:webmaster@cpuc.ca.gov)  
Sent: Friday, October 20, 2017 9:40:18 AM (UTC-08:00) Pacific Time (US & Canada)  
To: USRB  
Cc: [ldtd@pge.com](mailto:ldtd@pge.com)  
Subject: Electric Safety Incident Reported- PG&E Incident No: 171020-8586

**The Following information regarding this incident has been reported:**

**Reporting Date:** 10/20/2017 9:38:48 AM  
**Incident Date:** 10/8/2017 @ 00:00 a.m.  
**Reported By:** Laxmi Terala, Compliance Specialist, Expert  
**Utility Name:** PG&E  
**Phone Number:** (925)768-6603  
**Email Address:** [ldtd@pge.com](mailto:ldtd@pge.com)

**Incident Location:** 1721 Partrick Road Napa, Napa

**Reasons For Reporting:**

- Fatalities? No (Utility: , Others: )
- Names of Fatalities:
- Injuries? (Utility: , Others: )
- Names of Injured:
- Damage? Yes (Utility: , Others: )
- Interruption? (Total Customers: , Total Hours: )
- Operator Judgement? No
- Media Coverage? No

**Cause of Incident:** Other (Other Cause: )

**Agencies on Scene:**

**Facilities Affected:**

- Utilities Facilities: Pueblo 2103
- Voltage (KV): 21
- Customer's Facilities:

**DigIn Information:**

- Excavator Name:
- Contact:
- Phone: (\_\_\_\_)\_\_\_\_ - \_\_\_\_\_

**Incident Recovery:**

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

**Summary:** On Wednesday, October 18, 2017, near the City of Napa, Napa County, PG&E identified a 25-inch diameter Live Oak, approximately 70 feet tall that struck and took down one phase of the Pueblo 2103 Circuit near 1721 Partrick Road. The Live Oak was rooted uphill, approximately 44 feet from the distribution conductors. CalFire has taken possession of the span of the primary conductors. This information is preliminary and PG&E is fully cooperating with Cal Fire.