

From: USRB
Sent: Friday, October 27, 2017 10:37 AM
To: SED-Gas Section-South; SED-Gas Section-North; TerKeurst, Charlotte; Palmer, Leslie L.; SED-Electric Safety and Reliability Branch - North; SED-Electric Safety and Reliability Branch - South
Subject: FW: Updated Initial Summary - FW: Electric Safety Incident Reported- PG&E Incident No: 171026-8601

From: Terala, Laxmi
Sent: Friday, October 27, 2017 10:37:16 AM (UTC-08:00) Pacific Time (US & Canada)
To: USRB; Yamamoto, Ryan
Cc: Northern Incident Data Requests
Subject: Updated Initial Summary - FW: Electric Safety Incident Reported- PG&E Incident No: 171026-8601

Please see the updated initial summary for the incident in Napa reported to CPUC yesterday. Please note the change in date included in the summary.

Summary: On Wednesday, October **25**, 2017, near the City of Calistoga, Napa County, CalFire took possession of a set of three in-service distribution line fused cutouts at Fused Cutout 773 on the Calistoga 1101 (12kV) circuit, two sets of in-service transformer fused cutouts, and a secondary service line that had detached from the fire-damaged home at 1128 Bennett Lane. CalFire also took possession of multiple sections of customer-owned overhead conductor that served multiple pieces of customer-owned equipment on the property. No damage to PG&E equipment was readily apparent. This information is preliminary and PG&E is fully cooperating with Cal Fire.

Thanks
Laxmi Terala
Distribution Compliance
925-415-2571

From: webmaster@cpuc.ca.gov [mailto:webmaster@cpuc.ca.gov]
Sent: Thursday, October 26, 2017 10:34 AM
To: usrb@cpuc.ca.gov
Cc: Terala, Laxmi
Subject: Electric Safety Incident Reported- PG&E Incident No: 171026-8601

*******CAUTION:** This email was sent from an EXTERNAL source. Think before clicking links or opening attachments.*****

The Following information regarding this incident has been reported:

Reporting Date: 10/26/2017 10:28:56 AM

Incident Date: 10/8/2017 @ 9:45 p.m.

Reported By: Laxmi D Terala, Compliance Specialist, Expert

Utility Name: PG&E

Phone Number: (925)768-6603

Email Address: ldtd@pge.com

Incident Location: 1128 Bennett Lane Calistoga, Napa

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? Yes (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? No
- Media Coverage? No

Cause of Incident: Other (Other Cause:)

Agencies on Scene:

Facilities Affected:

- Utilities Facilities: Calistoga 1101
- Voltage (KV): 12
- Customer's Facilities:

DigIn Information:

- Excavator Name:
- Contact:
- Phone: (____)____ - ____

Incident Recovery:

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

Summary: On Wednesday, October 26, 2017, near the City of Calistoga, Napa County, CalFire took possession of a set of three in-service distribution line fused cutouts at Fused Cutout 773 on the Calistoga 1101 (12kV) circuit, two sets of in-service transformer fused cutouts, and a secondary service line that had detached from the fire-damaged home at 1128 Bennett Lane. CalFire also took possession of multiple sections of customer-owned overhead conductor that served multiple pieces of customer-owned equipment on the property. No damage to PG&E equipment was readily apparent. This information is preliminary and PG&E is fully cooperating with Cal Fire.